

State Load Despatch Center,Airoli (MSETCL)
Power System Position from 06/Nov/2017 to 12/Nov/2017

Supply Position During Morning Peak (MW)

Date	Time	MSGENCO				Central Sector Receipt	Wind	CPP	SOLAR	TPCL Exch.	MSEDCL Cateder Demand	Load Shedding(LS)	MSEDCL Demand (Incl. LS)	TPCL Gen.	R-INFRA Gen.	State Demand Met	State Demand (Incl. LS)	Freq.
		THM	HYDRO	GAS	Total													
		MW	MW	MW	MW	MW	MW	MW	MW	MW	MW	MW	MW	MW	MW	MW	MW	Hzs
06/11/2017	12 Hrs	4522	962	399	5883	6205	616	6011	524	-1272	17967	0	17967	1293	500	21032	21032	49.92
07/11/2017	12 Hrs	4960	1280	396	6636	5823	186	6158	510	-1251	18062	18	18080	1330	501	21144	21162	49.86
08/11/2017	12 Hrs	4969	979	398	6346	6370	205	6002	501	-1288	18136	0	18136	1304	496	21224	21224	49.92
09/11/2017	12 Hrs	4906	1552	413	6871	6629	99	5548	478	-1224	18401	0	18401	1342	499	21466	21466	49.95
10/11/2017	12 Hrs	4989	707	419	6115	7023	219	4866	486	-1208	17501	0	17501	1330	503	20542	20542	49.94
11/11/2017	12 Hrs	5036	624	402	6062	6712	398	4981	491	-1062	17582	0	17582	1191	503	20338	20338	49.93
12/11/2017	12 Hrs	5223	713	413	6349	6614	170	4719	494	-708	17638	0	17638	960	503	19809	19809	49.94
Maximum		5223	1552	419	6871	7023	616	6158	524	-708	18401	18	18401	1342	503	21466	21466	49.95
Minimum		4522	624	396	5883	5823	99	4719	478	-1288	17501	0	17501	960	496	19809	19809	49.86
Average		4944	974	406	6323	6482	270	5469	498	-1145	17898	3	17901	1250	501	20794	20796	49.92

Supply Position During Day Peak (MW)

Date	Time	MSGENCO				Central Sector Receipt	Wind	CPP	SOLAR	TPCL Exch.	MSEDCL Cateder Demand	Load Shedding(LS)	MSEDCL Demand (Incl. LS)	TPCL Gen.	R-INFRA Gen.	State Demand Met	State Demand (Incl. LS)	Freq.
		THM	HYDRO	GAS	Total													
		MW	MW	MW	MW	MW	MW	MW	MW	MW	MW	MW	MW	MW	MW	MW	MW	Hzs
06/11/2017	15 Hrs	4826	984	399	6209	6167	286	6021	378	-1328	17733	0	17733	1242	500	20803	20803	49.87
07/11/2017	13 Hrs	4980	1293	404	6677	5933	122	6165	510	-1225	18182	18	18200	1313	501	21221	21239	49.93
08/11/2017	13 Hrs	4977	911	394	6282	6545	170	5976	454	-1266	18161	0	18161	1291	501	21219	21219	49.94
09/11/2017	14 Hrs	4875	1319	389	6583	6717	79	5553	433	-1138	18227	0	18227	1266	502	21133	21133	50.01
10/11/2017	13 Hrs	4936	709	398	6043	7139	189	4882	491	-1172	17572	0	17572	1302	503	20549	20549	49.95
11/11/2017	13 Hrs	4950	548	398	5896	7063	302	4986	500	-1045	17702	0	17702	1170	502	20419	20419	49.93
12/11/2017	13 Hrs	5188	548	412	6148	6843	138	4655	505	-653	17636	0	17636	960	502	19751	19751	49.95
Maximum		5188	1319	412	6677	7139	302	6165	510	-653	18227	18	18227	1313	503	21221	21239	50.01
Minimum		4826	548	389	5896	5933	79	4655	378	-1328	17572	0	17572	960	500	19751	19751	49.87
Average		4962	902	399	6263	6630	184	5463	467	-1118	17888	3	17890	1221	502	20728	20730	49.94

Supply Position During Evening Peak (MW)

Date	Time	MSGENCO				Central Sector Receipt	Wind	CPP	SOLAR	TPCL Exch.	MSEDCL Cateder Demand	Load Shedding(LS)	MSEDCL Demand (Incl. LS)	TPCL Gen.	R-INFRA Gen.	State Demand Met	State Demand (Incl. LS)	Freq.
		THM	HYDRO	GAS	Total													
		MW	MW	MW	MW	MW	MW	MW	MW	MW	MW	MW	MW	MW	MW	MW	MW	Hzs
06/11/2017	19 Hrs	4981	276	422	5679	5544	153	6143	0	-1340	16179	0	16179	1080	504	19103	19103	49.92
07/11/2017	19 Hrs	4997	245	412	5654	5395	194	6133	0	-1253	16123	0	16123	1256	494	19126	19126	49.97
08/11/2017	19 Hrs	4922	524	427	5873	5305	134	6029	0	-1176	16165	0	16165	1323	503	19167	19167	49.96
09/11/2017	19 Hrs	4976	443	417	5836	5767	158	5534	0	-1174	16121	0	16121	1261	500	19056	19056	49.97
10/11/2017	19 Hrs	4719	879	418	6016	5687	128	4764	0	-1143	15452	0	15452	1295	503	18393	18393	49.99
11/11/2017	19 Hrs	5279	624	431	6334	5597	152	4895	0	-999	15979	0	15979	1228	502	18708	18708	50.00
12/11/2017	19 Hrs	5110	581	419	6110	5261	65	4672	0	-757	15351	0	15351	965	497	17570	17570	49.98
Maximum		5279	879	431	6334	5767	194	6143	0	-757	16179	0	16179	1323	504	19167	19167	50.00
Minimum		4719	245	412	5654	5261	65	4672	0	-1340	15351	0	15351	965	494	17570	17570	49.92
Average		4998	510	421	5929	5508	141	5453	0	-1120	15910	0	15910	1201	500	18732	18732	49.97

Supply Position During Night Off Peak (MW)

Date	Time	MSGENCO				Central Sector Receipt	Wind	CPP	SOLAR	TPCL Exch.	MSEDCL Cateder Demand	Load Shedding(LS)	MSEDCL Demand (Incl. LS)	TPCL Gen.	R-INFRA Gen.	State Demand Met	State Demand (Incl. LS)	Freq.
		THM	HYDRO	GAS	Total													
		MW	MW	MW	MW	MW	MW	MW	MW	MW	MW	MW	MW	MW	MW	MW	MW	Hzs
06/11/2017	1 Hrs	4495	150	440	5085	3793	393	4333	0	-1042	12562	0	12562	640	374	14618	14618	49.94
07/11/2017	1 Hrs	4469	192	434	5095	4332	311	4860	0	-1174	13424	0	13424	719	375	15692	15692	49.86
08/11/2017	1 Hrs	4765	88	453	5306	4347	153	4802	0	-1213	13395	0	13395	641	376	15625	15625	49.97
09/11/2017	24 Hrs	4369	98	430	4897	4631	285	4434	0	-1253	12994	0	12994	697	376	15320	15320	49.98
10/11/2017	24 Hrs	4385	102	426	4913	4600	507	3809	0	-1253	12576	0	12576	700	376	14905	14905	49.95
11/11/2017	24 Hrs	4621	111	446	5178	4043	582	3755	0	-1172	12386	0	12386	700	376	14634	14634	49.95
12/11/2017	24 Hrs	4292	114	447	4853	4554	127	3617	0	-980	12171	0	12171	691	376	14218	14218	50.01
Maximum		4765	192	453	5306	4631	582	4860	0	-980	13424	0	13424	719	376	15692	15692	50.01
Minimum		4292	88	426	4853	3793	127	3617	0	-1253	12171	0	12171	640	374	14218	14218	49.86
Average		4485	122	439	5047	4329	337	4230	0	-1155	12787	0	12787	684	376	15002	15002	49.95

Details of Supply Position (MUs)

Date	MSGENCO				Pench (MS)	Central Sector Receipt	Central Sector Share	WIND	CPP	SOLAR	TPCL Gen.	R-INFRA Gen.	TPCL Exch.	Energy Requirement		
	THM	HYDRO	GAS	Total										MSEDCL	MUMBAI	STATE
	Mus	Mus	Mus	Mus	Mus	Mus	Mus	Mus	Mus	Mus	Mus	Mus	Mus	Mus	Mus	Mus
06/11/2017	112.049	9.575	10.111	131.735	0.167	121.613	124.620	9.414	130.719	3.483	22.852	10.668	-26.975	369.989	60.495	430.484
07/11/2017	118.007	11.825	10.140	139.972	0.202	125.962	126.061	4.532	136.489	3.605	22.995	10.372	-28.375	382.185	61.736	443.921
08/11/2017	116.929	12.658	10.228	139.815	0.218	127.787	130.358	3.715	135.931	3.428	23.531	10.732	-27.393	383.283	61.656	444.939
09/11/2017	114.589	15.597	10.189	140.375	0.098	134.969	134.037	3.112	126.695	3.366	23.598	10.826	-26.182	382.335	60.606	442.941
10/11/2017	115.595	14.176	10.243	140.014	0.093	137.598	135.100	6.214	110.421	3.330	24.391	10.996	-24.705	372.872	60.095	432.967
11/11/2017	117.605	12.023	10.300	139.928	0.080	131.344	127.727	8.606	110.551	3.314	22.871	10.957	-22.384	371.359	56.212	427.571
12/11/2017	118.817	8.888	10.372	138.077	0.108	132.589	129.215	4.724	102.362	3.412	19.851	10.733	-17.939	363.226	48.527	411.753
Maximum	118.817	15.597	10.372	140.375	0.218	137.598	135.100	118.817	136.489	3.605	24.391	10.996	-17.939	383.283	61.736	444.939
Minimum	112.049	8.888	10.111	131.735	0.080	121.613	124.620	112.049	102.362	3.314	19.851	10.372	-28.375	363.226	48.527	411.753
Average	116.227	12.106	10.226	138.559	0.138	130.266	129.588	116.227	121.881	3.420	22.870	10.755	-24.850	375.036	58.475	433.511

Details of Koyna Water Consumption (in TMC)

Date	For the Day	For the Month	Balance
06/11/2017	0.164	0.448	47.206
07/11/2017	0.207	0.655	46.999
08/11/2017	0.208	0.863	46.791
09/11/2017	0.278	1.141	46.513
10/11/2017	0.267	1.408	46.246
11/11/2017	0.183	1.591	46.063
12/11/2017	0.143	1.734	45.920

State Load Despatch Center, Airoli (MSETCL)
Central Sector Share/Drawal from 06/Nov/2017 to 12/Nov/2017

Date	DAY	Central Sector Share		Total Interstate Bilateral Purchase		Total Share		Total Drawal		Overdrawal(+) / UnderDrawal(-)	
		MUs	Avg. MW	MUs	Avg. MW	MUs	Avg. MW	MUs	Avg. MW	MUs	Avg. MW
		1		2		1+2=3		4		3-4=5	
06/11/2017	MONDAY	100.849	5169	23.771	990	124.620	5192	121.613	5067	-3.007	-125
07/11/2017	TUESDAY	103.226	5230	22.835	951	126.061	5253	125.962	5248	-0.099	-4
08/11/2017	WEDNESDA	101.200	5402	29.158	1215	130.358	5432	127.787	5324	-2.571	-107
09/11/2017	THURSDAY	103.408	5554	30.629	1276	134.037	5585	134.969	5624	0.932	39
10/11/2017	FRIDAY	103.108	5597	31.992	1333	135.100	5629	137.598	5733	2.498	104
11/11/2017	SATURDAY	97.798	5292	29.929	1247	127.727	5322	131.344	5473	3.617	151
12/11/2017	SUNDAY	95.221	5350	33.994	1416	129.215	5384	132.589	5525	3.374	141
Total		704.811		202.307		907.118		911.863		4.745	

GENERATING UNITS OUTAGES FOR THE WEEK FROM 06/11/2017 TO 12/11/2017							
Generator	Generating Unit	Capacity	Tripped Date	Tripped Time	Synch. Date	Synch Time	Reason
PLANNED OUTAGES							
IPP	Tata Trombay 6	500MW	15/Jul/2015	17.08		Continued.	Economic shutdown(Converted to AOH for 30 Days from 00.00Hrs 06-03-2016)
CS	TARAPUR 4	540MW	23/Apr/2017	19:55	10/Nov/2017	05.13	Annual Maintenance
CS	Tarapur 1	160MW	04/Jun/2017	19.09		Continued.	3 months outage for refuelling.
MSPGCL	Chandrapur Unit 5	500MW	01/Nov/2017	09.20		Continued.	Annual Overhaul
FORCED OUTAGES							
IPP	IEPL Unit 1	270MW	17/May/2013	18.21	10/Nov/2017	11.15	Withdrawn due to some Maint.work after COD
RGPL	Dabhol Dabhol 1B	230MW	28/May/2013	22:02		Continued.	Gas Shortage.
RGPL	Dabhol Dabhol 1X	230MW	27/Jun/2013	21.46		Continued.	Gas Shortage
RGPL	Dabhol Dabhol 1A	230MW	27/Jun/2013	21.47		Continued.	Gas Shortage
MSPGCL	Koradi Unit 6	210MW	20/Mar/2015	01.02		Continued.	EE R&M LE Work
IPP	SWPGL U-1	135MW	16/Feb/2016	17.09		Continued.	Change Over , No Schedule
IPP	SWPGL U-2	135MW	29/Feb/2016	21.46		Continued.	Change over against Unit III
MSPGCL	Parli Unit 4	210MW	01/Apr/2016	00.00		Continued.	Economic shutdown
MSPGCL	Parli Unit 5	210MW	01/Apr/2016	00.00		Continued.	Economic shutdown
MSPGCL	Bhusawal Unit 2	210MW	14/Jun/2016	19.35		Continued.	Boiler Tube Leakage(Converted to Zero Shedule By MSEDCCL from 00.00Hrs dt.19-6-16)
MSPGCL	Uran Unit 8	108MW	14/Aug/2016	07.56		Continued.	Maintenance work
RGPL	Dabhol 2A	230MW	24/Aug/2016	13.31		Continued.	Change Over.
MSPGCL	Koradi Unit 5	200MW	05/Sep/2016	00.21		Continued.	ID Fan problem, Converted to Zero Schedule By MSEDCCL from 00.00hrs/22-9-16. Shutdown taken on 18.10.2016 at 00:00Hrs for Turbine inspection and maintenance work
IPP	PGPL U1	262MW	07/Feb/2017	17.30		Continued.	No Schedule
IPP	PGPL U2	126MW	07/Feb/2017	17.30		Continued.	No Schedule
MSPGCL	Ghatghar Unit-2	125MW	28/Jul/2017	00.00		Continued.	due to common pressure shaft with unit 1.
IPP	SWPGL U-3	135MW	26/Aug/2017	17.40	20/Nov/2017	01.52	Boiler Tube Leakage
MSPGCL	Khaparkhedha Unit 3	210MW	12/Sep/2017	00.00		Continued.	Coal Shortage
IPP	RPL(AMT) U-3	270MW	17/Sep/2017	00.02		Continued.	Coal Shortage
IPP	RPL(AMT) U-5	270MW	17/Sep/2017	02.01		Continued.	Coal Shortage
MSPGCL	Parli Unit 7	250MW	12/Oct/2017	00.00	13/Nov/2017	15.00	Zero Schedule from 12.10.2017 to 31.10.2017, Shutdown due to coal shortage from 00:00Hrs of 01.11.2017
MSPGCL	Chandrapur Unit 3		25/Oct/2017	00.45		Continued.	Boiler tube leakage. Continued due to shortage of water from dt.01/11/17 0:00 hrs
IPP	Dhariwal		27/Oct/2017	17.31		Continued.	Drum level Not Maintained
MSPGCL	Chandrapur Unit 4		29/Oct/2017	04.45		Continued.	Auxiliary supply failure. Continued due to water shortage from dt. 01/11/17 0:00 hrs.
MSPGCL	Nasik Unit 3		30/Oct/2017	23.35	17/Nov/2017	10.45	GOVERNING SYSTEM PROBLEM.(Coal Shortage since 07.11.2017)
MSPGCL	Bhusawal Unit 3		31/Oct/2017	22.37		Continued.	Coal Shortage
IPP	SWPGL U-4		01/Nov/2017	00.02		Continued.	Boiler Tube Leakage
MSPGCL	Koradi Unit 7		01/Nov/2017	00.05		Continued.	Poor Coal Receipt.
MSPGCL	Chandrapur Unit 9		03/Nov/2017	08.00	07/Nov/2017	02.09	Economizer Tube Leakage.
MSPGCL	Koradi Unit-8		07/Nov/2017	00.06		Continued.	poor coal receipt.
MSPGCL	Khaparkhedha Unit 5		08/Nov/2017	08.56	11/Nov/2017	10.57	Boiler Tube Leakage
MSPGCL	Ghatghar Unit-1		09/Nov/2017	20.00	10/Nov/2017	10.00	Generator T/F Problem
MSPGCL	Koyna Unit 6		10/Nov/2017	01.10	10/Nov/2017	03.50	LLB Trip. load Affected Nil.
MSPGCL	Koyna Unit 5		10/Nov/2017	01.10	10/Nov/2017	03.00	LLB Trip. load Affected Nil.
MSPGCL	Koyna Unit 8		10/Nov/2017	01.10	10/Nov/2017	02.35	LLB Trip. load Affected Nil.
IPP	RPL(AMT) U-2		10/Nov/2017	00.00		Continued.	Coal Shortage
IPP	Adani U-1		10/Nov/2017	02.29	20/Nov/2017	06.08	Coal Shortage
MSPGCL	Koyna Unit 7		10/Nov/2017	01.10	10/Nov/2017	04.00	LLB Trip. load Affected Nil.
IPP	IEPL Unit 1		11/Nov/2017	02.07	11/Nov/2017	13.20	M.S.Temp Low
IPP	IEPL Unit 1		11/Nov/2017	17.52	11/Nov/2017	20.09	Low furnace pressure
IPP	JSW (J) U2		12/Nov/2017	01.33	14/Nov/2017	20.28	CW duct leakage
IPP	IEPL Unit 1		12/Nov/2017	21.38	13/Nov/2017	04.15	Furnace Pressure High
MSPGCL	Chandrapur Unit-8		12/Nov/2017	22.06	15/Nov/2017	13.42	Boiler Tube Leakage

LINE OUTAGES AND RIPPING FOR THE WEEK FROM 06/11/2017 TO 12/11/2017

Voltage	Name of Line	Tripping Date	Tripping Time	Synch Date	Synch Time	Reason
400 KV	Karad -Solapur (PG)	03/May/2017	11:49		Continued.	Line converted as 220 kV Solapur (PG)- Jeur from LOC 403
400 KV	Ektuni-Bableshtar ckt I	26/Oct/2017	15.16	08/Nov/2017	12.29	SCADA work (RFC 19.53Hrs Dt.27/10/2017)
400 KV	Babhaleshwar - Padghe-II	04/Nov/2017	06.01	07/Nov/2017	21.13	Reorientation of Bay
400 KV	Padghe - Kalwa - I	05/Nov/2017	05.45	06/Nov/2017	08.19	Reorientation of Bay
400 KV	Dhule Sar'Sarovar II	05/Nov/2017	17.07	06/Nov/2017	06.36	Over Voltage
400 KV	Jaigad-Karad Ckt-II	05/Nov/2017	17.08	06/Nov/2017	11.07	Over Voltage
400 KV	Karad -kolhapur-I	05/Nov/2017	17.16	06/Nov/2017	11.01	Over Voltage
400 KV	Chakan Talegaon(Pg)	05/Nov/2017	18.06	06/Nov/2017	01.32	To attend conductor snapping work.
400 KV	Babhaleshwar - Padghe-I	05/Nov/2017	19.18	06/Nov/2017	15.58	Reorientation of line at padghe.
400 KV	Padghe - Kalwa-II	06/Nov/2017	05.09	06/Nov/2017	20.20	Reorientation of line at padghe.
400 KV	Karad -kolhapur-I	06/Nov/2017	17.04	07/Nov/2017	09.04	Over Voltage
400 KV	Jaigad-Karad Ckt-II	06/Nov/2017	17.06	07/Nov/2017	10.05	Over Voltage
400 KV	N Koyna-Karad -Ckt II	06/Nov/2017	17.39	07/Nov/2017	09.01	main bus-1 outage.
400 KV	Dhule Sar'Sarovar I	06/Nov/2017	18.57	13/Nov/2017	06.26	Over Voltage
400 KV	Chandrapur - Khaperkheda	07/Nov/2017	10.57	07/Nov/2017	14.28	fixing of broken earh wire.
400 KV	koaradi II - Wardha(PG)	07/Nov/2017	12.07	07/Nov/2017	13.10	Attending Hot Spot
400 KV	Lonikand I - Koyna stage-IV	07/Nov/2017	13.40	07/Nov/2017	14.48	Distance Protection
400 KV	Dabhol Nagothane I	07/Nov/2017	14.21	07/Nov/2017	19.41	Distance Protection
400 KV	Chandrapur - Khaperkheda	07/Nov/2017	14.59	07/Nov/2017	15.11	Testing Work
400 KV	Karad -kolhapur-II	07/Nov/2017	18.51	08/Nov/2017	10.29	Over Voltage
400 KV	Jaigad-Karad Ckt-I	07/Nov/2017	18.57	08/Nov/2017	10.21	Over Voltage
400 KV	Khadka-Aurangabad (Waluj)	07/Nov/2017	20.16	08/Nov/2017	06.19	Over Voltage
400 KV	Lonikand I - Koyna stage-IV	07/Nov/2017	22.42	08/Nov/2017	06.11	Over Voltage
400 KV	New Koyna -Koyna Stage IV-I	08/Nov/2017	09.07	08/Nov/2017	19.21	Insulator Washing Work.
400 KV	Chandrapur II - Chandrapur ckt 2	08/Nov/2017	10.29	08/Nov/2017	15.37	Diagnostic Testing Work.
400 KV	Kolhapur(M)-Kolhapur(GIS) ckt1	08/Nov/2017	12.24	08/Nov/2017	20.27	Annual Maintenance Work
400 KV	Ektuni-Bableshtar ckt II	08/Nov/2017	12.41	14/Nov/2017	10.11	Over Voltage
400 KV	Karad -kolhapur-I	08/Nov/2017	20.30	09/Nov/2017	08.08	Over Voltage
400 KV	Karad - Jaigad - II	08/Nov/2017	20.35	09/Nov/2017	08.13	Over Voltage
400 KV	Khadka-Aurangabad (Waluj)	08/Nov/2017	20.38	09/Nov/2017	07.06	Over Voltage
400 KV	Karad-Jaigad - I	09/Nov/2017	10.02	09/Nov/2017	16.44	Routine Maintenance Work
400 KV	Warora -IEPL	09/Nov/2017	12.47	09/Nov/2017	18.48	Attending Hot Spot
400 KV	Khadka-Aurangabad (Waluj)	09/Nov/2017	19.07	10/Nov/2017	06.44	Over Voltage
400 KV	Karad - Jaigad - II	09/Nov/2017	19.51	10/Nov/2017	10.19	Over Voltage
400 KV	Karad -kolhapur-II	09/Nov/2017	19.57	10/Nov/2017	10.17	Over Voltage
400 KV	Padghe(HVDC)- Padghe(HVAC)-I	10/Nov/2017	11.22	12/Nov/2017	21.34	Attending Hot Spot
400 KV	Khadka-Aurangabad (Waluj)	10/Nov/2017	17.13	11/Nov/2017	07.03	Over Voltage
400 KV	Karad - Jaigad - II	10/Nov/2017	18.43	12/Nov/2017	11.18	Over Voltage
400 KV	Karad -kolhapur-II	10/Nov/2017	18.51	12/Nov/2017	11.26	Over Voltage
400 KV	Khadka-Aurangabad (Waluj)	11/Nov/2017	17.43	12/Nov/2017	06.38	Over Voltage
400 KV	Lonikand I - Koyna stage-IV	11/Nov/2017	21.45	12/Nov/2017	05.20	Over Voltage
400 KV	Karad -kolhapur-I	12/Nov/2017	17.48	13/Nov/2017	11.40	Over Voltage
400 KV	Khadka-Aurangabad (Waluj)	12/Nov/2017	17.49	13/Nov/2017	06.14	Over Voltage
400 KV	Jaigad-Karad Ckt-II	12/Nov/2017	17.49	13/Nov/2017	11.31	Over Voltage
400 KV	Lonikand I - Koyna stage-IV	12/Nov/2017	23.14	13/Nov/2017	06.10	Over Voltage
400 KV	Karad - Jaigad - II	18/Nov/2017	17.44		Continued.	Over Voltage
400 KV	Karad -kolhapur-I	18/Nov/2017	20.07		Continued.	Over Voltage
400 KV	Alkud-Kolhapur(Talandage)	20/Nov/2017	11.54		Continued.	Quarterly Maintenance Work
400 KV	Ektuni-Bableshtar ckt II	20/Nov/2017	16.02		Continued.	Attending Hot Spot
220 KV	Chandrapur GCR - Warora - I	05/Apr/2015	09.13		Continued.	Bunching of conductor Loc no 86 Disconnecting of jumper at Loc no 86 & 107 and de-energising the line bet.86 to 107.
220 KV	Chandrapur GCR - Wani	05/Apr/2015	09.15		Continued.	Bunching of conductor Loc no 86 Disconnecting of jumper at Loc no 86 & 107 and de-energising the line bet.86 to 107.
220 KV	Talandage - Chikodi	01/Jun/2017	00.01		Continued.	NO SCHEDULE.
220 KV	Mudshingi - Chikodi	01/Jun/2017	00.06		Continued.	NO SCHEDULE.
220 KV	Kharghar-Borivali ckt II	07/Jun/2017	12.23		Continued.	Distance Protection RY phase fault.
220 KV	Pedambe-Nerle	23/Sep/2017	00.50		Continued.	B Phase CT Burst at Pedambe End
220 KV	Chalisgaon - Deepnagar	06/Nov/2017	08.43	06/Nov/2017	16.03	diagnostic testing work.
220 KV	Badnera - Amravati	06/Nov/2017	09.35	06/Nov/2017	13.45	diagnostic testing work.
220 KV	Karad(400kv) - Wathar	06/Nov/2017	10.15	06/Nov/2017	17.37	bus isolator Maintenance Work.
220 KV	Parly-Parly Extn-I	06/Nov/2017	12.10	06/Nov/2017	18.12	Tan Delta Measurment of CTs
220 KV	New Koyna - Niwali	06/Nov/2017	13.16	06/Nov/2017	17.47	Line Maintenance work
220 KV	Dahanu-Viraj	06/Nov/2017	16.30	06/Nov/2017	18.23	Attending Hot Spot
220 KV	GIS Bhandup - Borivali	07/Nov/2017	05.58	07/Nov/2017	17.45	construction work.
220 KV	Nerul - Sonkhar	07/Nov/2017	06.28	07/Nov/2017	10.22	Attending Hot Spot
220 KV	Boisar Versova Line	07/Nov/2017	07.21	07/Nov/2017	09.39	attend red hot on y-ph ct at versova.
220 KV	Kalwa - Borivali	07/Nov/2017	08.00	09/Nov/2017	17.50	Taken on TBC for Isolator replacement
220 KV	Malharpeth - Karad(400kv)	07/Nov/2017	09.06	07/Nov/2017	22.14	Replacement of cts.
220 KV	Khadka-Chalisgaon-1	07/Nov/2017	09.08	07/Nov/2017	11.11	Testing Work
220 KV	Deepnagar Bambhori	07/Nov/2017	12.47	07/Nov/2017	16.52	Testing Work
220 KV	Phulambri-Bhokardan	07/Nov/2017	13.43	07/Nov/2017	16.50	Attending Hot Spot
220 KV	Deepnagar Bambhori	07/Nov/2017	16.56	07/Nov/2017	22.52	insulator string flash out.
220 KV	Lamboti(solapur)-Karkamb	07/Nov/2017	19.28	08/Nov/2017	05.03	Over Voltage
220 KV	GIS Bhandup - Borivali	08/Nov/2017	06.03	08/Nov/2017	17.56	Line Maintenance work
220 KV	Mudshingi-Wathar	08/Nov/2017	10.10	08/Nov/2017	13.57	Attending Hot Spot
220 KV	Wardha Deoli (Pg)	08/Nov/2017	11.25	08/Nov/2017	18.53	Wardha Main Bus Outage.
220 KV	Karad -Mudshingi Ckt- IV	08/Nov/2017	15.01	08/Nov/2017	18.02	Annual Maintenance Work
220 KV	Kandalgaon - Bhira	08/Nov/2017	16.20	08/Nov/2017	19.35	Routine Maintenance Work
220 KV	Lamboti - Pandharpur li	08/Nov/2017	20.41	09/Nov/2017	06.06	Over Voltage

Voltage	Name of Line	Tripping Date	Tripping Time	Synch Date	Synch Time	Reason
220 KV	Theur-Phursungi	09/Nov/2017	09.37	09/Nov/2017	17.28	Routine Maintenance Work
220 KV	Urse - Talegaon (Ambi) Ckt 1	09/Nov/2017	10.20	09/Nov/2017	16.46	Routine Maintenance Work
220 KV	Karad(400kv) - Ogalewadi Ckt 1	09/Nov/2017	10.50	09/Nov/2017	14.21	Routine Maintenance Work
220 KV	Paras-Balapur li	09/Nov/2017	11.04	09/Nov/2017	18.18	Measurment of Tan Delta of CT Measurment of CB timing and CRM measurment of IR Values of CT
220 KV	Yeotmal- Pused	09/Nov/2017	13.36	09/Nov/2017	15.06	Line Maintenance work
220 KV	Solapur(PG)- Jeur	09/Nov/2017	14.18	09/Nov/2017	18.56	String Replacement by hot line
220 KV	Kandalgaon - Bhira	09/Nov/2017	14.30	09/Nov/2017	18.02	Isolator work
220 KV	Pedambe-Pophali	10/Nov/2017	01.10	10/Nov/2017	02.55	LLB Trip. load Affected Nil.
220 KV	Pophali - Nerale	10/Nov/2017	01.10	10/Nov/2017	03.05	LLB Trip. load Affected Nil.
220 KV	Pophali - New Koyna	10/Nov/2017	01.10	10/Nov/2017	02.15	LLB Trip. load Affected Nil.
220 KV	Bus Section II @ Pophali	10/Nov/2017	01.10	10/Nov/2017	02.15	LLB Trip. load Affected Nil.
220 KV	Nashik-Padgha	10/Nov/2017	09.03	10/Nov/2017	13.17	Daignostic testing work
220 KV	Mumewadi -Halkarni I	10/Nov/2017	09.08	10/Nov/2017	18.24	Coal washing
220 KV	Bapgaon - Kalwa	10/Nov/2017	09.32	10/Nov/2017	20.25	CT Replcement work
220 KV	Jambhul - Anandnagar	10/Nov/2017	10.07	10/Nov/2017	19.01	Routine Maintenance Work
220 KV	Mudshingi - Chikodi	10/Nov/2017	10.52	10/Nov/2017	17.39	Diagnostic testing
220 KV	Uran - Jnpt	10/Nov/2017	11.53	10/Nov/2017	16.45	Routine Maintenance Work
220 KV	Butibori - Wardha	10/Nov/2017	22.01	10/Nov/2017	22.39	R PH CT BURST AT DHAMANGAON CKT. BUS BAR OPERATED. LOAD AFFECTED APPROX 14 MW.
220 KV	Bhugaon- Wardha	10/Nov/2017	22.01	10/Nov/2017	22.29	R PH CT BURST AT DHAMANGAON CKT. BUS BAR OPERATED. LOAD AFFECTED APPROX 14 MW.
220 KV	Abhijeet-Wardha-II	10/Nov/2017	22.01	10/Nov/2017	22.37	R PH CT BURST AT DHAMANGAON CKT. BUS BAR OPERATED. LOAD AFFECTED APPROX 14 MW.
220 KV	Abhijeet-Wardha-I	10/Nov/2017	22.01	10/Nov/2017	22.34	R PH CT BURST AT DHAMANGAON CKT. BUS BAR OPERATED. LOAD AFFECTED APPROX 14 MW.
220 KV	Wardha Deoli (Pg)	10/Nov/2017	22.01	10/Nov/2017	22.29	R PH CT BURST AT DHAMANGAON CKT. BUS BAR OPERATED. LOAD AFFECTED APPROX 14 MW.
220 KV	Warora - Wardha	10/Nov/2017	22.01	10/Nov/2017	22.45	R PH CT BURST AT DHAMANGAON CKT. BUS BAR OPERATED. LOAD AFFECTED APPROX 14 MW.
220 KV	Wardha-Yeotmal	10/Nov/2017	22.01	10/Nov/2017	22.41	R PH CT BURST AT DHAMANGAON CKT. BUS BAR OPERATED. LOAD AFFECTED APPROX 14 MW.
220 KV	Wardha-Dhamangaon	10/Nov/2017	22.01	11/Nov/2017	23.05	R PH CT BURST AT DHAMANGAON CKT. BUS BAR OPERATED.
220 KV	Wardha - Wardharlytss1	10/Nov/2017	22.01	10/Nov/2017	22.30	R PH CT BURST AT DHAMANGAON CKT. BUS BAR OPERATED. LOAD AFFECTED APPROX 14 MW.
220 KV	Wardha - Wardha Rly Tss 2	10/Nov/2017	22.01	10/Nov/2017	22.30	R PH CT BURST AT DHAMANGAON CKT. BUS BAR OPERATED. LOAD AFFECTED APPROX 14 MW.
220 KV	Malegaon-Satana	11/Nov/2017	09.05	11/Nov/2017	12.15	Testing Work
220 KV	Halkarni-Mahalaxmiline	11/Nov/2017	09.38	11/Nov/2017	18.39	insulator cleaning work.
220 KV	Pophali - New Koyna	11/Nov/2017	09.46	11/Nov/2017	14.43	Testing Work
220 KV	Nanded-Waghale I	11/Nov/2017	10.05	11/Nov/2017	14.26	To attend Hot Spot
220 KV	Adlabs - Pedambe	11/Nov/2017	10.22	11/Nov/2017	18.30	Insulator Replacement Work
220 KV	Chandrapur GCR - Sicom I	11/Nov/2017	10.45	11/Nov/2017	12.39	Line Maintenance work
220 KV	Nashik-Airoli Knowledge Park	11/Nov/2017	11.49	11/Nov/2017	18.53	Outage on 220kv Nashik Bableshwar-1 line.
220 KV	Eklahara(Gcr)(Nasik)- Bableshwar-I	11/Nov/2017	12.03	11/Nov/2017	18.46	Attending Hot Spot
220 KV	Kalmeshwar-Pandhurna	11/Nov/2017	12.32	11/Nov/2017	18.27	Work at pandurna end.
220 KV	Nanded-Waghale II	11/Nov/2017	14.33	11/Nov/2017	17.20	To attend Hot Spot
220 KV	Trombay - Mulund	12/Nov/2017	07.21	12/Nov/2017	11.50	Replacement of jumper.
220 KV	Dahanu Versova	12/Nov/2017	09.14	12/Nov/2017	19.39	La Replacement work.
220 KV	Salsette Borivli 2	12/Nov/2017	8.40	12/Nov/2017	15.51	For safety purpose.
220 KV	Mumewadi -Halkarni II	17/Nov/2017	10.00		Continued.	Tower erection work (temporarily line would be Mumewadi-Tillari)
220 KV	Halkarni - Tillari II	17/Nov/2017	12.25		Continued.	Tower erection work. (temporarily line would be Mumewadi-Tillari)
132 KV	Suprim - Pahur	08/Nov/2017	16.05	08/Nov/2017	16.44	Back Up Protection Optd. Tripped At Suprim End.
132 KV	Waghala - Kandhar	11/Nov/2017	17.42	11/Nov/2017	19.43	Bus Bar Protection Operated
132 KV	Nanded - Jangamwadi II	11/Nov/2017	17.42	11/Nov/2017	19.18	Bus Bar Protection Operated
132 KV	Nanded - Umri II	11/Nov/2017	17.42	12/Nov/2017	22.30	B Phase CT Burst, Bus Bar Prot.operated
132 KV	Waghala-Vishnupurick1	11/Nov/2017	17.42	11/Nov/2017	18.32	Bus Bar Protection Operated
132 KV	Waghala(Nanded2) - Ardhapur	11/Nov/2017	17.42	11/Nov/2017	19.38	Bus Bar Protection Operated
132 KV	Waghala -Nanded-I(Jangamwadi)	11/Nov/2017	17.42	11/Nov/2017	18.20	Bus Bar Protection Operated
132 KV	Waghala (Nanded2) - Umri 1	11/Nov/2017	17.42	11/Nov/2017	18.34	Bus Bar Protection Operated
132 KV	Waghala (Nanded2) - Tamsa	11/Nov/2017	17.42	11/Nov/2017	18.25	Bus Bar Protection Operated
132 KV	Waghala (Nanded2) - Narsi	11/Nov/2017	17.42	11/Nov/2017	18.23	Bus Bar Protection Operated
132 KV	Waghala (Nanded2) - Elichpur	11/Nov/2017	17.42	11/Nov/2017	19.41	Bus Bar Protection Operated