

# State Load Despatch Center, Airoli (MSETCL)

## Power System Position from 15/Apr/2019 to 21/Apr/2019

### Supply Position During Morning Peak (MW)

| Date           | Time   | MSGENCO     |             |            |             | Central Sector Receipt | Wind       | CPP         | SOLAR       | TPCL Exch.   | MSEDCL Catered Demand | Load Sheddin g(LS) | MSEDCL Demand (Incl. LS) | TPCL Gen.   | R-INFRA Gen. | State Demand Met | State Demand (Incl. LS) | Freq.        |
|----------------|--------|-------------|-------------|------------|-------------|------------------------|------------|-------------|-------------|--------------|-----------------------|--------------------|--------------------------|-------------|--------------|------------------|-------------------------|--------------|
|                |        | THM         | HYDRO       | GAS        | Total       |                        |            |             |             |              |                       |                    |                          |             |              |                  |                         |              |
|                |        | MW          | MW          | MW         | MW          | MW                     | MW         | MW          | MW          | MW           | MW                    | MW                 | MW                       | MW          | MW           | MW               | MW                      | Hzs          |
| 15/04/2019     | 12 Hrs | 6306        | 1093        | 281        | 7680        | 6526                   | 202        | 5450        | 713         | -1783        | 18788                 | 0                  | 18788                    | 1092        | 481          | 22144            | 22144                   | 50.03        |
| 16/04/2019     | 12 Hrs | 6269        | 538         | 271        | 7078        | 6691                   | 176        | 5316        | 762         | -1841        | 18182                 | 0                  | 18182                    | 1053        | 493          | 21569            | 21569                   | 49.97        |
| 17/04/2019     | 12 Hrs | 5866        | 841         | 282        | 6989        | 6737                   | 440        | 4304        | 995         | -1795        | 17670                 | 0                  | 17670                    | 956         | 250          | 20671            | 20671                   | 50.03        |
| 18/04/2019     | 12 Hrs | 6233        | 1503        | 282        | 8018        | 6836                   | 191        | 3474        | 1025        | -1402        | 18142                 | 0                  | 18142                    | 1308        | 499          | 21351            | 21351                   | 50.03        |
| 19/04/2019     | 12 Hrs | 6421        | 1144        | 279        | 7844        | 6625                   | 179        | 4127        | 1003        | -1687        | 18091                 | 0                  | 18091                    | 891         | 373          | 21042            | 21042                   | 50.03        |
| 20/04/2019     | 12 Hrs | 6540        | 1501        | 280        | 8321        | 6764                   | 200        | 4406        | 1027        | -1696        | 19022                 | 0                  | 19022                    | 954         | 373          | 22045            | 22045                   | 50.00        |
| 21/04/2019     | 12 Hrs | 6142        | 1076        | 282        | 7500        | 6369                   | 182        | 4557        | 992         | -1189        | 18411                 | 0                  | 18411                    | 695         | 371          | 20666            | 20666                   | 50.04        |
| <b>Maximum</b> |        | <b>6540</b> | <b>1503</b> | <b>282</b> | <b>8321</b> | <b>6836</b>            | <b>440</b> | <b>5450</b> | <b>1027</b> | <b>-1189</b> | <b>19022</b>          | <b>0</b>           | <b>19022</b>             | <b>1308</b> | <b>499</b>   | <b>22144</b>     | <b>22144</b>            | <b>50.04</b> |
| <b>Minimum</b> |        | <b>5866</b> | <b>538</b>  | <b>271</b> | <b>6989</b> | <b>6369</b>            | <b>176</b> | <b>3474</b> | <b>713</b>  | <b>-1841</b> | <b>17670</b>          | <b>0</b>           | <b>17670</b>             | <b>695</b>  | <b>250</b>   | <b>20666</b>     | <b>20666</b>            | <b>49.97</b> |
| <b>Average</b> |        | <b>6254</b> | <b>1099</b> | <b>280</b> | <b>7633</b> | <b>6650</b>            | <b>224</b> | <b>4519</b> | <b>931</b>  | <b>-1628</b> | <b>18329</b>          | <b>0</b>           | <b>18329</b>             | <b>993</b>  | <b>406</b>   | <b>21355</b>     | <b>21355</b>            | <b>50.02</b> |

### Supply Position During Day Peak (MW)

| Date           | Time   | MSGENCO     |             |            |             | Central Sector Receipt | Wind       | CPP         | SOLAR       | TPCL Exch.   | MSEDCL Catered Demand | Load Sheddin g(LS) | MSEDCL Demand (Incl. LS) | TPCL Gen.   | R-INFRA Gen. | State Demand Met | State Demand (Incl. LS) | Freq.        |
|----------------|--------|-------------|-------------|------------|-------------|------------------------|------------|-------------|-------------|--------------|-----------------------|--------------------|--------------------------|-------------|--------------|------------------|-------------------------|--------------|
|                |        | THM         | HYDRO       | GAS        | Total       |                        |            |             |             |              |                       |                    |                          |             |              |                  |                         |              |
|                |        | MW          | MW          | MW         | MW          | MW                     | MW         | MW          | MW          | MW           | MW                    | MW                 | MW                       | MW          | MW           | MW               | MW                      | Hzs          |
| 15/04/2019     | 15 Hrs | 6496        | 1276        | 284        | 8056        | 6868                   | 446        | 5337        | 584         | -1827        | 19464                 | 0                  | 19464                    | 1110        | 422          | 22823            | 22823                   | 49.98        |
| 16/04/2019     | 16 Hrs | 6425        | 806         | 284        | 7515        | 6656                   | 550        | 5271        | 302         | -1772        | 18522                 | 0                  | 18522                    | 1107        | 495          | 21896            | 21896                   | 50.06        |
| 17/04/2019     | 13 Hrs | 5899        | 1128        | 281        | 7308        | 6412                   | 552        | 4284        | 1064        | -1780        | 17840                 | 0                  | 17840                    | 959         | 250          | 20829            | 20829                   | 50.01        |
| 18/04/2019     | 16 Hrs | 6315        | 1575        | 281        | 8171        | 6699                   | 378        | 3758        | 720         | -1393        | 18333                 | 0                  | 18333                    | 1286        | 501          | 21513            | 21513                   | 49.97        |
| 19/04/2019     | 13 Hrs | 6419        | 1257        | 267        | 7943        | 6448                   | 325        | 4178        | 993         | -1705        | 18182                 | 0                  | 18182                    | 885         | 371          | 21143            | 21143                   | 50.04        |
| 20/04/2019     | 16 Hrs | 6336        | 1288        | 281        | 7905        | 6634                   | 666        | 4536        | 510         | -1698        | 18553                 | 0                  | 18553                    | 915         | 372          | 21538            | 21538                   | 49.97        |
| 21/04/2019     | 13 Hrs | 6012        | 1227        | 282        | 7521        | 6175                   | 219        | 4597        | 1007        | -1264        | 18255                 | 0                  | 18255                    | 696         | 372          | 20587            | 20587                   | 50.00        |
| <b>Maximum</b> |        | <b>6496</b> | <b>1575</b> | <b>284</b> | <b>8171</b> | <b>6868</b>            | <b>666</b> | <b>5337</b> | <b>1064</b> | <b>-1264</b> | <b>19464</b>          | <b>0</b>           | <b>19464</b>             | <b>1286</b> | <b>501</b>   | <b>22823</b>     | <b>22823</b>            | <b>50.06</b> |
| <b>Minimum</b> |        | <b>5899</b> | <b>806</b>  | <b>267</b> | <b>7308</b> | <b>6175</b>            | <b>219</b> | <b>3758</b> | <b>302</b>  | <b>-1827</b> | <b>17840</b>          | <b>0</b>           | <b>17840</b>             | <b>696</b>  | <b>250</b>   | <b>20587</b>     | <b>20587</b>            | <b>49.97</b> |
| <b>Average</b> |        | <b>6272</b> | <b>1222</b> | <b>280</b> | <b>7774</b> | <b>6556</b>            | <b>448</b> | <b>4566</b> | <b>740</b>  | <b>-1634</b> | <b>18450</b>          | <b>0</b>           | <b>18450</b>             | <b>994</b>  | <b>398</b>   | <b>21476</b>     | <b>21476</b>            | <b>50.00</b> |

# State Load Despatch Center, Airoli (MSETCL)

## Power System Position from 15/Apr/2019 to 21/Apr/2019

### Supply Position During Evening Peak (MW)

| Date           | Time   | MSGENCO     |             |            |             | Central Sector Receipt | Wind        | CPP         | SOLAR     | TPCL Exch.   | MSEDCL Catered Demand | Load Sheddin g(LS) | MSEDCL Demand (Incl. LS) | TPCL Gen.   | R-INFRA Gen. | State Demand Met | State Demand (Incl. LS) | Freq.        |
|----------------|--------|-------------|-------------|------------|-------------|------------------------|-------------|-------------|-----------|--------------|-----------------------|--------------------|--------------------------|-------------|--------------|------------------|-------------------------|--------------|
|                |        | THM         | HYDRO       | GAS        | Total       |                        |             |             |           |              |                       |                    |                          |             |              |                  |                         |              |
|                |        | MW          | MW          | MW         | MW          | MW                     | MW          | MW          | MW        | MW           | MW                    | MW                 | MW                       | MW          | MW           | MW               | MW                      | Hzs          |
| 15/04/2019     | 19 Hrs | 5729        | 214         | 287        | 6230        | 5839                   | 1254        | 4846        | 15        | -1554        | 16630                 | 0                  | 16630                    | 995         | 501          | 19680            | 19680                   | 50.05        |
| 16/04/2019     | 20 Hrs | 6035        | 828         | 288        | 7151        | 5564                   | 1115        | 4652        | 0         | -1668        | 16814                 | 0                  | 16814                    | 982         | 377          | 19841            | 19841                   | 50.07        |
| 17/04/2019     | 20 Hrs | 5561        | 1647        | 289        | 7497        | 5837                   | 985         | 4584        | 0         | -1552        | 17351                 | 0                  | 17351                    | 948         | 251          | 20102            | 20102                   | 49.98        |
| 18/04/2019     | 20 Hrs | 6289        | 1041        | 287        | 7617        | 6255                   | 647         | 4387        | 0         | -1424        | 17482                 | 0                  | 17482                    | 1040        | 374          | 20320            | 20320                   | 49.97        |
| 19/04/2019     | 20 Hrs | 5942        | 1312        | 285        | 7539        | 5808                   | 967         | 4339        | 0         | -1559        | 17094                 | 0                  | 17094                    | 849         | 373          | 19875            | 19875                   | 50.00        |
| 20/04/2019     | 20 Hrs | 5819        | 1349        | 287        | 7455        | 5691                   | 906         | 4752        | 0         | -1491        | 17313                 | 0                  | 17313                    | 931         | 373          | 20108            | 20108                   | 49.99        |
| 21/04/2019     | 20 Hrs | 5528        | 929         | 287        | 6744        | 5621                   | 1229        | 4165        | 0         | -1251        | 16508                 | 0                  | 16508                    | 770         | 375          | 18904            | 18904                   | 49.97        |
| <b>Maximum</b> |        | <b>6289</b> | <b>1647</b> | <b>289</b> | <b>7617</b> | <b>6255</b>            | <b>1254</b> | <b>4846</b> | <b>15</b> | <b>-1251</b> | <b>17482</b>          | <b>0</b>           | <b>17482</b>             | <b>1040</b> | <b>501</b>   | <b>20320</b>     | <b>20320</b>            | <b>50.07</b> |
| <b>Minimum</b> |        | <b>5528</b> | <b>214</b>  | <b>285</b> | <b>6230</b> | <b>5564</b>            | <b>647</b>  | <b>4165</b> | <b>0</b>  | <b>-1668</b> | <b>16508</b>          | <b>0</b>           | <b>16508</b>             | <b>770</b>  | <b>251</b>   | <b>18904</b>     | <b>18904</b>            | <b>49.97</b> |
| <b>Average</b> |        | <b>5843</b> | <b>1046</b> | <b>287</b> | <b>7176</b> | <b>5802</b>            | <b>1015</b> | <b>4532</b> | <b>2</b>  | <b>-1500</b> | <b>17027</b>          | <b>0</b>           | <b>17027</b>             | <b>931</b>  | <b>375</b>   | <b>19833</b>     | <b>19833</b>            | <b>50.00</b> |

### Supply Position During Night Off Peak (MW)

| Date           | Time  | MSGENCO     |             |            |             | Central Sector Receipt | Wind        | CPP         | SOLAR    | TPCL Exch.   | MSEDCL Catered Demand | Load Sheddin g(LS) | MSEDCL Demand (Incl. LS) | TPCL Gen.  | R-INFRA Gen. | State Demand Met | State Demand (Incl. LS) | Freq.        |
|----------------|-------|-------------|-------------|------------|-------------|------------------------|-------------|-------------|----------|--------------|-----------------------|--------------------|--------------------------|------------|--------------|------------------|-------------------------|--------------|
|                |       | THM         | HYDRO       | GAS        | Total       |                        |             |             |          |              |                       |                    |                          |            |              |                  |                         |              |
|                |       | MW          | MW          | MW         | MW          | MW                     | MW          | MW          | MW       | MW           | MW                    | MW                 | MW                       | MW         | MW           | MW               | MW                      | Hzs          |
| 15/04/2019     | 4 Hrs | 5568        | 915         | 289        | 6772        | 5310                   | 562         | 4534        | 0        | -1186        | 15992                 | 0                  | 15992                    | 629        | 374          | 18181            | 18181                   | 50.03        |
| 16/04/2019     | 4 Hrs | 5961        | 619         | 291        | 6871        | 5630                   | 334         | 4056        | 0        | -1064        | 15827                 | 0                  | 15827                    | 676        | 492          | 18059            | 18059                   | 50.04        |
| 17/04/2019     | 4 Hrs | 5535        | 664         | 291        | 6490        | 5751                   | 1122        | 3820        | 0        | -1266        | 15917                 | 0                  | 15917                    | 650        | 250          | 18083            | 18083                   | 50.02        |
| 18/04/2019     | 4 Hrs | 6012        | 748         | 298        | 7058        | 6119                   | 721         | 3690        | 0        | -1122        | 16466                 | 0                  | 16466                    | 681        | 198          | 18467            | 18467                   | 49.97        |
| 19/04/2019     | 4 Hrs | 6287        | 459         | 292        | 7038        | 5923                   | 523         | 4222        | 0        | -1008        | 16698                 | 0                  | 16698                    | 693        | 375          | 18774            | 18774                   | 50.03        |
| 20/04/2019     | 4 Hrs | 6152        | 1455        | 305        | 7912        | 5774                   | 432         | 3831        | 0        | -1026        | 16923                 | 0                  | 16923                    | 687        | 373          | 19009            | 19009                   | 50.06        |
| 21/04/2019     | 4 Hrs | 5679        | 665         | 294        | 6638        | 5585                   | 1032        | 4264        | 0        | -1046        | 16473                 | 0                  | 16473                    | 696        | 373          | 18588            | 18588                   | 49.92        |
| <b>Maximum</b> |       | <b>6287</b> | <b>1455</b> | <b>305</b> | <b>7912</b> | <b>6119</b>            | <b>1122</b> | <b>4534</b> | <b>0</b> | <b>-1008</b> | <b>16923</b>          | <b>0</b>           | <b>16923</b>             | <b>696</b> | <b>492</b>   | <b>19009</b>     | <b>19009</b>            | <b>50.06</b> |
| <b>Minimum</b> |       | <b>5535</b> | <b>459</b>  | <b>289</b> | <b>6490</b> | <b>5310</b>            | <b>334</b>  | <b>3690</b> | <b>0</b> | <b>-1266</b> | <b>15827</b>          | <b>0</b>           | <b>15827</b>             | <b>629</b> | <b>198</b>   | <b>18059</b>     | <b>18059</b>            | <b>49.92</b> |
| <b>Average</b> |       | <b>5885</b> | <b>789</b>  | <b>294</b> | <b>6968</b> | <b>5727</b>            | <b>675</b>  | <b>4060</b> | <b>0</b> | <b>-1103</b> | <b>16328</b>          | <b>0</b>           | <b>16328</b>             | <b>673</b> | <b>348</b>   | <b>18452</b>     | <b>18452</b>            | <b>50.01</b> |

**State Load Despatch Center,Airoli (MSETCL)**  
**Power System Position from 15/Apr/2019 to 21/Apr/2019**

**Details of Supply Position (MUs)**

| Date           | MSGENCO        |               |              |                | Pench<br>(MS) | Central<br>Sector<br>Receipt | Central<br>Sector<br>Share | WIND           | CPP            | SOLAR        | TPCL<br>Gen.  | R-INFRA<br>Gen. | TPCL<br>Exch.  | Energy Requirement |               |                |
|----------------|----------------|---------------|--------------|----------------|---------------|------------------------------|----------------------------|----------------|----------------|--------------|---------------|-----------------|----------------|--------------------|---------------|----------------|
|                | THM            | HYDRO         | GAS          | Total          |               |                              |                            |                |                |              |               |                 |                | MSEDCL             | MUMBAI        | STATE          |
|                | Mus            | Mus           | Mus          | Mus            | Mus           | Mus                          | Mus                        | Mus            | Mus            | Mus          | Mus           | Mus             | Mus            | Mus                | Mus           | Mus            |
| 15/04/2019     | 144.827        | 21.328        | 6.866        | 173.021        | 0.096         | 141.321                      | 142.927                    | 13.876         | 118.971        | 5.235        | 21.077        | 10.256          | -36.756        | 415.668            | 68.088        | 483.756        |
| 16/04/2019     | 145.387        | 15.353        | 6.901        | 167.641        | 0.123         | 146.324                      | 146.933                    | 13.641         | 113.309        | 5.174        | 21.391        | 10.794          | -36.422        | 409.667            | 68.607        | 478.274        |
| 17/04/2019     | 137.542        | 24.149        | 6.920        | 168.611        | 0.023         | 144.944                      | 144.846                    | 20.476         | 102.552        | 7.751        | 19.994        | 6.085           | -36.408        | 407.926            | 62.487        | 470.413        |
| 18/04/2019     | 147.671        | 28.159        | 6.987        | 182.817        | 0.043         | 153.603                      | 152.867                    | 13.501         | 91.853         | 7.944        | 23.923        | 8.642           | -31.010        | 418.708            | 63.575        | 482.283        |
| 19/04/2019     | 151.046        | 21.467        | 6.867        | 179.380        | 0.040         | 146.985                      | 148.117                    | 14.525         | 100.608        | 7.783        | 19.309        | 9.199           | -33.065        | 416.216            | 61.575        | 477.791        |
| 20/04/2019     | 147.310        | 30.623        | 6.938        | 184.871        | 0.030         | 148.150                      | 149.727                    | 13.664         | 103.735        | 7.762        | 19.870        | 9.327           | -32.952        | 425.230            | 62.149        | 487.379        |
| 21/04/2019     | 139.491        | 21.356        | 6.964        | 167.811        | 0.056         | 141.722                      | 144.784                    | 18.257         | 107.048        | 7.655        | 17.042        | 8.942           | -28.525        | 413.968            | 54.509        | 468.477        |
| <b>Maximum</b> | <b>151.046</b> | <b>30.623</b> | <b>6.987</b> | <b>184.871</b> | <b>0.123</b>  | <b>153.603</b>               | <b>152.867</b>             | <b>151.046</b> | <b>118.971</b> | <b>7.944</b> | <b>23.923</b> | <b>10.794</b>   | <b>-28.525</b> | <b>425.230</b>     | <b>68.607</b> | <b>487.379</b> |
| <b>Minimum</b> | <b>137.542</b> | <b>15.353</b> | <b>6.866</b> | <b>167.641</b> | <b>0.023</b>  | <b>141.321</b>               | <b>142.927</b>             | <b>137.542</b> | <b>91.853</b>  | <b>5.174</b> | <b>17.042</b> | <b>6.085</b>    | <b>-36.756</b> | <b>407.926</b>     | <b>54.509</b> | <b>468.477</b> |
| <b>Average</b> | <b>144.753</b> | <b>23.205</b> | <b>6.920</b> | <b>174.879</b> | <b>0.059</b>  | <b>146.150</b>               | <b>147.172</b>             | <b>144.753</b> | <b>105.439</b> | <b>7.043</b> | <b>20.372</b> | <b>9.035</b>    | <b>-33.591</b> | <b>415.340</b>     | <b>62.999</b> | <b>478.339</b> |

## Details of Koyna Water Consumption (in TMC)

---

| Date       | For the Day | For the Month | Balance |
|------------|-------------|---------------|---------|
| 15/04/2019 | 0.414       | 5.157         | 29.566  |
| 16/04/2019 | 0.263       | 5.420         | 29.303  |
| 17/04/2019 | 0.486       | 5.906         | 28.817  |
| 18/04/2019 | 0.546       | 6.452         | 28.271  |
| 19/04/2019 | 0.445       | 6.897         | 27.826  |
| 20/04/2019 | 0.617       | 7.514         | 27.209  |
| 21/04/2019 | 0.422       | 7.936         | 26.787  |

**State Load Despatch Center,Airoli (MSETCL)**  
**Central Sector Share/Drawal from 15/Apr/2019 to 21/Apr/2019**

| Date         | DAY       | Central Sector Share |         | Total Interstate<br>Bilateral Purchase |         | Total Share     |         | Total Drawal    |         | Overdrawal(+) /<br>UnderDrawal(-) |         |
|--------------|-----------|----------------------|---------|----------------------------------------|---------|-----------------|---------|-----------------|---------|-----------------------------------|---------|
|              |           | MUs                  | Avg. MW | MUs                                    | Avg. MW | MUs             | Avg. MW | MUs             | Avg. MW | MUs                               | Avg. MW |
|              |           | <b>1</b>             |         | <b>2</b>                               |         | <b>1+2=3</b>    |         | <b>4</b>        |         | <b>3-4=5</b>                      |         |
| 15/04/2019   | MONDAY    | 111.959              | 5924    | 30.968                                 | 1290    | 142.927         | 5955    | 141.321         | 5888    | -1.606                            | -67     |
| 16/04/2019   | TUESDAY   | 113.480              | 6089    | 33.453                                 | 1394    | 146.933         | 6122    | 146.324         | 6097    | -0.609                            | -25     |
| 17/04/2019   | WEDNESDAY | 109.804              | 6000    | 35.042                                 | 1460    | 144.846         | 6035    | 144.944         | 6039    | 0.098                             | 4       |
| 18/04/2019   | THURSDAY  | 117.922              | 6335    | 34.945                                 | 1456    | 152.867         | 6369    | 153.603         | 6400    | 0.736                             | 31      |
| 19/04/2019   | FRIDAY    | 116.755              | 6140    | 31.362                                 | 1307    | 148.117         | 6172    | 146.985         | 6124    | -1.132                            | -47     |
| 20/04/2019   | SATURDAY  | 116.928              | 6206    | 32.799                                 | 1367    | 149.727         | 6239    | 148.150         | 6173    | -1.577                            | -66     |
| 21/04/2019   | SUNDAY    | 113.526              | 6001    | 31.258                                 | 1302    | 144.784         | 6033    | 141.722         | 5905    | -3.062                            | -128    |
| <b>Total</b> |           | <b>800.375</b>       |         | <b>229.826</b>                         |         | <b>1030.201</b> |         | <b>1023.049</b> |         | <b>-7.152</b>                     |         |

| Generating Unit Outages for the week 15 Apr- 2019 to 21 Apr -2019 |             |                    |           |           |           |            |                                                                                                                            |
|-------------------------------------------------------------------|-------------|--------------------|-----------|-----------|-----------|------------|----------------------------------------------------------------------------------------------------------------------------|
| Sr No                                                             | Outage Type | Name               | Trip Date | Trip Time | Sync Date | Sync Time  | Reason                                                                                                                     |
| 1                                                                 | PLANNED     | SWPGL U-3          | 1-Nov-18  | 0.28      |           | Continued. | Annual Overhaul                                                                                                            |
| 2                                                                 | PLANNED     | Parli Unit 7       | 12-Dec-18 | 0         |           | Continued. | Zero Schedule. (From Dt-27/01/2019 Converted Zero sch to AOH) and (from dt-15/02/2019 Converted AOH to Zero sch by MSEDCL) |
| 3                                                                 | FORCED      | Trombay 6          | 15-Jul-15 | 17:08     |           | Continued. | Economic shutdown                                                                                                          |
| 4                                                                 | FORCED      | SWPGL U-1          | 16-Feb-16 | 17.09     |           | Continued. | No PPA.                                                                                                                    |
| 5                                                                 | FORCED      | Parli Unit 4       | 1-Apr-16  | 0         |           | Continued. | Economic shutdown                                                                                                          |
| 6                                                                 | FORCED      | Parli Unit 5       | 1-Apr-16  | 0         |           | Continued. | Economic shutdown                                                                                                          |
| 7                                                                 | FORCED      | PGPL U1            | 7-Feb-17  | 17.3      |           | Continued. | No Schedule                                                                                                                |
| 8                                                                 | FORCED      | PGPL U2            | 7-Feb-17  | 17.3      |           | Continued. | No Schedule                                                                                                                |
| 9                                                                 | FORCED      | Uran Unit 7        | 20-Jul-18 | 12.53     |           | Continued. | Compressor & Turbine Blade Failure.                                                                                        |
| 10                                                                | FORCED      | IEPL Unit 1        | 28-Aug-18 | 21.26     |           | Continued. | Poor Coal Receipt                                                                                                          |
| 11                                                                | FORCED      | Uran Unit B0       | 8-Sep-18  | 12.19     |           | Continued. | T/F Shifting Work.                                                                                                         |
| 12                                                                | FORCED      | Uran Unit 8        | 8-Sep-18  | 22.08     |           | Continued. | Withdrawn Due To B0 & U-7                                                                                                  |
| 13                                                                | FORCED      | RPL(AMT) U-4       | 20-Sep-18 | 0.01      |           | Continued. | Zero Schedule.                                                                                                             |
| 14                                                                | FORCED      | SWPGL U-2          | 27-Nov-18 | 0         |           | Continued. | No Schedule.                                                                                                               |
| 15                                                                | FORCED      | Parli Unit 6       | 12-Dec-18 | 0         |           | Continued. | Zero Schedule.                                                                                                             |
| 16                                                                | FORCED      | Bhusawal Unit 3    | 14-Dec-18 | 3         |           | Continued. | Zero Schedule.                                                                                                             |
| 17                                                                | FORCED      | SWPGL U-4          | 15-Dec-18 | 0         |           | Continued. | No Schedule                                                                                                                |
| 18                                                                | FORCED      | RPL(AMT) U-5       | 28-Dec-18 | 19.3      | 18-Apr-19 | 6.54       | Zero Schedule.                                                                                                             |
| 19                                                                | FORCED      | VIPL U-1           | 29-Dec-18 | 0.3       |           | Continued. | Coal Shortage                                                                                                              |
| 20                                                                | FORCED      | VIPL U-2           | 17-Jan-19 | 0.15      |           | Continued. | Coal Shortage                                                                                                              |
| 21                                                                | FORCED      | Koradi Unit 7      | 19-Jan-19 | 18.21     |           | Continued. | Poor Coal Receipt                                                                                                          |
| 22                                                                | FORCED      | Chandrapur Unit 6  | 20-Feb-19 | 22.07     |           | Continued. | Rotor Earth Fault                                                                                                          |
| 23                                                                | FORCED      | Nasik Unit 4       | 12-Apr-19 | 21.35     | 19-Apr-19 | 2.29       | R PHASE Boiler Tube CUBAICAL BURST                                                                                         |
| 24                                                                | FORCED      | Nasik Unit 5       | 14-Apr-19 | 7.25      | 16-Apr-19 | 2.25       | Boiler Tube Leakage                                                                                                        |
| 25                                                                | FORCED      | Parli Unit 8       | 15-Apr-19 | 7.3       | 15-Apr-19 | 11.08      | Due to failure of data processing unit supply.                                                                             |
| 26                                                                | FORCED      | Khaparkheda Unit 3 | 16-Apr-19 | 4.4       | 18-Apr-19 | 9.17       | Furnace Pressure High                                                                                                      |
| 27                                                                | FORCED      | Parli Unit 8       | 16-Apr-19 | 5.51      | 16-Apr-19 | 8.4        | Turbine Tripped.                                                                                                           |
| 28                                                                | FORCED      | Parli Unit 8       | 16-Apr-19 | 8.54      | 16-Apr-19 | 10.38      | Turbine Protection                                                                                                         |
| 29                                                                | FORCED      | RPL(AMT) U-1       | 16-Apr-19 | 0         | 18-Apr-19 | 4.17       | Zero schedule.                                                                                                             |
| 30                                                                | FORCED      | AEML Unit 2        | 17-Apr-19 | 0.58      | 18-Apr-19 | 8.32       | Problem in Condenser cooling system                                                                                        |
| 31                                                                | FORCED      | Koradi Unit-8      | 17-Apr-19 | 16.55     | 22-Apr-19 | 18.26      | Less coal receipt & suspected boiler water                                                                                 |
| 32                                                                | FORCED      | Parli Unit 8       | 17-Apr-19 | 5.17      | 17-Apr-19 | 9.15       | DC supply Failure                                                                                                          |
| 33                                                                | FORCED      | Chandrapur Unit 4  | 17-Apr-19 | 13.52     | 17-Apr-19 | 19.3       | Furnace draft high.                                                                                                        |
| 34                                                                | FORCED      | Adani U-4          | 17-Apr-19 | 0.16      | 20-Apr-19 | 10.04      | APH-A hot PA Bellow leakage                                                                                                |
| 35                                                                | FORCED      | Adani U-5          | 18-Apr-19 | 0.22      | 21-Apr-19 | 11.11      | Drain line leakage.                                                                                                        |
| 36                                                                | FORCED      | Dhariwal           | 18-Apr-19 | 0.15      | 19-Apr-19 | 9.5        | Problem in Economizer ash Evacuation.                                                                                      |
| 37                                                                | FORCED      | Adani U-2          | 18-Apr-19 | 8.04      | 18-Apr-19 | 14.5       | Loss of fuel.                                                                                                              |
| 38                                                                | FORCED      | Nasik Unit 5       | 18-Apr-19 | 22:05     | 19-Apr-19 | 11.35      | Station T/F Tripped.                                                                                                       |
| 39                                                                | FORCED      | Nasik Unit 3       | 19-Apr-19 | 12.22     |           | Continued. | Boiler Tube Leakage                                                                                                        |
| 40                                                                | FORCED      | Koradi Unit 6      | 20-Apr-19 | 21.06     | 23-Apr-19 | 11.18      | To Attend Leakages On Turbine And Boiler Side.                                                                             |
| 41                                                                | FORCED      | RPL(AMT) U-1       | 20-Apr-19 | 0.01      |           | Continued. | Zero Schedule.                                                                                                             |
| 42                                                                | FORCED      | RPL(AMT) U-5       | 21-Apr-19 | 0.01      |           | Continued. | Zero Schedule.                                                                                                             |
| 43                                                                | FORCED      | Tarapur 1          | 21-Apr-19 | 13        |           | Continued. | Steam Isolation Problem.                                                                                                   |

**List of Transmission line Trippings/Outages for the week 15 Apr- 2019 to 21 Apr -2019**

| Sr. No. | Voltage Level | Outage Type | Name                                           | Trip Date | Trip Time | Sync Date | Sync Time  | Reason                                                                                                                                 |
|---------|---------------|-------------|------------------------------------------------|-----------|-----------|-----------|------------|----------------------------------------------------------------------------------------------------------------------------------------|
| 1       | 132 KV        | HT          | Kanhan-Pench                                   | 22-Jan-19 | 18.44     |           | Continued. | After Completion of Outage.                                                                                                            |
| 2       | 132 KV        | HT          | Mansar Pench                                   | 7-Mar-19  | 15.4      |           | Continued. | Hand trip From Pench end for system requirement.                                                                                       |
| 3       | 132 KV        | Tripped     | Bableshwar - Sangamner                         | 15-Apr-19 | 6.58      | 15-Apr-19 | 10.05      | Distance protection Z-1 R-E D-4084 KM 80MW.                                                                                            |
| 4       | 132 KV        | Tripped     | lol - Boisar Midc                              | 18-Apr-19 | 0.56      | 18-Apr-19 | 2.1        | Tripped at one end only without any indication.                                                                                        |
| 5       | 132 KV        | Tripped     | Gadchiroli - Mul                               | 18-Apr-19 | 21.15     | 18-Apr-19 | 22.05      | B-Phases burst PT burst at Gadchiroli.                                                                                                 |
| 6       | 132 KV        | HT          | Pusad-Jambazar                                 | 20-Apr-19 | 9.11      | 20-Apr-19 | 20.15      | For Outage On 220Kv Pusad-Wardha(PG).                                                                                                  |
| 7       | 220 KV        | PO          | Chandrapur GCR - Warora - I                    | 5-Apr-15  | 9.13      |           | Continued. | Bunching of Conductor Loc No 86 Disconnecting of Jumper At Loc No 86 & 107 And De-energising The Line Bet.86 To 107.                   |
| 8       | 220 KV        | PO          | Chandrapur GCR - Wani                          | 5-Apr-15  | 9.15      |           | Continued. | For Bunching of Conductor At Loc No.86 Disconnecting of Jumper At Loc No.86 To 107 And Deenergising The Line Between Loc No.86 To 107. |
| 9       | 220 KV        | PO          | Talandage - Chikodi                            | 1-Jun-17  | 0.01      |           | Continued. | No Schedule                                                                                                                            |
| 10      | 220 KV        | PO          | Mudshingi - Chikodi                            | 1-Jun-17  | 0.06      |           | Continued. | No Schedule.                                                                                                                           |
| 11      | 220 KV        | HT          | BOISAR BORIVALI                                | 24-Jul-18 | 13.18     |           | Continued. | To Control Line Loading.                                                                                                               |
| 12      | 220 KV        | Tripped     | 220/100 Kv 200 MVA ICT-II @Trombay             | 28-Mar-19 | 22.48     |           | Continued. | Buccholz Trip.                                                                                                                         |
| 13      | 220 KV        | PO          | 220/100 Kv 100 Mva Vijai lct 1 @Jambhul        | 14-Apr-19 | 9.53      | 16-Apr-19 | 0.03       | Replacement of HV CB due to Air leakage problem                                                                                        |
| 14      | 220 KV        | PO          | Dondaicha- Shahada                             | 15-Apr-19 | 6.04      | 15-Apr-19 | 9.22       | Daigonistic Testing Work of CT.                                                                                                        |
| 15      | 220 KV        | EO          | Apta - Tambati                                 | 15-Apr-19 | 8.45      | 15-Apr-19 | 10.5       | Emergency tree cutting.                                                                                                                |
| 16      | 220 KV        | PO          | Khadka-Bhadli-2                                | 15-Apr-19 | 9         | 15-Apr-19 | 20.18      | Line Maintenance work                                                                                                                  |
| 17      | 220 KV        | PO          | 220/33kv 100 MVA Transformer 3 @Ghodbunder R/S | 15-Apr-19 | 9         | 15-Apr-19 | 19.01      | Annual Maintenance Work                                                                                                                |
| 18      | 220 KV        | PO          | Kharepatan -Pawas Line                         | 15-Apr-19 | 9.07      | 15-Apr-19 | 19.35      | Tree cutting work.                                                                                                                     |
| 19      | 220 KV        | PO          | 220/132-110/11kv 200MVA ICT 1 @Miraj           | 15-Apr-19 | 9.21      | 15-Apr-19 | 12.15      | CT replacement work.                                                                                                                   |
| 20      | 220 KV        | Tripped     | AKOLA ANJANGAON (VIHIGAON) CKT-II              | 15-Apr-19 | 9.45      | 15-Apr-19 | 11.31      | B-PH CT clamp hotspot.                                                                                                                 |
| 21      | 220 KV        | PO          | Nashik-Airoli Knowledge Park                   | 15-Apr-19 | 10.02     | 15-Apr-19 | 18.3       | Relay Testing Work.                                                                                                                    |
| 22      | 220 KV        | PO          | Miraj - Mhaishal                               | 15-Apr-19 | 10.1      | 15-Apr-19 | 17.36      | Fixing of bird guards.                                                                                                                 |
| 23      | 220 KV        | PO          | Mumewadi-Belewadi                              | 15-Apr-19 | 10.18     | 15-Apr-19 | 12.5       | Routine Maintenance Work                                                                                                               |
| 24      | 220 KV        | PO          | Hingoli- Girawali                              | 15-Apr-19 | 11.3      | 15-Apr-19 | 16.28      | Attending Hot Spot                                                                                                                     |
| 25      | 220 KV        | Tripped     | Koradi II - Kawlewada                          | 16-Apr-19 | 1.47      | 17-Apr-19 | 2.06       | Distance Protection Zone 1                                                                                                             |
| 26      | 220 KV        | Tripped     | Karad(400kv) -Mudshingi Ckt 2-Tak              | 16-Apr-19 | 5.58      | 16-Apr-19 | 6.25       | Distance protection at Z-1 5.9KA 23.6KM.                                                                                               |
| 27      | 220 KV        | EO          | Trombay - Kalwa                                | 16-Apr-19 | 6.35      | 16-Apr-19 | 8.13       | To attend Hot Spot                                                                                                                     |
| 28      | 220 KV        | PO          | Kandalgaon - Sona Alloys                       | 16-Apr-19 | 8.45      | 16-Apr-19 | 19.18      | Cold line Cleaning of Insulators                                                                                                       |
| 29      | 220 KV        | PO          | Mumewadi -Halkarni I                           | 16-Apr-19 | 9.32      | 16-Apr-19 | 17.03      | Replacement of Faulty Disc Insulators                                                                                                  |
| 30      | 220 KV        | EO          | PARLY (PG) - OSMANABAD                         | 16-Apr-19 | 10.42     | 16-Apr-19 | 14.59      | To attend Hot Spot                                                                                                                     |
| 31      | 220 KV        | PO          | Topworth - Kharghar                            | 16-Apr-19 | 11.31     | 16-Apr-19 | 18.02      | Line Maintenance work                                                                                                                  |
| 32      | 220 KV        | EO          | Talandage(400kv) - Five Star Midc              | 16-Apr-19 | 12.06     | 16-Apr-19 | 15.49      | To attend problem in CB                                                                                                                |
| 33      | 220 KV        | Tripped     | Balapur-Akola li                               | 16-Apr-19 | 20.46     | 17-Apr-19 | 1.29       | Distance Protection Zone 1                                                                                                             |
| 34      | 220 KV        | Tripped     | Balapur-Akola I                                | 16-Apr-19 | 20.46     | 17-Apr-19 | 1.29       | Distance Protection Zone 1                                                                                                             |

**List of Transmission line Trippings/Outages for the week 15 Apr- 2019 to 21 Apr -2019**

| Sr. No. | Voltage Level | Outage Type | Name                                       | Trip Date | Trip Time | Sync Date | Sync Time | Reason                                                                                                                                |
|---------|---------------|-------------|--------------------------------------------|-----------|-----------|-----------|-----------|---------------------------------------------------------------------------------------------------------------------------------------|
| 35      | 220 KV        | HT          | Taptitanda- Jalna ckt- I                   | 16-Apr-19 | 22.4      | 17-Apr-19 | 0.01      | Chattering sound in CC due to heavy stormy weather                                                                                    |
| 36      | 220 KV        | Tripped     | Karad(400kv) -Mudshingi Ckt 2-Tak          | 17-Apr-19 | 5.03      | 17-Apr-19 | 5.17      | Distance Protection Zone 1                                                                                                            |
| 37      | 220 KV        | PO          | Tillari Amona                              | 17-Apr-19 | 9.14      | 17-Apr-19 | 17.5      | Testing Work                                                                                                                          |
| 38      | 220 KV        | Tripped     | Dahanu Versova                             | 17-Apr-19 | 9.58      | 17-Apr-19 | 12.48     | Distance Protection PH.PH fault.                                                                                                      |
| 39      | 220 KV        | PO          | Tembhurni - Jeur                           | 17-Apr-19 | 10.2      | 17-Apr-19 | 12.5      | Quarterly Maintainance Work                                                                                                           |
| 40      | 220 KV        | HT          | Eklahare (Gcr) - Airoli Know Park          | 17-Apr-19 | 10.36     | 17-Apr-19 | 12.11     | To attend trip ckt faulty work.                                                                                                       |
| 41      | 220 KV        | HT          | Boisar Versova Line                        | 17-Apr-19 | 16.36     | 18-Apr-19 | 0.51      | Load management purpose.                                                                                                              |
| 42      | 220 KV        | Tripped     | Borivali - Tarapur                         | 17-Apr-19 | 19.4      | 18-Apr-19 | 12.48     | Distance protection Z-1 RY-E IY10.6KA IR 10.06KA D-27.97KM.                                                                           |
| 43      | 220 KV        | PO          | Kandalgaon - Sona Alloys                   | 18-Apr-19 | 8.05      | 18-Apr-19 | 19.17     | Line Maintenance work                                                                                                                 |
| 44      | 220 KV        | PO          | Kalmeshwar-Pandhurna                       | 18-Apr-19 | 8.18      | 18-Apr-19 | 21.19     | Restranging of bottom PH conductor.                                                                                                   |
| 45      | 220 KV        | PO          | Oni Kharepatan Line                        | 18-Apr-19 | 8.59      | 18-Apr-19 | 19.33     | Routine Maintenance Work & Replacement Work.                                                                                          |
| 46      | 220 KV        | EO          | Belewadi-Nagar Ckt I                       | 18-Apr-19 | 9.27      | 18-Apr-19 | 11        | Attending Hot Spot                                                                                                                    |
| 47      | 220 KV        | PO          | Pophali - Nerale                           | 18-Apr-19 | 9.45      | 18-Apr-19 | 17.15     | Line Maintenance work                                                                                                                 |
| 48      | 220 KV        | PO          | Uran - Kharghar 2                          | 18-Apr-19 | 10.27     | 18-Apr-19 | 13.13     | Replacement of Faulty Disc Insulators By Polymer                                                                                      |
| 49      | 220 KV        | PO          | VILEBHAGAD KANDALGAON                      | 18-Apr-19 | 10.3      | 18-Apr-19 | 18.26     | Routine Maintenance Work                                                                                                              |
| 50      | 220 KV        | PO          | Karad -Mudshingi Ckt- IV                   | 18-Apr-19 | 10.3      | 18-Apr-19 | 13.57     | Quarterly Maintenance Work                                                                                                            |
| 51      | 220 KV        | PO          | 220/132 Kv 200 Mva Vijai Ict 1 @Ranjangaon | 18-Apr-19 | 11.4      | 18-Apr-19 | 18.3      | Diagnostic Testing Work.                                                                                                              |
| 52      | 220 KV        | PO          | Shirsuphal-Bhigwan                         | 18-Apr-19 | 13.18     | 18-Apr-19 | 17.54     | Testing & Routine Maintenance Work.                                                                                                   |
| 53      | 220 KV        | Tripped     | Virur - Gadchiroli                         | 18-Apr-19 | 21.15     | 18-Apr-19 | 22.35     | Distance Protection                                                                                                                   |
| 54      | 220 KV        | PO          | Khadka-Chalisgaon-2                        | 19-Apr-19 | 7         | 19-Apr-19 | 11.58     | Replacement Of Conductor Of 400Kv Deepnagar-Taptitanda.                                                                               |
| 55      | 220 KV        | PO          | Deepnagar Khadaka 2                        | 19-Apr-19 | 7.14      | 19-Apr-19 | 12.09     | Replacement Of Conductor Of 400Kv Deepnagar-Taptitanda.                                                                               |
| 56      | 220 KV        | PO          | Solapur(Bale) - Tuljapur                   | 19-Apr-19 | 7.2       | 23-Apr-19 | 20.43     | Erection Of Line Tower At Loc.No.36B & Resrtringing Work After Erection.Line Converted In 220Kv Osmanabad-Tuljapur.(Charged At 15.31) |
| 57      | 220 KV        | PO          | Osmanabad - Solapur (Bale)                 | 19-Apr-19 | 7.22      | 23-Apr-19 | 20.56     | Erection Of Line Tower At Loc.No.36B & Restranging Work After Erection.Line Converted In 220Kv Osmanabad-Tuljapur.(Charged At 15.31)  |
| 58      | 220 KV        | PO          | Pophali - Nerale                           | 19-Apr-19 | 8.15      | 19-Apr-19 | 19.1      | Replacement of Conductor At Loc No.46 & 33.                                                                                           |
| 59      | 220 KV        | PO          | Kandalgaon - Sona Alloys                   | 19-Apr-19 | 8.28      | 19-Apr-19 | 19.52     | Cold Line Cleaning Of Insulators.                                                                                                     |
| 60      | 220 KV        | PO          | Kalwa-TIFIL                                | 19-Apr-19 | 8.4       | 19-Apr-19 | 16.4      | Testing Work & Routine Maintenance Work.                                                                                              |
| 61      | 220 KV        | EO          | Kandalgaon-POSCO                           | 19-Apr-19 | 11.3      | 19-Apr-19 | 15.5      | Nut Bolt Replacement & Maint Work.                                                                                                    |
| 62      | 220 KV        | Tripped     | Shivajinagar - Malegaon                    | 19-Apr-19 | 13.07     | 19-Apr-19 | 13.27     | Distance Protection Z-1 B-PH 24.43KM.                                                                                                 |
| 63      | 220 KV        | PO          | Dasturi-Kandalgaon Line                    | 19-Apr-19 | 15.58     | 19-Apr-19 | 19.28     | Work In Vicinity Safety Permit For Working On Kandalgaon-Sona alloy Line.                                                             |
| 64      | 220 KV        | EO          | Oni Kharepatan Line                        | 20-Apr-19 | 8.1       | 20-Apr-19 | 9         | To Attend The Red Hot In Y-PH CB Palm (70 deg).                                                                                       |
| 65      | 220 KV        | PO          | Gadchandur - Virur-I                       | 20-Apr-19 | 8.32      | 20-Apr-19 | 13.3      | Conductor Crimping Work.                                                                                                              |
| 66      | 220 KV        | PO          | Pophali - Pedambe II                       | 20-Apr-19 | 9.15      | 20-Apr-19 | 12.4      | Replacement Of Insulator String At Loc No.17B.                                                                                        |
| 67      | 220 KV        | HT          | Pusad-Ghatodi                              | 20-Apr-19 | 9.16      | 20-Apr-19 | 20.08     | For Outage On 220Kv Pusad-Wardha(PG).                                                                                                 |
| 68      | 220 KV        | HT          | Pusad - Hingoli                            | 20-Apr-19 | 9.2       | 20-Apr-19 | 20.12     | For Outage On 220Kv Pusad-Wardha(PG).                                                                                                 |

**List of Transmission line Trippings/Outages for the week 15 Apr- 2019 to 21 Apr -2019**

| Sr. No. | Voltage Level | Outage Type | Name                                         | Trip Date | Trip Time | Sync Date | Sync Time  | Reason                                                              |
|---------|---------------|-------------|----------------------------------------------|-----------|-----------|-----------|------------|---------------------------------------------------------------------|
| 69      | 220 KV        | PO          | Pusad-WardhaPG(Deoli)                        | 20-Apr-19 | 9.22      | 20-Apr-19 | 20.01      | Routine Maintenance Work                                            |
| 70      | 220 KV        | PO          | Kandalgaon - Sona Alloys                     | 20-Apr-19 | 9.45      | 20-Apr-19 | 19.15      | Cold Line Cleaning Of Insulators                                    |
| 71      | 220 KV        | PO          | 200MVA ICT VI @ Nasik GCR                    | 20-Apr-19 | 10.4      | 20-Apr-19 | 19.42      | Structure & Isolator Replacement Work.                              |
| 72      | 220 KV        | PO          | Akola-Paras Ckt No-Ii                        | 20-Apr-19 | 10.42     | 20-Apr-19 | 18.04      | Testing Work & Bay Routine Maintenance Work.                        |
| 73      | 220 KV        | EO          | Uran - Apta IV                               | 20-Apr-19 | 10.45     | 20-Apr-19 | 15.51      | Earth Wire Replacement.                                             |
| 74      | 220 KV        | EO          | Uran - Apta III                              | 20-Apr-19 | 10.46     | 20-Apr-19 | 15.52      | Earth Wire Replacement.                                             |
| 75      | 220 KV        | PO          | Devgaon - Rangari                            | 20-Apr-19 | 11.03     | 20-Apr-19 | 13.31      | Tightening Of Arcing Horn Nut Bolt At Loc No58 Line Signature Test. |
| 76      | 220 KV        | PO          | 220/22 Kv 50 Mva Areva Ptr 4 @Colourchem     | 20-Apr-19 | 18.57     | 20-Apr-19 | 21.3       | Crow Fault At LV Side Load Affected 30MW.                           |
| 77      | 220 KV        | PO          | Arey - TPC Borivali                          | 21-Apr-19 | 0.12      | 21-Apr-19 | 6.56       | Metro Work                                                          |
| 78      | 220 KV        | PO          | Parli New Tps - Beed Ckt 2                   | 21-Apr-19 | 5         | 21-Apr-19 | 19.42      | Construction Work                                                   |
| 79      | 220 KV        | PO          | Parli New Tps - Beed Ckt 1                   | 21-Apr-19 | 5.28      | 22-Apr-19 | 19.08      | Conductor Restranging Work Near Railway Crossing.                   |
| 80      | 220 KV        | PO          | Salsette - Sahara                            | 21-Apr-19 | 9         | 21-Apr-19 | 18.31      | Shifting of OPGW                                                    |
| 81      | 220 KV        | PO          | Kandalgaon - Sona Alloys                     | 21-Apr-19 | 9.33      | 21-Apr-19 | 18.55      | Cold Line cleaning of Insulators                                    |
| 82      | 220 KV        | PO          | Trombay MSETCL Tie 2                         | 21-Apr-19 | 15.05     | 21-Apr-19 | 17.4       | CT Leakage                                                          |
| 83      | 400 KV        | PO          | Karad Solapur (PG)                           | 3-May-17  | 11:49     |           | Continued. | Line Converted As 220 Kv Solapur (PG)- Jeur From LOC                |
| 84      | 400 KV        | Tripped     | 400/220/33 Kv 315 Mva ICT 1 @Padghe          | 15-Nov-18 | 10.07     |           | Continued. | Differential Protection Declared Faulty.                            |
| 85      | 400 KV        | PO          | 400/220/33 Kv 315 MVA ICT -I @Kharghar       | 26-Mar-19 | 11.02     |           | Continued. | Overhauling work                                                    |
| 86      | 400 KV        | HT          | 400/220/33 Kv 500 Mva Ict 1 @ CHANDRAPUR 2   | 12-Apr-19 | 17.1      |           | Continued. | Due To CVT Porcelain Collars Of The ICT-1 Are Damaged.              |
| 87      | 400 KV        | HT          | Bhusawal-Aurangabad                          | 12-Apr-19 | 18        | 16-Apr-19 | 11.2       | Over Voltage                                                        |
| 88      | 400 KV        | PO          | 400/220kv 315 Mva ICT I @Karad               | 13-Apr-19 | 9.42      | 16-Apr-19 | 14         | oltc overhauling work.                                              |
| 89      | 400 KV        | PO          | 400/220/33 Kv 315 MVA ICT II @Chandrapur GCR | 13-Apr-19 | 12.47     | 16-Apr-19 | 9.44       | COMPLETE OIL FILTRATION.                                            |
| 90      | 400 KV        | PO          | 400/220 Kv 315 Mva Ict -2 @New Koyna         | 15-Apr-19 | 8.58      | 15-Apr-19 | 18.45      | CTR maintenance work.                                               |
| 91      | 400 KV        | PO          | 400/220kv Spare Ict 1 105 Mva @Karad         | 15-Apr-19 | 11.29     | 15-Apr-19 | 15.55      | Temp meter calibration.                                             |
| 92      | 400 KV        | Tripped     | Girwali-Solapur (Lamboti)                    | 15-Apr-19 | 13.14     | 15-Apr-19 | 15.2       | Lighting arrester jump broken.                                      |
| 93      | 400 KV        | PO          | 400/220/33kv 500 MVA ICT-I @Khaparkheda      | 16-Apr-19 | 7.55      | 16-Apr-19 | 12.04      | Removal and refitting of Corona shieldform line side Isolator       |
| 94      | 400 KV        | PO          | 400/220 Kv 315 MVA ICT -I @New Koyna         | 16-Apr-19 | 8.48      | 16-Apr-19 | 18.06      | CTR Fire Extinguisher system maintenance work                       |
| 95      | 400 KV        | PO          | Chandrapur-II - Nanded ckt I                 | 16-Apr-19 | 11.26     | 17-Apr-19 | 10.18      | Replacement of Polymer String                                       |
| 96      | 400 KV        | PO          | Koradi-Khaparkheda I                         | 16-Apr-19 | 12.53     | 16-Apr-19 | 15.57      | Removal and refitting of Corona shieldform line side Isolator       |
| 97      | 400 KV        | Tripped     | Karad-Jaigad - I                             | 16-Apr-19 | 15.39     | 17-Apr-19 | 7.04       | Tripped on PDR                                                      |
| 98      | 400 KV        | HT          | Khadka-Aurangabad (Waluj)                    | 16-Apr-19 | 17.22     | 18-Apr-19 | 10.18      | Over Voltage                                                        |
| 99      | 400 KV        | Tripped     | Taptitanda Waluj                             | 16-Apr-19 | 19.24     | 17-Apr-19 | 13.51      | Distance Protection Zone 1                                          |
| 100     | 400 KV        | HT          | Akola Wardha I                               | 17-Apr-19 | 0.1       | 17-Apr-19 | 16.3       | Sparking observed on B Phase Wave Trap                              |
| 101     | 400 KV        | PO          | Lonikand I - Koyna stage-IV                  | 17-Apr-19 | 8.47      | 17-Apr-19 | 12.56      | Replacement of damaged insulators.                                  |
| 102     | 400 KV        | PO          | Parly(MS)- Nanded ckt II                     | 17-Apr-19 | 10.51     | 17-Apr-19 | 17.06      | Relay testing work.                                                 |

**List of Transmission line Trippings/Outages for the week 15 Apr- 2019 to 21 Apr -2019**

| Sr. No. | Voltage Level | Outage Type | Name                                    | Trip Date | Trip Time | Sync Date | Sync Time  | Reason                                                     |
|---------|---------------|-------------|-----------------------------------------|-----------|-----------|-----------|------------|------------------------------------------------------------|
| 103     | 400 KV        | PO          | Nagothane - Dabhol-II                   | 18-Apr-19 | 7.58      | 18-Apr-19 | 18.4       | Tree Cutting Work.                                         |
| 104     | 400 KV        | PO          | Karad - Lonikand 1                      | 18-Apr-19 | 9.1       | 18-Apr-19 | 19.26      | Routine Maintenance Work                                   |
| 105     | 400 KV        | PO          | Jaigad-New Koyna Ckt-I                  | 18-Apr-19 | 9.44      | 19-Apr-19 | 21.49      | Retro Fitting Work.                                        |
| 106     | 400 KV        | PO          | Bus Coupler @ Chandrapur                | 18-Apr-19 | 12.32     | 18-Apr-19 | 15.19      | Termination of CT Core In New Bus Bar Scheme.              |
| 107     | 400 KV        | HT          | Khadka-Aurangabad (Waluj)               | 18-Apr-19 | 18.11     | 19-Apr-19 | 6.28       | Over Voltage                                               |
| 108     | 400 KV        | PO          | Deepnagar Taptitanda                    | 19-Apr-19 | 6.35      | 19-Apr-19 | 18         | Replacement Of Conductor.                                  |
| 109     | 400 KV        | PO          | Kala Kudus Ckt-II                       | 19-Apr-19 | 8.29      | 19-Apr-19 | 21.03      | Routine Maintenance Work                                   |
| 110     | 400 KV        | PO          | Kala Kudus Ckt-I                        | 19-Apr-19 | 8.29      | 19-Apr-19 | 21.01      | Routine Maintenance Work                                   |
| 111     | 400 KV        | PO          | Chandrapur-II - Nanded ckt II           | 19-Apr-19 | 11.12     | 19-Apr-19 | 19.32      | Line Maintenance work                                      |
| 112     | 400 KV        | EO          | 400/220/33 Kv 315 MVA ICT- 2 @Nagothane | 19-Apr-19 | 14.5      | 19-Apr-19 | 17.37      | Attending Hot Spot On R=PH 220Kv CT Stud Clamp.            |
| 113     | 400 KV        | EO          | Chandrapur II - Dhariwal -I             | 19-Apr-19 | 16.53     | 19-Apr-19 | 20.01      | R-PH CT Of Protection Core Showing Less Current.           |
| 114     | 400 KV        | HT          | Khadka-Aurangabad (Waluj)               | 19-Apr-19 | 18.04     | 20-Apr-19 | 6.28       | Over Voltage                                               |
| 115     | 400 KV        | PO          | Deepnagar Taptitanda                    | 20-Apr-19 | 6.3       | 20-Apr-19 | 19.21      | Replacement Of Conductor.                                  |
| 116     | 400 KV        | PO          | Kala Kudus Ckt-I                        | 20-Apr-19 | 7.59      | 20-Apr-19 | 21.15      | Replacement Of Flash over Insulators.                      |
| 117     | 400 KV        | PO          | Kala Kudus Ckt-II                       | 20-Apr-19 | 7.59      | 20-Apr-19 | 21.14      | Replacement Of Flash over Insulators.                      |
| 118     | 400 KV        | HT          | Khadka-Aurangabad (Waluj)               | 20-Apr-19 | 17.35     | 22-Apr-19 | 9.39       | Over Voltage                                               |
| 119     | 400 KV        | PO          | Wardha (Pg) Warora I                    | 21-Apr-19 | 9.01      | 21-Apr-19 | 18.2       | Line Maintenance work                                      |
| 120     | 400 KV        | HT          | Dhule Sar'Sarovar II                    | 24-Apr-19 | 18.07     |           | Continued. | Over Voltage                                               |
| 121     | 400 KV        | HT          | Bhusawal-Aurangabad                     | 24-Apr-19 | 18.56     |           | Continued. | Over Voltage                                               |
| 122     | 400 KV        | PO          | Karad - Jaigad - II                     | 24-Apr-19 | 19.38     |           | Continued. | Retrofitting Work of Relays.                               |
| 123     | 400 KV        | Tripped     | Deepnagar - Aurangabad                  | 24-Apr-19 | 20.5      |           | Continued. | Distance Protection R-Phase Zone-1 124KM Waluj End 2.57KA. |
| 124     | 500 KV        | EO          | Chandrapur - Padghe Hvdc Pole 2         | 14-Apr-19 | 20.27     | 15-Apr-19 | 2.39       | Y Phase Valve Oil Leakage Inspection in Valve Hall         |