

**State Load Despatch Center,Airoli (MSETCL)**  
**Power System Position from 12/Apr/2021 to 18/Apr/2021**

**Supply Position During Morning Peak (MW)**

| Date           | Time   | MSGENCO     |             |            |             | Central Sector Receipt | Wind       | CPP         | SOLAR       | TPCL Exch.   | MSEDCL Catered Demand | Load Shedding (LS) | MSEDCL Demand (Incl. LS) | TPCL Gen.   | R-INFRA Gen. | State Demand Met | State Demand (Incl. LS) | Freq.        |
|----------------|--------|-------------|-------------|------------|-------------|------------------------|------------|-------------|-------------|--------------|-----------------------|--------------------|--------------------------|-------------|--------------|------------------|-------------------------|--------------|
|                |        | THM         | HYDRO       | GAS        | Total       |                        |            |             |             |              |                       |                    |                          |             |              |                  |                         |              |
|                |        | MW          | MW          | MW         | MW          | MW                     | MW         | MW          | MW          | MW           | MW                    | MW                 | MW                       | MW          | MW           | MW               | MW                      | Hzs          |
| 12-04-2021     | 12 Hrs | 5411        | 1020        | 293        | 6724        | 8771                   | 152        | 6211        | 992         | -1249        | 21601                 | 0                  | 21601                    | 1109        | 501          | 24460            | 24460                   | 50.01        |
| 13-04-2021     | 12 Hrs | 6382        | 480         | 272        | 7134        | 8419                   | 122        | 5856        | 1050        | -1385        | 21196                 | 0                  | 21196                    | 685         | 500          | 23766            | 23766                   | 50.00        |
| 14-04-2021     | 12 Hrs | 6765        | 494         | 272        | 7531        | 7896                   | 144        | 5770        | 962         | -1241        | 21062                 | 0                  | 21062                    | 948         | 500          | 23751            | 23751                   | 49.99        |
| 15-04-2021     | 12 Hrs | 6690        | 390         | 274        | 7354        | 7618                   | 106        | 5185        | 1132        | -1101        | 20294                 | 0                  | 20294                    | 1072        | 500          | 22967            | 22967                   | 49.93        |
| 16-04-2021     | 12 Hrs | 6928        | 484         | 263        | 7674        | 7365                   | 272        | 5296        | 1141        | -1266        | 20482                 | 0                  | 20482                    | 856         | 500          | 23104            | 23104                   | 49.95        |
| 17-04-2021     | 12 Hrs | 5947        | 406         | 273        | 6626        | 7926                   | 349        | 6118        | 1128        | -875         | 21272                 | 0                  | 21272                    | 1085        | 501          | 23734            | 23734                   | 50.00        |
| 18-04-2021     | 11 Hrs | 6354        | 436         | 271        | 7060        | 7272                   | 753        | 5496        | 1056        | -744         | 20894                 | 0                  | 20894                    | 880         | 489          | 23006            | 23006                   | 50.05        |
| <b>Maximum</b> |        | <b>6928</b> | <b>1020</b> | <b>293</b> | <b>7674</b> | <b>8771</b>            | <b>753</b> | <b>6211</b> | <b>1141</b> | <b>-744</b>  | <b>21601</b>          | <b>0</b>           | <b>21601</b>             | <b>1109</b> | <b>501</b>   | <b>24460</b>     | <b>24460</b>            | <b>50.05</b> |
| <b>Minimum</b> |        | <b>5411</b> | <b>390</b>  | <b>263</b> | <b>6626</b> | <b>7272</b>            | <b>106</b> | <b>5185</b> | <b>962</b>  | <b>-1385</b> | <b>20294</b>          | <b>0</b>           | <b>20294</b>             | <b>685</b>  | <b>489</b>   | <b>22967</b>     | <b>22967</b>            | <b>49.93</b> |
| <b>Average</b> |        | <b>6354</b> | <b>530</b>  | <b>274</b> | <b>7158</b> | <b>7895</b>            | <b>271</b> | <b>5705</b> | <b>1066</b> | <b>-1123</b> | <b>20972</b>          | <b>0</b>           | <b>20972</b>             | <b>948</b>  | <b>499</b>   | <b>23541</b>     | <b>23541</b>            | <b>49.99</b> |

**Supply Position During Day Peak (MW)**

| Date           | Time   | MSGENCO     |             |            |             | Central Sector Receipt | Wind       | CPP         | SOLAR       | TPCL Exch.   | MSEDCL Catered Demand | Load Shedding (LS) | MSEDCL Demand (Incl. LS) | TPCL Gen.   | R-INFRA Gen. | State Demand Met | State Demand (Incl. LS) | Freq.        |
|----------------|--------|-------------|-------------|------------|-------------|------------------------|------------|-------------|-------------|--------------|-----------------------|--------------------|--------------------------|-------------|--------------|------------------|-------------------------|--------------|
|                |        | THM         | HYDRO       | GAS        | Total       |                        |            |             |             |              |                       |                    |                          |             |              |                  |                         |              |
|                |        | MW          | MW          | MW         | MW          | MW                     | MW         | MW          | MW          | MW           | MW                    | MW                 | MW                       | MW          | MW           | MW               | MW                      | Hzs          |
| 12-04-2021     | 15 Hrs | 5752        | 994         | 272        | 7018        | 8718                   | 181        | 6206        | 885         | -1215        | 21793                 | 0                  | 21793                    | 1087        | 499          | 24594            | 24594                   | 49.93        |
| 13-04-2021     | 13 Hrs | 6392        | 502         | 282        | 7176        | 8351                   | 115        | 5789        | 1027        | -1433        | 21025                 | 0                  | 21025                    | 680         | 501          | 23639            | 23639                   | 49.97        |
| 14-04-2021     | 15 Hrs | 6658        | 895         | 281        | 7834        | 8264                   | 183        | 5318        | 592         | -1183        | 21008                 | 0                  | 21008                    | 1073        | 501          | 23765            | 23765                   | 49.86        |
| 15-04-2021     | 16 Hrs | 6780        | 620         | 273        | 7673        | 7514                   | 264        | 5486        | 742         | -1345        | 20334                 | 0                  | 20334                    | 847         | 500          | 23026            | 23026                   | 49.95        |
| 16-04-2021     | 16 Hrs | 6862        | 1016        | 19         | 7896        | 7587                   | 322        | 5319        | 716         | -1107        | 20734                 | 0                  | 20734                    | 1073        | 500          | 23414            | 23414                   | 50.06        |
| 17-04-2021     | 16 Hrs | 6377        | 732         | 263        | 7372        | 7899                   | 289        | 6081        | 688         | -995         | 21334                 | 0                  | 21334                    | 1054        | 500          | 23884            | 23884                   | 50.00        |
| 18-04-2021     | 15 Hrs | 6395        | 888         | 271        | 7554        | 7977                   | 117        | 5446        | 965         | -981         | 21078                 | 0                  | 21078                    | 806         | 499          | 23364            | 23364                   | 49.99        |
| <b>Maximum</b> |        | <b>6862</b> | <b>1016</b> | <b>282</b> | <b>7896</b> | <b>8718</b>            | <b>322</b> | <b>6206</b> | <b>1027</b> | <b>-981</b>  | <b>21793</b>          | <b>0</b>           | <b>21793</b>             | <b>1087</b> | <b>501</b>   | <b>24594</b>     | <b>24594</b>            | <b>50.06</b> |
| <b>Minimum</b> |        | <b>5752</b> | <b>502</b>  | <b>19</b>  | <b>7018</b> | <b>7514</b>            | <b>115</b> | <b>5318</b> | <b>592</b>  | <b>-1433</b> | <b>20334</b>          | <b>0</b>           | <b>20334</b>             | <b>680</b>  | <b>499</b>   | <b>23026</b>     | <b>23026</b>            | <b>49.86</b> |
| <b>Average</b> |        | <b>6459</b> | <b>807</b>  | <b>237</b> | <b>7503</b> | <b>8044</b>            | <b>210</b> | <b>5664</b> | <b>802</b>  | <b>-1180</b> | <b>21044</b>          | <b>0</b>           | <b>21044</b>             | <b>946</b>  | <b>500</b>   | <b>23669</b>     | <b>23669</b>            | <b>49.97</b> |

**Supply Position During Evening Peak (MW)**

| Date           | Time   | MSGENCO     |             |            |             | Central Sector Receipt | Wind       | CPP         | SOLAR    | TPCL Exch.   | MSEDCL Catered Demand | Load Shedding (LS) | MSEDCL Demand (Incl. LS) | TPCL Gen.   | R-INFRA Gen. | State Demand Met | State Demand (Incl. LS) | Freq.        |
|----------------|--------|-------------|-------------|------------|-------------|------------------------|------------|-------------|----------|--------------|-----------------------|--------------------|--------------------------|-------------|--------------|------------------|-------------------------|--------------|
|                |        | THM         | HYDRO       | GAS        | Total       |                        |            |             |          |              |                       |                    |                          |             |              |                  |                         |              |
|                |        | MW          | MW          | MW         | MW          | MW                     | MW         | MW          | MW       | MW           | MW                    | MW                 | MW                       | MW          | MW           | MW               | MW                      | Hzs          |
| 12-04-2021     | 20 Hrs | 5626        | 595         | 275        | 6496        | 5927                   | 880        | 6243        | 0        | -1217        | 18329                 | 0                  | 18329                    | 845         | 459          | 20850            | 20850                   | 50.02        |
| 13-04-2021     | 22 Hrs | 6492        | 465         | 297        | 7254        | 5758                   | 675        | 5248        | 0        | -1403        | 17532                 | 0                  | 17532                    | 716         | 401          | 20052            | 20052                   | 50.00        |
| 14-04-2021     | 19 Hrs | 6287        | 266         | 275        | 6828        | 5953                   | 324        | 4895        | 9        | -1173        | 16836                 | 0                  | 16836                    | 1016        | 285          | 19310            | 19310                   | 50.03        |
| 15-04-2021     | 22 Hrs | 6641        | 620         | 286        | 7547        | 6031                   | 563        | 5952        | 0        | -1230        | 18863                 | 0                  | 18863                    | 776         | 501          | 21370            | 21370                   | 49.98        |
| 16-04-2021     | 22 Hrs | 6474        | 632         | 158        | 7264        | 6426                   | 541        | 5707        | 0        | -933         | 19004                 | 0                  | 19004                    | 973         | 501          | 21412            | 21412                   | 49.99        |
| 17-04-2021     | 22 Hrs | 6139        | 1346        | 285        | 7770        | 6521                   | 366        | 5535        | 0        | -948         | 19244                 | 0                  | 19244                    | 1020        | 500          | 21712            | 21712                   | 49.91        |
| 18-04-2021     | 22 Hrs | 6341        | 478         | 296        | 7116        | 6321                   | 820        | 5470        | 0        | -1014        | 18712                 | 0                  | 18712                    | 932         | 501          | 21160            | 21160                   | 49.98        |
| <b>Maximum</b> |        | <b>6641</b> | <b>1346</b> | <b>297</b> | <b>7770</b> | <b>6521</b>            | <b>880</b> | <b>6243</b> | <b>9</b> | <b>-933</b>  | <b>19244</b>          | <b>0</b>           | <b>19244</b>             | <b>1020</b> | <b>501</b>   | <b>21712</b>     | <b>21712</b>            | <b>50.03</b> |
| <b>Minimum</b> |        | <b>5626</b> | <b>266</b>  | <b>158</b> | <b>6496</b> | <b>5758</b>            | <b>324</b> | <b>4895</b> | <b>0</b> | <b>-1403</b> | <b>16836</b>          | <b>0</b>           | <b>16836</b>             | <b>716</b>  | <b>285</b>   | <b>19310</b>     | <b>19310</b>            | <b>49.91</b> |
| <b>Average</b> |        | <b>6286</b> | <b>629</b>  | <b>267</b> | <b>7182</b> | <b>6134</b>            | <b>596</b> | <b>5579</b> | <b>1</b> | <b>-1131</b> | <b>18360</b>          | <b>0</b>           | <b>18360</b>             | <b>897</b>  | <b>450</b>   | <b>20838</b>     | <b>20838</b>            | <b>49.99</b> |

## Supply Position During Night Off Peak (MW)

| Date       | Time   | MSGENCO |       |     |       | Central Sector Receipt | Wind | CPP  | SOLAR | TPCL Exch. | MSEDCL Cateder Demand | Load Sheddin g(LS) | MSEDCL Demand (Incl. LS) | TPCL Gen. | R-INFRA Gen. | State Demand Met | State Demand (Incl. LS) | Freq. |
|------------|--------|---------|-------|-----|-------|------------------------|------|------|-------|------------|-----------------------|--------------------|--------------------------|-----------|--------------|------------------|-------------------------|-------|
|            |        | THM     | HYDRO | GAS | Total |                        |      |      |       |            |                       |                    |                          |           |              |                  |                         |       |
|            |        | MW      | MW    | MW  | MW    | MW                     | MW   | MW   | MW    | MW         | MW                    | MW                 | MW                       | MW        | MW           | MW               | MW                      | Hzs   |
| 12-04-2021 | 4 Hrs  | 5206    | 560   | 298 | 6064  | 7329                   | 137  | 5802 | 0     | -775       | 18557                 | 0                  | 18557                    | 738       | 500          | 20570            | 20570                   | 49.97 |
| 13-04-2021 | 4 Hrs  | 6063    | 263   | 277 | 6603  | 6645                   | 366  | 6092 | 0     | -1246      | 18460                 | 0                  | 18460                    | 529       | 285          | 20520            | 20520                   | 49.99 |
| 14-04-2021 | 23 Hrs | 5784    | 402   | 297 | 6483  | 5540                   | 1030 | 4891 | 0     | -1149      | 16795                 | 0                  | 16795                    | 981       | 501          | 19426            | 19426                   | 49.99 |
| 15-04-2021 | 4 Hrs  | 6398    | 419   | 298 | 7115  | 5663                   | 476  | 4675 | 0     | -1074      | 16855                 | 0                  | 16855                    | 544       | 501          | 18974            | 18974                   | 49.95 |
| 16-04-2021 | 4 Hrs  | 6674    | 260   | 298 | 7232  | 5796                   | 1013 | 5867 | 0     | -1242      | 18666                 | 0                  | 18666                    | 533       | 285          | 20726            | 20726                   | 49.94 |
| 17-04-2021 | 4 Hrs  | 5923    | 336   | 178 | 6438  | 5848                   | 1087 | 6150 | 0     | -697       | 18826                 | 0                  | 18826                    | 810       | 502          | 20834            | 20834                   | 50.02 |
| 18-04-2021 | 4 Hrs  | 6287    | 512   | 298 | 7098  | 6651                   | 854  | 5520 | 0     | -747       | 19376                 | 0                  | 19376                    | 817       | 500          | 21440            | 21440                   | 49.96 |
| Maximum    |        | 6674    | 560   | 298 | 7232  | 7329                   | 1087 | 6150 | 0     | -697       | 19376                 | 0                  | 19376                    | 981       | 502          | 21440            | 21440                   | 50.02 |
| Minimum    |        | 5206    | 260   | 178 | 6064  | 5540                   | 137  | 4675 | 0     | -1246      | 16795                 | 0                  | 16795                    | 529       | 285          | 18974            | 18974                   | 49.94 |
| Average    |        | 6048    | 393   | 278 | 6719  | 6210                   | 709  | 5571 | 0     | -990       | 18219                 | 0                  | 18219                    | 707       | 439          | 20356            | 20356                   | 49.97 |

## Details of Supply Position (MUs)

| Date       | MSGENCO |        |       |         | Pench (MS) | Central Sector Receipt | Central Sector Share | WIND    | CPP     | SOLAR | TPCL Gen. | R-INFRA Gen. | TPCL Exch. | Energy Requirement |        |         |
|------------|---------|--------|-------|---------|------------|------------------------|----------------------|---------|---------|-------|-----------|--------------|------------|--------------------|--------|---------|
|            | THM     | HYDRO  | GAS   | Total   |            |                        |                      |         |         |       |           |              |            | MSEDCL             | MUMBAI | STATE   |
|            | Mus     | Mus    | Mus   | Mus     | Mus        | Mus                    | Mus                  | Mus     | Mus     | Mus   | Mus       | Mus          | Mus        | Mus                | Mus    | Mus     |
| 12-04-2021 | 132.119 | 17.234 | 6.850 | 156.203 | 0.061      | 182.368                | 185.812              | 7.994   | 146.150 | 7.080 | 21.651    | 11.402       | -26.098    | 473.697            | 59.151 | 532.848 |
| 13-04-2021 | 151.839 | 10.125 | 6.826 | 168.790 | 0.091      | 170.764                | 176.035              | 9.450   | 136.505 | 6.827 | 16.561    | 10.614       | -30.430    | 461.906            | 57.605 | 519.511 |
| 14-04-2021 | 156.097 | 9.698  | 6.839 | 172.634 | 0.173      | 162.358                | 168.680              | 9.344   | 129.835 | 6.359 | 20.878    | 9.967        | -28.470    | 452.060            | 59.315 | 511.375 |
| 15-04-2021 | 157.715 | 9.995  | 6.867 | 174.577 | 0.000      | 156.921                | 159.003              | 10.719  | 128.295 | 8.495 | 19.089    | 12.015       | -27.786    | 451.221            | 58.890 | 510.111 |
| 16-04-2021 | 161.638 | 13.096 | 4.392 | 179.126 | 0.046      | 159.619                | 162.358              | 13.011  | 135.172 | 8.471 | 21.422    | 10.903       | -25.235    | 470.164            | 57.560 | 527.724 |
| 17-04-2021 | 145.169 | 16.212 | 6.133 | 167.514 | 0.129      | 167.193                | 169.997              | 13.003  | 144.756 | 8.265 | 22.745    | 11.686       | -21.083    | 479.648            | 55.514 | 535.162 |
| 18-04-2021 | 151.464 | 14.880 | 6.763 | 173.107 | 0.082      | 170.298                | 171.280              | 15.034  | 131.682 | 8.536 | 19.977    | 11.258       | -21.859    | 476.798            | 53.094 | 529.892 |
| Maximum    | 161.638 | 17.234 | 6.867 | 179.126 | 0.173      | 182.368                | 185.812              | 161.638 | 146.150 | 8.536 | 22.745    | 12.015       | -21.083    | 479.648            | 59.315 | 535.162 |
| Minimum    | 132.119 | 9.698  | 4.392 | 156.203 | 0.000      | 156.921                | 159.003              | 132.119 | 128.295 | 6.359 | 16.561    | 9.967        | -30.430    | 451.221            | 53.094 | 510.111 |
| Average    | 150.863 | 13.034 | 6.381 | 170.279 | 0.083      | 167.074                | 170.452              | 150.863 | 136.056 | 7.719 | 20.332    | 11.121       | -25.852    | 466.499            | 57.304 | 523.803 |

**Details of Koyna Water Consumption  
(in TMC)**

| Date       | For the Day | For the Month | Balance |
|------------|-------------|---------------|---------|
| 12-04-2021 | 0.234       | 4.920         | 15.702  |
| 13-04-2021 | 0.075       | 4.994         | 15.628  |
| 14-04-2021 | 0.083       | 5.077         | 15.545  |
| 15-04-2021 | 0.076       | 5.153         | 15.469  |
| 16-04-2021 | 0.142       | 5.296         | 15.327  |
| 17-04-2021 | 0.221       | 5.517         | 15.105  |
| 18-04-2021 | 0.181       | 5.698         | 14.925  |

**State Load Despatch Center,Airoli (MSETCL)  
Central Sector Share/Drawal from 12/Apr/2021 to 18/Apr/2021**

| Date         | DAY       | Central Sector Share |         | Total Interstate |         | Total Share     |         | Total Drawal    |         | Overdrawal(+) / |         |
|--------------|-----------|----------------------|---------|------------------|---------|-----------------|---------|-----------------|---------|-----------------|---------|
|              |           | MUs                  | Avg. MW | MUs              | Avg. MW | MUs             | Avg. MW | MUs             | Avg. MW | MUs             | Avg. MW |
|              |           | 1                    |         | 2                |         | 1+2=3           |         | 4               |         | 3-4=5           |         |
| 12-04-2021   | MONDAY    | 131.507              | 7688    | 54.305           | 2263    | 185.812         | 7742    | 182.368         | 7599    | -3.444          | -144    |
| 13-04-2021   | TUESDAY   | 128.911              | 7288    | 47.124           | 1964    | 176.035         | 7335    | 170.764         | 7115    | -5.271          | -220    |
| 14-04-2021   | WEDNESDAY | 122.695              | 6982    | 45.985           | 1916    | 168.680         | 7028    | 162.358         | 6765    | -6.322          | -263    |
| 15-04-2021   | THURSDAY  | 121.215              | 6587    | 37.788           | 1574    | 159.003         | 6625    | 156.921         | 6538    | -2.082          | -87     |
| 16-04-2021   | FRIDAY    | 126.279              | 6729    | 36.079           | 1503    | 162.358         | 6765    | 159.619         | 6651    | -2.739          | -114    |
| 17-04-2021   | SATURDAY  | 130.141              | 7043    | 39.856           | 1661    | 169.997         | 7083    | 167.193         | 6966    | -2.804          | -117    |
| 18-04-2021   | SUNDAY    | 124.912              | 7090    | 46.368           | 1932    | 171.280         | 7137    | 170.298         | 7096    | -0.982          | -41     |
| <b>Total</b> |           | <b>885.659</b>       |         | <b>307.506</b>   |         | <b>1193.165</b> |         | <b>1169.521</b> |         | <b>-23.644</b>  |         |

| Generator Unit Outages/Trippings from 12.04.2021 to 18.04.2021 |            |           |            |            |                                                                        |             |
|----------------------------------------------------------------|------------|-----------|------------|------------|------------------------------------------------------------------------|-------------|
| Name of Unit                                                   | Date Trip  | Time Trip | Date Sync  | Time Sync  | Reason                                                                 | Outage Type |
| SWPGPL U-1                                                     | 16-02-2016 | 17.09     |            | Continued. | No PPA.                                                                | FORCED      |
| PGPL U1                                                        | 07-02-2017 | 17.3      |            | Continued. | No Schedule (NO PPA)                                                   | FORCED      |
| PGPL U2                                                        | 07-02-2017 | 17.3      |            | Continued. | No Schedule.(NO PPA)                                                   | FORCED      |
| IEPL Unit 1                                                    | 28-08-2018 | 21.26     |            | Continued. | No PPA                                                                 | FORCED      |
| VIPL U-1                                                       | 29-12-2018 | 0.3       |            | Continued. | Coal Shortage. (NO PPA From 20.05.2019)                                | FORCED      |
| VIPL U-2                                                       | 17-01-2019 | 0.15      |            | Continued. | Coal shortage.(NO PPA From 20.05.2019)                                 | FORCED      |
| Uran Unit 7                                                    | 25-05-2020 | 12.51     |            | Continued. | Turbine Blade Failure                                                  | FORCED      |
| Chandrapur Unit 3                                              | 05-04-2021 | 10.43     | 12-04-2021 | 17.47      | ID Fan Bearing Temperature High.                                       | FORCED      |
| Adani U-2                                                      | 09-04-2021 | 1.3       | 12-04-2021 | 1.52       | APH-A guide Bearing abnormal sound                                     | FORCED      |
| Bhusawal Unit 4                                                | 10-04-2021 | 0         | 12-04-2021 | 6.26       | Boiler Tube Leakage                                                    | FORCED      |
| Bhusawal Unit 3                                                | 11-04-2021 | 4.08      | 13-04-2021 | 6.43       | Boiler Tube Leakage                                                    | FORCED      |
| JSW (J) U4                                                     | 11-04-2021 | 3.02      | 24-05-2021 | 6.17       | NO SCHEDULE.                                                           | FORCED      |
| Paras Unit 4                                                   | 11-04-2021 | 21.05     | 12-04-2021 | 2.2        | Furnace Pressure High                                                  | FORCED      |
| Bhusawal Unit 4                                                | 12-04-2021 | 6.39      | 12-04-2021 | 8.21       | Electrical Protection.                                                 | FORCED      |
| Nasik Unit 5                                                   | 11-04-2021 | 23.1      | 13-04-2021 | 1.3        | Foreign Material Observed In Impeller Of ID A.                         | FORCED      |
| Koradi Unit 6                                                  | 11-04-2021 | 22.15     | 12-04-2021 | 16.55      | AC Failure.                                                            | FORCED      |
| Koradi Unit 7                                                  | 11-04-2021 | 22.14     | 12-04-2021 | 19.42      | AC Failure.                                                            | FORCED      |
| Koyna STG-IV Unit-1                                            | 12-04-2021 | 10.1      | 13-04-2021 | 3.4        | Outage For Turbine Guide Bearing Oil Temperature RTD Sensor Work.      | FORCED      |
| Parli Unit 7                                                   | 12-04-2021 | 10.35     | 12-04-2021 | 13.25      | Due To Flash Over In Coal Mill.                                        | FORCED      |
| Koyna STG-IV Unit-4                                            | 12-04-2021 | 15.39     | 13-04-2021 | 3.4        | Tripped due To Voltage Jerk.                                           | FORCED      |
| Koradi Unit 6                                                  | 12-04-2021 | 18.56     | 12-04-2021 | 22.35      | Due To Both Vacuum Dump Tripped.                                       | FORCED      |
| SWPGPL U-2                                                     | 13-04-2021 | 12.15     | 16-04-2021 | 16.47      | Conveyor Belt Problem.                                                 | FORCED      |
| Koyna STG-IV Unit-2                                            | 12-04-2021 | 15.39     | 12-04-2021 | 22.3       | Tripped due To Voltage Jerk.                                           | FORCED      |
| Koyna STG-IV Unit-3                                            | 12-04-2021 | 15.39     | 12-04-2021 | 21.35      | Tripped due To Voltage Jerk.                                           | FORCED      |
| Paras Unit 3                                                   | 12-04-2021 | 15.4      | 13-04-2021 | 0.15       | Due To Clinker Formation.                                              | FORCED      |
| Ghatghar Unit-2                                                | 14-04-2021 | 0         | 18-04-2021 | 12         | Maintenance work                                                       | FORCED      |
| Koyna STG-IV Unit-4                                            | 15-04-2021 | 12        | 18-04-2021 | 11.45      | Spiral case air drain valve replacement work                           | PLANNED     |
| Khaparkhedda Unit 2                                            | 15-04-2021 | 16.54     | 27-05-2021 | 14.06      | Critical coal stock position                                           | FORCED      |
| Uran Unit 8                                                    | 16-04-2021 | 12.23     | 16-04-2021 | 15.4       | Joint Islanding trial conductor with mahatransco.                      | FORCED      |
| Uran Unit 6                                                    | 16-04-2021 | 12.23     | 16-04-2021 | 20.13      | Joint Islanding trial conductor with mahatransco.                      | FORCED      |
| Uran Unit B0                                                   | 16-04-2021 | 12.23     | 16-04-2021 | 21.57      | Joint Islanding trial conductor with mahatransco.                      | FORCED      |
| Uran Unit A0                                                   | 16-04-2021 | 12.23     | 17-04-2021 | 7.27       | Joint Islanding trial conductor with mahatransco.                      | FORCED      |
| Adani U-1                                                      | 16-04-2021 | 10.59     | 16-04-2021 | 19.44      | To attend hotspot in GT-Y-phase neutral bushing palm.                  | FORCED      |
| Bhusawal Unit 5                                                | 17-04-2021 | 7.56      | 17-04-2021 | 11.26      | Furnace Pressure High                                                  | FORCED      |
| Chandrapur Unit 6                                              | 16-04-2021 | 23.58     | 21-04-2021 | 12.28      | Boiler validity expiry.                                                | FORCED      |
| Adani U-3                                                      | 17-04-2021 | 20.55     | 21-04-2021 | 13.28      | APH-A Hot Bellow leakage                                               | FORCED      |
| Ghatghar Unit-1                                                | 18-04-2021 | 18        | 25-04-2021 | 17.45      | Bypass Work.                                                           | FORCED      |
| Nasik Unit 3                                                   | 03-12-2020 | 6.45      |            | Continued. | PA Fan Problem (Under Case 4 Bidding From 11.00Hrs DT. 21-01-2021).    | FORCED      |
| Koyna Unit 11                                                  | 19-01-2021 | 10.05     | 29-05-2021 | 15.2       | Tripped on stator earth fault (will not be available till dt.24.05.21) | FORCED      |
| JSW (J) U1                                                     | 01-02-2021 | 18        | 04-05-2021 | 14.52      | Due to turbine vibration high                                          | FORCED      |
| Chandrapur Unit 7                                              | 20-02-2021 | 23.43     |            | Continued. | Generator Earth Fault.                                                 | FORCED      |
| Chandrapur Unit 4                                              | 16-03-2021 | 8.08      | 27-05-2021 | 9.01       | Boiler Tube Leakage(converted to Capital overhaul)                     | PLANNED     |
| Uran Unit 5                                                    | 02-04-2021 | 23.19     | 25-04-2021 | 17.28      | Gas shortage                                                           | FORCED      |

| Transmission Line Outages/Trippings from 12.04.2021 to 18.04.2021 |            |           |            |            |                                                                                                                                                   |             |         |
|-------------------------------------------------------------------|------------|-----------|------------|------------|---------------------------------------------------------------------------------------------------------------------------------------------------|-------------|---------|
| Name of Line                                                      | Date Trip  | Time Trip | Date Sync  | Time Sync  | Reason                                                                                                                                            | Outage Type | Voltage |
| Mudshingi Chikodi                                                 | 24-09-2019 | 17.12     |            | Continued. | No Schedule(Charge from Mudshingi end only)                                                                                                       | PO          | 220 KV  |
| Talandage - Chikodi                                               | 01-10-2019 | 17.1      |            | Continued. | No Schedule(Close at Chikodi end only)                                                                                                            | PO          | 220 KV  |
| Parli 3 (Old Gcr)-Girwali Ckt 2                                   | 25-03-2021 | 10.28     | 16-04-2021 | 21.11      | Railway crossing tower erection work                                                                                                              | PO          | 220 KV  |
| Hinganghat - Bhugaon                                              | 09-04-2021 | 13.49     | 16-04-2021 | 22.33      | Work of diversion from LOC 226 to 235 of 220KV wardha-warora & bhugaon hinganghat D/C line being carried out by VIDC under supervision of MSETCL. | PO          | 220 KV  |
| Warora - Wardha                                                   | 09-04-2021 | 14.03     | 16-04-2021 | 20.03      | Work of diversion from LOC 226 to 235 of 220KV Wardha-Warora & Bhugaon-Hinganghat                                                                 | PO          | 220 KV  |
| Uran - Apta III                                                   | 10-04-2021 | 18.55     | 13-04-2021 | 0.23       | Tan Delta Measurment of CTs                                                                                                                       | EO          | 220 KV  |
| Chikhli-Jalna-I                                                   | 11-04-2021 | 21.2      | 13-04-2021 | 8.16       | To Control Akola ICT Loading.                                                                                                                     | HT          | 220 KV  |
| Chikhli-Jalna-II                                                  | 11-04-2021 | 21.2      | 13-04-2021 | 8.16       | To Control Akola ICT Loading.                                                                                                                     | HT          | 220 KV  |
| 220/100 Kv 200 MVA ICT IV @Padghe                                 | 12-04-2021 | 11.12     | 12-04-2021 | 15.02      | Transfer Backup Protection On Diff Protection And Make Core Spare Available For Bus Bar Protection.                                               | PO          | 220 KV  |
| 220/22 Kv 50 Mva Bhel Ptr 1 @Padghe                               | 12-04-2021 | 15.42     | 12-04-2021 | 18.04      | For Connecting CT Ckt In New Bus Bar Protection.                                                                                                  | PO          | 220 KV  |
| 220/33kV 100 MVA Transformer 1 @Ghodbunder R/S                    | 12-04-2021 | 9.57      | 12-04-2021 | 15.15      | Replacement Of Doors Of CB Mechanism And Marshaling Box.                                                                                          | PO          | 220 KV  |
| ACCIL - Apta                                                      | 12-04-2021 | 14.27     | 12-04-2021 | 18.1       | Testing Work                                                                                                                                      | PO          | 220 KV  |
| KORADI 2 - KAULEWADA CKT - I                                      | 12-04-2021 | 17.16     | 13-04-2021 | 4.44       | Distance Protection                                                                                                                               | T           | 220 KV  |
| Kharghar-Borivali ckt I                                           | 12-04-2021 | 18.44     | 13-04-2021 | 8.58       | Distance Protection                                                                                                                               | T           | 220 KV  |
| Pargaon( Kathapur)-Lonikand                                       | 12-04-2021 | 15.4      | 12-04-2021 | 16         | Distance Protection                                                                                                                               | T           | 220 KV  |
| Valve-Jamde                                                       | 12-04-2021 | 16.36     | 12-04-2021 | 19.22      | Jumper Connection.                                                                                                                                | PO          | 220 KV  |
| 220/132 Kv 200 Mva Bbl Ict 3 @Padegaon                            | 13-04-2021 | 14.57     | 13-04-2021 | 15.09      | LV Backup Protection Operated.                                                                                                                    | T           | 220 KV  |
| Kanhan-Bhandara I                                                 | 13-04-2021 | 12.19     | 14-04-2021 | 0.47       | To attend Hot Spot                                                                                                                                | EO          | 220 KV  |
| Karad - Vita Ckt- II                                              | 13-04-2021 | 9.46      | 13-04-2021 | 17.59      | Emergency String Replacement And Insulator Washing Work.                                                                                          | EO          | 220 KV  |
| Kharghar-Borivali ckt I                                           | 13-04-2021 | 10.01     | 13-04-2021 | 15         | For Replacement Of STUB Bus Twin Jumper Due To Broken Conductor strands.                                                                          | PO          | 220 KV  |
| PARLY (PG) - OLD GCR PARLI                                        | 13-04-2021 | 14.1      | 13-04-2021 | 18.11      | Distance Protection                                                                                                                               | T           | 220 KV  |
| 220 KV JALKOT - NANDED (KUMBHARGAON) CKT - 1                      | 14-04-2021 | 19.28     | 14-04-2021 | 22.22      | Distance Protection                                                                                                                               | T           | 220 KV  |
| 220/132 Kv 100 Mva Ict 1 @South Solapur (Kumbhari)                | 14-04-2021 | 11.2      | 14-04-2021 | 14.2       | Quarterly Maintenance Work                                                                                                                        | PO          | 220 KV  |
| 220/132 Kv 200 Mva Bbl Ict 2 @Waghala Nanded                      | 14-04-2021 | 20.35     | 14-04-2021 | 20.53      | HV and LV Backup Protection                                                                                                                       | T           | 220 KV  |
| 220/132 kV 200 MVA ICT- I @ Nanded                                | 14-04-2021 | 20.35     | 14-04-2021 | 20.5       | HV and LV Backup Protection                                                                                                                       | T           | 220 KV  |
| 220/132kV 200MVA ICT-III @ Nanded                                 | 14-04-2021 | 20.35     | 14-04-2021 | 20.55      | HV and LV Backup Protection                                                                                                                       | T           | 220 KV  |

| Transmission Line Outages/Trippings from 12.04.2021 to 18.04.2021 |            |           |            |           |                                                        |             |         |
|-------------------------------------------------------------------|------------|-----------|------------|-----------|--------------------------------------------------------|-------------|---------|
| Name of Line                                                      | Date Trip  | Time Trip | Date Sync  | Time Sync | Reason                                                 | Outage Type | Voltage |
| Chandrapur(MIDC)-Ballarshah II                                    | 14-04-2021 | 9.58      | 14-04-2021 | 15.1      | Tightening suspension clamp Nut Bolts of Pilot String  | PO          | 220 KV  |
| KORADI 2 - KAULEWADA CKT - II                                     | 14-04-2021 | 13.4      | 14-04-2021 | 15.25     | To attend Hot Spot                                     | PO          | 220 KV  |
| Karad - Kadegaon                                                  | 14-04-2021 | 22.59     | 16-04-2021 | 0.21      | Distance Protection                                    | T           | 220 KV  |
| Karad - Kadegaon                                                  | 14-04-2021 | 21.05     | 14-04-2021 | 22.56     | Removing of Plastic paper trapped on conductor         | EO          | 220 KV  |
| Solapur(PG)- Jeur                                                 | 14-04-2021 | 12.11     | 14-04-2021 | 19.53     | Quarterly Maintenance Work                             | PO          | 220 KV  |
| Trombay - Kalwa                                                   | 14-04-2021 | 12.27     | 22-04-2021 | 18.26     | Conductor replacement.                                 | PO          | 220 KV  |
| Trombay - Mulund                                                  | 14-04-2021 | 12.4      | 14-04-2021 | 20.57     | For Safety purpose for dismantling of existing Tower   | PO          | 220 KV  |
| Trombay Dharavi 5                                                 | 14-04-2021 | 11.47     | 14-04-2021 | 19.53     | For ARR commissioning work                             | PO          | 220 KV  |
| Virur - Gadchiroli                                                | 14-04-2021 | 9.27      | 14-04-2021 | 9.54      | Distance Protection                                    | T           | 220 KV  |
| Vita - Ghatnandre                                                 | 14-04-2021 | 11        | 14-04-2021 | 13.51     | To attend CT leakage                                   | PO          | 220 KV  |
| Wardha-Yeotmal                                                    | 14-04-2021 | 19.25     | 14-04-2021 | 21.05     | Distance Protection                                    | T           | 220 KV  |
| KORADI 2 - KAULEWADA CKT - II                                     | 15-04-2021 | 8.54      | 15-04-2021 | 19.24     | Replacement of Mid Span Joints                         | PO          | 220 KV  |
| Karad-Nerle                                                       | 15-04-2021 | 16.11     | 15-04-2021 | 20.51     | Extension on new PT to metering Ckt                    | PO          | 220 KV  |
| Koradi-Ambazari-I                                                 | 15-04-2021 | 9.33      | 15-04-2021 | 13.26     | Line Maintenance work                                  | PO          | 220 KV  |
| Trombay Dharavi 6                                                 | 15-04-2021 | 10.14     | 15-04-2021 | 16.42     | ARR Commissioning work                                 | PO          | 220 KV  |
| Vasai Kamba                                                       | 15-04-2021 | 10.45     | 15-04-2021 | 15        | Replacement of Faulty Insulator Strings                | PO          | 220 KV  |
| 220/100 Kv 200 MVA ICT-II @Trombay                                | 16-04-2021 | 10.33     | 16-04-2021 | 22.51     | 110KV Bus zone PT fail.                                | T           | 220 KV  |
| 220/132kv 200MVA ICT-III @ Nanded                                 | 16-04-2021 | 11.35     | 16-04-2021 | 12.48     | To attend Hot Spot                                     | PO          | 220 KV  |
| KORADI 2 - KAULEWADA CKT - I                                      | 16-04-2021 | 8.5       | 16-04-2021 | 20.03     | Mid span joint replacement.                            | PO          | 220 KV  |
| Koradi-Ambazari-Ii                                                | 16-04-2021 | 9.33      | 16-04-2021 | 13.38     | Yearly diagnostic testing work and general.            | PO          | 220 KV  |
| Pandarpur-Khanapur                                                | 16-04-2021 | 7.27      | 16-04-2021 | 9.17      | Y-PH wavetrap hotspot.                                 | HT          | 220 KV  |
| Pedhambe - Oni                                                    | 16-04-2021 | 8.4       | 16-04-2021 | 17.55     | Quarterly Maintainance Work                            | PO          | 220 KV  |
| Roma-Bhavgar                                                      | 16-04-2021 | 10.28     | 16-04-2021 | 17.36     | Replacement work                                       | PO          | 220 KV  |
| Sahara-Urse                                                       | 16-04-2021 | 11.17     | 16-04-2021 | 13.35     | Load management.                                       | HT          | 220 KV  |
| Talandge-Mudshingi Ckt-I                                          | 16-04-2021 | 15.05     | 16-04-2021 | 21.25     | Replacement of 220kv B ph CT due to heavy oil leakage. | EO          | 220 KV  |
| Uran - Apta II                                                    | 16-04-2021 | 12.39     | 16-04-2021 | 13.25     | TF2 LV CT burst at Uran.                               | T           | 220 KV  |
| Uran - Apta III                                                   | 16-04-2021 | 12.39     | 16-04-2021 | 13.28     | TF2 LV CT burst at Uran.                               | T           | 220 KV  |
| Uran - Apta IV                                                    | 16-04-2021 | 12.39     | 16-04-2021 | 13.17     | TF2 LV CT burst at Uran.                               | T           | 220 KV  |
| Uran - Jnpt                                                       | 16-04-2021 | 12.39     | 16-04-2021 | 13.26     | TF2 LV CT burst at Uran.                               | T           | 220 KV  |
| Uran - Kharghar 2                                                 | 16-04-2021 | 12.39     | 16-04-2021 | 13.27     | TF2 LV CT burst at Uran.                               | T           | 220 KV  |
| Uran - Kharghar I                                                 | 16-04-2021 | 12.39     | 16-04-2021 | 13.18     | TF2 LV CT burst at Uran.                               | T           | 220 KV  |
| Uran - Ongc Uran                                                  | 16-04-2021 | 12.39     | 16-04-2021 | 13.22     | TF2 LV CT burst at Uran.                               | T           | 220 KV  |
| Urse - Talegaon (Ambi) Ckt 2                                      | 16-04-2021 | 11.25     | 16-04-2021 | 13.21     | Attending Hot Spot                                     | PO          | 220 KV  |
| Warora - Hinganghat                                               | 16-04-2021 | 18.1      | 16-04-2021 | 20.03     | Original ckt is Warora Wardha ckt.                     | HT          | 220 KV  |
| 220/100 Kv 200MVA ICT-I @Padghe                                   | 17-04-2021 | 13.14     | 17-04-2021 | 18.46     | To attend Hot Spot                                     | PO          | 220 KV  |
| 220KV Chalisagaon-Kopergaon                                       | 17-04-2021 | 16.31     | 17-04-2021 | 18.48     | To attend Hot Spot                                     | EO          | 220 KV  |
| Bableshtar- Alephata ckt I                                        | 17-04-2021 | 21.2      | 18-04-2021 | 4.5       | Sparking in 29B Phase Isolator                         | EO          | 220 KV  |
| Bableshtar- Alephata ckt I                                        | 17-04-2021 | 12.36     | 17-04-2021 | 14.52     | Distance Protection                                    | T           | 220 KV  |
| Karad - Kadegaon                                                  | 17-04-2021 | 16.44     | 17-04-2021 | 21.38     | Replacement of faulty Disc Insulator string            | EO          | 220 KV  |

| Transmission Line Outages/Trippings from 12.04.2021 to 18.04.2021 |            |           |            |            |                                                                                                                 |             |         |
|-------------------------------------------------------------------|------------|-----------|------------|------------|-----------------------------------------------------------------------------------------------------------------|-------------|---------|
| Name of Line                                                      | Date Trip  | Time Trip | Date Sync  | Time Sync  | Reason                                                                                                          | Outage Type | Voltage |
| Karad - Kadegaon                                                  | 17-04-2021 | 17.44     | 18-04-2021 | 21.38      | Replacement Faulty String Insulator Work At loc No,21 B-PH.                                                     | EO          | 220 KV  |
| Khaparkheda-Ambazari-Ii                                           | 17-04-2021 | 9.32      | 17-04-2021 | 14.02      | Testing Work                                                                                                    | PO          | 220 KV  |
| Nanded- Bhokar I                                                  | 17-04-2021 | 10.28     | 17-04-2021 | 11.55      | To attend Hot Spot                                                                                              | EO          | 220 KV  |
| Padgha - Temghar I                                                | 17-04-2021 | 16.15     | 17-04-2021 | 23.4       | Replacement of Distance Relay                                                                                   | PO          | 220 KV  |
| Pandarpur-Khanapur                                                | 17-04-2021 | 9         | 17-04-2021 | 11.58      | To attend Hot Spot                                                                                              | EO          | 220 KV  |
| Wada - Bhaveghar                                                  | 17-04-2021 | 10.2      | 17-04-2021 | 18.39      | Replacement of Faulty Insulator Strings                                                                         | PO          | 220 KV  |
| Colourchem - Temghar                                              | 18-04-2021 | 13.55     | 18-04-2021 | 15.18      | To attend Hot Spot                                                                                              | PO          | 220 KV  |
| Kalwa - Colourchem                                                | 18-04-2021 | 16.37     | 18-04-2021 | 17.4       | To attend Hot Spot                                                                                              | EO          | 220 KV  |
| Kalwa-TIFIL                                                       | 18-04-2021 | 11.58     | 18-04-2021 | 13.07      | Distance Protection                                                                                             | T           | 220 KV  |
| Kandalgaon - ONGC Panvel                                          | 18-04-2021 | 13.07     | 18-04-2021 | 16.57      | Distance Protection                                                                                             | T           | 220 KV  |
| Mulund - GIS Bhandup                                              | 18-04-2021 | 19.25     | 18-04-2021 | 21.25      | Distance Protection                                                                                             | T           | 220 KV  |
| Chandrapur II - Chandrapur ckt 2                                  | 09-04-2021 | 15.47     | 09-04-2021 | 18.12      | Over Voltage protection.                                                                                        | T           | 400 KV  |
| Deepnagar Waluj 1                                                 | 09-04-2021 | 23.14     | 10-04-2021 | 16.19      | Distance Protection                                                                                             | T           | 400 KV  |
| Babhaleshwar - Padghe-I                                           | 10-04-2021 | 17.02     | 10-04-2021 | 19.26      | Distance Protection,,Z1,R-N,20 KM,9.46 KA FROM BBLR END.                                                        | T           | 400 KV  |
| Deepnagar Waluj 1                                                 | 10-04-2021 | 16.23     | 11-04-2021 | 13.43      | Distance Protection                                                                                             | T           | 400 KV  |
| Karad-Jaigad - I                                                  | 10-04-2021 | 8.37      | 10-04-2021 | 16.28      | For Additional Earthing.                                                                                        | PO          | 400 KV  |
| 400/220 Kv 500 MVA ICT 3 @KOLHAPUR-III (TALANDGE)                 | 11-04-2021 | 19.45     | 11-04-2021 | 22.22      | Tripped On NDR Protection.                                                                                      | T           | 400 KV  |
| Dhule Sar'Sarovar II                                              | 11-04-2021 | 18.43     | 12-04-2021 | 8.17       | Over Voltage                                                                                                    | HT          | 400 KV  |
| Padghe - Kalwa-II                                                 | 11-04-2021 | 10.45     | 11-04-2021 | 14.4       | To attend Hot Spot At Y-Phase Kalwa Side on loc no.1064 by Hot line method.                                     | EO          | 400 KV  |
| Khadka-Aurangabad (Waluj)                                         | 31-12-2020 | 17.33     |            | Continued. | Over Voltage                                                                                                    | HT          | 400 KV  |
| Chandrapur - Padghe Hvdc Pole 2                                   | 06-04-2021 | 17.34     | 07-04-2021 | 2          | Attending Oil Leakage                                                                                           | EO          | 500 KV  |
| Chandrapur - Padghe Hvdc Pole 2                                   | 07-04-2021 | 13.27     | 14-04-2021 | 1.3        | H/T at Padghe end                                                                                               | EO          | 500 KV  |
| Ektuni - Akola II Ckt I                                           | 06-04-2021 | 6.46      | 20-04-2021 | 11.58      | Nagpur-Mumbai Express Highway Work.                                                                             | PO          | 765 KV  |
| Karad Solapur (PG)                                                | 03-05-2017 | 11:49     |            | Continued. | Line Converted As 220 Kv Solapur (PG)-Jeur From LOC 403                                                         | PO          | 400 KV  |
| 400/220kv 315 MVA ICT I @ KOLHAPUR-III (TALANDGE)                 | 10-08-2020 | 9.58      |            | Continued. | Replacement of existing 315 MVA ICT by 3*167 MVA ICT.                                                           | PO          | 400 KV  |
| Dhule Sar'Sarovar II                                              | 11-04-2021 | 18.43     | 12-04-2021 | 8.17       | Over Voltage                                                                                                    | HT          | 400 KV  |
| 125 MVAR Bus Reactor @ Warora                                     | 12-04-2021 | 9.19      | 12-04-2021 | 19.4       | For Attending Problem In Nitrogen Injection Fire Prevention & Extinguishing System Of 400KV,125MVR Bus Reactor. | PO          | 400 KV  |
| 400/220 Kv 500 MVA ICT 3 @KOLHAPUR-III (TALANDGE)                 | 12-04-2021 | 17.42     | 12-04-2021 | 22.35      | Testing Of NDR.                                                                                                 | EO          | 400 KV  |
| Deepnagar Waluj 1                                                 | 12-04-2021 | 2.42      | 12-04-2021 | 13.12      | Distance Protection                                                                                             | T           | 400 KV  |
| Deepnagar Waluj 1                                                 | 12-04-2021 | 19.16     | 13-04-2021 | 5.1        | Distance Protection                                                                                             | T           | 400 KV  |
| Dhule Sar'Sarovar I                                               | 12-04-2021 | 18.38     | 13-04-2021 | 8.07       | Over Voltage                                                                                                    | HT          | 400 KV  |
| Girwali-Solapur (Lamboti)                                         | 12-04-2021 | 18.46     | 13-04-2021 | 9.52       | Distance Protection                                                                                             | T           | 400 KV  |
| Lonikand I - Koyna stage-IV                                       | 12-04-2021 | 15.39     | 12-04-2021 | 21.09      | Distance Protection                                                                                             | T           | 400 KV  |
| 400/220 KV 500MVA ICT-IV @ Babhaleshwar                           | 13-04-2021 | 23.45     | 14-04-2021 | 18.29      | To attend Hot Spot                                                                                              | EO          | 400 KV  |

| Transmission Line Outages/Trippings from 12.04.2021 to 18.04.2021 |            |           |            |           |                                                                                                                         |             |         |
|-------------------------------------------------------------------|------------|-----------|------------|-----------|-------------------------------------------------------------------------------------------------------------------------|-------------|---------|
| Name of Line                                                      | Date Trip  | Time Trip | Date Sync  | Time Sync | Reason                                                                                                                  | Outage Type | Voltage |
| 400/220/33 Kv 315 Mva Ict 2 @Koradi                               | 13-04-2021 | 9.43      | 13-04-2021 | 17.2      | To Attend Oil Leakage From Radiator By Agency.                                                                          | PO          | 400 KV  |
| Girwali- Lonikand 2                                               | 13-04-2021 | 16.42     | 13-04-2021 | 18.5      | Distance Protection                                                                                                     | T           | 400 KV  |
| New Koyna - Dabhol-I                                              | 13-04-2021 | 9.5       | 13-04-2021 | 20.29     | Cold Washing & E/W Replacement Work.                                                                                    | PO          | 400 KV  |
| 400/220 Kv 600 MVA ICT-II @Kalwa                                  | 14-04-2021 | 14.52     | 14-04-2021 | 17.07     | Hot Line washing work of ICT Bay                                                                                        | PO          | 400 KV  |
| Akola - Bhusawal                                                  | 14-04-2021 | 15.13     | 14-04-2021 | 16.58     | Distance Protection                                                                                                     | T           | 400 KV  |
| Koradi Satpur                                                     | 14-04-2021 | 15.18     | 14-04-2021 | 16.25     | Distance Protection                                                                                                     | T           | 400 KV  |
| New Koyna -Koyna Stage IV-I                                       | 14-04-2021 | 9.13      | 14-04-2021 | 18.46     | Bus Conductor replacement work                                                                                          | PO          | 400 KV  |
| 400/220/33 Kv 315 Mva ICT I @ Akola (M)                           | 15-04-2021 | 0.47      | 15-04-2021 | 4.12      | Buccholz Protection Optd                                                                                                | T           | 400 KV  |
| 400/220kv, 500 Mva ICT-1 @Deepnagar                               | 15-04-2021 | 10.19     | 15-04-2021 | 19.54     | Main Bus CT Tan Delta testing                                                                                           | PO          | 400 KV  |
| Dabhol Nagothane I                                                | 15-04-2021 | 9.43      | 15-04-2021 | 19.44     | E/W replacement work                                                                                                    | PO          | 400 KV  |
| Dhule Sar'Sarovar I                                               | 15-04-2021 | 11.03     | 16-04-2021 | 7.39      | Insulator replacement(RFC 18.40Hrs)                                                                                     | PO          | 400 KV  |
| Jejuri- Koynastage-IV                                             | 15-04-2021 | 13.25     | 15-04-2021 | 17.53     | Faulty Insulator replacement work                                                                                       | PO          | 400 KV  |
| Wardha (Pg) Warora I                                              | 15-04-2021 | 21.16     | 16-04-2021 | 0.51      | To attend Hot Spot                                                                                                      | EO          | 400 KV  |
| Dhule Sar'Sarovar II                                              | 16-04-2021 | 8.12      | 17-04-2021 | 10.18     | Line Maintenance work (RFC 19.49)                                                                                       | HT          | 400 KV  |
| Nagothane - Dabhol I                                              | 16-04-2021 | 10.21     | 16-04-2021 | 18.49     | Cold washing ,E/W replacement Work & Faulty string replacement Work.                                                    | PO          | 400 KV  |
| Dabhol Nagothane I                                                | 17-04-2021 | 9.41      | 17-04-2021 | 18.46     | E/W replacement work                                                                                                    | PO          | 400 KV  |
| 400/220 Kv 315 MVA ICT-II @Chakan                                 | 18-04-2021 | 6.02      | 18-04-2021 | 21.35     | Load Management                                                                                                         | HT          | 400 KV  |
| Babhaleshwar - Padghe-II                                          | 18-04-2021 | 2.12      | 18-04-2021 | 4.36      | To attend Hot Spot                                                                                                      | EO          | 400 KV  |
| Padghe - Nagothane - I                                            | 18-04-2021 | 5.18      | 18-04-2021 | 17.14     | Distance Protection                                                                                                     | T           | 400 KV  |
| Padghe - Nagothane - II                                           | 18-04-2021 | 5.15      | 18-04-2021 | 8.32      | Frequent AR operated                                                                                                    | HT          | 400 KV  |
| Chandrapur - Padghe Hvdc Pole 2                                   | 07-04-2021 | 13.27     | 14-04-2021 | 1.3       | H/T at Padghe end                                                                                                       | EO          | 500 KV  |
| Chandrapur - Padghe Hvdc Pole 1                                   | 16-04-2021 | 22.22     | 18-04-2021 | 7.12      | To attend work of OLTC of R ph. converter transformer of HVDC pole 1 at Padgha end.                                     | PO          | 500 KV  |
| Chandrapur - Padghe Hvdc Pole 2                                   | 16-04-2021 | 22.37     | 16-04-2021 | 23.29     | pole-2 block at 22:37hrs<br>pole-2 deblock at 23:29hrs<br>pole-2 is in metallic return mode<br>power restriction 750MW. | PO          | 500 KV  |