

State Load Despatch Center,Airoli (MSETCL)
Power System Position from 15/Apr/2024 to 21/Apr/2024

Supply Position During Morning Peak (MW)

Date	Time	MSGENCO				Central Sector Receipt	Wind	CPP	SOLAR	TPCL Exch.	MSEDCL Catered Demand	Load Sheddin g(LS)	MSEDCL Demand (Incl. LS)	TPCL Gen.	R-INFRA Gen.	State Demand Met	State Demand (Incl. LS)	Freq.
		THM	HYDRO	GAS	Total													
		MW	MW	MW	MW	MW	MW	MW	MW	MW	MW	MW	MW	MW	MW	MW	MW	Hzs
15-04-2024	12 Hrs	7261	474	274	8009	9339	212	5750	2296	-2298	22798	0	22798	961	440	27007	27007	50.05
16-04-2024	11 Hrs	7274	677	275	8226	10060	235	5353	2081	-2225	23269	0	23269	1007	458	27420	27420	50.01
17-04-2024	12 Hrs	7621	484	278	8383	9956	126	6135	2177	-2351	23916	0	23916	1141	398	28316	28316	50.00
18-04-2024	11 Hrs	7136	294	276	7706	9788	748	5338	2098	-2352	22841	0	22841	1141	365	27184	27184	50.04
19-04-2024	12 Hrs	6550	891	370	7811	10962	230	5453	1990	-2457	23492	0	23492	1150	228	27824	27824	50.01
20-04-2024	12 Hrs	6671	204	424	7299	10574	243	5854	2186	-2313	23343	0	23343	1038	232	27426	27426	50.03
21-04-2024	12 Hrs	6108	166	279	6553	9501	300	5435	2217	-1844	21701	0	21701	611	302	24919	24919	49.98
Maximum		7621	891	424	8383	10962	748	6135	2296	-1844	23916	0	23916	1150	458	28316	28316	50.05
Minimum		6108	166	274	6553	9339	126	5338	1990	-2457	21701	0	21701	611	228	24919	24919	49.98
Average		6946	456	311	7712	10026	299	5617	2149	-2263	23052	0	23052	1007	346	27157	27157	50.02

Supply Position During Day Peak (MW)

Date	Time	MSGENCO				Central Sector Receipt	Wind	CPP	SOLAR	TPCL Exch.	MSEDCL Catered Demand	Load Sheddin g(LS)	MSEDCL Demand (Incl. LS)	TPCL Gen.	R-INFRA Gen.	State Demand Met	State Demand (Incl. LS)	Freq.
		THM	HYDRO	GAS	Total													
		MW	MW	MW	MW	MW	MW	MW	MW	MW	MW	MW	MW	MW	MW	MW	MW	Hzs
15-04-2024	16 Hrs	7645	805	270	8720	10204	108	5759	1389	-2257	23416	0	23416	1256	460	27896	27896	49.99
16-04-2024	16 Hrs	7813	965	275	9053	10299	146	5887	1342	-2459	23767	0	23767	1292	291	28310	28310	50.01
17-04-2024	16 Hrs	7741	1247	280	9268	9553	660	6783	1107	-2502	24340	0	24340	1270	268	28909	28909	49.93
18-04-2024	16 Hrs	7728	809	458	8995	10123	318	6483	1358	-2548	24230	0	24230	1254	174	28705	28705	49.97
19-04-2024	16 Hrs	6867	1305	451	8623	10744	446	5872	1298	-2508	23982	0	23982	1259	204	28446	28446	49.98
20-04-2024	15 Hrs	6818	294	376	7488	9887	1386	5960	1649	-2245	23648	0	23648	1121	243	27734	27734	49.92
21-04-2024	16 Hrs	7053	164	278	7495	9541	336	6703	1198	-1819	22971	0	22971	739	306	26318	26318	49.96
Maximum		7813	1305	458	9268	10744	1386	6783	1649	-1819	24340	0	24340	1292	460	28909	28909	50.01
Minimum		6818	164	270	7488	9541	108	5759	1107	-2548	22971	0	22971	739	174	26318	26318	49.92
Average		7381	798	341	8520	10050	486	6207	1334	-2334	23765	0	23765	1170	278	28045	28045	49.97

Supply Position During Evening Peak (MW)

Date	Time	MSGENCO				Central Sector Receipt	Wind	CPP	SOLAR	TPCL Exch.	MSEDCL Catered Demand	Load Sheddin g(LS)	MSEDCL Demand (Incl. LS)	TPCL Gen.	R-INFRA Gen.	State Demand Met	State Demand (Incl. LS)	Freq.
		THM	HYDRO	GAS	Total													
		MW	MW	MW	MW	MW	MW	MW	MW	MW	MW	MW	MW	MW	MW	MW	MW	Hzs
15-04-2024	20 Hrs	7427	769	366	8562	9822	483	6064	0	-1755	22695	0	22695	1214	481	26626	26626	50.00
16-04-2024	20 Hrs	8048	1328	284	9660	8591	357	6325	0	-1778	22651	0	22651	1275	503	26711	26711	50.02
17-04-2024	20 Hrs	7361	586	384	8331	8418	1172	6482	0	-1868	22030	0	22030	1177	493	26073	26073	50.03
18-04-2024	20 Hrs	7834	1166	467	9467	8650	662	7121	0	-1966	23420	0	23420	1278	222	27400	27400	50.04
19-04-2024	20 Hrs	7330	1356	386	9072	9111	518	7188	0	-2259	23133	0	23133	987	216	27092	27092	49.95
20-04-2024	20 Hrs	6537	367	474	7378	8683	797	5969	0	-1824	20500	0	20500	978	381	24186	24186	50.03
21-04-2024	20 Hrs	7259	557	284	8100	8337	450	6979	0	-1543	21840	0	21840	735	436	25037	25037	49.98
Maximum		8048	1356	474	9660	9822	1172	7188	0	-1543	23420	0	23420	1278	503	27400	27400	50.04
Minimum		6537	367	284	7378	8337	357	5969	0	-2259	20500	0	20500	735	216	24186	24186	49.95
Average		7399	876	378	8653	8802	634	6590	0	-1856	22324	0	22324	1092	390	26161	26161	50.01

Supply Position During Night Off Peak (MW)

Date	Time	MSGENCO				Central Sector Receipt	Wind	CPP	SOLAR	TPCL Exch.	MSEDCL Catered Demand	Load Sheddin g(LS)	MSEDCL Demand (Incl. LS)	TPCL Gen.	R-INFRA Gen.	State Demand Met	State Demand (Incl. LS)	Freq.
		THM	HYDRO	GAS	Total													
		MW	MW	MW	MW	MW	MW	MW	MW	MW	MW	MW	MW	MW	MW	MW	MW	Hzs
15-04-2024	4 Hrs	7844	695	292	8831	7306	280	5795	0	-1225	20616	0	20616	623	454	23289	23289	49.98
16-04-2024	5 Hrs	7450	543	287	8280	8671	352	6175	0	-1317	21794	0	21794	714	469	24661	24661	49.96
17-04-2024	4 Hrs	7981	397	379	8757	8366	324	6364	0	-1303	22176	0	22176	929	502	25242	25242	50.02
18-04-2024	8 Hrs	6961	639	307	7907	8747	562	5881	552	-1544	21641	0	21641	809	489	24947	24947	50.02
19-04-2024	8 Hrs	7413	203	311	7927	8516	413	6820	501	-1786	21943	0	21943	736	233	25146	25146	50.06
20-04-2024	23 Hrs	7172	339	289	7800	7952	345	7153	0	-1484	21277	0	21277	1117	467	24834	24834	49.92
21-04-2024	8 Hrs	6794	185	290	7269	7784	411	6395	496	-1352	20562	0	20562	620	441	23416	23416	50.01
Maximum		7981	695	379	8831	8747	562	7153	552	-1225	22176	0	22176	1117	502	25242	25242	50.06
Minimum		6794	185	287	7269	7306	280	5795	0	-1786	20562	0	20562	620	233	23289	23289	49.92
Average		7374	429	308	8110	8192	384	6369	221	-1430	21430	0	21430	793	436	24505	24505	50.00

Details of Supply Position (MUs)

Date	MSGENCO				Pench (MS)	Central Sector Receipt	Central Sector Share	WIND	CPP	SOLAR	TPCL Gen.	R-INFRA Gen.	TPCL Exch.	Energy Requirement		
	THM	HYDRO	GAS	Total										MSEDCL	MUMBAI	STATE
	Mus	Mus	Mus	Mus	Mus	Mus	Mus	Mus	Mus	Mus	Mus	Mus	Mus	Mus	Mus	Mus
15-04-2024	179.836	23.088	7.030	209.954	0.229	207.445	210.233	7.335	140.539	16.627	22.377	11.126	-42.776	528.051	76.279	615.403
16-04-2024	183.073	24.867	6.864	214.804	0.301	214.253	218.064	6.997	143.548	16.271	26.055	10.512	-43.845	541.330	80.412	632.440
17-04-2024	183.360	17.259	8.457	209.076	0.053	213.459	219.035	11.357	153.636	15.070	26.099	10.281	-45.137	546.368	81.517	638.978
18-04-2024	175.545	13.286	9.592	198.423	0.158	214.006	216.810	16.580	154.532	16.707	26.739	7.904	-46.660	542.329	81.299	634.887
19-04-2024	171.949	15.258	10.256	197.463	0.376	226.433	231.492	13.348	157.603	15.088	25.098	5.544	-49.301	549.842	79.943	640.577
20-04-2024	165.153	9.718	10.015	184.886	0.256	219.074	225.586	18.760	153.504	15.211	23.691	6.746	-44.487	535.942	74.924	621.872
21-04-2024	166.320	10.416	6.852	183.588	0.248	202.821	209.195	9.866	157.722	16.130	17.971	9.311	-37.716	521.757	64.998	597.409
Maximum	183.360	24.867	10.256	214.804	0.376	226.433	231.492	183.360	157.722	16.707	26.739	11.126	-37.716	549.842	81.517	640.577
Minimum	165.153	9.718	6.852	183.588	0.053	202.821	209.195	165.153	140.539	15.070	17.971	5.544	-49.301	521.757	64.998	597.409
Average	175.034	16.270	8.438	199.742	0.232	213.927	218.631	175.034	151.583	15.872	24.004	8.775	-44.275	537.946	77.053	625.938

Details of Koyna Water Consumption (in TMC)			
Date	For the Day	For the Month	Balance
15-04-2024	0.414	2.215	26.589
16-04-2024	0.465	2.680	26.124
17-04-2024	0.299	2.979	25.825
18-04-2024	0.205	3.184	25.620
19-04-2024	0.266	3.451	25.353
20-04-2024	0.129	3.580	25.224
21-04-2024	0.164	3.743	25.061

State Load Despatch Center,Airoli (MSETCL)
Central Sector Share/Drawal from 15/Apr/2024 to 21/Apr/2024

Date	DAY	Central Sector Share		Total Interstate		Total Share		Total Drawal		Overdrawal(+) /	
		MUs	Avg. MW	MUs	Avg. MW	MUs	Avg. MW	MUs	Avg. MW	MUs	Avg. MW
		1		2		1+2=3		4		3-4=5	
15-04-2024	MONDAY	115.940	8665	94.293	3929	210.233	8760	207.445	8644	-2.788	-116
16-04-2024	TUESDAY	108.969	8977	109.095	4546	218.064	9086	214.253	8927	-3.811	-159
17-04-2024	WEDNESDAY	112.100	9020	106.935	4456	219.035	9126	213.459	8894	-5.576	-232
18-04-2024	THURSDAY	115.421	8932	101.389	4225	216.810	9034	214.006	8917	-2.804	-117
19-04-2024	FRIDAY	113.956	9528	117.536	4897	231.492	9646	226.433	9435	-5.059	-211
20-04-2024	SATURDAY	136.387	9310	89.199	3717	225.586	9399	219.074	9128	-6.512	-271
21-04-2024	SUNDAY	101.575	8609	107.620	4484	209.195	8716	202.821	8451	-6.374	-266
Total		804.348		726.067		1530.415		1497.491		-32.924	

Generator Unit Outages/Trippings from 15.04.2024 to 21.04.2024						
Name of Unit	Date Trip	Time Trip	Date Sync	Time Sync	Reason	Outage Type
PGPL U2	07-02-2017	17.3		Continued.	No Schedule.(NO PPA)	NOPPA
PGPL U1	07-02-2017	17.3		Continued.	No Schedule (NO PPA)	NOPPA
VIPL U-1	29-12-2018	0.3		Continued.	Coal Shortage. (NO PPA From 20.05.2019)	NOPPA
VIPL U-2	17-01-2019	0.15		Continued.	Coal shortage.(NO PPA From 20.05.2019)	NOPPA
Tarapur 1	08-01-2020	10:37		Continued.	Refueling. While refueling preparation, some repair works identified which are being executed before refueling.	FORCED
Tarapur 2	13-07-2020	04:38		Continued.	For cleaning of clogged basket strainer of cooling water system due to heavy ingress of debris from sea. The outage extended for repair and re-fueling.	FORCED
Koradi Unit 7	27-04-2021	20.03		Continued.	Retired (04/08/2021 At 00.00)	FORCED
Uran Unit A0	07-09-2022	16:30		Continued.	TURBINE TRIPPED ON HIGH VIBRATIONS	FORCED
Uran Unit 5	12-11-2022	13:23	17-04-2024	18:41	Major overhaul.	PLANNED
Koyna Unit 11	10-07-2023	09:40		Continued.	Capital Overhaul	PLANNED
Uran Unit 6	07-04-2024	06:57	15-04-2024	18:19	Zero Schedule(Due to open cycle can be taken on bar as per MSEDCL requirement)	ZEROSCH/R SD
RPL(AMT) U-1	12-04-2024	05:30	15-04-2024	18:18	Bottom ash evacuation problem	FORCED
Chandrapur Unit 5	13-04-2024	00:31	16-04-2024	07:45	Excessively high DM consumption due to FD 47 and boiler side leakages.	FORCED
Adani U-3	13-04-2024	04:57	17-04-2024	07:15	APH-A inlet bellow leakage	FORCED
Ghatghar Unit-1	13-04-2024	15:00	17-04-2024	16:00	GM Link Fault	FORCED
JPL Unit 2	14-04-2024	08:49	18-04-2024	16:34	Low net sales realization. (Unit is under Forced outage from 12:00hrs of Dt.16.04.2024 due to Turbine bearing Temp. high)	ZEROSCH/R SD
Koradi Unit 6	15-04-2024	16:35	18-04-2024	21:06	Boiler Tube Leakage	FORCED
Chandrapur Unit 4	15-04-2024	17:18	18-04-2024	05:11	Boiler Tube Leakage	FORCED
Koyna STG-IV Unit-3	15-04-2024	21:20	15-04-2024	23:05	Numerical protection 32 trial tripped.	FORCED

Uran Unit 6	15-04-2024	21:30	16-04-2024	22:00	Zero Schedule(Due to open cycle can be taken on bar as per MSEDCL requirement)	NOPPA
Uran Unit 6	17-04-2024	06:47	17-04-2024	15:51	Zero schedule (due to open cycle can be taken on bar as per MSEDCL requirement).	NOPPA
Uran Unit 5	17-04-2024	19:29	17-04-2024	20:33	Excitation Fault.	FORCED
Bhusawal Unit 5	18-04-2024	00:43	18-04-2024	04:19	Condenser Vacuum low	FORCED
Uran Unit 5	18-04-2024	02:44	18-04-2024	13:55	A1 Boiler Work	FORCED
Uran Unit 6	18-04-2024	07:15	18-04-2024	13:07	Zero Sch by MSEDCL	ZEROSCH/R SD
AEML Unit 2	18-04-2024	10:52	20-04-2024	15:56	Boiler Tube Leakage	FORCED
Bhusawal Unit 4	18-04-2024	22:33		Continued.	Boiler Tube Leakage	FORCED
Uran Unit 6	19-04-2024	07:01	19-04-2024	09:38	Zero Sch Given by MSEDCL	ZEROSCH/R SD
Uran Unit 5	19-04-2024	07:20	19-04-2024	12:46	Zero Sch Given by MSEDCL	ZEROSCH/R SD
Chandrapur Unit 8	19-04-2024	11:15	21-04-2024	23.34	Boiler Tube Leakage	FORCED
Uran Unit 6	20-04-2024	20:11	21-04-2024	23:47	Zero Schedule given by MSEDCL	ZEROSCH/R SD
Uran Unit 5	20-04-2024	20:34	22-04-2024	00:28	Zero Schedule given by MSEDCL	ZEROSCH/R SD
Koyna STG-IV Unit-4	21-04-2024	21:45	22-04-2024	00:25	Tripped on Gov. Rupture bolt fault	FORCED
Koradi Unit-10	21-04-2024	23:14		Continued.	USPECTED MSV DRAIN LINE LEAKAGE	FORCED
Chandrapur Unit 8	21-04-2024	23:48		Continued.	Generator Elect. Fault	FORCED

Transmission Line Outages/Trippings from 15.04.2024 to 21.04.2024

Name of Line	Date Trip	Time Trip	Date Sync	Time Sync	Reason	Outage Type	Voltage
765/400kV 1500MVA ICT @ AKOLA 2	14-04-2024	10:17	15-04-2024	03:41	Insulation Coating of 33KV Tertiary yard	PO	765 KV
TIE BAY (705) OF ICT - 2 & BUS REACTOR @ KORADI 3	15-04-2024	10:38	15-04-2024	17:11	Annual Maintenance of CB at Koradi-III SS.	PO	765 KV
TIE BAY (702) OF 765/21KV GT-4 and 765/400KV ICT (HV Side) @ TIRORA	16-04-2024	12:43	16-04-2024	16:37	CT OIL SAMPLE COLLECTION FOR DGA	PO	765 KV
TIRORA - KORADI 3 CKT - 1	19-04-2024	12:26	19-04-2024	16:53	CT OIL SAMPLE COLLECTION FOR DGA	PO	765 KV
SOLAPUR (PG) - PUNE (GIS)	20-04-2024	14:33	20-04-2024	16:12	Line tripped on distance protection.	HT	765 KV
TIRODA - KORADI 3 CKT - 2	20-04-2024	10:06	20-04-2024	15:29	CT Oil Sample Collection for DGA	PO	765 KV
CHANDRAPUR - PADGHE HVDC POLE 2	18-04-2024	22:50	19-04-2024	06:11	To attend defects and cleaning of polluted insulator strings in Naneghat section	PO	500 KV
AURANGABAD(MS) - PUNE (GIS) CKT - 2	28-03-2024	23:52	16-04-2024	20:55	For load management of Talegaon Chakan line	HT	400 KV
PADGHE - KALWA CKT - 1	12-04-2024	13:58	17-04-2024	04:56	1.B Bus PG Isolator replacement work under LES Scheme. 2. 400kV Kalwa-I in service through TBC. 3.CB Diagnostic Testing Work.	PO	400 KV
MAIN BUS - 2 @ PADGHE	13-04-2024	12:40	15-04-2024	17:49	1.Replacement of Hanger Assembly of B Bus PG Isolator of Kalwa-1 by hot line method. 2. All feeders on B Bus will be in service.	PO	400 KV
NEW KOYNA-KARAD CKT - 1	15-04-2024	12:10	15-04-2024	20:43	Diagnostic testing & Relay testing work , Routine maint. Work & B bus isolatar IPS tube extension work	PO	400 KV
400/220/20 KV 100 MVA SPARE BHEL ICT @ KORADI	15-04-2024	08:05	15-04-2024	16:57	For replacement of 29D isolator drive mechanism & alignment works. Other routine maintenance works.	PO	400 KV

Transmission Line Outages/Trippings from 15.04.2024 to 21.04.2024

Name of Line	Date Trip	Time Trip	Date Sync	Time Sync	Reason	Outage Type	Voltage
TIE BAY (402) OF 400/21KV GT-1 and 765/400KV ICT (LV Side) @ TIRORA	15-04-2024	16:34	15-04-2024	18:06	CT OIL SAMPLE COLLECTION FOR DGA	PO	400 KV
CHANDRAPUR 2 - CHD SWITCHING CKT - 2	16-04-2024	18:24	17-04-2024	01:43	Diagnostic testing and allied bay Maintenance work	PO	400 KV
400/220 KV 315MVA ICT - 2 @ KARAD	16-04-2024	17:41	17-04-2024	01:44	Replacement of MOG & Buchholz relay of R Phase Unit. Diagnostic testing work of ICT-1	PO	400 KV
400/220/33 KV 500MVA ICT - 2 @ KORADI 2	16-04-2024	10:39			To attend NDR alarm		400 KV
400/220KV 105 MVA SPARE ICT @ KHADKA	16-04-2024	09:00	16-04-2024	12:00	For premonsoon maintenance and routine maintenance works.	PO	400 KV
TIE BAY (408) OF WARORA CKT - 2 AND ST - 2 @ TIRORA	16-04-2024	17:27	16-04-2024	18:55	CT OIL SAMPLE COLLECTION FOR DGA	PO	400 KV
CHANDRAPUR-PARLI CKT-3	17-04-2024	19:01	18-04-2024	00:39	Heavy sparking observed. y ph cvt jumper open.	T	400 KV
PADGHE - KALWA CKT - 1	17-04-2024	00:55	17-04-2024	04:56	Emergency outage availed for hotspot attending work	HT	400 KV
PARLI - KUMBHARGAON(NANDED) CKT - 2	17-04-2024	19:55	18-04-2024	10:55	Heavy sparking observed.	T	400 KV
400/220/20 KV 500MVA ICT - 3 @ KALWA	17-04-2024	05:22	17-04-2024	06:22	Emergency outage availed for hot spot attending work	HT	400 KV
400/220/33 KV 315 MVA ICT - 1 @ PARLI	17-04-2024	19:00	17-04-2024	21:16	Heavy sparking observed , heavy rains,lightening and storm at parly.	T	400 KV
400/220/33 KV 500 MVA ICT - 3 @ PARLI	17-04-2024	20:13	17-04-2024	22:42	Only lv cb tripped on PDR.	HT	400 KV
400/220/33 KV 500 MVA ICT - 3 @ PARLI	17-04-2024	22:47	18-04-2024	03:29	Tripped on pdr from lv side only.	HT	400 KV
400/220/33 KV 500MVA ICT - 2 @ KORADI 2	17-04-2024	10:39			To attend NDR alarm		400 KV
AURANGABAD(MS) - PUNE (GIS) CKT - 2	17-04-2024	03:46	17-04-2024	19:42	H/T for load management	HT	400 KV
PARLI - KARJAT CKT - 2	17-04-2024	14:55	17-04-2024	15:49	D/P,Z1,YPH,3.63KA,107KM	T	400 KV

Transmission Line Outages/Trippings from 15.04.2024 to 21.04.2024

Name of Line	Date Trip	Time Trip	Date Sync	Time Sync	Reason	Outage Type	Voltage
PARLI - KARJAT CKT - 2	17-04-2024	20:17	18-04-2024	00:17	Tripped on o/v	HT	400 KV
PARLI - KARJAT CKT - 2	17-04-2024	19:07	17-04-2024	20:09	Tripped on o/v.	T	400 KV
PARLI - KUMBHARGAON (NANDED) CKT - 1	17-04-2024	19:31	18-04-2024	10:48	Heavy sparking observed.	T	400 KV
TIE BAY (405) OF WARORA CKT - 1 & STN TF - 1 @ TIRORA	17-04-2024	16:36	17-04-2024	18:52	CT OIL SAMPLE COLLECTION FOR DGA	PO	400 KV
400/132 KV 200 MVA ICT - 2 @ KHADKA	18-04-2024	08:24	18-04-2024	16:05	For ICT premonsoon maintenance works and Dignostic testing works.	PO	400 KV
400/220/33 KV 500 MVA ICT - 3 @ WALUJ	18-04-2024	11:30	18-04-2024	13:30	Tripped on Bucholz.	T	400 KV
400/220/33 KV 500 MVA ICT - 3 @ WALUJ	18-04-2024	11:30	18-04-2024	13:30	Tripped on YPH buchholz.	T	400 KV
AURANGABAD(MS) - PUNE (GIS) CKT - 1	18-04-2024	06:08	18-04-2024	13:39	Control line loading.	T	400 KV
AURANGABAD(MS) - PUNE (GIS) CKT - 1	18-04-2024	06:08	18-04-2024	13:02	H/T for load management	T	400 KV
AURANGABAD(MS) - PUNE (GIS) CKT - 2	18-04-2024	13:08	18-04-2024	19:58	Line tripped on distance protection.	T	400 KV
LONIKAND - JEJURI CKT - 2	18-04-2024	21:55	19-04-2024	02:18	Auto reclosure trials to be taken to ensure the healthiness of AR	PO	400 KV
PARLI - KARJAT CKT - 1	18-04-2024	02:41	18-04-2024	10:08	R-ph Ia broken at bottam stag and hanging needed to be replaced.	T	400 KV
KARAD - TALANDGE CKT - 1	19-04-2024	17:40	19-04-2024	18:59	Tripped at Kolhapur end only	T	400 KV
400/220/33 KV 500 MVA ICT - 3 @ KOLHAPUR	19-04-2024	17:37	19-04-2024	18:53	Tripped on NDR protection	T	400 KV
AURANGABAD(MS) - AURANGABAD(PG) CKT -2	19-04-2024	12:55	19-04-2024	19:58	Work at PG End.		400 KV
AURANGABAD(MS) - PUNE (GIS) CKT - 1	19-04-2024	08:53	20-04-2024	15:14	For load management on 400 KV Talegaon - Chakan line.	HT	400 KV
DEEPNAGAR - THAPTI TANDA	19-04-2024	06:21	20-04-2024	20:48	For string replacement work	PO	400 KV
DEEPNAGAR - THAPTI TANDA	19-04-2024	06:18	19-04-2024	19:45	Replacement of faulty disc insulators by LRP strings	PO	400 KV
MAIN BAY (412) OF STATION TF 4 @ TIRORA	19-04-2024	15:58	19-04-2024	18:12	CT OIL SAMPLE COLLECTION FOR DGA	PO	400 KV

Transmission Line Outages/Trippings from 15.04.2024 to 21.04.2024

Name of Line	Date Trip	Time Trip	Date Sync	Time Sync	Reason	Outage Type	Voltage
PARLI - KARJAT CKT - 2	19-04-2024	13:10	19-04-2024	13:59	Line tripped on distance protection.	HT	400 KV
CHANDRAPUR 2 - CHD SWITCHING CKT - 2	20-04-2024	13:01	20-04-2024	16:58	For conductor hardware tightening fitting work	PO	400 KV
DHULE - KHANDWA CKT - 1	20-04-2024	09:58	20-04-2024	23:11	Simultaneous outage of TIE BAY - 400KV-KHANDWA-DHULE-MS-1 , 400KV-KHANDWA-DHULE-MS-1 and 400KV/220KV KHANDWA-ICT-1 is required for LBB retrofitting work, Line Outage, Dia to be kept opened at both end, and Line-2 Auto Recloser Non-auto Mode	PO	400 KV
400/220/33 KV 500 MVA ICT - 3 @ WALUJ	20-04-2024	18:40	20-04-2024	20:45	Tripped on NDR	T	400 KV
400/220/33 KV 500MVA ICT - 2 @ DEEPNAGAR	20-04-2024	06:02	20-04-2024	13:31	For Pre-monsoon Maintenance work in all aspect with Tan delta testing of Bushings, Windings & MV Side CTs & both HV & MV Bay maintenance work to be carried out.	PO	400 KV
AURANGABAD(MS) - AURANGABAD(PG) CKT -2	20-04-2024	18:43	21-04-2024	02:39	LINE TRIPPED ON DISTANCE PROTECTION.	T	400 KV
DEEPNAGAR - THAPTI TANDA	20-04-2024	06:48	20-04-2024	20:48	Replacement of faulty disc insulators by LRP strings	PO	400 KV
PARLI - KARJAT CKT - 2	20-04-2024	15:57	20-04-2024	16:41	Line tripped on distance protection.	T	400 KV
TIE BAY (411) OF 400/21KV GT-2 and 400/11.5KV ST-4 @ TIRORA	20-04-2024	17:28	20-04-2024	19:23	CT OIL SAMPLE COLLECTION FOR DGA		400 KV
400/220 KV 500MVA ICT - 4 @ KALWA	21-04-2024	04:52	21-04-2024	08:10	Hotspot attending of B ph HV(92 Degree) bushing,Y Ph HV CT(102Degree) Pad, LV CT Pad(128)	PO	400 KV
AURANGABAD(MS) - PUNE (GIS) CKT - 1	21-04-2024	08:14			H/T For load Management	HT	400 KV
DEEPNAGAR - THAPTI TANDA	21-04-2024	06:05	21-04-2024	18:34	Replacement of faulty disc insulators by LRP strings	PO	400 KV

Transmission Line Outages/Trippings from 15.04.2024 to 21.04.2024

Name of Line	Date Trip	Time Trip	Date Sync	Time Sync	Reason	Outage Type	Voltage
URAN - KHARGHAR 2	14-02-2024	08:41	19-04-2024	20:33	For making LILO of 220kV cable at 220kV Ulwe GIS & Waghiwali & Retrofitting of "DIFF" relay at 400kV KHARGHAR s/s.	PO	220 KV
BOISAR - VERSOVA	09-04-2024	22:53	20-04-2024	12:40	Shifting of Lines on Newly constructed Towers for DFCCIL 1. Bunching of lines will be done on Tower no 82.		220 KV
DAHANU - VERSOVA	09-04-2024	22:49	20-04-2024	13:06	Shifting of Lines on Newly constructed Towers for DFCCIL 1. Bunching of lines will be done on Tower no 82.	PO	220 KV
BHUGAON - WARDHA (PG)	15-04-2024	10:37	15-04-2024	21:31	Routine line maintenance work	PO	220 KV
MIRAJ - ICHALKARANJI	15-04-2024	17:22	15-04-2024	21:24	1)For load management , 220KV Miraj Circuit Kept off for 220KV Talandage Circuit-1	PO	220 KV
NIGADE- PETH LINE	15-04-2024	11:24	15-04-2024	17:52	CT Replacement Work of R,Y & B Ph	PO	220 KV
PADGHE - TEMGHAR - 1	15-04-2024	16:05	17-04-2024	23:12	Permission for shifting on TBC for Replacement of 245kV CB of 220kV Padghe- Temghar-1 line under project work	PO	220 KV
TALANDGE - ICHALKARANJI 2	15-04-2024	17:24	15-04-2024	21:22	1) For Quarterly bay maintenance work. 2) Attending hotspots & Equipement testing work	PO	220 KV
TALEGAON (AMBI)-TALEGAON (PG) CKT 1	15-04-2024	15:00	15-04-2024	15:37	Tripped on distance protection	T	220 KV
200 MVA 220/132 KV ICT - 1 @ VIRODA	15-04-2024	15:00	15-04-2024	19:31	FOR 220 KV BUS 1 ISOLATOR MAINTENANCE WORK	PO	220 KV
220 KV BUS COUPLER	15-04-2024	17:32	15-04-2024	19:04	FOR 220 KV BUS 1 ISOLATOR MAINTENANCE WORK	PO	220 KV

Transmission Line Outages/Trippings from 15.04.2024 to 21.04.2024

Name of Line	Date Trip	Time Trip	Date Sync	Time Sync	Reason	Outage Type	Voltage
220 KV PARAS - MALKAPUR CKT	15-04-2024	10:19	15-04-2024	14:17	FOR REPLACEMENT OF DAMAGED INSULATOR DISC AT LOC NO 137 (DTN) R-PHASE UNDER EHV LINE MAINTENANCE SUB DIVISION, KHAMGAON	PO	220 KV
220/132 KV 200 MVA ICT 2	15-04-2024	10:32	15-04-2024	16:35	FOR DIGNOSTIC TESTING WORK BY MOBILE TESTING UNIT AKOLA AND CTR MAKE NIFPS PROTECTION TRIALS AND MAINTENANCE AND ICT PREMANSOON MAINTENANCE WORK.	PO	220 KV
220/132-110KV 100MVA PTR 2 @ WATHAR	15-04-2024	09:10	15-04-2024	18:49	1) Quarterly maintenance work 2) Diagnostic testing work	PO	220 KV
220/132KV 100MVA PTR 1 @ KHAREPATAN	15-04-2024	08:20	15-04-2024	13:04	For 1)Isolator alignment & maintenance. 2)Bay equipment cold washing.	PO	220 KV
220/22 KV 50 MVA PTR 1 @ PADGHE	15-04-2024	09:23	15-04-2024	12:13	Shifting of 220/22kv 50MVA BHEL TF on TBC for replacement of Y Phase Jaw Due to burnt during Sparking.	PO	220 KV
220/33 kv 50 MVA CGL PTR 1 @ MUDSHINGI	15-04-2024	08:20	15-04-2024	12:05	"Transformer painting work." "	PO	220 KV
220 KV DEEPNAGAR - VIRODA	15-04-2024	16:36	15-04-2024	19:20	LINE MAINT	PO	220 KV

Transmission Line Outages/Trippings from 15.04.2024 to 21.04.2024

Name of Line	Date Trip	Time Trip	Date Sync	Time Sync	Reason	Outage Type	Voltage
GHODBUNDER - MSETCL BOISAR	15-04-2024	14:20	15-04-2024	18:00	Tripped on overcurrent	T	220 KV
KEKATNIMBHORA - CHALISGAON CKT	15-04-2024	15:04	15-04-2024	17:41	CHALIS= D/P YPH BPH 3.47KM IY 9.47KA, IB 8.212KA	T	220 KV
NARANGWADI - SOLAPUR PG CKT - 1	15-04-2024	09:55	15-04-2024	20:20	Flashover String replacement at Loc no.187 R Ph, Pilot String clamp fixing at Loc no. H1-Y Ph, 239 - Y & B Ph	PO	220 KV
PHALTAN MIDC - SWARAJ CO GEN	15-04-2024	09:26	15-04-2024	14:42	1.Relay Testing Work 2.Diagnostic Testing Work 3.Quarterely Maintenance Work	PO	220 KV
POPHALI - KDPH	15-04-2024	11:30	15-04-2024	19:09	For installation of OPGW from tower loc no. 1 to 11 of 220kV KDPH LILO line.	PO	220 KV
TATA BORIVLI MSETCL BORIVLI - 5	15-04-2024	00:04	15-04-2024	02:57	Cleaning & paint applying on porcelain insulator strings at Gantry Structure MSETCL Borivali end as observed heavy corona discharge on insulator string.	PO	220 KV
TBC @ PAL-DOMBIVALI-220 kV	15-04-2024	10:10	15-04-2024	13:31	CB Diagnostic & RM Work	PO	220 KV
APTA - TALOJA	16-04-2024	05:47	16-04-2024	13:22	Fitting of cross arm and Stringing of conductor between Loc no. 638 to 639 on new erected tower for height raising work at Taloja MIDC road crossing.	PO	220 KV
BORIVALI - TARAPUR	16-04-2024	12:44	16-04-2024	16:05	tripped on overcurrent protection again	T	220 KV
BORIVALI - TARAPUR	16-04-2024	11:45	16-04-2024	12:15	tripped on overcurrent protection	T	220 KV
KANDALGAON - PIRANGUT	16-04-2024	09:16	16-04-2024	15:25	Tripped on distance protection	T	220 KV
WARDHA-YEOTMAL	16-04-2024	09:10	16-04-2024	17:05	Restranging of loose span	PO	220 KV
220/132 KV 100 MVA ICT 2	16-04-2024	10:04	16-04-2024	18:13	LV side R Phase CT to Stub Bus Jumpering work	PO	220 KV
220/132 KV 200 MVA ICT 2 @ MALEGAON	16-04-2024	09:10	16-04-2024	20:12	Testing and R.M.work	PO	220 KV

Transmission Line Outages/Trippings from 15.04.2024 to 21.04.2024

Name of Line	Date Trip	Time Trip	Date Sync	Time Sync	Reason	Outage Type	Voltage
220/132/11 KV 200 MVA ICT 1 @ AMRAVATI	16-04-2024	08:37	16-04-2024	16:55	Testing work	PO	220 KV
220/33KV 50MVA BBL T/F @ OGLEWADI	16-04-2024	08:21	16-04-2024	19:21	1.Oil Leakage attending Work 2.TF Painting Wprk	PO	220 KV
GHODBUNDER - MSETCL BOISAR	16-04-2024	10:28	17-04-2024	02:14	tripped on overcurrent protection	T	220 KV
KARAD - VITA CKT- 1	16-04-2024	00:32	16-04-2024	01:33	Line tripped on distance protection	T	220 KV
NARANGWADI - SOLAPUR PG CKT - 2	16-04-2024	10:56	16-04-2024	18:43	Pilot string clamp fixing	PO	220 KV
NARANGWADI - SOLAPUR PG CKT - 2	16-04-2024	10:56	16-04-2024	18:43	Pilot String clamp fixing at Loc no.226 -R ph, H6-Y pH, H2-Y ph, 192- Y Ph	PO	220 KV
PEDAMBE-KALAMBANI(TSS)	16-04-2024	12:47	16-04-2024	19:35	For cold washing of insulator strings, monkey patrolling and other line maintenance work.	PO	220 KV
RANJANGAON - U TECH SUGAR CKT	16-04-2024	18:55	16-04-2024	22:27	Tripped on distance protection.	T	220 KV
ABHIJEET-WARDHA-1	17-04-2024	12:57	17-04-2024	13:26	D/P,Z1,BPH,1.7KA.	T	220 KV
APTA - TALOJA	17-04-2024	06:28	17-04-2024	11:32	Fitting of bottom phase cross arm and Stringing of conductor between Loc no. 638 to 639 on new erected tower for height raising work at Taloja MIDC road crossing.	PO	220 KV
BORIVALI - TARAPUR	17-04-2024	12:04	17-04-2024	13:14	Tripped on overcurrent protection	T	220 KV
BORIVALI - TARAPUR	17-04-2024	14:25	17-04-2024	17:28	Tripped on overcurrent protection	T	220 KV
BUTIBORI 3-PURTI	17-04-2024	08:56	17-04-2024	10:43	Removal of street light pole , legally erected by midc between loc no. 194-195.	HT	220 KV
KANDALGAON - KOYNA (POPHALI)	17-04-2024	06:09	17-04-2024	08:09	Urgent tree cutting spans observed in ground patrolling Loc 297-298-299	PO	220 KV
MIRAJ - MHAISHAL	17-04-2024	16:32	17-04-2024	22:14	Replacement of Cross Arm at Loc no.10 B Ph and Insulators	PO	220 KV
PARLI NEW TPS - BEED CKT 2	17-04-2024	10:30	17-04-2024	19:45	Replacement work of distance protection relay.	HT	220 KV

Transmission Line Outages/Trippings from 15.04.2024 to 21.04.2024

Name of Line	Date Trip	Time Trip	Date Sync	Time Sync	Reason	Outage Type	Voltage
PUSAD - HINGOLI	17-04-2024	19:08	17-04-2024	22:20	DIST. P[ROTN OPTED B PH 35.2.985KA H-B PH 25.54KM 2.693KA.	T	220 KV
132 KV JALGAON JAMOD - BALAPUR - CKT 1	17-04-2024	11:08	17-04-2024	12:17	Flashover disc replacement at 215 r-ph.	HT	220 KV
132 KV MAIN BUS SECT. 1	17-04-2024	21:23	17-04-2024	22:05	Tripped on 220kv tuljapur-lamboti stand by ckt fault. ckt tripped on dist prot R H, Z1, 9.4 KM, 1.4 KA.	T	220 KV
132KV GIRAWALI(220KV)-PARLI(132KV) CKT 2	17-04-2024	19:00	17-04-2024	21:00	Tripped.	T	220 KV
220/132 KV 100 MVA ICT 1	17-04-2024	21:23	17-04-2024	22:07	Tripped on 220kv tuljapur-lamboti stand by ckt fault. ckt tripped on dist prot R H, Z1, 9.4 KM, 1.4 KA.	T	220 KV
220/132 KV 100 MVA ICT 1 @ PHALTAN MIDC	17-04-2024	09:10	17-04-2024	15:55	1.Relay Testing Work 2.Diagnostic Testing Work 3.Quarterly Maintenance Work	PO	220 KV
220/22 KV 50 MVA PTR 1 @ PAL-DOMBIVALI	17-04-2024	09:55	17-04-2024	12:20	CB Diagnostic & RM Work.	PO	220 KV
220/33 KV 50 MVA PTR 1	17-04-2024	21:23	17-04-2024	22:11	Tripped on 220kv tuljapur-lamboti stand by ckt fault. ckt tripped on dist prot R H, Z1, 9.4 KM, 1.4 KA.	T	220 KV
GHODBUNDER - MSETCL BOISAR	17-04-2024	09:39	18-04-2024	01:57	Tripped on overcurrent protection	T	220 KV
LAMBOTI - TULJAPUR CKT - 1	17-04-2024	21:23	17-04-2024	22:00	Tripped on 220kv tuljapur-lamboti stand by ckt fault. ckt tripped on dist prot R H, Z1, 9.4 KM, 1.4 KA.	T	220 KV
LAMBOTI - TULJAPUR CKT - 2	17-04-2024	21:23	17-04-2024	22:02	Tripped on 220kv tuljapur-lamboti stand by ckt fault. ckt tripped on dist prot R H, Z1, 9.4 KM, 1.4 KA.	T	220 KV
PARLI (OLD GCR) - PARLY (PG) CKT 1	17-04-2024	19:00	18-04-2024	01:39	PLY --> B PH, 24.74KM ,6.35KA.	T	220 KV
PARLI (OLD GCR) - PARLY (PG) CKT 1	17-04-2024	11:55	17-04-2024	15:30	D/P,Z1,11.55KM,7.7KA,BPH.	T	220 KV
PARLI 3(OLD GCR)-PARLI NEWTPS CKT 1	17-04-2024	19:00	18-04-2024	01:39	Tripped.	T	220 KV

Transmission Line Outages/Trippings from 15.04.2024 to 21.04.2024

Name of Line	Date Trip	Time Trip	Date Sync	Time Sync	Reason	Outage Type	Voltage
PEDAMBE-KALAMBANI(TSS)	17-04-2024	12:50	17-04-2024	18:33	For cold washing of insulator strings, monkey patrolling and other line maintenance work.	PO	220 KV
VITA WAIPHALE	17-04-2024	18:14	18-04-2024	04:02	Tripped on distance protection.	T	220 KV
AKOLA-PARAS CKT NO-I	18-04-2024	09:25	18-04-2024	19:03	Bus 1 and line isolator overhauling and jaw replacement work of 220 kv paras-akola i bay at 220 kv paras ss.	HT	220 KV
BORIVALI - TARAPUR	18-04-2024	12:13	18-04-2024	22:33	Line tripped on Overcurrent.	T	220 KV
CHALISGAON -BABHALESHWAR	18-04-2024	13:02	18-04-2024	18:32	Work at BBLSR end.	HT	220 KV
CHALISGAON -BABHALESHWAR	18-04-2024	13:00	18-04-2024	18:19	Distance,B/U,CT,Tan Delta,LBB Relay	PO	220 KV
PARLI NEW TPS - BEED CKT 2	18-04-2024	17:27	18-04-2024	21:02	Attending work of distance protection relays for enabling auto reclose function.	T	220 KV
220 KV JALNA - THAPTITANDA CKT - I	18-04-2024	10:20	18-04-2024	18:27	Replacement of faulty strings found flashover at loc. no.162rph,172rph & 196cp rph.	HT	220 KV
220/132 KV 100 MVA ICT 1 @ LONIKAND 2	18-04-2024	10:01	18-04-2024	16:55	For Half yearly maint. & diag testing work	PO	220 KV
220/132 KV 100 MVA ICT 2 @ LONIKAND 2	18-04-2024	17:13	18-04-2024	19:08	For Half yearly maint. & diag testing work.	PO	220 KV
220/33 KV 50 MVA PTR 2 @ HAMIDWADA	18-04-2024	17:15	18-04-2024	20:10	Maintenance work & Attending oil leakage in 33KV CT.	PO	220 KV
ALKUD - VITA	18-04-2024	17:55	18-04-2024	23:39	Polymer Insulator Replacement Work	PO	220 KV
CHINCHWAD-2 - TELCO	18-04-2024	13:41	18-04-2024	18:19	Half Yearly Maintenace, CT C tan delta work, CB timing testing, CB CRM testing, Attending hot spot of Y Phase Wave Trap (109đC).	PO	220 KV
GHODBUNDER - MSETCL BORIVALI	18-04-2024	08:53	18-04-2024	11:19	Line hand tripped for load management of 220 kv Boisar - Ghodbunder line.	T	220 KV
GHODBUNDER - MSETCL BOISAR	18-04-2024	11:15	18-04-2024	20:56	Line tripped on Overcurrent.	T	220 KV

Transmission Line Outages/Trippings from 15.04.2024 to 21.04.2024

Name of Line	Date Trip	Time Trip	Date Sync	Time Sync	Reason	Outage Type	Voltage
JEJURI (400kV) - LONAND CKT - 1	18-04-2024	10:54	18-04-2024	18:47	LA Replacement Work	PO	220 KV
SALSETTE BORIVLI - 1	18-04-2024	00:27	18-04-2024	02:10	Protection Testing and Trial Operations in isolated conditions	PO	220 KV
TROMBAY - VIKHROLI (GIS) CKT - 2	18-04-2024	00:56	18-04-2024	04:01	for attending hot spot at location 13, Mahul creek near to Trombay.	PO	220 KV
TROMBAY DHARAVI - 5	18-04-2024	00:55	18-04-2024	04:17	Work in vicinity for 220KV Trombay KVTL 2 line work	PO	220 KV
VANKUSWADE - KDPH	18-04-2024	14:30	18-04-2024	19:20	Quarterly Maintenance Work	PO	220 KV
AKOLA-PARAS CKT NO-I	19-04-2024	11:48	19-04-2024	18:37	Bus 1 & line isolator overhauling & jaw replacement work of 220kV Paras-Akola 2 bay at 220kV Paras ss.		220 KV
AKOLA-PARAS CKT NO-II	19-04-2024	11:48	19-04-2024	18:37	Isolator alignment work.	PO	220 KV
BORIVALI - TARAPUR	19-04-2024	14:23	19-04-2024	17:23	Tripped on overcurrent protection	T	220 KV
KHAREPATAN -PAWAS LINE	19-04-2024	09:27	19-04-2024	15:41	For carrying out insulator cleaning in 220kV Bus Section I and Wave trap & CT gantry beam for 220kV Pawas Kharepatan line bay at 220kV Pawas S/s.	PO	220 KV
TALANDGE - BIDRI	19-04-2024	17:37	19-04-2024	21:18	Tripped on R ph to ground fault	T	220 KV
220/22-22 KV 50 MVA PTR 3 @ ANANDNAGAR	19-04-2024	06:24	19-04-2024	07:00	For inspection of oil leakage	PO	220 KV
220/33 KV 50 MVA PTR 1 @ MALEGAON	19-04-2024	07:58	19-04-2024	10:36	For TF Diagnostic testing work	PO	220 KV
220/33 KV 50 MVA PTR 2 @ MALEGAON	19-04-2024	10:40	19-04-2024	13:10	For TF Diagnostic testing work.	PO	220 KV
220/33 KV 50 MVA T/F 3 @ MALEGAON	19-04-2024	14:06	19-04-2024	15:53	For TF Diagnostic testin work.	PO	220 KV
CHINCHWAD-2 - TELCO	19-04-2024	11:50	19-04-2024	12:42	For load management.	HT	220 KV

Transmission Line Outages/Trippings from 15.04.2024 to 21.04.2024

Name of Line	Date Trip	Time Trip	Date Sync	Time Sync	Reason	Outage Type	Voltage
DAHANU - GHODBUNDER CKT - 2	19-04-2024	22:45	20-04-2024	05:17	Shifting of Lines on Newly constructed Towers for DFCCIL 1. Connection of Jumpers 192A (Virar) 2. De-Bunching between LS & SS Lines - Virar & Vasai area.	PO	220 KV
FLAGSHIP-CHINCHWAD	19-04-2024	08:22	19-04-2024	18:47	C.B POLE Overhauling work & Half Yearly Maint,D.T	PO	220 KV
GHODBUNDER - MSETCL BORIVALI	19-04-2024	10:12	19-04-2024	12:59	To control line loading on 220 Kv MSETCL Boisar- AEML Ghodbunder	T	220 KV
GHODBUNDER - MSETCL BOISAR	19-04-2024	12:54	19-04-2024	20:20	Line tripped on Overcurrent.	HT	220 KV
KHARGHAR - ULWE GIS CKT-1	19-04-2024	15:22			Wavetrap uncoiled at Kharghar end	T	220 KV
MALHARPETH SATARA MIDC	19-04-2024	09:33	19-04-2024	15:07	Replacement of Polymer Insulator String by AF	PO	220 KV
Main Bus Section-1 @ JAMBHUL- 220 KV	19-04-2024	11:59			220kV Main Bus Jumpering Work	PO	220 KV
PAWAS - FINOLEX CKT - 2	19-04-2024	09:52	19-04-2024	15:10	For carrying out insulator cleaning in 220kV Bus Section I and Wave trap & CT gantry beam for 220kV Pawas Kharepatan line bay at 220kV Pawas S/s.	PO	220 KV
BOISAR - VERSOVA	20-04-2024	08:59	20-04-2024	13:54	Shifting of Lines on Newly constructed Towers for DFCCIL 1. De-Bunching of lines will be done on Tower no 82	PO	220 KV
KHAPARKHEDA-AMBAZARI-I	20-04-2024	09:13	20-04-2024	12:32	Diagnostic testing work of CT, CB, at 220kV Ambazari s/s.	PO	220 KV
POPHLI PEDHMBE LINE- 1	20-04-2024	22:40	20-04-2024	23:20	while withdrawing unit no.9 LBB operated due to CB pole stuck of Unit 9	T	220 KV
TALANDGE - SAWANTWADI	20-04-2024	09:27	20-04-2024	13:04	Replacement of flashover insulator	PO	220 KV
220 / 110 / 22kV 250MVA ICT 1 @ BORIVALI (TATA)	20-04-2024	08:45	20-04-2024	19:57	R/M AND TESTING	PO	220 KV

Transmission Line Outages/Trippings from 15.04.2024 to 21.04.2024

Name of Line	Date Trip	Time Trip	Date Sync	Time Sync	Reason	Outage Type	Voltage
220/132 KV 100 MVA ICT 1 @ BHENDA	20-04-2024	18:16	20-04-2024	20:02	For attending red hot at; 1. ICT 1 R phase CT (P1 side) Temp 77 c(image no 18616) 2. ICT-1 Y phase CT (PT Side) Temp 105 C (Image no 18618) 3. ICT-1 Y phase CT (P1 side) Temp 70 C (Image no. 18620)	PO	220 KV
220/132 KV 200 MVA ICT 3	20-04-2024	15:42	20-04-2024	17:24	Attending heavy oil leakage from HV side 220kV R phase bushing turret.		220 KV
220/132 KV 200 MVA ICT 2 @ CHALISGAON	20-04-2024	10:18	20-04-2024	14:35	Replacement of faulty differential relay by testing unit	PO	220 KV
220/33 KV 25 MVA PTR - 2 @ PHALTAN MIDC	20-04-2024	09:20	20-04-2024	14:50	For transformer winding tan delta testing	PO	220 KV
220/33KV 25MVA PTR 2 @ PAWAS	20-04-2024	09:23	20-04-2024	16:48	For carrying out insulator cleaning work in 220kV Main Bus Section II at 220kV Pawas S/s.	PO	220 KV
220/33KV 25MVA PTR 1 @ PAWAS	20-04-2024	09:23	20-04-2024	16:48	For carrying out insulator cleaning work in 220kV Main Bus Section II at 220kV Pawas S/s.	PO	220 KV
220KV HARANGUL ICL CKT	20-04-2024	16:17	20-04-2024	17:48	D/P Z1 A/R Lockout R PH IR 5.5KA	T	220 KV
AMRAPUR - TAPTITANDA CKT - 2	20-04-2024	19:30	20-04-2024	21:51	Work at Amrapur end.	PO	220 KV
DAHANU - GHODBUNDER CKT - 1	20-04-2024	05:26	20-04-2024	08:49	Shifting of Lines on Newly constructed Towers for DFCCIL 1. Connection of Jumpers 192, 192A & 228A (Virar & Vasai) 2. De-Bunching between LS & SS Lines - Virar & Vasai area.	PO	220 KV
DAHANU - VERSOVA	20-04-2024	08:59	20-04-2024	13:06	Shifting of Lines on Newly constructed Towers for DFCCIL 1. De-Bunching of lines will be done on Tower no 82.	PO	220 KV

Transmission Line Outages/Trippings from 15.04.2024 to 21.04.2024

Name of Line	Date Trip	Time Trip	Date Sync	Time Sync	Reason	Outage Type	Voltage
MAIN BUS SECTION - 1 @ PEDAMBE	20-04-2024	22:40	20-04-2024	23:40	while withdrawing unit no.9 LBB operated due to CB pole stuck of Unit 9	T	220 KV
NEW KOYNA - PEDAMBE	20-04-2024	22:40	20-04-2024	23:33	while withdrawing unit no.9 LBB operated due to CB pole stuck of Unit 9	T	220 KV
NIWALI - PAWAS LINE	20-04-2024	09:38	20-04-2024	17:12	For carrying out insulator cleaning work in 220kV Main Bus Section II at 220kV Pawas S/s.	PO	220 KV
PAWAS - FINOLEX CKT - 1	20-04-2024	09:45	20-04-2024	16:32	For carrying out insulator cleaning work in 220kV Main Bus Section II at 220kV Pawas S/s.	PO	220 KV
WARORA-BHUGAON CKT - 2	20-04-2024	09:12	20-04-2024	20:06	Line maintenance and Diagnostic testing work.	PO	220 KV
220 / 105 / 33kV 250 MVA ICT 7 @ DHARAVI	21-04-2024	09:35	21-04-2024	16:04	R/M, PM checks, device trials, LT cable box inspection	PO	220 KV
KHAREPATAN -PAWAS LINE	21-04-2024	09:15	21-04-2024	17:00	Insulator cold washing of loc no. 1-30 & 76-82	PO	220 KV
220 / 110 / 33kV 250MVA ICT 2 @ SAKI	21-04-2024	09:09	21-04-2024	16:04	R/M AND TESTING	PO	220 KV
LONAND - KANDALGAON (SONA ALLOY TAP)	21-04-2024	15:10	21-04-2024	19:19	Replacement of flashover insulator at Loc No.D22	PO	220 KV
PARLI (OLD GCR) - PARLY (PG) CKT 1	21-04-2024	08:38	21-04-2024	09:26	Abnormal looking and heavily swinging of line side jump of b-ph ct.	PO	220 KV
TROMBAY - VIKHROLI (GIS) CKT - 1 / CARNAC 7	21-04-2024	00:31	21-04-2024	05:11	Repair to damaged B Ph loop connector at loc. 24	PO	220 KV
TROMBAY - VIKHROLI (GIS) CKT - 1 / CARNAC 7	21-04-2024	00:31			TLA installation on loc 4,5 & 10 of 220 kV Trombay KVTL 1 Carnac 7.	PO	220 KV
TROMBAY DHARAVI - 6	21-04-2024	00:06	21-04-2024	06:12	repair to critical hot spot on C Ph online termination loop connection	PO	220 KV

Transmission Line Outages/Trippings from 15.04.2024 to 21.04.2024

Name of Line	Date Trip	Time Trip	Date Sync	Time Sync	Reason	Outage Type	Voltage
MANSAR-PENCH	15-04-2024	17:30	15-04-2024	19:20	DUE TO SUPPLY FAILED OF PENCH CKT DUE TO TRIPPING OF GOPAL GANJ CKT	T	132 KV
KANHAN-PENCH	18-04-2024	10:56	18-04-2024	17:54	Routine Maint. Work (Rescheduled of OCC approved outage of 10.04.2024)	PO	132 KV
MANSAR-PENCH	19-04-2024	19:20	20-04-2024	21:50	Tripped on B phase	T	132 KV
BHIVPURI - AMBERNATH CKT - 1	15-04-2024	05:25	15-04-2024	11:57	For CT to line side GOD bus connecting work	PO	110 KV
ZONE 1 (BUS SECTION 1+2+3) @ BHIVPURI	17-04-2024	01:05	17-04-2024	08:28	110KV BA- 1 line MBS side GOD bus connection and and PT # 1 onnection tapping work for new CRP	PO	110 KV
NERAL - AMBERNATH	19-04-2024	06:18	19-04-2024	07:30	Installation of Vibration Dampers and Bird nest removal	PO	110 KV
KOLSHET - BMC - BORIVALI (T) - BORIVALI (M)	20-04-2024	23:33	21-04-2024	07:28	BMC END WORK	PO	110 KV
KHOPOLI - BHOKARPADA	21-04-2024	11:28	21-04-2024	12:01	FOR BIRD NEST REMOVAL	PO	110 KV
WAGHIVALI - CHEMBUR	21-04-2024	00:35	21-04-2024	11:07	MANDALE PROJECT WORK	PO	110 KV