

State Load Despatch Center, Airoli (MSETCL)
Power System Position from 18/May/2015 to 24/May/2015

Supply Position During Morning Peak (MW)

Date	Time	MSGENCO				Central Sector Receipt	Wind	CPP	SOLAR	TPCL Exch.	MSEDCL Catered Demand	Load Shedding(LS)	MSEDCL Demand (Incl. LS)	TPCL Gen.	R-INFRA Gen.	State Demand Met	State Demand (Incl. LS)	Freq.
		THM	HYDRO	GAS	Total													
		MW	MW	MW	MW	MW	MW	MW	MW	MW	MW	MW	MW	MW	MW	MW	MW	Hzs
18/05/2015	12 Hrs	5798	948	276	7022	5310	587	4466	202	-1534	16053	52	16105	1282	505	19374	19426	49.99
19/05/2015	11 Hrs	6025	1032	273	7330	4645	787	4428	157	-1517	15830	73	15903	1160	516	19023	19096	49.98
20/05/2015	11 Hrs	5542	1807	272	7621	5542	437	4264	170	-1698	16336	414	16750	1246	252	19532	19946	49.97
21/05/2015	12 Hrs	5332	1571	279	7182	4893	734	4453	172	-1381	16053	101	16154	1377	480	19291	19392	49.93
22/05/2015	12 Hrs	5211	1551	271	7033	5190	779	4040	178	-1494	15726	66	15792	1233	515	18968	19034	49.94
23/05/2015	12 Hrs	5157	1788	272	7217	4858	749	4137	159	-1479	15641	46	15687	1015	516	18651	18697	49.93
24/05/2015	12 Hrs	4849	1496	274	6619	5140	1161	3385	181	-915	15571	42	15613	884	517	17887	17929	49.93
Maximum		6025	1807	279	7621	5542	1161	4466	202	-915	16336	414	16750	1377	517	19532	19946	50
Minimum		4849	948	271	6619	4645	437	3385	157	-1698	15571	42	15613	884	252	17887	17929	50
Average		5416	1456	274	7146	5083	748	4168	174	-1431	15887	42	16001	1171	472	18961	19074	50

Supply Position During Day Peak (MW)

Date	Time	MSGENCO				Central Sector Receipt	Wind	CPP	SOLAR	TPCL Exch.	MSEDCL Catered Demand	Load Shedding(LS)	MSEDCL Demand (Incl. LS)	TPCL Gen.	R-INFRA Gen.	State Demand Met	State Demand (Incl. LS)	Freq.
		THM	HYDRO	GAS	Total													
		MW	MW	MW	MW	MW	MW	MW	MW	MW	MW	MW	MW	MW	MW	MW	MW	Hzs
18/05/2015	15 Hrs	5853	892	274	7019	5483	718	4406	156	-1544	16238	45	16283	1277	514	19573	19618	49.94
19/05/2015	15 Hrs	5495	896	227	6618	6185	975	4062	145	-1533	16452	43	16495	1251	513	19749	19792	50.00
20/05/2015	16 Hrs	5430	1672	274	7376	5398	894	4416	132	-1724	16492	228	16720	1370	251	19837	20065	49.92
21/05/2015	16 Hrs	5267	1727	280	7274	5088	1008	4456	136	-1485	16477	49	16526	1317	513	19792	19841	49.95
22/05/2015	15 Hrs	5231	1509	277	7017	5601	847	3576	144	-1486	15699	46	15745	1278	518	18981	19027	49.82
23/05/2015	13 Hrs	5168	1301	280	6749	5177	861	4159	175	-1516	15605	46	15651	989	517	18627	18673	49.97
24/05/2015	16 Hrs	4717	1911	275	6903	4917	1215	3544	117	-1032	15664	40	15704	870	518	18084	18124	49.94
Maximum		5853	1911	280	7376	6185	1215	4456	175	-1032	16492	228	16720	1370	518	19837	20065	50
Minimum		4717	892	227	6618	4917	718	3544	117	-1724	15605	40	15651	870	251	18084	18124	50
Average		5309	1415	270	6994	5407	931	4088	144	-1474	16090	40	16161	1193	478	19235	19306	50

Supply Position During Evening Peak (MW)

Date	Time	MSGENCO				Central Sector Receipt	Wind	CPP	SOLAR	TPCL Exch.	MSEDCL Cateder Demand	Load Shedding(LS)	MSEDCL Demand (Incl. LS)	TPCL Gen.	R-INFRA Gen.	State Demand Met	State Demand (Incl. LS)	Freq.
		THM	HYDRO	GAS	Total													
		MW	MW	MW	MW	MW	MW	MW	MW	MW	MW	MW	MW	MW	MW	MW	MW	Hzs
18/05/2015	21 Hrs	5264	381	281	5926	4704	1116	4293	0	-1328	14711	48	14759	1008	518	17565	17613	49.98
19/05/2015	20 Hrs	5198	856	270	6324	4741	1479	3620	0	-1460	14704	46	14750	979	518	17661	17707	49.94
20/05/2015	20 Hrs	5098	1592	276	6966	4717	1019	4262	0	-1517	15447	57	15504	1155	259	18378	18435	49.85
21/05/2015	21 Hrs	4919	849	275	6043	4906	1214	4288	0	-1453	14998	52	15050	947	519	17917	17969	49.92
22/05/2015	21 Hrs	5158	794	276	6228	4931	958	3862	0	-1285	14694	41	14735	1053	518	17550	17591	49.93
23/05/2015	21 Hrs	4982	859	274	6115	4976	1240	3901	0	-1468	14764	39	14803	734	518	17484	17523	49.98
24/05/2015	21 Hrs	4563	1458	274	6295	4141	1406	4006	0	-1330	14518	40	14558	781	379	17008	17048	49.95
Maximum		5264	1592	281	6966	4976	1479	4293	0	-1285	15447	57	15504	1155	519	18378	18435	50
Minimum		4563	381	270	5926	4141	958	3620	0	-1517	14518	39	14558	734	259	17008	17048	50
Average		5026	970	275	6271	4731	1205	4033	0	-1406	14834	39	14880	951	461	17652	17698	50

Supply Position During Night Off Peak (MW)

Date	Time	MSGENCO				Central Sector Receipt	Wind	CPP	SOLAR	TPCL Exch.	MSEDCL Cateder Demand	Load Shedding(LS)	MSEDCL Demand (Incl. LS)	TPCL Gen.	R-INFRA Gen.	State Demand Met	State Demand (Incl. LS)	Freq.
		THM	HYDRO	GAS	Total													
		MW	MW	MW	MW	MW	MW	MW	MW	MW	MW	MW	MW	MW	MW	MW	MW	Hzs
18/05/2015	5 Hrs	5311	90	281	5682	3636	1064	4185	0	-825	13742	49	13791	807	497	15871	15920	50.01
19/05/2015	5 Hrs	5343	193	289	5825	4675	1287	3625	0	-1100	14312	47	14359	686	390	16488	16535	49.96
20/05/2015	7 Hrs	5164	967	284	6415	4220	1125	3917	9	-1005	14681	92	14773	847	259	16792	16884	50.08
21/05/2015	5 Hrs	5143	104	277	5524	4703	1148	4344	0	-1260	14459	53	14512	617	260	16596	16649	49.95
22/05/2015	5 Hrs	5044	682	276	6002	4281	1322	3909	0	-1123	14391	47	14438	621	382	16517	16564	49.96
23/05/2015	5 Hrs	5033	1255	276	6564	4029	1527	3904	0	-1081	14943	43	14986	699	384	17107	17150	49.97
24/05/2015	8 Hrs	4899	592	274	5765	4190	1390	3480	40	-526	14339	43	14382	965	517	16347	16390	50.05
Maximum		5343	1255	289	6564	4703	1527	4344	40	-526	14943	92	14986	965	517	17107	17150	50
Minimum		4899	90	274	5524	3636	1064	3480	0	-1260	13742	43	13791	617	259	15871	15920	50
Average		5134	555	280	5968	4248	1266	3909	7	-989	14410	43	14463	749	384	16531	16585	50

Details of Supply Position (MUs)

Date	MSGENCO				Pench (MS)	Central Sector Receipt	Central Sector Share	WIND	CPP	SOLAR	TPCL Gen.	R-INFRA Gen.	TPCL Exch.	Energy Requirement		
	THM	HYDRO	GAS	Total										MSEDCL	MUMBAI	STATE
	Mus	Mus	Mus	Mus	Mus	Mus	Mus	Mus	Mus	Mus	Mus	Mus	Mus	Mus	Mus	Mus
18/05/2015	131.513	12.266	6.666	150.445	0.109	112.306	112.200	21.968	103.422	1.433	24.297	12.016	-30.665	358.912	66.975	425.887
19/05/2015	133.109	14.364	6.456	153.929	0.109	114.329	114.202	28.092	97.874	1.266	23.229	11.118	-33.009	362.481	67.356	429.837
20/05/2015	129.297	29.970	6.667	165.934	0.189	115.848	114.205	20.944	100.789	1.449	25.267	6.168	-35.635	369.329	67.070	436.399
21/05/2015	124.253	22.230	6.635	153.118	0.017	113.577	113.314	24.908	104.290	1.328	24.110	9.629	-32.981	364.240	66.725	430.965
22/05/2015	123.712	25.732	6.649	156.093	0.113	115.896	110.623	24.661	93.140	1.317	23.487	11.663	-31.399	359.708	66.549	426.257
23/05/2015	121.959	28.276	6.633	156.868	0.055	114.641	109.973	28.732	94.241	1.297	18.933	11.300	-32.566	363.213	62.798	426.011
24/05/2015	114.534	25.643	6.605	146.782	0.099	112.258	106.686	33.425	86.584	1.321	19.582	11.154	-24.862	355.511	55.595	411.106
Maximum	133.109	29.970	6.667	165.934	0.189	115.896	114.205	133.109	104.290	1.449	25.267	12.016	-24.862	369.329	67.356	436.399
Minimum	114.534	12.266	6.456	146.782	0.017	112.258	106.686	114.534	86.584	1.266	18.933	6.168	-35.635	355.511	55.595	411.106
Average	125.482	22.640	6.616	154.738	0.099	114.122	111.600	125.482	97.191	1.344	18.933	10.435	-31.588	361.913	64.724	426.637

Details of Koyna Water Consumption (in TMC)

Date	For the Day	For the Month	Balance
18/05/2015	0.216	6.507	4.832
19/05/2015	0.240	6.747	4.592
20/05/2015	0.592	7.339	4.000
21/05/2015	0.431	7.770	3.569
22/05/2015	0.528	8.298	3.041
23/05/2015	0.605	8.903	2.436
24/05/2015	0.519	9.422	1.917

State Load Despatch Center, Airoli (MSETCL)
Central Sector Share/Drawal from 18/May/2015 to 24/May/2015

Date	DAY	Central Sector Share		Total Interstate Bilateral Purchase		Total Share		Total Drawal		Overdrawal(+) / UnderDrawal(-)	
		MUs	Avg. MW	MUs	Avg. MW	MUs	Avg. MW	MUs	Avg. MW	MUs	Avg. MW
		1		2		1+2=3		4		3-4=5	
18/05/2015	MONDAY	90.645	4653	21.555	898	112.200	4675	112.306	4679	0.106	4
19/05/2015	TUESDAY	92.151	4736	22.051	919	114.202	4758	114.329	4764	0.127	5
20/05/2015	WEDNESDA	93.524	4738	20.681	862	114.205	4759	115.848	4827	1.643	68
21/05/2015	THURSDAY	94.903	4703	18.411	767	113.314	4721	113.577	4732	0.263	11
22/05/2015	FRIDAY	92.005	4591	18.618	776	110.623	4609	115.896	4829	5.273	220
23/05/2015	SATURDAY	92.075	4564	17.898	746	109.973	4582	114.641	4777	4.668	194
24/05/2015	SUNDAY	92.246	4431	14.440	602	106.686	4445	112.258	4677	5.572	232
Total		647.550		133.653		781.203		798.855		17.652	

GENERATING UNITS OUTAGES FOR THE WEEK FROM 18/05/2015 TO 24/05/2015

Generator	Generating Unit	Capacity	Tripped Date	Tripped Time	Synch. Date	Synch Time	Reason
PLANNED OUTAGES							
MSPGCL	Koradi Unit 6	210MW	20/Mar/2015	1:02		Continued.	Renovation and Modification work
MSPGCL	Parli Unit 4		13/Apr/2015	11:27		Continued.	Turbine vibration high. Continued to AOH w.e.f.01.05.2015
FORCED OUTAGES							
IPP	Dhariwal	300MW	28/May/2014	2:27		Continued.	PA Fan Vibration Problem
MSPGCL	Chandrapur Unit 1	210MW	28/Aug/2014	07:15		Continued.	Economic Shutdown.
MSPGCL	Bhusawal Unit 2	210MW	13/Sep/2014	12:43		Continued.	Economic shutdown
IPP	RPL(AMT)U1	270MW	21/Mar/2015	23:28		Continued.	Turbine vibration high.
IPP	Tata Trombay 6	500MW	06/Apr/2015	16:27		Continued.	Economic shut down.
MSPGCL	Bhusawal Unit 3	210MW	20/Apr/2015	0:00		Continued.	no buyer as per msdcl reqirment
IPP	Adani U-3	660MW	11/May/2015	0:52		Continued.	Main Steam Drain MIY Bonnet Leakage.
IPP	JSW (J) U1	300MW	14/May/2015	19:16		Continued.	Turbine Bearing Problem
MSPGCL	Chandrapur Unit 3	210MW	16/May/2015	15:40	19/May/2015	4:43	Bottam hash hopper work
IPP	WPCL U-3	135MW	18/May/2015	3:07	21/May/2015	10:23	Withdrawn
MSPGCL	Parli Unit 3	210MW	19/May/2015	18:12	22/May/2015	0:04	Drum level low
MSPGCL	Nasik Unit 3	210MW	20/May/2015	9:28	21/May/2015	19:45	Drum level low
MSPGCL	Parli Unit 7	250MW	20/May/2015	19:16	23/May/2015	15:33	BLR Validity extension for 48 Hrs.
MSPGCL	Bhusawal Unit 5	500MW	23/May/2015	16:23		Continued.	Boiler Tube Leakage
MSPGCL	Paras Unit 3	250MW	23/May/2015	0:05	23/May/2015	10:56	Furnace Pressure High
MSPGCL	Parli Unit 5	210MW	23/May/2015	20:34		Continued.	Boiler Tube Leakage
IPP	RPL(AMT)U2	270MW	24/May/2015	10:06	24/May/2015	13:08	Boiler Feed Pump Tripped.
MSPGCL	Chandrapur Unit 2	210MW	24/May/2015	12:04	24/May/2015	18:55	Furnace Pressure High
MSPGCL	Paras Unit 4	250MW	24/May/2015	19:28	24/May/2015	21:22	Flame Failure

LINE OUTAGES FOR THE WEEK FROM 18/05/2015 TO 24/05/2015

Voltage	Name of Line	Tripping Date	Tripping Time	Synch Date	Synch Time	Reason
765 KV	Wardha PG -Aurangabad PG III	03/May/2015	7:24		Continued.	To Control ICT Loading.
765 KV	765/400kv 1500MVA ICT-I@Koradi-III	20/May/2015	9:14		Continued.	Annual Maintenance Work
765 KV	Koradi III - Tirora - I	22/May/2015	11:59	22/May/2015	17:17	Jumper Tighting Work.
765 KV	Wardha(PG)-Aurangabad(PG)- II	22/May/2015	16:44		Continued.	To Control ICT Loading.
400 KV	Akola II - RPL(Rattanindia) Ckt I	07/Apr/2015	0:27		Continued.	"R" Phase Metering CT Burst.
400 KV	Kolhapur Mapusa II	17/May/2015	16:09	18/May/2015	09:16	Over Voltage
400 KV	karad -kolhapur-I	17/May/2015	16:45	18/May/2015	07:00	Over Voltage
400 KV	Dhule Sar'Sarovar I	17/May/2015	17:17	18/May/2015	14:12	Over Voltage
400 KV	Bhusawal-Aurangabad	17/May/2015	17:53	18/May/2015	07:55	Over Voltage
400 KV	00/220kv 315MVA ICT-II @Talegaon(P	18/May/2015	9:52	18/May/2015	15:02	Premansoon Maintence Work.
400 KV	400/220 KV 315 MVA ICT- I @Koradi	18/May/2015	11:47		Continued.	Dismantling and Errection of Duct with LA.
400 KV	Bhusawal-Aurangabad	18/May/2015	14:12	18/May/2015	14:32	Tripped at Aurangabad end only.
400 KV	00/220kv 315MVA ICT-I @Talegaon(P	18/May/2015	15:08	18/May/2015	18:42	Premansoon Maintention Work.
400 KV	karad -kolhapur-II	18/May/2015	17:04	19/May/2015	7:13	To Control Voltage.
400 KV	Dhule Sar'Sarovar II	18/May/2015	17:55	19/May/2015	8:18	Over Voltage
400 KV	Bhusawal-Aurangabad	18/May/2015	18:08	19/May/2015	7:58	To Control Voltage.
400 KV	Padghe - Kalwa- I	19/May/2015	6:28	19/May/2015	12:20	Attending hot spot.
400 KV	00/220 Kv 315 MVA ICT - I @New Koy	19/May/2015	10:41	19/May/2015	20:17	Repl of 33KV PT.
400 KV	00/220/33 Kv 315 Mva ICT- II @Padgh	19/May/2015	12:22	19/May/2015	13:56	OLTC Bucholz Prot Optd.
400 KV	Karad - Lonikand 1	19/May/2015	13:21	19/May/2015	13:43	Distance Protection
400 KV	Karad - Lonikand 1	19/May/2015	14:47	19/May/2015	20:02	Distance Protection
400 KV	Kolhapur Mapusa II	19/May/2015	16:42	20/May/2015	8:38	Over Voltage
400 KV	Dhule Sar'Sarovar I	19/May/2015	18:04	20/May/2015	10:44	Over Voltage
400 KV	Wardha (PG)-Warora II	20/May/2015	2:39		Continued.	Breaker Accumulator Oil Leakage
400 KV	400/220 Kv 600 MVA ICT-II @Kalwa	20/May/2015	6:42	20/May/2015	8:17	Backup relay testing for load trimming sceheme.
400 KV	Padghe - Kharghar	20/May/2015	8:50	20/May/2015	16:50	Shifted on TBC.
400 KV	Akola II - Taptitanda	20/May/2015	8:59		Continued.	Ckt I and Ckt 2 new charged to control BBLSR ICT loading.
400 KV	Dhule Sar'Sarovar I	20/May/2015	10:44	21/May/2015	6:00	Outage.
400 KV	400/220 KV 500 MVA ICT- I @Warora	20/May/2015	11:42	20/May/2015	21:09	Maint.work.
400 KV	400/220 Kv 500 MVA ICT II @Lamboti	20/May/2015	16:40	20/May/2015	20:06	Testing work.
400 KV	Bhusawal-Aurangabad	20/May/2015	16:44	21/May/2015	9:48	Over Voltage
400 KV	Kolhapur Mapusa I	20/May/2015	17:57	20/May/2015	20:11	Over Voltage
400 KV	karad -kolhapur-II	20/May/2015	18:23	21/May/2015	6:32	Over Voltage
400 KV	Padghe - Kalwa-II	21/May/2015	1:21	21/May/2015	10:47	Hot spot at Y-Ph wave trap at Kalwa end.
400 KV	0/220/33kv, 500 Mva Ict-2 @Khaparkhe	21/May/2015	9:09	21/May/2015	17:28	Annual Maintenance Work
400 KV	Dhule Sar'Sarovar II	21/May/2015	10:49	22/May/2015	9:02	Over Voltage
400 KV	Lonikand I - Koyna stage-IV	21/May/2015	13:24	21/May/2015	18:23	Replacement of Wavetrap Jumper
400 KV	karad -kolhapur-II	21/May/2015	18:04	22/May/2015	7:45	Over Voltage
400 KV	Bhusawal-Aurangabad	21/May/2015	21:30	22/May/2015	9:02	Over Voltage
400 KV	New Koyna -Koyna Stage IV-I	22/May/2015	8:13	22/May/2015	19:40	Cold Line Insulator Washing Work.
400 KV	Cahndrapur II - Dhariwal II	22/May/2015	8:52	22/May/2015	13:19	P M of line spacer, Replacement of WT at Dhariwal end
400 KV	Koradi-India Bulls	22/May/2015	9:21	22/May/2015	17:28	Faulty Disc Replcement,Fixing Spacers,Damper Line Maint.Work.
400 KV	Jejuri- Koynastage-IV	22/May/2015	12:14	22/May/2015	12:32	Distance Protection
400 KV	karad -kolhapur-II	22/May/2015	16:10	23/May/2015	8:29	Over Voltage
400 KV	Kolhapur Mapusa I	22/May/2015	17:38	23/May/2015	7:30	Over Voltage
400 KV	Bhusawal-Aurangabad	22/May/2015	17:40	23/May/2015	8:24	Over Voltage
400 KV	Dhule Sar'Sarovar II	22/May/2015	19:02	24/May/2015	10:10	After Complition of Outage CKT ready for Charging.

400 KV	karad -kolhapur-II	23/May/2015	16:34	24/May/2015	8:42	Over Voltage
400 KV	Bhusawal-Aurangabad	23/May/2015	17:13	24/May/2015	9:01	Over Voltage
400 KV	Karad-Jaigad - I	23/May/2015	18:04	24/May/2015	8:45	Over Voltage
400 KV	Koradi-Bhusawal	23/May/2015	19:04	24/May/2015	0:20	Red Hot on Y Ph Line Isolator.
400 KV	New Koyna -Koyna Stage IV-I	24/May/2015	8:19	24/May/2015	15:19	Cold Line Insulator Washing Work.
400 KV	Kolhapur Mapusa II	24/May/2015	16:13	24/May/2015	23:16	Over Voltage
400 KV	karad -kolhapur-I	24/May/2015	16:16	25/May/2015	8:38	Over Voltage
400 KV	Karad-Jaigad - I	24/May/2015	17:26	25/May/2015	8:40	Over Voltage
400 KV	Bhusawal-Aurangabad	24/May/2015	17:31	25/May/2015	8:19	Over Voltage
400 KV	Dhule Sar'Sarovar I	24/May/2015	18:04	25/May/2015	8:10	Over Voltage
400 KV	Kolhapur Solapur(PG) I	24/May/2015	18:13	24/May/2015	22:38	Over Voltage
400 KV	Kolhapur Mapusa I	25/May/2015	17:20		Continued.	Over Voltage
400 KV	karad -kolhapur-II	25/May/2015	17:26		Continued.	Over Voltage
400 KV	Bhusawal-Aurangabad	25/May/2015	18:00		Continued.	Over Voltage
400 KV	Karad-Jaigad - I	25/May/2015	18:05		Continued.	Over Voltage
400 KV	Dhule Sar'Sarovar I	25/May/2015	18:56		Continued.	Over Voltage
220 KV	220/100 Kv 200 MVA ICT III @Borivali	21/Sep/2014	9:16		Continued.	Internal Fault
220 KV	Sahara-Urse	03/Mar/2015	11:06		Continued.	Tower erection work (90Days)
220 KV	Chandrapur Gcr - Warora - I	05/Apr/2015	9:13		Continued.	Bunching of conductor Loc no 86 Disconnecting of jumer at Loc no 86 & 107 and deenergising the line bet.86 to 107.
220 KV	Chandrapur Gcr - Wani	05/Apr/2015	9:15		Continued.	Bunching of conductor Loc no 86 Disconnecting of jumer at Loc no 86 & 107 and deenergising the line bet.86 to 107.
220 KV	Eklahara-(Ocr)-Navasari I	05/May/2015	23:09		Continued.	To control Load on Bus section at Nasik GCR
220 KV	Kharghar - Nerul	17/May/2015	4:47	18/May/2015	4:35	Erection of W/T and CC.
220 KV	Padgha - Temghar I	17/May/2015	6:36	18/May/2015	0:16	A Bus Outage at Padgha End.
220 KV	Padgha-Temghar-II	17/May/2015	6:36	18/May/2015	0:18	A Bus Outage at Padgha End.
220 KV	Padghe - Kamba	17/May/2015	23:55	18/May/2015	1:55	Load Trimming Operated.
220 KV	Halkarni - Tillari II	18/May/2015	0:26	18/May/2015	4:38	Removing of Broken Earth Wire.
220 KV	Mudshingi-Wathar	18/May/2015	0:33	18/May/2015	12:49	R Phase CT Burst.
220 KV	Halkarni-Mahalaxmiline	18/May/2015	0:39	18/May/2015	4:42	Removing of Broken Earth Wire.
220 KV	Mudshingi-Wathar	18/May/2015	0:33	18/May/2015	12:48	Bus Bar Protection Operated and R Ph CT Burst.
220 KV	Akola-Paras Ckt No-Ii	18/May/2015	10:07	18/May/2015	16:34	C TAN Delta Testing of CT and Bay Routine Maint. Work.
220 KV	Kharepatan -Pawas Line	18/May/2015	11:20	18/May/2015	13:04	Hot Washing of Bay.
220 KV	2kv 100 Mva Imp Ict 1 @Limbala Midc	18/May/2015	11:27	18/May/2015	17:15	SFRA and Routine Maintenance Work.
220 KV	Talandage - Sawantwadi I	18/May/2015	12:19	18/May/2015	12:34	Distance Protection Operated, Y-Ph.
220 KV	220/132 KV 200MVA ICT I @ Kanhan	18/May/2015	14:17	18/May/2015	17:44	Due to Abnormal R-Ph current in R-Ph HV CT.
220 KV	Niwali - Pawas Line	18/May/2015	16:01	18/May/2015	17:41	Annual Maintenance Work
220 KV	Boisar II - Tarapur	19/May/2015	7:42	19/May/2015	8:31	Removing bird nest from gantry.
220 KV	Raymond - Washala	19/May/2015	8:45	19/May/2015	17:31	Cold washing of disc.
220 KV	TBC @ Nagothane	19/May/2015	9:00	19/May/2015	11:00	CT Tan Delta Work.
220 KV	Deepnagar Amalner	19/May/2015	9:16	19/May/2015	12:50	Attending Hot Spot
220 KV	Kadegaon-Miraj	19/May/2015	10:10	19/May/2015	11:20	Red hot on R-Ph CT.
220 KV	20/110KV, 200MVA T/F-III at Mudshing	19/May/2015	10:24	19/May/2015	17:28	Attending hot spot.
220 KV	Khaparkheda-Butibori 3	19/May/2015	10:26	19/May/2015	13:18	Measurement of CB timing and CRM.
220 KV	Vankuswade - Kdph	19/May/2015	11:00	19/May/2015	17:25	Line crossing work of Karad -Koyna Ckt.
220 KV	Mumewadi-Belewadi	19/May/2015	11:37	19/May/2015	17:35	Scada commissioning work.
220 KV	Kamba - Kolshet	20/May/2015	6:40	20/May/2015	9:25	Bus Bar Optd at Kamba S/S.
220 KV	Padghe - Kamba	20/May/2015	6:40	20/May/2015	9:18	Bus Bar Optd at Kamba S/S.
220 KV	Taloja li - Ocil 1	20/May/2015	7:25	20/May/2015	18:30	Maint.work.
220 KV	Pedambe-Nerle	20/May/2015	7:30	20/May/2015	15:35	Maint.work.
220 KV	Pedhambe - Oni	20/May/2015	9:05	20/May/2015	19:35	Repl of conductor.

220 KV	Ghodbunder MSETCL Boisar line	20/May/2015	9:20	21/May/2015	13:15	To control line loading.
220 KV	Parli 3(Old Gcr)-Parli Newtps Ckt-2	20/May/2015	9:22	20/May/2015	11:38	Attending Hot Spot
220 KV	Loteparshuram- Dasturi Line	20/May/2015	12:14	20/May/2015	16:14	Attending Hot Spot
220 KV	Kamba - Kolshet	20/May/2015	13:00	20/May/2015	17:19	Bus Bar Testing Work.
220 KV	Apta - Hoc	20/May/2015	13:34	20/May/2015	16:35	Tan delta, Testing work.
220 KV	Parli 3 (Old Gcr)-Girwali Ckt-3	21/May/2015	2:35	21/May/2015	14:18	Y-Ph CT Burst.
220 KV	Parli 3(Old Gcr)- Girwali Ckt 4	21/May/2015	2:35	21/May/2015	3:13	Distance Protection
220 KV	220/100 Kv 200 Mva Bhel Ict 1 @Kalwa	21/May/2015	6:25	21/May/2015	9:42	Attending Hot Spot
220 KV	Pohali-Nerle	21/May/2015	8:00	21/May/2015	18:05	Annual Maintenance Work
220 KV	Mahindra Vehicle-Bridgestone	21/May/2015	10:00	21/May/2015	18:30	Annual Maintenance Work
220 KV	Centuri Enka- Bhosari	21/May/2015	11:07	21/May/2015	19:08	Annual Maintenance Work
220 KV	Eklahare (Gcr) - Ghatghar	21/May/2015	11:19	21/May/2015	18:46	Annual Maintenance Work
220 KV	Nagothane - Posco	21/May/2015	11:48	21/May/2015	17:40	Annual Maintenance Work
220 KV	Pedambe-Nerle	21/May/2015	13:00	21/May/2015	13:13	Distance Protection
220 KV	Butibori-Abhijeet	22/May/2015	6:23	22/May/2015	10:35	IR Value of CT @ Butibori End.IR of LA is found Low Replacement of Stack @ Butibori End.
220 KV	0/132 Kv 100 Mva Bhel Ict 2 @Padega	22/May/2015	7:18	24/May/2015	19:18	Replacement of 2 No. of HV Bushing(R & Y Ph) & Filtration of ICT.
220 KV	Kandalgaon - Koyna	22/May/2015	9:30	22/May/2015	18:05	Maintenance Work.
220 KV	Padgha-Temghar-II	22/May/2015	10:30	22/May/2015	11:19	Tripped Only from Temghar End.
220 KV	Vita - Ghatnandre	22/May/2015	10:30	22/May/2015	15:05	P.M.Work.
220 KV	Padgha - Temghar I	22/May/2015	10:30	22/May/2015	11:19	Distance Protection
220 KV	Nashik-Airoli Knowledge Park	22/May/2015	15:25	22/May/2015	16:48	Maintenance Work.
220 KV	0/132 Kv 200 Mva Cgl Ict 3 @Babhlesh	22/May/2015	15:25	22/May/2015	18:43	Testing Work
220 KV	Wpcl-Warora 1	22/May/2015	16:44	22/May/2015	18:47	To Attend Hotspot on R Ph W.T.
220 KV	Main Bus I @ Kalwa	23/May/2015	7:00	23/May/2015	17:44	Jumpering work at interconnector
220 KV	Khadka-Bhadli-1	23/May/2015	7:18	23/May/2015	14:50	For Attending CB Closing Problem.
220 KV	Nashik-Padgha	23/May/2015	7:25	23/May/2015	18:00	A/R Out.
220 KV	220/132kV 200MVA ICT-III @ Nanded	23/May/2015	7:30	23/May/2015	12:05	Oil leakage attending work
220 KV	Khadka-Chalisingaon-1	23/May/2015	9:08	23/May/2015	12:50	R Ph String Replacement Work.
220 KV	220/100 Kv 200 MVA ICT II @Kolshet	23/May/2015	10:03	23/May/2015	19:05	Maintenance Work.
220 KV	0/132 Kv 100 Mva Ibt Ptr @Old Gcr Pa	23/May/2015	10:30	23/May/2015	12:40	To attend hotspoton Y-ph CT
220 KV	Boisar(M) - Ghodbunder	24/May/2015	4:04	24/May/2015	10:51	For Boisar-2(M)-PG-I Outage.
220 KV	Boisar Versova Line	24/May/2015	4:30	24/May/2015	16:12	For Boisar-2(M)-PG-I Outage.
220 KV	Boisar II - PGCIL I	24/May/2015	4:36	24/May/2015	10:39	Routine Maintenance Work
220 KV	Boisar(MS) - Boisar (PG) - I	24/May/2015	4:36	24/May/2015	10:39	Maintenance Work.
220 KV	Kalwa - Mulund 1	24/May/2015	5:02	24/May/2015	9:44	Maintenance Work.
220 KV	Nashik-Padgha	24/May/2015	7:35		Continued.	A/R Out.
220 KV	Dahanu Versova	24/May/2015	10:38	24/May/2015	10:38	A/R Succssful
220 KV	Jejuri-Phursungi 2	24/May/2015	11:02	24/May/2015	13:36	Attending Hot Spot
220 KV	Padgha - Temghar I	24/May/2015	11:06	24/May/2015	21:05	To Avail Outage on Bus B at Padgha End.
220 KV	Kalwa-Salsette-VI	24/May/2015	12:10	24/May/2015	18:42	Cross ARM Painting Work.
220 KV	Bus B @ Padaghe	24/May/2015	12:47	24/May/2015	17:58	Commissioning of Hybrid Pass.
220 KV	Bableshtar - Bableshtar-I	24/May/2015	17:15	24/May/2015	22:43	Attending Hot Spot
132 KV	Waghala - Kandhar	18/May/2015	12:50	18/May/2015	14:10	Ten Delta MEAS of CT.
132 KV	Gangakhed - Kandhar	18/May/2015	14:43	18/May/2015	15:30	TAN Delta MEAS of CT.
132 KV	Parbhani li - Partur	18/May/2015	17:57	18/May/2015	20:06	For by Pass of NT Switch.
132 KV	Mankapur - Hingna-I	19/May/2015	11:23	19/May/2015	14:29	Distance Protection
132 KV	Seloo - Mahatmasugar	19/May/2015	19:31	19/May/2015	20:30	Distance Protection
132 KV	Khapri-Besa	19/May/2015	21:05	20/May/2015	10:00	Distance Protection
132 KV	Paras-Malkapur	23/May/2015	0:18	24/May/2015	10:20	For Akola ICT Loading.
132 KV	Buldana-Motala	23/May/2015	0:50	24/May/2015	9:25	For Akola ICT Loading.

132 KV	Paranda - Bhairavnath Cogeneration	23/May/2015	8:30	23/May/2015	9:16	B & Y Ph Pick up Bhairavnth Gen Not on Bar.
132 KV	Paras-Warwat Bakal	24/May/2015	16:03		Continued.	To Control 132kv Paras-For Akola ICT-II Loading.