

State Load Despatch Center,Airoli (MSETCL)
Power System Position from 13/May/2024 to 19/May/2024

Supply Position During Morning Peak (MW)

Date	Time	MSGENCO				Central Sector Receipt	Wind	CPP	SOLAR	TPCL Exch.	MSEDCL Catered Demand	Load Sheddin g(LS)	MSEDCL Demand (Incl. LS)	TPCL Gen.	R-INFRA Gen.	State Demand Met	State Demand (Incl. LS)	Freq.
		THM	HYDRO	GAS	Total													
		MW	MW	MW	MW	MW	MW	MW	MW	MW	MW	MW	MW	MW	MW	MW	MW	Hzs
13-05-2024	12 Hrs	6056	334	361	6751	8586	239	5151	2183	-2357	20038	0	20038	1116	249	24275	24275	49.97
14-05-2024	12 Hrs	6551	314	273	7138	8856	140	5351	2200	-2353	20805	0	20805	1056	252	24993	24993	50.01
15-05-2024	12 Hrs	5977	139	273	6389	9349	114	5770	2149	-2347	20911	0	20911	974	362	25107	25107	50.00
16-05-2024	12 Hrs	6989	194	355	7538	9444	153	5383	2144	-2263	21842	0	21842	1212	503	26377	26377	49.96
17-05-2024	12 Hrs	6299	368	136	6803	9280	134	5003	2088	-2269	20487	0	20487	1039	500	24847	24847	49.98
18-05-2024	12 Hrs	6394	427	277	7098	9303	158	5112	2239	-2241	21138	0	21138	1029	501	25440	25440	49.91
19-05-2024	12 Hrs	6740	227	278	7245	9111	175	5113	2345	-1987	21505	0	21505	694	318	25001	25001	49.99
Maximum		6989	427	361	7538	9444	239	5770	2345	-1987	21842	0	21842	1212	503	26377	26377	50.01
Minimum		5977	139	136	6389	8586	114	5003	2088	-2357	20038	0	20038	694	249	24275	24275	49.91
Average		6429	286	279	6995	9133	159	5269	2193	-2260	20961	0	20961	1017	384	25149	25149	49.97

Supply Position During Day Peak (MW)

Date	Time	MSGENCO				Central Sector Receipt	Wind	CPP	SOLAR	TPCL Exch.	MSEDCL Catered Demand	Load Sheddin g(LS)	MSEDCL Demand (Incl. LS)	TPCL Gen.	R-INFRA Gen.	State Demand Met	State Demand (Incl. LS)	Freq.
		THM	HYDRO	GAS	Total													
		MW	MW	MW	MW	MW	MW	MW	MW	MW	MW	MW	MW	MW	MW	MW	MW	Hzs
13-05-2024	15 Hrs	6448	469	372	7289	8746	189	5165	1996	-2352	20513	0	20513	1183	248	24816	24816	49.95
14-05-2024	16 Hrs	6736	1305	275	8316	8834	527	5742	995	-2376	21507	0	21507	1270	251	25935	25935	50.02
15-05-2024	16 Hrs	6314	1011	275	7600	9126	135	6743	1390	-2265	22195	0	22195	1175	503	26672	26672	50.02
16-05-2024	15 Hrs	7176	383	353	7912	9283	449	5497	1566	-2250	21956	0	21956	1286	503	26496	26496	49.96
17-05-2024	16 Hrs	7384	907	135	8426	8838	487	5548	1349	-2249	21863	0	21863	1193	501	26342	26342	50.04
18-05-2024	16 Hrs	6779	1793	376	8948	8587	312	5546	1388	-2161	22102	0	22102	1273	500	26554	26554	49.95
19-05-2024	16 Hrs	7206	1395	282	8883	8687	611	5176	1513	-2294	22090	0	22090	681	312	25863	25863	50.03
Maximum		7384	1793	376	8948	9283	611	6743	1996	-2161	22195	0	22195	1286	503	26672	26672	50.04
Minimum		6314	383	135	7289	8587	135	5165	995	-2376	20513	0	20513	681	248	24816	24816	49.95
Average		6863	1038	295	8196	8872	387	5631	1457	-2278	21746	0	21746	1152	403	26097	26097	50.00

Supply Position During Evening Peak (MW)

Date	Time	MSGENCO				Central Sector Receipt	Wind	CPP	SOLAR	TPCL Exch.	MSEDCL Catered Demand	Load Sheddin g(LS)	MSEDCL Demand (Incl. LS)	TPCL Gen.	R-INFRA Gen.	State Demand Met	State Demand (Incl. LS)	Freq.
		THM	HYDRO	GAS	Total													
		MW	MW	MW	MW	MW	MW	MW	MW	MW	MW	MW	MW	MW	MW	MW	MW	Hzs
13-05-2024	20 Hrs	7366	688	384	8438	7127	449	6405	0	-1813	20104	0	20104	959	244	23622	23622	50.02
14-05-2024	22 Hrs	6704	2047	285	9036	6112	366	6927	0	-1687	20249	0	20249	1227	204	23872	23872	50.00
15-05-2024	20 Hrs	5838	2010	375	8223	9008	309	7016	0	-1739	22267	134	22401	1268	503	26327	26461	49.99
16-05-2024	22 Hrs	7449	1168	289	8906	5710	503	6740	0	-1502	19837	0	19837	1208	443	23510	23510	49.98
17-05-2024	20 Hrs	7101	1676	279	9056	7630	456	6715	0	-1885	21469	0	21469	1260	451	25568	25568	49.94
18-05-2024	21 Hrs	7151	1508	379	9038	8210	571	6804	0	-1752	22342	0	22342	1253	473	26349	26349	50.02
19-05-2024	22 Hrs	7548	1826	285	9659	6478	602	6215	0	-1849	20596	0	20596	877	496	24327	24327	49.97
Maximum		7548	2047	384	9659	9008	602	7016	0	-1502	22342	134	22401	1268	503	26349	26461	50.02
Minimum		5838	688	279	8223	5710	309	6215	0	-1885	19837	0	19837	877	204	23510	23510	49.94
Average		7022	1560	325	8908	7182	465	6689	0	-1747	20981	19	21000	1150	402	24796	24816	49.99

Supply Position During Night Off Peak (MW)

Date	Time	MSGENCO				Central Sector Receipt	Wind	CPP	SOLAR	TPCL Exch.	MSEDCL Catered Demand	Load Sheddin g(LS)	MSEDCL Demand (Incl. LS)	TPCL Gen.	R-INFRA Gen.	State Demand Met	State Demand (Incl. LS)	Freq.
		THM	HYDRO	GAS	Total													
		MW	MW	MW	MW	MW	MW	MW	MW	MW	MW	MW	MW	MW	MW	MW	MW	Hzs
13-05-2024	8 Hrs	7067	160	283	7510	7175	573	6111	477	-1571	19806	0	19806	655	493	22994	22994	50.05
14-05-2024	5 Hrs	6759	209	291	7259	6286	1240	6271	0	-1473	19197	0	19197	635	232	21923	21923	50.02
15-05-2024	5 Hrs	6192	1534	293	8019	6881	146	6929	0	-1652	19927	0	19927	643	231	22849	22849	49.97
16-05-2024	8 Hrs	6978	332	287	7597	8367	71	6432	471	-1767	20679	0	20679	682	366	23986	23986	49.98
17-05-2024	4 Hrs	7156	411	143	7710	7530	399	6421	0	-1621	20055	0	20055	630	439	23129	23129	50.01
18-05-2024	8 Hrs	7091	344	290	7725	7791	161	6523	631	-1691	20638	0	20638	612	417	23860	23860	50.05
19-05-2024	8 Hrs	7493	208	285	7986	7300	225	6429	632	-1491	20596	0	20596	620	470	23662	23662	49.99
Maximum		7493	1534	293	8019	8367	1240	6929	632	-1473	20679	0	20679	682	493	23986	23986	50.05
Minimum		6192	160	143	7259	6286	71	6111	0	-1767	19197	0	19197	612	231	21923	21923	49.97
Average		6962	457	267	7687	7333	402	6445	316	-1609	20128	0	20128	640	378	23200	23200	50.01

Details of Supply Position (MUs)

Date	MSGENCO				Pench (MS)	Central Sector Receipt	Central Sector Share	WIND	CPP	SOLAR	TPCL Gen.	R-INFRA Gen.	TPCL Exch.	Energy Requirement		
	THM	HYDRO	GAS	Total										MSEDCL	MUMBAI	STATE
	Mus	Mus	Mus	Mus	Mus	Mus	Mus	Mus	Mus	Mus	Mus	Mus	Mus	Mus	Mus	Mus
13-05-2024	167.323	8.233	7.870	183.426	0.272	178.328	189.712	12.097	144.480	16.502	21.986	7.327	-44.989	478.524	74.302	564.146
14-05-2024	159.624	17.137	6.902	183.663	0.226	180.683	187.448	13.448	147.188	15.246	22.761	5.342	-46.977	481.647	75.080	568.331
15-05-2024	148.876	30.376	7.490	186.742	0.594	198.441	203.516	4.668	160.116	15.434	23.772	8.691	-46.254	507.550	78.717	597.864
16-05-2024	172.273	15.878	7.486	195.637	0.148	188.493	196.482	8.808	150.852	14.864	25.005	11.496	-44.817	501.998	81.318	595.155
17-05-2024	168.267	18.519	4.867	191.653	0.150	193.141	197.233	8.330	146.671	15.010	23.415	11.808	-45.194	497.738	80.417	590.028
18-05-2024	165.429	32.187	8.228	205.844	0.000	194.006	200.845	6.915	147.958	16.593	24.208	11.721	-44.985	514.536	80.914	607.245
19-05-2024	176.665	24.747	7.004	208.416	0.000	187.055	191.778	10.021	141.475	17.508	17.934	9.742	-44.749	508.249	72.425	592.151
Maximum	176.665	32.187	8.228	208.416	0.594	198.441	203.516	176.665	160.116	17.508	25.005	11.808	-44.749	514.536	81.318	607.245
Minimum	148.876	8.233	4.867	183.426	0.000	178.328	187.448	148.876	141.475	14.864	17.934	5.342	-46.977	478.524	72.425	564.146
Average	165.494	21.011	7.121	193.626	0.199	188.592	195.288	165.494	148.391	15.880	22.726	9.447	-45.424	498.606	77.596	587.846

Details of Koyna Water Consumption (in TMC)

Date	For the Day	For the Month	Balance
13-05-2024	0.090	3.657	18.256
14-05-2024	0.319	3.975	17.938
15-05-2024	0.631	4.606	17.307
16-05-2024	0.298	4.905	17.008
17-05-2024	0.354	5.259	16.655
18-05-2024	0.650	5.908	16.005
19-05-2024	0.489	6.397	15.516

State Load Despatch Center,Airoli (MSETCL) Central Sector Share/Drawal from 13/May/2024 to 19/May/2024

Date	DAY	Central Sector Share		Total Interstate		Total Share		Total Drawal		Overdrawal(+) /	
		MUs	Avg. MW	MUs	Avg. MW	MUs	Avg. MW	MUs	Avg. MW	MUs	Avg. MW
		1		2		1+2=3		4		3-4=5	
13-05-2024	MONDAY	103.014	7818	86.698	3612	189.712	7905	178.328	7430	-11.384	-474
14-05-2024	TUESDAY	98.220	7721	89.228	3718	187.448	7810	180.683	7528	-6.765	-282
15-05-2024	WEDNESDAY	119.535	8396	83.981	3499	203.516	8480	198.441	8268	-5.075	-211
16-05-2024	THURSDAY	116.757	8107	79.725	3322	196.482	8187	188.493	7854	-7.989	-333
17-05-2024	FRIDAY	110.747	8132	86.486	3604	197.233	8218	193.141	8048	-4.092	-170
18-05-2024	SATURDAY	90.017	8258	110.828	4618	200.845	8369	194.006	8084	-6.839	-285
19-05-2024	SUNDAY	102.585	7902	89.193	3716	191.778	7991	187.055	7794	-4.723	-197
Total		740.876		626.138		1367.014		1320.147		-46.867	

Generator Unit Outages/Trippings from 13.05.2024 to 19.05.2024						
Name of Unit	Date Trip	Time Trip	Date Sync	Time Sync	Reason	Outage Type
PGPL U1	07-02-2017	17.3		Continued.	No Schedule (NO PPA)	NOPPA
PGPL U2	07-02-2017	17.3		Continued.	No Schedule.(NO PPA)	NOPPA
VIPL U-1	29-12-2018	0.3		Continued.	Coal Shortage. (NO PPA From 20.05.2019)	NOPPA
VIPL U-2	17-01-2019	0.15		Continued.	Coal shortage.(NO PPA From 20.05.2019)	NOPPA
Tarapur 1	08-01-2020	10:37		Continued.	Refueling. While refueling preparation, some repair works identified which are being executed before refueling.	FORCED
Tarapur 2	13-07-2020	04:38		Continued.	For cleaning of clogged basket strainer of cooling water system due to heavy ingress of debris from sea. The outage extended for repair and re-fueling.	FORCED
Koradi Unit 7	27-04-2021	20.03		Continued.	Retired (04/08/2021 At 00.00)	FORCED
Uran Unit A0	07-09-2022	16:30		Continued.	TURBINE TRIPPED ON HIGH VIBRATIONS	FORCED
Uran Unit 6	06-05-2024	23:54	13-05-2024	10:29	Zero Schedule given by MSEDCL	ZEROSCH/R SD
Uran Unit 5	09-05-2024	20:15	15-05-2024	18:05	No Schedule from MSEDCL	ZEROSCH/R SD
Khaparkheda Unit 5	11-05-2024	04:22	13-05-2024	20:20	Generator protection	FORCED
Koradi Unit 6	12-05-2024	18:31	14-05-2024	17:13	GS WATER TANK LOW	FORCED
AEML Unit 1	13-05-2024	10:38	15-05-2024	10:25	Boiler Tube Leakage	FORCED
Nasik Unit 3	13-05-2024	14:10	15-05-2024	14:26	ID Fan Problem	FORCED
Uran Unit 6	13-05-2024	22:03	14-05-2024	22:16	No Schedule from MSEDCL	ZEROSCH/R SD
Chandrapur Unit 6	14-05-2024	00:00	15-05-2024	23:02	EXCESSIVELY HIGH DM WATER CONSUMPTION AND ABNORMAL PARAMETER DUE TO SUSPECTED BTL	FORCED
Bhusawal Unit 4	14-05-2024	00:30	15-05-2024	19:29	BTL attending work	FORCED
Parli Unit 8	14-05-2024	16:45	15-05-2024	19:15	Zero Schedule Given By MSEDCL.	ZEROSCH/R SD
Koradi Unit 8	14-05-2024	22:17	18-05-2024	20:07	SUSPECTED BTL	FORCED
Uran Unit 6	15-05-2024	02:01	16-05-2024	11:00	No Schedule from MSEDCL	ZEROSCH/R SD
Koradi Unit 9	15-05-2024	18:10	15-05-2024	20:10	Due to feed water flow low.	FORCED
Uran Unit 5	16-05-2024	02:00	17-05-2024	22:17	No Schedule from MSEDCL	ZEROSCH/R SD
JPL Unit 2	16-05-2024	07:43	16-05-2024	09:05	Flame Failure	FORCED
Uran Unit 6	16-05-2024	17:50	17-05-2024	23:27	No Schedule from MSEDCL	ZEROSCH/R SD
Uran Unit 7	17-05-2024	02:53	17-05-2024	16:14	Filter replacement work	PLANNED
RPL(AMT) U-5	17-05-2024	05:55	19-05-2024	19:32	Cooling Water Line Problem	FORCED
Chandrapur Unit 6	17-05-2024	16:44	20-05-2024	07:13	Boiler Tube Leakage	FORCED
Uran Unit 6	18-05-2024	01:58		Continued.	No Schedule from MSEDCL	ZEROSCH/R SD
Uran Unit 5	18-05-2024	02:15	18-05-2024	12:55	No Schedule from MSEDCL	ZEROSCH/R SD
Uran Unit 5	19-05-2024	02:00		Continued.	As per MSEDCL zero schedule.	ZEROSCH/R SD
Paras Unit 4	19-05-2024	23:30	20-05-2024	02:32	Generator Mechanical protection operated.	FORCED

Transmission Line Outages/Trippings from 13.05.2024 to 19.05.2024							
Name of Line	Date Trip	Time Trip	Date Sync	Time Sync	Reason	Outage Type	Voltage
TIE BAY - 705 OF EKTUNI-AKOLA II ckt-1 @ EKTUNI	14-05-2024	10:19	14-05-2024	17:05	Outage required for routine testing and Maintenance Works	PO	765 KV
CHANDRAPUR - PADGHE HVDC POLE 1	13-05-2024	16:07	13-05-2024	16:36	It was tripped on commutation failure dt. 13.05.2024 @16.07 hrs due to voltage dip occurred owing to transient faults in the system.	T	500 KV
CHANDRAPUR - PADGHE HVDC POLE 2	13-05-2024	16:10	13-05-2024	16:49	It was tripped on commutation failure dt. 13.05.2024 @16.10 hrs due to voltage dip occurred owing to transient faults in the system.	T	500 KV
33KV ANJUR- PADGHE ELECTRODE	17-05-2024	23:20	18-05-2024	04:56	For emergency line maintenance work.	HT	500 KV
AURANGABAD(MS) - PUNE (GIS)	01-05-2024	22:11	13-05-2024	17:06	For faciliating outage on 765 Kv	HT	400 KV
BABHALESHWAR - PADGHE CKT - 2	10-05-2024	09:56	14-05-2024	18:52	1. B Bus PG Isolator Replacement work under LES Scheme. 2. CB Diagnostic Testing Work. 3.400kV BBLR-II in service through TBC.	PO	400 KV
MAIN BUS - 2 @ PADGHE	10-05-2024	10:23	14-05-2024	14:57	1.Replacement of Hanger Assembly of B Bus PG Isolator of BBLR-2 by Hot Line Method. 2.All Feeders on B Bus will be in service.	PO	400 KV
DHULE - SSNNL CKT - 1	12-05-2024	16:10	13-05-2024	19:32	Tripped on distance protection	T	400 KV
220 KV WARORA - CHANDRAPUR (400 KV) CKT	13-05-2024	09:28	13-05-2024	19:49	Retrofitting of distance relay ALSTOM/GE make.	PO	400 KV
400/220 KV 3X200 MVA ICT - 2 @ KALWA	13-05-2024	15:47	13-05-2024	16:25	Tripped due to 220 kV Bus 2 LBB protection operated	T	400 KV
400/220/20 KV 500MVA ICT - 1 @ KALWA	13-05-2024	15:47	13-05-2024	18:39	220KV bus 2 LBB operated due to DCHI feeder.	T	400 KV
400/220/33 KV 315 MVA ICT - 2 @ KHARGHAR	13-05-2024	15:53	13-05-2024	16:26	Tripped on OSR protection	T	400 KV
400/220/33 KV 500MVA ICT - 2 @ WARORA	13-05-2024	09:45	16-05-2024	12:37	CB, CT Diagnostic Testing work	PO	400 KV
400/220KV 315 MVA ICT - 2 @ NEW KOYNA	13-05-2024	10:41	13-05-2024	22:44	Diagnostic testing & Relay testing work , Routine maint. Work	PO	400 KV
220 KV CHANDRAPUR GCR - CHANDRAPUR 2 CKT	14-05-2024	09:10	14-05-2024	19:08	Retrofitting of distance Relay	PO	400 KV
400/220 KV 315MVA ICT - 1 @ KARAD	14-05-2024	18:10	14-05-2024	20:24	Tripped on Rph. OLTC buchholz.	T	400 KV
AURANGABAD(MS) - AURANGABAD(PG) CKT -2	14-05-2024	12:40	14-05-2024	19:16	CVT replacement work		400 KV
AURANGABAD(MS) - PUNE (GIS) CKT - 1	14-05-2024	12:30			HT for load Management	HT	400 KV
DABHOL - NAGOTHANE CKT - 1	14-05-2024	13:37	14-05-2024	18:02	Cold Washing Work	PO	400 KV

Transmission Line Outages/Trippings from 13.05.2024 to 19.05.2024							
Name of Line	Date Trip	Time Trip	Date Sync	Time Sync	Reason	Outage Type	Voltage
DHULE - SSNNL CKT - 2	14-05-2024	09:11	14-05-2024	18:38	For Replacement of Missing Earth wire, Missing Hardware , Cold line washing & Other maintenance work.400 KV Dhule-SSNNL CKT 1 Auto Reclose switchwill be kept on Non Auto mode during Outage	PO	400 KV
MAIN BAY (405) OF KHADKA CKT - 1 @ DEEPNAGAR	14-05-2024	08:07	14-05-2024	11:43	For the work of chemical cleaning (cold line cleaning and washing) of insulator of equipments at 400 KV Deepnagar-Khadka Ckt 1 Main bay	PO	400 KV
TIE BAY (406) OF KHADKA CKT - 1 @ DEEPNAGAR	14-05-2024	16:23	14-05-2024	19:02	For the work of chemical cleaning (cold line cleaning and washing) of insulator of equipments at 400 KV Deepnagar-Khadka Ckt 1 TIE bay	PO	400 KV
CHANDRAPUR 2 - DHARIWAL CKT - 1	15-05-2024	07:28	15-05-2024	16:45	outage on 400 kv line for pm and bay equipments testing work	PO	400 KV
KORADI - KHAPERKHEDA CKT - 2	15-05-2024	13:42	15-05-2024	18:12	Diagnostic Testing of CTs	PO	400 KV
EKTUNI - BABLESHWAR CKT - 1	15-05-2024	19:43	16-05-2024	01:10	Line Maintenance Works & Bay Maintenance Works	PO	400 KV
MAIN BAY (411) of THAPTITANDA @ DEEPNAGAR	15-05-2024	08:12	15-05-2024	10:05	For the work of chemical cleaning (cold line cleaning and washing) of insulator of equipments at 400 KV Deepnagar-Tapatitanda Ckt Main bay	PO	400 KV
PARLI-SOLAPUR (LAMBOTI)	15-05-2024	17:02	15-05-2024	21:39	1) Distance M1 & M2 relays retrofitting work. (2) Bay maintenance work. 3)Hardware tightening & fitting work	PO	400 KV
CHANDRAPUR 2 - KUMBHARGAON(NANDED) CKT - 2	16-05-2024	06:38	16-05-2024	16:00	Daignostic testing and allied maintenance work	PO	400 KV
220 KV KORADI (400 KV) - BUTIBORI CKT	16-05-2024	08:06	16-05-2024	12:05	Measurement of ct tan delta & isolator routine maintenance works. (outage by 400/220kv koradi-1 s/s).	HT	400 KV
DHULE- - BABLESHWAR CKT - 1	16-05-2024	12:06	16-05-2024	19:24	400 kV Dhule -Bableshtar ckt 1 Routine line maintenance work	PO	400 KV
LONIKAND II - LONIKAND I (INTERCONNECTOR) - 1	16-05-2024	09:25	16-05-2024	17:43	DT Work & Bay Maintenance	PO	400 KV
MAIN BAY (414) OF 500 MVA ICT - 2 @ DEEPNAGAR	16-05-2024	09:55	16-05-2024	11:11	For Chemical Cleaning of equipment of ICT-2 Main Bay	PO	400 KV
PADGHE - BOISAR (PG)	16-05-2024	17:46	16-05-2024	19:08	Tripped on distance protection	T	400 KV
PARLI - KARJAT CKT - 2	16-05-2024	14:43	16-05-2024	16:46	Tripped on distance protection	T	400 KV
TIE BAY (415) OF 500MVA ICT - 2 & STATION TF 4A @ DEEPNAGAR	16-05-2024	16:20	16-05-2024	19:06	For Chemical Cleaning of equipment of ICT-2 TIE Bay	PO	400 KV
220 KV DEEPNAGAR - VIRODA CKT	17-05-2024	15:00	17-05-2024	18:04	Replacement of r- ph flashover string at loc no 45.	HT	400 KV
400/220/33 KV 315 MVA ICT - 3 @ KHARGHAR	17-05-2024	18:15	17-05-2024	23:12	For Diagnostic and Testing Activities	PO	400 KV

Transmission Line Outages/Trippings from 13.05.2024 to 19.05.2024							
Name of Line	Date Trip	Time Trip	Date Sync	Time Sync	Reason	Outage Type	Voltage
400/220/33 KV 500MVA ICT - 2 @ KHAPARKHEDA	17-05-2024	07:28			Replacement of R Ph & Y Ph Unit Neutral Bushing along with oil filtration	PO	400 KV
DABHOL - NAGOTHANE CKT - 2	17-05-2024	11:40	17-05-2024	18:33	Cold Washing Work	PO	400 KV
DHULE - SSNNL CKT - 1	17-05-2024	08:20	17-05-2024	18:18	Replacement of 400KV Line dropping jumpers	PO	400 KV
MAIN BAY (405) OF 315 MVA ICT - 2 @ AKOLA	17-05-2024	17:46	17-05-2024	18:17	Attend the mis alignment of 40589b r-phase isolator.	HT	400 KV
MAIN BAY (417) OF 500 MVA ICT - 1 @ DEEPNAGAR	17-05-2024	08:29	17-05-2024	11:55	For Chemical Cleaning of Equipment of ICT-1 Main Bay	PO	400 KV
TIE BAY (418) OF ICT - 1 & ST 4B @ DEEPNAGAR	17-05-2024	17:17	17-05-2024	19:52	For Chemical Cleaning of equipment of ICT-1 TIE Bay	PO	400 KV
AURANGABAD(MS) - PUNE (GIS) CKT - 2	18-05-2024	15:25	18-05-2024	18:06	H/T for load management	HT	400 KV
PARLI - KARJAT CKT - 2	18-05-2024	19:26	19-05-2024	01:10	Hardware tightening and cold line Cleaning	PO	400 KV
PUNE(GIS) - TALEGAON(PG) CKT - 3	18-05-2024	12:17	18-05-2024	18:24	Emergency outage by powergrid	HT	400 KV
STATION TRANSFORMER - 1 @ NANDGAON PETH	18-05-2024	06:20			Following work will be carried out during Station Transformer-1 outage Period :- 1. ST#1- OLTC maintenance work(Before & After DCRM testing, oil Filtration & Diverter Switch Maintenance) 2. Complete ST#1 transformer testing. 3. FDS & SFRA test of transformer. 4. Testing of LA, MCT & MCVT.	PO	400 KV
PARLI - KARJAT CKT - 1	19-05-2024	21:09	20-05-2024	03:01	Hardware tightening and cold line Cleaning	PO	400 KV
PARLI - KARJAT CKT - 2	19-05-2024	15:35	19-05-2024	16:16	Tripped on distance protection	T	400 KV
EKLAHARE (OCR) - NAVASARI CKT - 2	11-05-2024	17:20	13-05-2024	13:07	H/T for load management	T	220 KV
APTA - TALOJA	13-05-2024	16:37	13-05-2024	18:39	tripped on distance protection	T	220 KV
EKLAHARE (OCR) - NAVASARI CKT - 1	13-05-2024	13:27	18-05-2024	13:18	To make the LILO point connection at Loc. 1 (Loc. 19 of 220kV Nashik - Navsari Line) of new 220kV CPRI Line & substation	PO	220 KV
KALWA - MULUND 1	13-05-2024	15:47	13-05-2024	18:49	Tripped due to 220 kV Bus 2 LBB protection operated at 400 kV Kalwa	T	220 KV
KALWA - BORIVALI	13-05-2024	15:47	13-05-2024	16:44	Tripped due to 220 kV Bus 2 LBB protection operated at 400 kV Kalwa	T	220 KV
KALWA - MULUND 2	13-05-2024	15:50	13-05-2024	16:49	Tripped on backup protection	T	220 KV
KALWA - TFIPL	13-05-2024	15:47	13-05-2024	16:45	Tripped due to 220 kV Bus 2 LBB protection operated at 400 kV Kalwa ss	T	220 KV

Transmission Line Outages/Trippings from 13.05.2024 to 19.05.2024							
Name of Line	Date Trip	Time Trip	Date Sync	Time Sync	Reason	Outage Type	Voltage
MUDSHINGI - CHIKODI	13-05-2024	11:25	13-05-2024	20:28	For all phases conductor restringing work between tower loc no. 271 to 280.	PO	220 KV
PANDHARPUR - MALINAGAR	13-05-2024	11:43	13-05-2024	18:32	Destringing & strining from Loc no. 37 to 46 to attain issue of low ground clearance.	PO	220 KV
URAN - APTA 2	13-05-2024	17:00	15-05-2024	19:08	conductor snapping at loc 5,6	T	220 KV
URAN - APTA 3	13-05-2024	17:00	13-05-2024	22:19	Conductor snapping of Apta ckt 2 at loc. 5,6	T	220 KV
URAN - APTA 4	13-05-2024	17:00	13-05-2024	22:18	Conductor snapping of Apta ckt 2 at loc. 5,6	T	220 KV
132 KV HARANGUL CHAKUR CKT	13-05-2024	12:14	13-05-2024	14:22	Flashover disc replacement work.	PO	220 KV
220 kV-Wardha(PG)-Yawatmal Ckt-1	13-05-2024	14:30	13-05-2024	19:43	For attending hot glow on y-ph jumper pad on Yavatmal side at loc no. 97.		220 KV
220/110 kV 200 MVA ICT 3 @ MUDSHINGI	13-05-2024	09:08	13-05-2024	18:07	1) Annual Diagnostic testing of TF (C & tan delta,DFRA etc) 2) Quarterly maint. Work	PO	220 KV
220/132 KV 100 MVA ICT 2	13-05-2024	08:30	13-05-2024	12:25	For diagnostic testing work.	PO	220 KV
220/33 KV 50 MVA PTR - 7 @ WATHAR	13-05-2024	10:24	13-05-2024	18:07	Quarterly maint work	PO	220 KV
220/33-33KV 100MVA TF- 2 @ ICHALKARANJI - II	13-05-2024	09:54	13-05-2024	18:05	1) Relay Replacement work 2) Buchlozs Relay replacement work & 3) TF Painting work.	PO	220 KV
220KV KALWA - GIS DCHI	13-05-2024	15:47	14-05-2024	01:49	Tripped on distance protection	T	220 KV
BHAVEGHAR - ROMA	13-05-2024	15:42	13-05-2024	17:21	Tripped on distance protection	T	220 KV
KALWA SALSETTE - 3	13-05-2024	15:47	13-05-2024	16:28	Tripped due to 220 kV Bus 2 LBB protection operated at 400 kV Kalwa	T	220 KV
KHARGHAR - BORIVALI CKT - 2	13-05-2024	15:42	13-05-2024	22:15	Tipped on distance protection	T	220 KV
KHARGHAR - KHANDESHWAR CKT - 2	13-05-2024	15:47	13-05-2024	18:34	Tripped on distance protection	T	220 KV
LONAND - KANDALGAON (SONA ALLOY TAP)	13-05-2024	18:06	13-05-2024	18:22	Tripped on distance protection	T	220 KV
NEW KOYNA - LOTEPARSHURAM	13-05-2024	17:29	13-05-2024	19:14	Tripped on distance protection	T	220 KV
PALGHAR - NALASOPARA	13-05-2024	15:02	13-05-2024	17:45	Tripped on distance protection	T	220 KV
TROMBAY - VIKHROLI (GIS) CKT - 1 / CARNAC 7	13-05-2024	16:14	13-05-2024	16:23	Tripped on distance protection	T	220 KV
TROMBAY - VIKHROLI (GIS) CKT - 4	13-05-2024	16:10	13-05-2024	18:43	Tripped on distance protection	T	220 KV
URAN - APTA CKT - 1	13-05-2024	23:09	14-05-2024	02:04	For hot spot attending work at wave trap Y Ph bottem clamp (hotspot temperature 70 degC)	EO	220 KV
EKLAHARE (GCR) - GHATGHAR	14-05-2024	17:04	15-05-2024	06:14	Tripped on distance protection.	T	220 KV
KALWA - BORIVALI	14-05-2024	22:16	15-05-2024	05:06	For the installation of saver assembly sets at TL no. 4, 7, 20, 21, 22, 23, 25 & 26 (Total 27 sets out of 33 sets are to be installed)	PO	220 KV

Transmission Line Outages/Trippings from 13.05.2024 to 19.05.2024							
Name of Line	Date Trip	Time Trip	Date Sync	Time Sync	Reason	Outage Type	Voltage
KALWA - SIEMENS	14-05-2024	02:05	14-05-2024	05:51	To attend red hotspot on top ph jumper cone at Siemens LLO loc. No. 1	EO	220 KV
MALHARPETH - KARAD	14-05-2024	12:51	14-05-2024	17:02	Erection of B Ph Coupling Capacitor & Quarterly Maintenance Work at 220kV Malharpeth end	PO	220 KV
MIRAJ - ICHALKARANJI	14-05-2024	13:03	14-05-2024	20:31	1)For replacement of Relay & testing work only	PO	220 KV
PANDHARPUR - MALINAGAR	14-05-2024	16:18	14-05-2024	19:20	Destringing & strining from Loc no. 37 to 46 to attain issue of low ground clearance.	PO	220 KV
TILLARI - AMONA LINE	14-05-2024	09:35	15-05-2024	00:31	For replacement of polymer by longrod	PO	220 KV
220/132 100MVA ICT-1 @ AMRAPUR	14-05-2024	16:14	14-05-2024	20:20	1)Premansoon Maintenance of both ICT 2) Tan Delta of Both ICT 3)SFRA of ICT I by Mobile Testing Unit , Nashik.	PO	220 KV
220/132 100MVA ICT-2 @ AMRAPUR	14-05-2024	16:15	14-05-2024	20:22	Premansoon Maintenance of both ICT 2) Tan Delta of Both ICT 3)SFRA of ICT I by Mobile Testing Unit , Nashik.	PO	220 KV
220/132 KV 100 MVA ICT 1	14-05-2024	09:25	14-05-2024	14:01	R.M.work	PO	220 KV
220/132 KV 200 MVA ICT - 2 @ HARANGUL	14-05-2024	08:18	14-05-2024	17:44	Maintenance work	PO	220 KV
220/132-110 KV 100MVA ICT 2 @ JATH	14-05-2024	16:01	14-05-2024	17:33	LV Side Y & B Ph CT Oil filling Work	PO	220 KV
220KV GEORAI(220KV)-TAPTITHANDA(400KV)CKT	14-05-2024	15:35	14-05-2024	16:42	Distance Protection	T	220 KV
220KV PANDHARKAWDA - WANI CKT I	14-05-2024	07:19	14-05-2024	12:34	Measurement of Tan Delta	PO	220 KV
BORIVALI - CTRLS CKT	14-05-2024	22:11	15-05-2024	04:53	For the installation of saver assembly sets at TL no. 27/3, 28, 43, 45, 46, 47 & 48 (Total 24 sets out of 60 sets are to be installed)	PO	220 KV
MAIN BUS @ TOPWORTH	14-05-2024	15:46	14-05-2024	19:17	"Maintenance work and Diagnostic Testing Work of metering CT, PT, and protection CT, PT & CBs. "	PO	220 KV
NEW KOYNA - LOTEPARSHURAM	14-05-2024	15:26	14-05-2024	17:40	Tripped on distance protection.	T	220 KV
PARLI 3(OLD GCR)-PARLI NEWTPS CKT 1	14-05-2024	14:05	14-05-2024	19:51	220KV Y Phase CT replacement work	PO	220 KV
TOPWORTH - KHANDESHWAR	14-05-2024	15:45	14-05-2024	23:10	"Routine Lines Maintenance Work Diagnostic Testing of metering CT and bus isolator maintenance work at Topworth S/s"	PO	220 KV
TOPWORTH - Vile - bhagad	14-05-2024	15:43	14-05-2024	19:17	"Maintenance work and Diagnostic Testing Work of metering CT, PT, and protection CT, PT & CBs. "	PO	220 KV

Transmission Line Outages/Trippings from 13.05.2024 to 19.05.2024							
Name of Line	Date Trip	Time Trip	Date Sync	Time Sync	Reason	Outage Type	Voltage
220 KV KHAPARKHEDA 2 (NEW) - KANHAN CKT	15-05-2024	06:50	15-05-2024	16:21	REPLACEMENT OF F/O INSULATOR STRGS_ VARIOUS LOCATIONS	PO	220 KV
BIDRI - SAWANTWADI	15-05-2024	11:52	15-05-2024	13:27	For Diagnostic testing & pre-monsoon work.	PO	220 KV
GADCHANDUR - VIRUR-I	15-05-2024	06:03	15-05-2024	12:27	1) FIXING OF REPAIR SLEEVE AT LOC NO. 42 B-PH 2) FIXING OF REPAIR SLEEVE & ARCHING HORN NUTBOLTS AT LOC NO.46 B-PH		220 KV
KHAPARKHEDA-KALMESHWAR	15-05-2024	07:00	15-05-2024	16:42	REPLACEMENT OF F/O INSULATOR STRGS_ VARIOUS LOCATIONS	PO	220 KV
OSMANABAD - BARSHI	15-05-2024	09:29	15-05-2024	15:52	BUS OUTAGE AT 220 KV BARSHI END.		220 KV
TALANDGE - SAWANTWADI	15-05-2024	09:32	15-05-2024	11:45	Diagnostic testing & pre-monsoon work.	PO	220 KV
100 MVA 220/132 KV ICT 1	15-05-2024	09:26	15-05-2024	10:55	PRE MONSOON MAINTENANCE WORK	PO	220 KV
100 MVA 220/132 KV ICT 2	15-05-2024	11:01	15-05-2024	12:40	PRE MONSOON MAINTENANCE WORK	PO	220 KV
220 KV CHANDRAPUR GCR (400 KV) - WANI CKT	15-05-2024	14:10	15-05-2024	19:26	DIAGNOSTIC TESTING AND ROUTINE MAINTENANCE WORK. CT TAN DELTA, IR & CB CRM	PO	220 KV
220 KV HARANGUL - PARLY (PG) CKT	15-05-2024	10:32	15-05-2024	20:02	AMP of Line Bay	PO	220 KV
220/132 KV 200 MVA ICT 1@ BALE(SOLAPUR)	15-05-2024	10:15	15-05-2024	16:19	Quarterly Maintenance	PO	220 KV
220/132 KV 200 MVA ICT 1 @ AMALNER	15-05-2024	17:04	16-05-2024	21:27	SFRA & diagnostic testing related work & premonsoon activity related work.	HT	220 KV

Transmission Line Outages/Trippings from 13.05.2024 to 19.05.2024							
Name of Line	Date Trip	Time Trip	Date Sync	Time Sync	Reason	Outage Type	Voltage
220/33 KV 50 MVA TF I	15-05-2024	07:54	15-05-2024	14:12	1) DIAGNOSTIC TESTING WORK OF HV & LV BAY EQUIPMENTS 2) LV CB OVERHAULING WORK BY AGENCY M/S A. V. ENTERPRISES, AURANGABAD & LV CT NUT BOLT TIGHTENING WORK. 3) OLTC REMOTE OPERATION/ CONTROLLING WORK	PO	220 KV
220KV PANDHARKAWDA - WANI CKT I	15-05-2024	09:07	15-05-2024	13:47	AN-DELTA AND CAPACITANCE MEASUREMENT OF CT AND CRM OF CB	PO	220 KV
220KV PANDHARKAWDA - WANI CKT II	15-05-2024	09:07	15-05-2024	13:47	AN-DELTA AND CAPACITANCE MEASUREMENT OF CT AND CRM OF CB	PO	220 KV
220KV WARORA(220KV)-400KV WARORA(400KV)	15-05-2024	08:54	15-05-2024	13:21	HOTSPOTATTENDING	PO	220 KV
BUS @ BARSHI	15-05-2024	09:29	15-05-2024	15:50	Quarterly Maintenance	PO	220 KV
LAMBOTI - KARKAMB	15-05-2024	10:19	15-05-2024	19:57	Restraining of R Phase of Lamboti-Karkamb from Loc no.521 to 532 A for minimum safety clearance.	PO	220 KV
GADCHANDUR - VIRUR-II	16-05-2024	06:04	16-05-2024	11:44	Replacement of disc insulator string at loc no. 36 B-PH AND 71 B-PH.	HT	220 KV
JEJURI-PHURSUNGI 1	16-05-2024	05:55	16-05-2024	18:07	For Double Jumpering work Due to hotpost 1)L.N.-15, B Phase,82 Degree (D/C tower) 2) L.N.-21,R Phase,43 Degree (M/c tower) 3) L.N.-10,Y phase, 50 Degree 4) L.N.-6	PO	220 KV
TALANDAGE - CHIKODI	16-05-2024	10:34	16-05-2024	18:41	For all phases conductor restringing work between tower loc no. 271 to 280.	PO	220 KV
TALANDGE - ICHALKARANJI 2	16-05-2024	21:19	17-05-2024	01:31	1) For relay replacement work & testing work	PO	220 KV

Transmission Line Outages/Trippings from 13.05.2024 to 19.05.2024							
Name of Line	Date Trip	Time Trip	Date Sync	Time Sync	Reason	Outage Type	Voltage
URAN - ONGC URAN	16-05-2024	11:14	16-05-2024	19:31	For Distance relay replacement work at 220kV ONGC(uran) S/S. Existing D60 GE make relay is having error while communicating, thus DR taking not possible and relay setting cannot be done in currently installed distance relay, Hence GE Engineer alongwith Uran testing team will be replacing the existing relay.	PO	220 KV
220 KV KALMESHWAR WARUD CKT I	16-05-2024	08:25	16-05-2024	16:48	Punch point rectification work in r/o phase-v.	HT	220 KV
220 KV KALMESHWAR WARUD CKT II	16-05-2024	08:25	16-05-2024	16:50	Punch point rectification work in r/o phase-v.	HT	220 KV
220/132 KV 200 MVA ICT 1@ RANJANGAON	16-05-2024	10:59	16-05-2024	13:35	For Premansoon Bay maintenance work.	PO	220 KV
220/22KV 50MVA PTR 2 @ CHAKAN PHASE II	16-05-2024	10:07	16-05-2024	17:06	Diagnostic testing work, half Yearly and pre mansoon maintenance .	PO	220 KV
220/33 KV 50MVA PTR - 1 @ KALWAN	16-05-2024	11:10	16-05-2024	15:29	Pre-monsoon maintenance work.	PO	220 KV
220/33 KV 50MVA PTR - 2 @ KALWAN	16-05-2024	15:36	16-05-2024	18:31	Pre-monsoon maintenance work	PO	220 KV
220/33KV 25MVA PTR 3 @ @ KHAREPATAN	16-05-2024	08:01	16-05-2024	15:12	Premansoon maintenance work of EMCO make PTR-1.	PO	220 KV
220KV BUS PT 1	16-05-2024	12:00	16-05-2024	16:31	An outage required for replacement of 220 kv main bus section 1 -r,y ph pt under les scheme.	HT	220 KV
BADNERA - AMRAVATI	16-05-2024	09:00	16-05-2024	13:25	Replacement of flashover disc at loc no.04 b-ph, 62 b-ph, 85 r-ph normal tower.	HT	220 KV
BHAVEGHAR - ROMA	16-05-2024	18:41	16-05-2024	19:50	Tripped on distance protection	T	220 KV
BHIGWAN-BARAMATI AGRO	16-05-2024	11:10	16-05-2024	17:40	For replacement of R PH CT having oil leakage(through sec bushing)	PO	220 KV
JEUR - SOLAPUR PG	16-05-2024	14:06	16-05-2024	17:17	Tripped on distance protection	T	220 KV
KARAD - WATHAR	16-05-2024	06:21	16-05-2024	09:44	To replace flashover R ph polymer STN insulator string at loc no Lilo- 1.	PO	220 KV
LONAND - KANDALGAON (SONA ALLOY TAP)	16-05-2024	15:17	16-05-2024	19:50	Tripped on distance protection	T	220 KV
NEW KOYNA - LOTEPARSHURAM	16-05-2024	17:32	16-05-2024	22:50	For attending hotspot at loc no. 00 and 01 of 220kV Lote LILO location, cold washing and other line maintenance work.	PO	220 KV
PADGHE - PAL DOMBIVALI	16-05-2024	10:21	18-05-2024	19:01	Permission for shifting of 220kV Padghe-Pal line on TBC for pole overhauling work of own CB of 220kV Padghe- Pal Line	PO	220 KV
RANJANGAON - U TECH SUGAR CKT	16-05-2024	05:31	16-05-2024	13:12	Replacement of flashover disc insulator string at loc no. 247 R-ph, 37 B-ph,39 R-ph, & conductor damage at loc no. 248-249	PO	220 KV
TOPWORTH - KHANDESHWAR	16-05-2024	16:24	16-05-2024	18:35	Tripped on distance protection	T	220 KV

Transmission Line Outages/Trippings from 13.05.2024 to 19.05.2024							
Name of Line	Date Trip	Time Trip	Date Sync	Time Sync	Reason	Outage Type	Voltage
WAGHIVALI - DHARAVI 8	16-05-2024	06:08	16-05-2024	09:44	Work in vicinity of 110KV Mandale project	PO	220 KV
BOISAR II - BOISAR (PG) CKT - 1	17-05-2024	04:56	17-05-2024	09:25	work for replacement of existing 0.4 ACSR Zebra Conductor and all its Hardware by equivalent CCC HTLS Conductor and suitable Hardware for 220kV Boisar - PGCIL (Dead Line). Outage required of 220kV PGCIL - Boisar Line No. 1 for safety purpose only.	PO	220 KV
BUTIBORI 3 - WARDHA	17-05-2024	08:48	17-05-2024	13:47	1) complete diagnostic testing & to attend oil leakage on r ph ct 2) routine line maintenance work will be carried out by ehv lmsdn, wardha being in opportunity outage period .	HT	220 KV
100 MVA 220/132 KV ICT - I @ NARANGWADI	17-05-2024	11:00	17-05-2024	13:56	Routine maintenance and premonsoon maintenance work.	HT	220 KV
220/132 KV 100 MVA ICT 1 @ SAWANGI	17-05-2024	10:28	17-05-2024	18:02	Premon soon maint.& diagnostic testing work.	HT	220 KV
220/132 KV 150 MVA PTR NO 7 @ CHINCHWAD	17-05-2024	14:01	17-05-2024	21:26	Pre-monsoon maintenance, DT and Aux. Trials	PO	220 KV
220/132 KV 200MVA PTR NO 3 @ CHINCHWAD	17-05-2024	09:20	17-05-2024	13:25	Pre-monsoon maintenance, DT and Aux. Trials	PO	220 KV
220/33KV 100MVA PTR 1 @ GHATNANDRE	17-05-2024	16:38	17-05-2024	18:20	1.Diagnostic Testing Work 2.Quarterly Maintenance Work	PO	220 KV
220/33KV 100MVA PTR 2 @ GHATNANDRE	17-05-2024	09:30	17-05-2024	13:40	1.Diagnostic Testing Work 2.Quarterly Maintenance Work	PO	220 KV
220/33KV 100MVA PTR 3 @ GHATNANDRE	17-05-2024	14:48	17-05-2024	16:32	1.Diagnostic Testing Work 2.Quarterly Maintenance Work	PO	220 KV
220/33KV 50MVA TF NO.1 @ SAYNE	17-05-2024	12:21	17-05-2024	17:20	Pre-monsoon maintenance work Replacement of jumps of 33kV CT to CB & CB to Main Bus Iso of R-Ph & B-Ph.	PO	220 KV
BADNERA-AKOLA II	17-05-2024	09:01	17-05-2024	11:10	Replacement of flashover disc at loc. no. 61 (b) phase normal tower.	HT	220 KV
NEW KOYNA - PEDAMBE	17-05-2024	18:04	17-05-2024	19:42	Tripped on Backup protection at New koyna end only.	T	220 KV
POPHALI - KDPH	17-05-2024	09:35	17-05-2024	15:15	For emergency tree cutting work in reserve forest area and other line maintenance work.	PO	220 KV
TBC @ ANANDNAGAR	17-05-2024	09:20	17-05-2024	14:47	220 KV TBC Main bus isolator jumper removal & connection work to be carried out by hot line team and isolator maintenance work to be done by maintenance team Dombivali.	PO	220 KV
WAGHIVALI - DHARAVI 8	17-05-2024	06:06	17-05-2024	08:32	MANDALE PROJECT WORK IN VICINITY	PO	220 KV
ADLABS - PEDAMBE	18-05-2024	20:21	18-05-2024	20:45	tripped on distance protection	T	220 KV

Transmission Line Outages/Trippings from 13.05.2024 to 19.05.2024							
Name of Line	Date Trip	Time Trip	Date Sync	Time Sync	Reason	Outage Type	Voltage
BOISAR II - BOISAR (PG) CKT - 1	18-05-2024	05:20	18-05-2024	10:02	work for replacement of existing 0.4 ACSR Zebra Conductor and all its Hardware by equivalent CCC HTLS Conductor and suitable Hardware for 220kV Boisar - PGCIL (Dead Line). Outage required of 220kV PGCIL - Boisar Line No. 1 for safety purpose only.	PO	220 KV
CHALISGAON -BABHALESHWAR	18-05-2024	11:17	18-05-2024	16:43	Emergency outage at B Shwer end.	PO	220 KV
CHANDRAPUR GCR - SICOM I	18-05-2024	08:56	18-05-2024	17:45	Distance protection relay retrofitting work and maintenance work.	PO	220 KV
GHATODI-NANDED	18-05-2024	09:40	18-05-2024	17:22	LMSD Work.	PO	220 KV
200 MVA 220/132 KV ICT - 1 @ VIRODA	18-05-2024	10:25	18-05-2024	19:19	Pre-monsoon maintenance work.	PO	220 KV
220 / 110 / 23kV 250 MVA ICT 3 @ SALSETTE	18-05-2024	00:34	18-05-2024	05:45	PM CHECK	PO	220 KV
220/132 KV 100 MVA ICT II	18-05-2024	16:43	18-05-2024	18:14	Pre-monsoon maintenance & Diagnostic testing work.	PO	220 KV
220/132/11 KV 200 MVA ICT 2 @ AMRAVATI	18-05-2024	08:02	18-05-2024	16:43	Diagnostic testing work	PO	220 KV
220/33KV 50MVA PTR 1@ PETH	18-05-2024	14:08	18-05-2024	18:13	Pre Monsoon Maintenance Work	PO	220 KV
MAIN BUS - 1 @ SOUTH SOLAPUR	18-05-2024	10:40	18-05-2024	13:15	Outage is required for Erection of main Bus isolators for main bus-I & main bus-II forr 250MW Maruti Wind power project	PO	220 KV
MAIN BUS - 2 @ SOUTH SOLAPUR	18-05-2024	14:00	18-05-2024	16:15	Outage is required for Erection of main Bus isolators for main bus-I & main bus-II forr 250MW Maruti Wind power project	PO	220 KV
NERLE - PEDAMBE	18-05-2024	17:41	18-05-2024	19:10	Tripped on distance protection	T	220 KV
PARAS-BALAPUR I	18-05-2024	09:52	18-05-2024	13:18	Dislocated pilot suspension clamp fixing work.		220 KV
PARAS-BALAPUR III	18-05-2024	10:12	18-05-2024	13:20	Dislocated pilot suspension clamp fixing work.		220 KV
PEDAMBE-KALAMBANI(TSS)	18-05-2024	20:11	18-05-2024	21:40	Tripped on distance protection	T	220 KV
TROMBAY MSETCL TIE - 1	18-05-2024	23:37	19-05-2024	06:58	L.A. replacement	PO	220 KV
VSNL- KHADKI	18-05-2024	08:21	18-05-2024	19:48	For Stringing between New Monopole Loc No. 30 B to 31	PO	220 KV
WAGHIVALI - DHARAVI 8	18-05-2024	06:39	18-05-2024	09:21	MANDALE PROJECT WORK IN VICINITY	PO	220 KV
HALKARNI - TILARI LINE	19-05-2024	19:25	19-05-2024	20:33	Zone 2 tripping	T	220 KV
KALWA - MULUND 1	19-05-2024	07:15	19-05-2024	15:51	Rph CT replacement Work due to high tan-d value.	PO	220 KV
KANDALGAON - PIRANGUT	19-05-2024	05:13	19-05-2024	15:05	For double jumpering work & attending hot spot at various locations.	PO	220 KV
TILLARI - AMONA LINE	19-05-2024	19:25	19-05-2024	21:35	zone 2 trip.	T	220 KV
TILLARI - AMONA LINE	19-05-2024	16:30	19-05-2024	18:05	Tripped on distance protection	T	220 KV
220/110/33KV 250 MVA ICT-4 @ MAHALAXMI GIS (T)	19-05-2024	10:02	19-05-2024	18:48	R/M AND TESTING	PO	220 KV

Transmission Line Outages/Trippings from 13.05.2024 to 19.05.2024							
Name of Line	Date Trip	Time Trip	Date Sync	Time Sync	Reason	Outage Type	Voltage
220KV KARJAT-AHMEDNAGAR-CKT-1	19-05-2024	15:40	19-05-2024	19:19	Tripped on distance protection	T	220 KV
KALWA - SALESETTE CKT - 5	19-05-2024	08:35	19-05-2024	09:17	REMOVAL OF BIRD NEST	PO	220 KV
PEDAMBE-KALAMBANI(TSS)	19-05-2024	20:05	19-05-2024	21:24	Tripped on distance protection	T	220 KV
VANKUSWADE - KDPH	19-05-2024	09:55	19-05-2024	14:30	Replacement of flashover string at loc no.50 R ph & replacement of damaged jump at loc no.53 Y ph	PO	220 KV
AMALNER(220KV)-NARDANA	15-05-2024	08:53	15-05-2024	11:24	R-PH LA REPLACEMENT WORK & PREMONSOON MAINTAINANCE WORK	PO	132 KV
PUSAD-JAMBAZAR	15-05-2024	15:09	15-05-2024	17:09	TESTING OF RELAYS BY PROTECTION UNIT	PO	132 KV
WAGHIVALI - CHEMBUR	15-05-2024	09:00	15-05-2024	12:09	Insulator & Guard wire replacement from loc 54 - 58	PO	110 KV
KHOPOLI - BHOKARPADA	17-05-2024	22:27	18-05-2024	04:23	RECONNECTION OF CT	PO	110 KV
ZONE 1 (BUS SECTION 1+2+3) @ BHIVPURI	19-05-2024	06:00	19-05-2024	19:18	R/M AND TESTING	PO	110 KV