

State Load Despatch Center,Airoli (MSETCL)
Power System Position from 15/Jun/2015 to 21/Jun/2015

Supply Position During Morning Peak (MW)

Date	Time	MSGENCO				Central Sector Receipt	Wind	CPP	SOLAR	TPCL Exch.	MSEDCL Catered Demand	Load Shedding(LS)	MSEDCL Demand (Incl. LS)	TPCL Gen.	R-INFRA Gen.	State Demand Met	State Demand (Incl. LS)	Freq.
		THM	HYDRO	GAS	Total													
		MW	MW	MW	MW	MW	MW	MW	MW	MW	MW	MW	MW	MW	MW	MW	MW	Hzs
15/06/2015	11 Hrs	4666	302	135	5103	4582	1290	3744	116	-1272	13563	43	13606	983	510	16328	16371	49.99
16/06/2015	11 Hrs	4777	536	132	5445	4605	1101	4001	90	-1524	13718	43	13761	890	510	16642	16685	49.99
17/06/2015	11 Hrs	4684	311	266	5261	5591	861	3932	128	-1577	14196	42	14238	983	249	17005	17047	49.97
18/06/2015	null	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	
19/06/2015	9 Hrs	4478	84	251	4813	4496	1310	3363	61	-1123	12920	41	12961	657	257	14957	14998	50.01
20/06/2015	10 Hrs	4541	150	272	4963	3979	1665	3678	102	-1315	13072	40	13112	769	211	15367	15407	50.07
21/06/2015	11 Hrs	4385	562	252	5199	3797	1308	3273	111	-913	12775	40	12815	674	509	14871	14911	50.14
Maximum		4777	562	272	5445	5591	1665	4001	128	0	14196	43	14238	983	510	17005	17047	50
Minimum		0	0	0	0	0	0	0	0	-1577	0	0	0	0	0	0	0	50
Average		3933	278	187	4398	3864	1076	3142	87	-1103	11463	0	11499	708	321	13596	13631	50

Supply Position During Day Peak (MW)

Date	Time	MSGENCO				Central Sector Receipt	Wind	CPP	SOLAR	TPCL Exch.	MSEDCL Catered Demand	Load Shedding(LS)	MSEDCL Demand (Incl. LS)	TPCL Gen.	R-INFRA Gen.	State Demand Met	State Demand (Incl. LS)	Freq.
		THM	HYDRO	GAS	Total													
		MW	MW	MW	MW	MW	MW	MW	MW	MW	MW	MW	MW	MW	MW	MW	MW	Hzs
15/06/2015	13 Hrs	4669	200	143	5012	4319	1451	3550	93	-1334	13091	41	13132	993	513	15931	15972	50.00
16/06/2015	13 Hrs	4671	185	131	4987	5045	945	3842	93	-1514	13398	41	13439	936	510	16358	16399	49.99
17/06/2015	16 Hrs	4641	530	256	5427	4931	1098	3498	62	-1367	13649	33	13682	1126	256	16398	16431	50.00
18/06/2015	null	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	
19/06/2015	13 Hrs	4594	105	125	4824	3634	1397	3295	135	-1416	11869	42	11911	811	256	14352	14394	50.03
20/06/2015	16 Hrs	4689	447	264	5400	3852	1224	3481	52	-1181	12828	32	12860	818	381	15208	15240	49.99
21/06/2015	13 Hrs	4450	467	247	5164	3655	1195	3372	168	-962	12592	38	12630	678	507	14739	14777	50.04
Maximum		4689	530	264	5427	5045	1451	3842	168	0	13649	42	13682	1126	513	16398	16431	50
Minimum		0	0	0	0	0	0	0	0	-1514	0	0	0	0	0	0	0	50
Average		3959	276	167	4402	3634	1044	3005	86	-1111	11061	0	11093	766	346	13284	13316	50

Supply Position During Evening Peak (MW)

Date	Time	MSGENCO				Central Sector Receipt	Wind	CPP	SOLAR	TPCL Exch.	MSEDCL Catered Demand	Load Shedding(LS)	MSEDCL Demand (Incl. LS)	TPCL Gen.	R-INFRA Gen.	State Demand Met	State Demand (Incl. LS)	Freq.
		THM	HYDRO	GAS	Total													
		MW	MW	MW	MW	MW	MW	MW	MW	MW	MW	MW	MW	MW	MW	MW	MW	Hzs
15/06/2015	21 Hrs	4706	206	137	5049	4330	932	3901	0	-1112	13100	33	13133	874	514	15600	15633	49.93
16/06/2015	20 Hrs	4715	859	203	5777	3855	1245	3686	0	-1222	13341	32	13373	919	514	15996	16028	49.83
17/06/2015	20 Hrs	4601	853	266	5720	4518	1263	3694	1	-1526	13670	33	13703	837	258	16291	16324	49.92
18/06/2015	null	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	
19/06/2015	21 Hrs	4637	470	187	5294	3909	1263	3080	0	-1046	12500	32	12532	816	257	14619	14651	49.89
20/06/2015	21 Hrs	4762	170	254	5186	3992	1453	3522	0	-1056	13097	32	13129	822	392	15367	15399	49.96
21/06/2015	20 Hrs	4106	56	242	4404	3811	1348	3322	0	-1042	11843	32	11875	696	397	13978	14010	49.88
Maximum		4762	859	266	5777	4518	1453	3901	1	0	13670	33	13703	919	514	16291	16324	50
Minimum		0	0	0	0	0	0	0	0	-1526	0	0	0	0	0	0	0	50
Average		3932	373	184	4490	3488	1072	3029	0	-1001	11079	0	11106	709	333	13122	13149	50

Supply Position During Night Off Peak (MW)

Date	Time	MSGENCO				Central Sector Receipt	Wind	CPP	SOLAR	TPCL Exch.	MSEDCL Catered Demand	Load Shedding(LS)	MSEDCL Demand (Incl. LS)	TPCL Gen.	R-INFRA Gen.	State Demand Met	State Demand (Incl. LS)	Freq.
		THM	HYDRO	GAS	Total													
		MW	MW	MW	MW	MW	MW	MW	MW	MW	MW	MW	MW	MW	MW	MW	MW	Hzs
15/06/2015	4 Hrs	4575	79	136	4790	3025	1120	3393	0	-647	11681	39	11720	627	381	13336	13375	50.04
16/06/2015	5 Hrs	4263	83	137	4483	3237	1265	3184	0	-469	11700	39	11739	638	514	13321	13360	49.94
17/06/2015	4 Hrs	4514	94	281	4889	3107	948	3521	0	-728	11737	40	11777	647	255	13367	13407	50.02
18/06/2015	null	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	
19/06/2015	3 Hrs	4382	72	256	4710	2768	1377	3314	0	-645	11524	40	11564	658	257	13084	13124	49.97
20/06/2015	2 Hrs	4510	94	259	4863	2267	1392	3542	0	-701	11363	36	11399	623	246	12933	12969	50.01
21/06/2015	24 Hrs	4306	136	252	4694	2808	1222	3296	0	-924	11096	32	11128	624	393	13037	13069	49.99
Maximum		4575	136	281	4889	3237	1392	3542	0	0	11737	40	11777	658	514	13367	13407	50
Minimum		0	0	0	0	0	0	0	0	-924	0	0	0	0	0	0	0	50
Average		3793	80	189	4061	2459	1046	2893	0	-588	9872	0	9904	545	292	11297	11329	50

Details of Supply Position (MUs)

Date	MSGENCO				Pench (MS)	Central Sector Receipt	Central Sector Share	WIND	CPP	SOLAR	TPCL Gen.	R-INFRA Gen.	TPCL Exch.	Energy Requirement		
	THM	HYDRO	GAS	Total										MSEDCL	MUMBAI	STATE
	Mus	Mus	Mus	Mus	Mus	Mus	Mus	Mus	Mus	Mus	Mus	Mus	Mus	Mus	Mus	Mus
15/06/2015	110.280	4.307	3.301	117.888	0.120	92.080	86.528	29.330	86.970	1.040	18.965	11.623	-25.081	302.227	55.668	357.895
16/06/2015	109.842	7.446	4.020	121.308	0.128	97.461	96.130	27.015	86.169	0.597	19.001	11.759	-26.166	306.386	56.923	363.309
17/06/2015	110.252	8.844	6.447	125.543	0.117	101.279	98.651	22.458	86.448	0.875	20.953	6.137	-28.899	307.704	55.993	363.697
18/06/2015	110.664	4.092	6.465	121.221	0.000	95.749	97.864	29.605	76.466	0.799	21.620	6.161	-27.205	296.635	54.985	351.620
19/06/2015	109.452	3.534	4.766	117.752	0.188	82.681	83.643	32.403	78.342	0.882	17.130	6.153	-24.830	287.230	48.113	335.343
20/06/2015	111.030	4.994	6.135	122.159	0.060	80.112	77.201	33.675	84.372	0.958	17.267	7.097	-25.602	295.674	49.961	345.635
21/06/2015	104.249	5.445	6.096	115.790	0.042	79.811	79.058	31.148	81.310	0.959	16.049	10.255	-19.258	289.760	45.562	335.322
Maximum	111.030	8.844	6.465	125.543	0.188	101.279	98.651	111.030	86.970	1.040	21.620	11.759	-19.258	307.704	56.923	363.697
Minimum	104.249	3.534	3.301	115.790	0.000	79.811	77.201	104.249	76.466	0.597	16.049	6.137	-28.899	287.230	45.562	335.322
Average	109.396	5.523	5.319	120.237	0.094	89.882	88.439	109.396	82.868	0.873	16.049	8.455	-25.292	297.945	52.458	350.403

Details of Koyna Water Consumption (in TMC)

Date	For the Day	For the Month	Balance
15/06/2015	0.060	2.757	64.743
16/06/2015	0.114	2.871	64.629
17/06/2015	0.173	3.044	64.456
18/06/2015	0.059	3.103	64.397
19/06/2015	0.040	3.143	64.357
20/06/2015	0.061	3.204	64.296
21/06/2015	0.039	3.243	64.257

State Load Despatch Center, Airoli (MSETCL)
Central Sector Share/Drawal from 15/Jun/2015 to 21/Jun/2015

Date	DAY	Central Sector Share		Total Interstate Bilateral Purchase		Total Share		Total Drawal		Overdrawal(+) / UnderDrawal(-)	
		MUs	Avg. MW	MUs	Avg. MW	MUs	Avg. MW	MUs	Avg. MW	MUs	Avg. MW
		1		2		1+2=3		4		3-4=5	
15/06/2015	MONDAY	68.708	3588	17.820	742	86.528	3605	92.080	3837	5.552	231
16/06/2015	TUESDAY	80.983	3990	15.147	631	96.130	4005	97.461	4061	1.331	55
17/06/2015	WEDNESDA	83.753	4096	14.898	621	98.651	4110	101.279	4220	2.628	110
18/06/2015	THURSDAY	84.585	4064	13.279	553	97.864	4078	95.749	3990	-2.115	-88
19/06/2015	FRIDAY	67.207	3469	16.436	685	83.643	3485	82.681	3445	-0.962	-40
20/06/2015	SATURDAY	71.026	3211	6.175	257	77.201	3217	80.112	3338	2.911	121
21/06/2015	SUNDAY	66.656	3282	12.402	517	79.058	3294	79.811	3325	0.753	31
Total		522.917		96.158		619.075		629.173		10.098	

GENERATING UNITS OUTAGES FOR THE WEEK FROM 15/06/2015 TO 21/06/2015

Generator	Generating Unit	Capacity	Tripped Date	Tripped Time	Synch. Date	Synch Time	Reason
PLANNED OUTAGES							
MSPGCL	Parli Unit 4	210MW	13/Apr/2015	11:27		Continued.	Turbine vibration high. Continued to AOH w.e.f.01.05.2015
IPP	Adani U-1	660MW	01/Jun/2015	1:48		Continued.	Annual Overhaul
MSPGCL	Chandrapur Unit 6	500MW	09/Jun/2015	23:58		Continued.	COH
MSPGCL	Khaparkhedda Unit 4	210MW	19/Jun/2015	23:57		Continued.	Annual Overhaul
FORCED OUTAGES							
IPP	Dhariwal	300MW	28/May/2014	2:27		Continued.	PA Fan Vibration Problem
MSPGCL	Chandrapur Unit 1	210MW	28/Aug/2014	07:15		Continued.	Economic Shutdown.
MSPGCL	Bhusawal Unit 2	210MW	13/Sep/2014	12:43		Continued.	Economic shutdown
MSPGCL	Koradi Unit 6	210MW	20/Mar/2015	1:02		Continued.	Economic shutdown
IPP	JSW U-1	300MW	14/May/2015	19:16		Continued.	Turbine Bearing Problem
IPP	RPL(AMT)U2	270MW	01/Jun/2015	6:53		Continued.	Coal bunkering problem
IPP	Tata Trombay 6	500MW	05/Jun/2015	5:59		Continued.	Economic Shutdown.
MSPGCL	Nasik Unit 4	210MW	13/Jun/2015	22:05	19/Jun/2015	10:43	Boiler Validity extension work
MSPGCL	Chandrapur Unit 2	210MW	14/Jun/2015	21:35	15/Jun/2015	3:40	UAT Supply Fail.
MSPGCL	Parli Unit 3	210MW	14/Jun/2015	12:58		Continued.	Coal Shortage
MSPGCL	Bhusawal Unit 4	500MW	15/Jun/2015	21:09	16/Jun/2015	6:13	Due to Abnormal Sound in Turbine (Drain Valve Problem).
IPP	VIPL U-1	300MW	17/Jun/2015	20:40	18/Jun/2015	15:10	PRV of GT Optd.
IPP	RPL(AMT)U1	270MW	19/Jun/2015	18:59	19/Jun/2015	21:26	Generator Protection operated
MSPGCL	Koradi Unit 5	200MW	19/Jun/2015	19:03	19/Jun/2015	23:50	Flame Failure
MSPGCL	Parli Unit 6	250MW	21/Jun/2015	14:18	21/Jun/2015	18:22	Furnace Pressure High
MSPGCL	Chandrapur Unit 3	210MW	21/Jun/2015	12:05		Continued.	P A Fan A Problem.
MSPGCL	Parli Unit 7	250MW	21/Jun/2015	14:14		Continued.	Bottom Ash Hopper Plate Got Cracked.

LINE OUTAGES FOR THE WEEK FROM 15/06/2015 TO 21/06/2015

Voltage	Name of Line	Tripping Date	Tripping Time	Synch Date	Synch Time	Reason
500 KV	Chandrapur - Padghe HvdC Pole 1	16/Jun/2015	13:23	16/Jun/2015	15:49	Control problem from Padgha end.
500 KV	Chandrapur - Padghe HvdC Pole 2	17/Jun/2015	12:52		Continued.	Converter transformer diff prot optd.
400 KV	Akola II - RPL(Rattaniindia) Ckt I	07/Apr/2015	0:27	17/Jun/2015	19:23	"R" Phase Metering CT Burst.
400 KV	Wardha (PG)-Warora II	20/May/2015	2:39		Continued.	Breaker Accumulator Oil Leakage
400 KV	Akola II - Taptitanda	20/May/2015	8:59		Continued.	Ckt I and Ckt 2 new charged to control BBLSR ICT loading.
400 KV	New Koyna - Dabhol-I	08/Jun/2015	10:05		Continued.	Outage (RFC 16.07Hrs)
400 KV	Bhusawal-Aurangabad	11/Jun/2015	17:26	15/Jun/2015	7:15	Over Voltage
400 KV	Babhleshwar-Taptitanda ckt-II	12/Jun/2015	16:20	21/Jun/2015	19:48	Over Voltage
400 KV	Dhule Sar'Sarovar II	13/Jun/2015	5:09	17/Jun/2015	10:28	DT Received at Dhule
400 KV	karad -kolhapur-I	13/Jun/2015	13:33	15/Jun/2015	8:47	Over Voltage
400 KV	Karad-Jaigad - I	13/Jun/2015	16:04	15/Jun/2015	9:41	Over Voltage
400 KV	Lamboti - Solapur (PG)	14/Jun/2015	15:26	15/Jun/2015	14:01	Distance Protection
400 KV	Kolhapur Mapusa II	14/Jun/2015	15:52	15/Jun/2015	7:51	Over Voltage
400 KV	400/220/33 Kv 500 Mva Ict 3 @Girwali	14/Jun/2015	16:24	15/Jun/2015	6:05	Due to LV Side PRV Operated.
400 KV	Lonikand I - Koyna stage-IV	14/Jun/2015	17:26	15/Jun/2015	7:08	Over Voltage
400 KV	Kolhapur Solapur(PG) I	15/Jun/2015	0:11	15/Jun/2015	7:07	Over Voltage
400 KV	Padghe - Nagothane - I	15/Jun/2015	2:37	15/Jun/2015	9:27	Over Voltage
400 KV	400/220/33 Kv 315 MVA ICT I @Babhleshwar	15/Jun/2015	9:10		Continued.	LV Side Taken on TBC Bay Work.
400 KV	Lonikand I - Koyna stage-IV	15/Jun/2015	9:58	15/Jun/2015	13:43	Taken on TBC CB Compressor Problem.
400 KV	New Koyna - Koyna Stage IV-II	15/Jun/2015	14:58		Continued.	Taken on TBC to Attend Oil Leakage on Own CB.
400 KV	karad -kolhapur-II	15/Jun/2015	16:01	16/Jun/2015	9:00	Over Voltage
400 KV	Kolhapur Mapusa I	15/Jun/2015	16:25	16/Jun/2015	9:45	Over Voltage
400 KV	Karad - Jaigad - II	15/Jun/2015	16:40	16/Jun/2015	9:36	Over Voltage
400 KV	Bhusawal-Aurangabad	15/Jun/2015	17:46	16/Jun/2015	6:22	Over Voltage
400 KV	Kolhapur Solapur(PG) I	15/Jun/2015	18:28	16/Jun/2015	7:00	Over Voltage
400 KV	Lonikand I - Koyna stage-IV	15/Jun/2015	23:30	16/Jun/2015	6:36	Over Voltage
400 KV	Dhule Khandwa II	16/Jun/2015	11:33	17/Jun/2015	20:50	Taken on TBC,for hot spot on Bus II by hot line method.
400 KV	karad -kolhapur-I	16/Jun/2015	16:06	17/Jun/2015	6:57	Over Voltage
400 KV	Kolhapur Mapusa II	16/Jun/2015	16:47	17/Jun/2015	6:53	Over Voltage
400 KV	Karad-Jaigad - I	16/Jun/2015	17:16	17/Jun/2015	8:46	Over Voltage
400 KV	Bhusawal-Aurangabad	16/Jun/2015	17:53	17/Jun/2015	10:15	Over Voltage
400 KV	Lonikand I - Koyna stage-IV	16/Jun/2015	21:56	17/Jun/2015	6:11	Over Voltage
400 KV	Bhusawal-Aurangabad	17/Jun/2015	0:00	17/Jun/2015	10:15	Over Voltage
400 KV	Padghe - Nagothane - I	17/Jun/2015	0:01	17/Jun/2015	8:31	Over Voltage
400 KV	Kolhapur Solapur(PG) I	17/Jun/2015	3:05	18/Jun/2015	6:54	Over Voltage
400 KV	Dhule Khandwa I	17/Jun/2015	10:53	17/Jun/2015	19:36	Rectification of missing string at Khandwa end.
400 KV	Chandrapur-Parali 2	17/Jun/2015	12:38	17/Jun/2015	17:42	Insulator work.
400 KV	Bhusawal-Aurangabad	17/Jun/2015	17:38	18/Jun/2015	9:39	Over Voltage
400 KV	karad -kolhapur-II	17/Jun/2015	17:47	18/Jun/2015	9:02	Over Voltage
400 KV	Karad-Jaigad - I	17/Jun/2015	18:08	18/Jun/2015	9:09	Over Voltage
400 KV	Dhule Sar'Sarovar I	17/Jun/2015	19:00		Continued.	Over Voltage
400 KV	Karad - Lonikand 1	18/Jun/2015	9:26	19/Jun/2015	9:16	Relay testing RFC 18.06hrs.
400 KV	Kolhapur Mapusa I	18/Jun/2015	16:42	19/Jun/2015	9:17	Over Voltage
400 KV	karad -kolhapur-II	18/Jun/2015	16:57	19/Jun/2015	9:25	Over Voltage
400 KV	Karad-Jaigad - I	18/Jun/2015	21:06	20/Jun/2015	8:46	Over Voltage
400 KV	Bhusawal-Aurangabad	18/Jun/2015	21:32	19/Jun/2015	7:09	Over Voltage
400 KV	Kolhapur Solapur (PG) II	18/Jun/2015	22:51	19/Jun/2015	6:39	Over Voltage
400 KV	Bhusawal-Aurangabad	19/Jun/2015	13:10	20/Jun/2015	10:33	Over Voltage
400 KV	karad -kolhapur-II	19/Jun/2015	16:32	20/Jun/2015	8:42	Over Voltage
400 KV	Kolhapur Mapusa I	19/Jun/2015	16:41	20/Jun/2015	9:23	Over Voltage
400 KV	Padghe - Kalwa- I	19/Jun/2015	17:08	20/Jun/2015	0:11	Distance Protection
400 KV	Kalwa - Kharghar	19/Jun/2015	17:09	19/Jun/2015	17:25	Distance Protection
400 KV	Akola II - RPL(Rattaniindia) Ckt I	19/Jun/2015	18:59	20/Jun/2015	5:43	Distance Protection
400 KV	Kolhapur Solapur (PG) II	19/Jun/2015	20:47	20/Jun/2015	8:37	Over Voltage
400 KV	Lonikand I - Koyna stage-IV	19/Jun/2015	21:16	20/Jun/2015	6:27	Over Voltage
400 KV	Talegaon PG - Aurangabad - II	20/Jun/2015	9:55		Continued.	Annual Maintenance Work
400 KV	Parli (Pg) Wardha (Pg) I	20/Jun/2015	11:56	20/Jun/2015	19:33	Annual Maintenance Work
400 KV	Kolhapur Mapusa I	20/Jun/2015	16:54		Continued.	Over Voltage

400 KV	Karad-Jaigad - I	20/Jun/2015	17:10		Continued.	Over Voltage
400 KV	Lonikand I - Koyna stage-IV	20/Jun/2015	23:59	21/Jun/2015	9:00	Over Voltage
400 KV	Kolhapur Solapur(PG) I	21/Jun/2015	1:04	21/Jun/2015	9:06	Over Voltage
400 KV	Dhule - Bableshtar - li	21/Jun/2015	8:33	21/Jun/2015	21:12	A/R Out for OPGW Work.
400 KV	Kolhapur Solapur(PG) I	21/Jun/2015	13:09		Continued.	Over Voltage
400 KV	Bhusawal-Aurangabad	21/Jun/2015	13:10		Continued.	Over Voltage
400 KV	Dhule- Bableshtar - I	21/Jun/2015	14:53	21/Jun/2015	19:21	Distance Protection B Ph E/F Z-I @ Bblr End.
400 KV	Babhaleshtar-Taptitanda ckt-I	21/Jun/2015	17:37		Continued.	Distance Protection R Ph E/F,AR Lockout @ Bblr End.
400 KV	Lonikand I - Koyna stage-IV	21/Jun/2015	17:45	22/Jun/2015	6:52	Over Voltage
400 KV	400/220/33 Kv 315 Mva ICT II @Chandrapur	21/Jun/2015	20:45		Continued.	Differential protection
400 KV	Karad - Lonikand 1	21/Jun/2015	23:51		Continued.	Over Voltage
220 KV	220/100 Kv 200 MVA ICT III @Borivali	21/Sep/2014	9:16		Continued.	Internal Fault
220 KV	Sahara-Urse	03/Mar/2015	11:06	18/Jun/2015	18:46	Tower erection work (90Days)
220 KV	Chandrapur GCR - Warora - I	05/Apr/2015	9:13		Continued.	Bunching of conductor Loc no 86 Disconnecting of jumer at Loc no 86 & 107 and deenergising the line bet.86 to 107.
220 KV	Chandrapur GCR - Wani	05/Apr/2015	9:15		Continued.	Bunching of conductor Loc no 86 Disconnecting of jumer at Loc no 86 & 107 and deenergising the line bet.86 to 107.
220 KV	Padghe - Jambhul 2	09/Jun/2015	11:13	16/Jun/2015	12:41	Shifted on TBC, Bus isolator maint.
220 KV	Hingoli- Girawali	11/Jun/2015	20:10	18/Jun/2015	9:27	To control Wardha-Y'mal L/L.
220 KV	Nanded-Ghatodi	11/Jun/2015	20:56	18/Jun/2015	9:20	To control Wardha-Y'mal L/L.
220 KV	220/132 Kv 200 Mva Vijai Ict 1 @Eklahre (Gcr)	13/Jun/2015	9:36	17/Jun/2015	11:45	p.m.work
220 KV	Butibori-Inox	15/Jun/2015	8:45	15/Jun/2015	12:44	CRM & CB Timing.
220 KV	Ambazari-Amravati	15/Jun/2015	9:07	15/Jun/2015	15:45	Replacement of 2 No's Faulty Strings.
220 KV	Dasturi-Kandalgaon Line	15/Jun/2015	9:30	15/Jun/2015	16:15	Attending Hot Spot
220 KV	Loteparshuram- Dasturi Line	15/Jun/2015	9:40	15/Jun/2015	16:01	Replacement of Cross Arm.
220 KV	Dhamangaon New - Badnera	15/Jun/2015	10:01	15/Jun/2015	18:06	Premonsoon Maint., Measurement of Tan Delta of CT.
220 KV	Tillari Amona	15/Jun/2015	11:40	15/Jun/2015	16:44	Outage.
220 KV	Mahalakshmi Amona	15/Jun/2015	11:42	15/Jun/2015	16:10	Outage.
220 KV	Paranda-Barshi	15/Jun/2015	12:03	15/Jun/2015	16:52	Fising of Jumpers @ Cut Points.
220 KV	220/132 Kv 200 Mva Vijay Ict 1 @Chalisgaon	15/Jun/2015	12:24	15/Jun/2015	15:42	Retesting of Tandelta Measurement of R & Y Ph HV Side Bushing in Presenece of Company Engrs.
220 KV	220/132kv 200 Mva Aditya Vidyut Ict 1 @Kanhana	15/Jun/2015	13:02	15/Jun/2015	14:12	Attending Hot Spot on 1) Y Ph HV Side Bus Isolator 2) B Ph KV Side Bus Clamp.
220 KV	220/132 Kv 200 MVA ICT-I @Malegaon	15/Jun/2015	13:50	15/Jun/2015	17:57	Diff. Relay Replacement Work.
220 KV	220/132 Kv 200 Mva Aditya Vidyut Ict 1 @Chikhali	15/Jun/2015	13:56	15/Jun/2015	15:56	Attending Oil Leakage of LV R Ph Turret CT & R M Work.
220 KV	Bus Section @ VSNL	15/Jun/2015	16:50	15/Jun/2015	18:29	R ph CT Oil Leakage attending
220 KV	Parli 3 (Old Gcr)-Girwali Ckt-3	16/Jun/2015	8:25	16/Jun/2015	19:08	CT replacement.
220 KV	220/132KV 200MVA ICT @Kalewadi	16/Jun/2015	9:15	16/Jun/2015	15:51	Premonsoon Maintenance Work, Measurement of Tan Delta of CT
220 KV	Karad(400kv) -Mudshingi Ckt 2-Tak	16/Jun/2015	10:20	16/Jun/2015	15:00	Line Maintenance work
220 KV	Busa Section II @ Murud	16/Jun/2015	12:30	16/Jun/2015	18:35	Quarterly Maintainance Work
220 KV	Chandrapur MIDC - GEPL Ckt I	16/Jun/2015	16:08	16/Jun/2015	16:40	Distance Protection
220 KV	Dhule - Dondaicha Ckt	16/Jun/2015	16:29	17/Jun/2015	9:06	Distance Protection
220 KV	Kanhana - Suryalaxmi	16/Jun/2015	21:46	17/Jun/2015	10:04	Distance Protection
220 KV	Osmanabad - Solapur (Bale)	17/Jun/2015	9:10	17/Jun/2015	18:54	Strenging of E/W.
220 KV	220/132kv 200mva Emco Ict @Kurkumbh	17/Jun/2015	9:50	19/Jun/2015	22:15	C and R panel replacement.
220 KV	220/132 Kv 200 Mva Bbl Ict 2 @Beed	17/Jun/2015	10:00	17/Jun/2015	15:50	Attending problem of RTCC in presence of BBL representative.
220 KV	Boisar Versova Line	17/Jun/2015	10:37	17/Jun/2015	23:42	Due to L/L control.
220 KV	Pedambe-Pophali	17/Jun/2015	11:35	17/Jun/2015	12:00	Over Voltage
220 KV	Parli 3(Old Gcr)- Girwali Ckt 4	17/Jun/2015	11:41	17/Jun/2015	14:08	Q.M.Work.
220 KV	Aurangabad (Waluj)-Bhenda	17/Jun/2015	17:37	17/Jun/2015	18:25	O/C,F/F Optd.
220 KV	Butibori - Wardha	17/Jun/2015	20:40	17/Jun/2015	21:53	B Phase Pick at remote end
220 KV	Butibori - VIPL Ckt I	17/Jun/2015	20:40	17/Jun/2015	21:42	B Phase Pick at remote end
220 KV	Butibori - Puri	17/Jun/2015	20:40	17/Jun/2015	21:50	B Phase Pick at remote end
220 KV	Butibori - Khaperkheda	17/Jun/2015	20:40	17/Jun/2015	21:57	B phase E/F Pick at remote end
220 KV	Butibori - Butibori I	17/Jun/2015	20:40	17/Jun/2015	22:15	B Phase Pick at remote end
220 KV	220KV Bus I @ Butibori	17/Jun/2015	20:40	17/Jun/2015	21:40	B Phase Pick at remote end
220 KV	Khaparkheda-Ambazari-I	18/Jun/2015	6:43	18/Jun/2015	13:54	Stringing work of Koradi II-K'kheda new line.
220 KV	Khaparkheda-Butibori 3	18/Jun/2015	7:43	18/Jun/2015	14:56	Stringing work of Koradi II-K'kheda new line.
220 KV	220/100KV 200MVA ICT @ Ogalewadi	18/Jun/2015	8:20	18/Jun/2015	11:05	Attending Oil Leakage
220 KV	Boisar Versova Line	18/Jun/2015	8:22	18/Jun/2015	23:37	To control loading Boiser PG -Boiser line.

220 KV	Pusad-Ghatodi	18/Jun/2015	9:20	18/Jun/2015	15:25	Outage on Pusad-Y'mal and Pusad-Bhugaon.
220 KV	Bhugaon-Pusad	18/Jun/2015	9:27	18/Jun/2015	15:08	Stringing of E/W.
220 KV	Yeotmal- Pusad	18/Jun/2015	9:27	18/Jun/2015	15:08	Stringing of E/W.
220 KV	220/100 Kv 200 MVA ICT IV @Padghe	18/Jun/2015	11:29	18/Jun/2015	12:59	P.M.Work.
220 KV	200MVA ICT VI @ Nasik GCR	18/Jun/2015	11:40	20/Jun/2015	12:13	Attending Oil Leakage
220 KV	Hinjawadi I- Chinchwad	18/Jun/2015	11:54	18/Jun/2015	19:00	Outage on Urse-Sahara line.
220 KV	220/132-110 Kv 200 Mva Ptr 3 @Ichalkaranji-Ii	18/Jun/2015	12:00	18/Jun/2015	14:30	Relay testing work.
220 KV	Chinchwad- Parvati	18/Jun/2015	12:07	18/Jun/2015	18:51	Outage on Urse-Sahara line.
220 KV	Urse-Chinchwad	18/Jun/2015	12:16	18/Jun/2015	18:37	Dimental E/W Sahara-Urse-chinchwad line.
220 KV	Alephata-Pargaon(Kathapur)	18/Jun/2015	12:46	18/Jun/2015	19:45	LA Burst.
220 KV	Urse - Talegaon (Ambi) Ckt 2	18/Jun/2015	12:50	18/Jun/2015	18:05	Testing of CB and CT and bay maint.
220 KV	Talegaon(PG)-Talegaon(Ambi)-II	18/Jun/2015	13:27	18/Jun/2015	18:00	Testing of CB and CT and bay maint.
220 KV	220/100 kv 200 MVA ICT II @Padghe	18/Jun/2015	15:06	18/Jun/2015	17:22	P.M.Work.
220 KV	220/132 Kv 100 Mva Emco Ict @Shahada	19/Jun/2015	8:10	19/Jun/2015	19:15	Replacement of 132KV Breaker
220 KV	Khaparkheda-Kaulewada-II	19/Jun/2015	10:03	19/Jun/2015	13:22	Fixing of Pilot string to jumper suspension clamp
220 KV	Pophli Pedhmbe Line- 1	19/Jun/2015	10:10	19/Jun/2015	14:40	Routine Maintenance Work
220 KV	Waluj-Padegaon I	19/Jun/2015	10:56	19/Jun/2015	17:01	Half yearly maintenance work
220 KV	Kanhan-Umred 1	19/Jun/2015	11:56	19/Jun/2015	16:16	Tan Delta Measurment of CTs
220 KV	Dahanu Ghodbunder Line 1	19/Jun/2015	13:37	19/Jun/2015	14:25	Tree cutting work
220 KV	Nigade- Peth Line	20/Jun/2015	9:27	20/Jun/2015	10:41	Testing Work
220 KV	Peth- Mudshingi -I	20/Jun/2015	10:53	20/Jun/2015	12:04	Testing Work
220 KV	Pegasus - Infosys	20/Jun/2015	11:46	20/Jun/2015	17:06	Annual Maintenance Work
220 KV	Eklahara(Ocr)-Raymond (Padagha-I)	20/Jun/2015	13:41	20/Jun/2015	16:26	Replacement work
220 KV	Adlabs - Pedambe	21/Jun/2015	4:24	21/Jun/2015	16:05	Distance Protection
220 KV	Boisar(MS) - Boisar (PG) - I	21/Jun/2015	6:25	21/Jun/2015	11:49	Attending Hot Spot
220 KV	TATA Tie I	21/Jun/2015	9:21	21/Jun/2015	9:56	Shield Wire Inspection.
220 KV	Trombay MSETCL Tie 2	21/Jun/2015	10:17	21/Jun/2015	10:54	Shield Wire Inspection.
220 KV	Kalwa-Salsette-VI	21/Jun/2015	11:25	21/Jun/2015	14:48	Premonsoon Checks.
220 KV	Kalwa-Salsette-IV	21/Jun/2015	15:00	21/Jun/2015	19:10	Premonsoon Checks.
220 KV	Kandalgaon - Pirangut	21/Jun/2015	20:32		Continued.	LBB Operated @ Kandalgaon.
220 KV	Kandalgaon - Topworth	21/Jun/2015	20:32		Continued.	LBB Operated @ Kandalgaon.
220 KV	Kandalgaon - Koyna	21/Jun/2015	20:32		Continued.	Distance Protection,LBB Operated @ Kandalgaon.
132 KV	Amalner - Nardhana	15/Jun/2015	17:15	15/Jun/2015	17:42	Distance Protection
132 KV	Morshi-Warud	15/Jun/2015	22:40	15/Jun/2015	22:30	Distance Protection
132 KV	Khadka - Malkapur	19/Jun/2015	15:41	19/Jun/2015	15:58	Distance Protection
132 KV	Arvi - Talegaon	19/Jun/2015	17:30	19/Jun/2015	18:20	Distance Protection
132 KV	Talegaon-Tiwasa	19/Jun/2015	17:32	19/Jun/2015	17:45	Distance Protection