

State Load Despatch Center,Airoli (MSETCL)
Power System Position from 12/Jun/2017 to 18/Jun/2017

Supply Position During Morning Peak (MW)

Date	Time	MSGENCO				Central Sector Receipt	Wind	CPP	SOLAR	TPCL Exch.	MSEDCL Catered Demand	Load Shedding(LS)	MSEDCL Demand (Incl. LS)	TPCL Gen.	R-INFRA Gen.	State Demand Met	State Demand (Incl. LS)	Freq.
		THM	HYDRO	GAS	Total													
		MW	MW	MW	MW	MW	MW	MW	MW	MW	MW	MW	MW	MW	MW	MW	MW	Hzs
12/06/2017	12 Hrs	6139	228	431	6798	5173	421	3566	182	-1643	14497	0	14497	1115	389	17644	17644	49.94
13/06/2017	12 Hrs	5786	136	262	6184	5500	834	2569	135	-1533	13689	0	13689	1138	388	16748	16748	49.98
14/06/2017	12 Hrs	5399	281	251	5931	5484	461	3891	148	-1482	14433	0	14433	1230	496	17641	17641	49.98
15/06/2017	11 Hrs	5617	162	394	6173	4830	867	3831	157	-1616	14242	0	14242	1226	388	17472	17472	49.98
16/06/2017	12 Hrs	5576	196	384	6156	5080	681	2941	175	-1826	13207	0	13207	1085	389	16507	16507	49.99
17/06/2017	12 Hrs	5655	111	383	6149	5492	548	3485	267	-1727	14214	0	14214	1044	388	17373	17373	49.98
18/06/2017	12 Hrs	5118	390	391	5899	5414	621	3416	241	-1356	14235	0	14235	749	388	16728	16728	49.96
Maximum		6139	390	431	6798	5500	867	3891	267	-1356	14497	0	14497	1230	496	17644	17644	49.99
Minimum		5118	111	251	5899	4830	421	2569	135	-1826	13207	0	13207	749	388	16507	16507	49.94
Average		5613	215	357	6184	5282	633	3386	186	-1598	14074	0	14074	1084	404	17159	17159	49.97

Supply Position During Day Peak (MW)

Date	Time	MSGENCO				Central Sector Receipt	Wind	CPP	SOLAR	TPCL Exch.	MSEDCL Catered Demand	Load Shedding(LS)	MSEDCL Demand (Incl. LS)	TPCL Gen.	R-INFRA Gen.	State Demand Met	State Demand (Incl. LS)	Freq.
		THM	HYDRO	GAS	Total													
		MW	MW	MW	MW	MW	MW	MW	MW	MW	MW	MW	MW	MW	MW	MW	MW	Hzs
12/06/2017	13 Hrs	6084	206	416	6706	5434	445	3545	189	-1671	14648	0	14648	1081	387	17787	17787	49.95
13/06/2017	16 Hrs	5809	605	250	6664	5620	686	2555	71	-1524	14072	0	14072	1095	437	17128	17128	49.96
14/06/2017	15 Hrs	5536	329	252	6117	5877	377	3907	134	-1596	14816	0	14816	1194	420	18026	18026	49.98
15/06/2017	16 Hrs	5396	129	395	5920	4811	1613	3248	112	-1599	14105	0	14105	1245	387	17336	17336	49.98
16/06/2017	15 Hrs	5361	246	381	5988	5471	585	3016	152	-1807	13405	0	13405	1148	387	16747	16747	49.94
17/06/2017	16 Hrs	5792	269	386	6447	5054	1053	3796	156	-1727	14779	0	14779	1058	389	17953	17953	50.02
18/06/2017	16 Hrs	5328	140	383	5851	4769	1635	3902	186	-1458	14885	0	14885	745	389	17477	17477	49.96
Maximum		6084	605	416	6706	5877	1635	3907	189	-1458	14885	0	14885	1245	437	18026	18026	50.02
Minimum		5328	129	250	5851	4769	377	2555	71	-1807	13405	0	13405	745	387	16747	16747	49.94
Average		5615	275	352	6242	5291	913	3424	143	-1626	14387	0	14387	1081	399	17493	17493	49.97

Supply Position During Evening Peak (MW)

Date	Time	MSGENCO				Central Sector Receipt	Wind	CPP	SOLAR	TPCL Exch.	MSEDCL Cateder Demand	Load Shedding(LS)	MSEDCL Demand (Incl. LS)	TPCL Gen.	R-INFRA Gen.	State Demand Met	State Demand (Incl. LS)	Freq.
		THM	HYDRO	GAS	Total													
		MW	MW	MW	MW	MW	MW	MW	MW	MW	MW	MW	MW	MW	MW	MW	MW	Hzs
12/06/2017	20 Hrs	6251	397	419	7067	4210	1030	3234	0	-1490	14051	0	14051	982	389	16912	16912	49.96
13/06/2017	20 Hrs	6648	190	264	7102	4764	881	3495	0	-1509	14733	0	14733	958	388	17588	17588	49.96
14/06/2017	21 Hrs	5665	838	272	6775	4950	572	3895	0	-1249	14943	0	14943	1094	507	17793	17793	49.95
15/06/2017	20 Hrs	5752	151	387	6290	4711	1240	3097	0	-1393	13945	0	13945	1109	436	16883	16883	49.91
16/06/2017	21 Hrs	5474	193	401	6068	4977	1237	3352	0	-1550	14084	0	14084	1008	390	17032	17032	49.97
17/06/2017	21 Hrs	5798	384	390	6572	4994	1015	3446	0	-1522	14505	0	14505	1057	389	17473	17473	49.99
18/06/2017	21 Hrs	5542	502	406	6450	4305	1291	3882	0	-1290	14638	0	14638	926	494	17348	17348	49.94
Maximum		6648	838	419	7102	4994	1291	3895	0	-1249	14943	0	14943	1109	507	17793	17793	49.99
Minimum		5474	151	264	6068	4210	572	3097	0	-1550	13945	0	13945	926	388	16883	16883	49.91
Average		5876	379	363	6618	4702	1038	3486	0	-1429	14414	0	14414	1019	428	17290	17290	49.95

Supply Position During Night Off Peak (MW)

Date	Time	MSGENCO				Central Sector Receipt	Wind	CPP	SOLAR	TPCL Exch.	MSEDCL Cateder Demand	Load Shedding(LS)	MSEDCL Demand (Incl. LS)	TPCL Gen.	R-INFRA Gen.	State Demand Met	State Demand (Incl. LS)	Freq.
		THM	HYDRO	GAS	Total													
		MW	MW	MW	MW	MW	MW	MW	MW	MW	MW	MW	MW	MW	MW	MW	MW	Hzs
12/06/2017	4 Hrs	6011	61	437	6509	3672	448	2979	0	-812	12796	0	12796	688	389	14685	14685	49.98
13/06/2017	5 Hrs	5951	68	384	6403	2986	734	2709	0	-746	12086	0	12086	693	389	13914	13914	49.98
14/06/2017	4 Hrs	5257	61	259	5577	4095	526	3769	0	-929	13038	0	13038	696	389	15052	15052	49.95
15/06/2017	4 Hrs	5267	56	405	5728	3898	902	3556	0	-1022	13062	0	13062	708	388	15180	15180	50.00
16/06/2017	3 Hrs	5357	60	409	5826	4075	470	3150	0	-1130	12391	0	12391	693	390	14604	14604	50.02
17/06/2017	5 Hrs	5262	200	413	5875	4086	627	3030	0	-1044	12574	0	12574	703	389	14710	14710	49.99
18/06/2017	4 Hrs	5179	153	404	5736	3839	1070	3764	0	-1156	13253	0	13253	738	390	15537	15537	49.98
Maximum		6011	200	437	6509	4095	1070	3769	0	-746	13253	0	13253	738	390	15537	15537	50.02
Minimum		5179	56	259	5577	2986	448	2709	0	-1156	12086	0	12086	688	388	13914	13914	49.95
Average		5469	94	387	5951	3807	682	3280	0	-977	12743	0	12743	703	389	14812	14812	49.99

Details of Supply Position (MUs)

Date	MSGENCO				Pench (MS)	Central Sector Receipt	Central Sector Share	WIND	CPP	SOLAR	TPCL Gen.	R-INFRA Gen.	TPCL Exch.	Energy Requirement		
	THM	HYDRO	GAS	Total										MSEDCL	MUMBAI	STATE
	Mus	Mus	Mus	Mus	Mus	Mus	Mus	Mus	Mus	Mus	Mus	Mus	Mus	Mus	Mus	Mus
12/06/2017	147.101	4.351	10.195	161.647	0.055	103.442	102.407	16.159	75.899	1.333	21.120	9.335	-31.811	326.669	62.266	388.935
13/06/2017	143.890	6.792	7.173	157.855	0.047	109.258	104.798	16.616	69.064	1.016	21.396	9.470	-30.969	322.840	61.836	384.676
14/06/2017	131.423	9.675	6.463	147.561	0.093	116.982	113.521	10.755	92.459	1.131	23.664	10.433	-31.409	337.479	65.506	402.985
15/06/2017	131.647	4.748	9.526	145.921	0.034	110.401	109.458	22.618	82.496	1.241	24.235	10.090	-32.322	330.355	66.647	397.002
16/06/2017	131.928	3.524	9.585	145.037	0.099	114.700	114.711	16.581	74.816	1.273	22.923	9.462	-35.406	317.001	67.791	384.792
17/06/2017	135.114	4.276	9.632	149.022	0.026	113.643	112.606	19.745	82.331	1.998	21.109	9.331	-35.612	331.127	66.052	397.179
18/06/2017	127.654	5.549	9.592	142.795	0.028	109.697	107.916	25.704	89.164	2.123	18.191	9.566	-32.039	337.444	59.795	397.239
Maximum	147.101	9.675	10.195	161.647	0.099	116.982	114.711	147.101	92.459	2.123	24.235	10.433	-30.969	337.479	67.791	402.985
Minimum	127.654	3.524	6.463	142.795	0.026	103.442	102.407	127.654	69.064	1.016	18.191	9.331	-35.612	317.001	59.795	384.676
Average	135.537	5.559	8.881	149.977	0.055	111.160	109.345	135.537	80.890	1.445	21.805	9.670	-32.795	328.988	64.270	393.258

Details of Koyna Water Consumption (in TMC)

Date	For the Day	For the Month	Balance
12/06/2017	0.052	0.884	66.616
13/06/2017	0.099	0.983	66.517
14/06/2017	0.148	1.131	66.369
15/06/2017	0.079	1.210	66.290
16/06/2017	0.047	1.257	66.243
17/06/2017	0.065	1.322	66.178
18/06/2017	0.081	1.403	66.097

State Load Despatch Center,Airoli (MSETCL)
Central Sector Share/Drawal from 12/Jun/2017 to 18/Jun/2017

Date	DAY	Central Sector Share		Total Interstate Bilateral Purchase		Total Share		Total Drawal		Overdrawal(+) / UnderDrawal(-)	
		MUs	Avg. MW	MUs	Avg. MW	MUs	Avg. MW	MUs	Avg. MW	MUs	Avg. MW
		1		2		1+2=3		4		3-4=5	
12/06/2017	MONDAY	86.641	4251	15.766	657	102.407	4267	103.442	4310	1.035	43
13/06/2017	TUESDAY	88.345	4350	16.453	686	104.798	4367	109.258	4552	4.460	186
14/06/2017	WEDNESDA	97.646	4714	15.875	661	113.521	4730	116.982	4874	3.461	144
15/06/2017	THURSDAY	91.053	4542	18.405	767	109.458	4561	110.401	4600	0.943	39
16/06/2017	FRIDAY	91.996	4757	22.715	946	114.711	4780	114.700	4779	-0.011	-0
17/06/2017	SATURDAY	94.614	4674	17.992	750	112.606	4692	113.643	4735	1.037	43
18/06/2017	SUNDAY	91.475	4480	16.441	685	107.916	4496	109.697	4571	1.781	74
Total		641.772		123.645		765.417		778.123		12.706	

GENERATING UNITS OUTAGES FOR THE WEEK FROM 12/06/2017 TO 18/06/2017							
Generator	Generating Unit	Capacity	Tripped Date	Tripped Time	Synch. Date	Synch Time	Reason
PLANNED OUTAGES							
IPP	Tata Trombay 6	500MW	15/Jul/2015	17.08		Continued.	Economic shutdown(Converted to AOH for 30 Days from 00.00Hrs 06-03-2016)
MSPGCL	Chandrapur Unit 3	210MW	05/Jun/2017	23.24		Continued.	AOH.
MSPGCL	Khaparkheda Unit 2	210MW	14/Jun/2017	23.16		Continued.	Annual Overhaul
FORCED OUTAGES							
RGPL	Dabhol Dabhol 1B	230MW	28/May/2013	22:02		Continued.	Gas Shortage.
RGPL	Dabhol Dabhol 1X	230MW	27/Jun/2013	21.46		Continued.	Gas Shortage
RGPL	Dabhol Dabhol 1A	230MW	27/Jun/2013	21.47		Continued.	Gas Shortage
MSPGCL	Koradi Unit 6	210MW	20/Mar/2015	01.02		Continued.	EE R&M LE Work
IPP	SWPGL U-1	135MW	16/Feb/2016	17.09		Continued.	Change Over , No Schedule
IPP	SWPGL U-2	135MW	29/Feb/2016	21.46		Continued.	Change over against Unit III
MSPGCL	Parli Unit 4	210MW	01/Apr/2016	00.00		Continued.	Economic shutdown
MSPGCL	Parli Unit 5	210MW	01/Apr/2016	00.00		Continued.	Economic shutdown
MSPGCL	Bhusawal Unit 2	210MW	14/Jun/2016	19.35		Continued.	Boiler Tube Leakage(Converted to Zero Shedule By MSEDCL. from 00.00Hrs dt.19-6-16)
MSPGCL	Uran Unit 8	108MW	14/Aug/2016	07.56		Continued.	Maintenance work
RGPL	Dabhol 2A	230MW	24/Aug/2016	13.31		Continued.	Change Over.
MSPGCL	Koradi Unit 5	200MW	05/Sep/2016	00.21		Continued.	ID Fan problem, Converted to Zero Schedule By MSEDCL from 00.00hrs/22-9-16. Shutdown taken on 18.10.2016 at 00:00Hrs for Turbine inspection and maintenance work
IPP	PGPL U1	262MW	07/Feb/2017	17.30		Continued.	No Schedule
IPP	PGPL U2	126MW	07/Feb/2017	17.30		Continued.	No Schedule
IPP	RPL(AMT) U-1	270MW	24/May/2017	03.27		Continued.	Flame Failure
IPP	Adani U-5	660MW	28/May/2017	18.09	13/Jun/2017	17.30	EARTH FAULT PROTECTION STAGE 1 OPERATED.
MSPGCL	Nasik Unit 3	210MW	29/May/2017	11.30	17/Jun/2017	12.45	BTL(Converted to Zero schedule by MSEDCL. from 19.02 Hrs Dt.01.06.2017.
IPP	VIPL U-2	300MW	29/May/2017	23.51	12/Jun/2017	05.52	GT Problem
IPP	JSW (J) U2	300MW	31/May/2017	23.58		Continued.	NO SCHEDULE.
MSPGCL	Parli Unit 8	250MW	31/May/2017	21.56	12/Jun/2017	07.34	Coal Shortage
IPP	Dhariwal	300MW	01/Jun/2017	00.01		Continued.	NO SCHEDULE.
CS	Tarapur 1	160MW	04/Jun/2017	19.09		Continued.	3 months outage for refuelling.
IPP	RPL(AMT) U-3	270MW	05/Jun/2017	14.31		Continued.	swaping with unit-5.
IPP	RPL(AMT) U-5	270MW	09/Jun/2017	01.39		Continued.	Zero Schedule by MSEDCL
IPP	RPL(AMT) U-2	270MW	09/Jun/2017	04.24		Continued.	Zero Schedule by MSEDCL
IPP	RPL(AMT) U-4	270MW	09/Jun/2017	00.20		Continued.	Zero Schedule by MSEDCL
MSPGCL	Koradi Unit-8	660MW	11/Jun/2017	00.20	14/Jun/2017	12.24	Air duct Leakage
IPP	Adani U-2	660MW	12/Jun/2017	21.43	16/Jun/2017	07.32	PA Duct Bellow leakage
MSPGCL	Parli Unit 8	250MW	12/Jun/2017	10.20	12/Jun/2017	13.53	Flame Failure
MSPGCL	Parli Unit 7	250MW	13/Jun/2017	00.04		Continued.	Zero Schedule By MSEDCL
MSPGCL	Uran Unit 5	108MW	13/Jun/2017	08.34	14/Jun/2017	20.40	PRE FILTER REPLACEMENT WORK.
IPP	VIPL U-1	300MW	13/Jun/2017	08.30		Continued.	GT WORK
MSPGCL	Bhusawal Unit 3	210MW	13/Jun/2017	06.01		Continued.	Zero Schedule By MSEDCL
MSPGCL	Bhusawal Unit 5	500MW	14/Jun/2017	01.20	16/Jun/2017	08.56	Boiler Tube Leakage
MSPGCL	Parli Unit 6	250MW	14/Jun/2017	00.02		Continued.	Zero schedule by MSEDCL.
MSPGCL	Khaparkheda Unit 3	210MW	15/Jun/2017	18.02	17/Jun/2017	18.42	Boiler Tube Leakage
MSPGCL	Parli Unit 8	250MW	15/Jun/2017	11.29	15/Jun/2017	17.59	Flame Failure
IPP	Adani U-1	660MW	15/Jun/2017	17.27	19/Jun/2017	11.24	IP Turbine Peripheral Leakage
MSPGCL	Chandrapur Unit 4	210MW	16/Jun/2017	20.31	20/Jun/2017	05.56	Boiler Tube Leakage
MSPGCL	Bhusawal Unit 4	500MW	16/Jun/2017	11.42	16/Jun/2017	15.01	GENERATION PROTECTION OPERATED.
MSPGCL	Nasik Unit 5	210MW	17/Jun/2017	15.35		Continued.	Zero schedule by MSEDCL
MSPGCL	Parli Unit 8	250MW	17/Jun/2017	00.08		Continued.	Zero Schedule by MSEDCL
MSPGCL	Chandrapur Unit-8	500MW	18/Jun/2017	02.15		Continued.	Boiler Tube Leakage

LINE OUTAGES AND RIPPING FOR THE WEEK FROM 12/06/2017 TO 18/06/2017

Voltage	Name of Line	Tripping Date	Tripping Time	Synch Date	Synch Time	Reason
400 KV	Karad -Solapur (PG)	03/May/2017	11:49		Continued.	Line converted as 220 kV Solapur (PG)- Jeur from LOC 403
400 KV	Karad -Solapur (PG)	03/May/2017	11:49		Continued.	Line converted as 220 kV Solapur (PG)- Jeur from LOC 403
400 KV	Ektuni-Bableshtar ckt II	06/Jun/2017	20.53		Continued.	to control load on padghe- bableshtar.
400 KV	Dhule Sar'Sarovar II	08/Jun/2017	19.25	12/Jun/2017	07.46	Over Voltage
400 KV	Khadka-Aurangabad (Waluj)	09/Jun/2017	20.01	12/Jun/2017	08.30	Over Voltage
400 KV	karad -kolhapur-I	11/Jun/2017	17.29	12/Jun/2017	09.27	Over Voltage
400 KV	Karad - Jaigad - II	11/Jun/2017	18.05	12/Jun/2017	09.53	Over Voltage
400 KV	Lamboti - Solapur (PG)	12/Jun/2017	00.11	12/Jun/2017	00.44	Distance Protection
400 KV	Dhule Sar'Sarovar I	12/Jun/2017	08.51	13/Jun/2017	10.47	Preventive maint.work at SSP end(RFC 17.22Hrs)
400 KV	Talegaon PG-Aurangabad-I	12/Jun/2017	10.01	12/Jun/2017	12.58	Breaker work
400 KV	Chandrapur - Parli	12/Jun/2017	11.29	13/Jun/2017	08.57	Over Voltage
400 KV	Lamboti - Solapur (PG)	12/Jun/2017	14.16	13/Jun/2017	11.46	Distance Protection
400 KV	Talegaon PG - Aurangabad - II	12/Jun/2017	15.41	12/Jun/2017	18.11	Pre Monsoon maint.work
400 KV	karad -kolhapur-II	12/Jun/2017	17.37	13/Jun/2017	09.52	Over Voltage
400 KV	Bhusawal-Aurangabad	12/Jun/2017	18.06	18/Jun/2017	08.53	Over Voltage
400 KV	Deepnagar - Aurangabad	12/Jun/2017	21.21	12/Jun/2017	22.59	Distance Protection
400 KV	Karad-Jaigad - I	12/Jun/2017	23.56	14/Jun/2017	09.27	Over Voltage
400 KV	Dabhol - Nagothane II	13/Jun/2017	10.05	13/Jun/2017	20.34	tree cutting work.
400 KV	Dhule Sar'Sarovar II	13/Jun/2017	11.11	14/Jun/2017	11.06	Line Maintenance work.RFC.
400 KV	Girwalli-Solapur (Lamboti)	13/Jun/2017	12.27	13/Jun/2017	16.45	Line Maintenance work
400 KV	Koradi III(Adani)-Koradi II ckt 2	13/Jun/2017	16.10	13/Jun/2017	16.34	Distance Protection
400 KV	karad -kolhapur-II	13/Jun/2017	17.15	14/Jun/2017	09.02	Over Voltage
400 KV	Padghe - Nagothane - I	14/Jun/2017	03.11	14/Jun/2017	12.33	Distance Protection
400 KV	Kalwa - Talegaon(PG)	14/Jun/2017	06.39	14/Jun/2017	11.07	Attending Hot Spot
400 KV	Main Bus 1 @Nagothane	14/Jun/2017	09.56	15/Jun/2017	02.05	erection of cvts & rmw.
400 KV	Dhule(MS)- Dhule(BDTCL) -I	14/Jun/2017	11.15	14/Jun/2017	13.04	outages by wrldc.
400 KV	Dhule(MS)- Dhule(BDTCL) -II	14/Jun/2017	15.09	14/Jun/2017	16.23	outages by wrldc.
400 KV	Girwalli-Solapur (Lamboti)	14/Jun/2017	15.11	15/Jun/2017	09.25	Attending Hot Spot
400 KV	Dhule Sar'Sarovar I	14/Jun/2017	19.04	20/Jun/2017	06.18	Over Voltage
400 KV	karad -kolhapur-I	14/Jun/2017	21.25	15/Jun/2017	10.42	Over Voltage
400 KV	Karad - Jaigad - II	14/Jun/2017	21.29	17/Jun/2017	10.53	Over Voltage
400 KV	Girwalli - Lonikand 1	15/Jun/2017	11.20	16/Jun/2017	09.15	Line Maintenance work
400 KV	Nagothane - Dabhol I	15/Jun/2017	12.37	15/Jun/2017	13.11	Tripped from Dabhol end
400 KV	Main Bus-2 @Nagothane S/st.	15/Jun/2017	12.38	15/Jun/2017	19.12	Isolator Maint.work
400 KV	karad -kolhapur-I	15/Jun/2017	16.35	17/Jun/2017	10.22	Over Voltage
400 KV	Koradi-India Bulls	15/Jun/2017	18.40	18/Jun/2017	13.59	Over Voltage
400 KV	Padghe - Nagothane - I	16/Jun/2017	12.31	16/Jun/2017	18.57	LA REPLACEMENT
400 KV	Tapitanda Waluj	17/Jun/2017	13.14	17/Jun/2017	15.10	Tightening of Bolt & Fitting of Quarter Pin.
400 KV	karad -kolhapur-II	17/Jun/2017	18.13	19/Jun/2017	09.35	Over Voltage
400 KV	Karad-Jaigad - I	17/Jun/2017	18.54	19/Jun/2017	09.41	Over Voltage
400 KV	Bhusawal-Aurangabad	18/Jun/2017	18.01	19/Jun/2017	08.00	Over Voltage
400 KV	karad -kolhapur-I	19/Jun/2017	18.05		Continued.	Over Voltage
400 KV	Karad - Jaigad - II	19/Jun/2017	21.26		Continued.	Over Voltage
400 KV	Kalwa - Talegaon(PG)	20/Jun/2017	05.54		Continued.	To attend Hot Spot
220 KV	Chandrapur GCR - Warora - I	05/Apr/2015	09.13		Continued.	Bunching of conductor Loc no 86 Disconnecting of jumer at Loc no 86 & 107 and de-energising the line bet.86 to 107.
220 KV	Chandrapur GCR - Wani	05/Apr/2015	09.15		Continued.	Bunching of conductor Loc no 86 Disconnecting of jumer at Loc no 86 & 107 and de-energising the line bet.86 to 107.
220 KV	Talandage - Chikodi	01/Jun/2017	00.01		Continued.	NO SCHEDULE.
220 KV	Mudshingi - Chikodi	01/Jun/2017	00.06		Continued.	NO SCHEDULE.
220 KV	Walchandnagar-Bhigwan	04/Jun/2017	17.29		Continued.	Distance Protection
220 KV	Kharghar-Borivali ckt II	07/Jun/2017	12.23		Continued.	Distance Protection
220 KV	Ambazari-Amravati	12/Jun/2017	07.39	12/Jun/2017	15.04	Testing Work
220 KV	Mahad - Pedambe	12/Jun/2017	09.33	12/Jun/2017	19.28	Insulator Replacement Work
220 KV	Mumewadi-Belewadi	12/Jun/2017	10.01	12/Jun/2017	16.13	Quarterly Maintenance Work
220 KV	Butibori - VIPL Ckt I	12/Jun/2017	14.21	12/Jun/2017	17.42	Testing Work
220 KV	Kalwa - Airoli Knowledge Park	12/Jun/2017	17.55	12/Jun/2017	18.19	Distance Protection
220 KV	Nashik-Airoli Knowledge Park	12/Jun/2017	17.55	12/Jun/2017	22.21	Distance Protection
220 KV	Aurangabad (Waluj)-Bhenda	13/Jun/2017	09.18	13/Jun/2017	10.47	bus outage at bhenda end.
220 KV	Mudshingi-Belewadi	13/Jun/2017	10.10	13/Jun/2017	13.24	Insulator Replacement Work
220 KV	Adlabs - Pedambe	13/Jun/2017	11.30	13/Jun/2017	18.10	tree cutting work.
220 KV	Nanded-Ghatodi	13/Jun/2017	22.10	13/Jun/2017	23.18	Distance Protection
220 KV	Lamboti -Solapur li(Bale) Ckt- li	14/Jun/2017	08.35	15/Jun/2017	09.13	earthwire stringing work on multi circuit tower.
220 KV	Lamboti - Solapur li(Bale) Ckt- I	14/Jun/2017	08.35	15/Jun/2017	09.08	earthwire stringing work on multi circuit tower.
220 KV	Lamboti - Pandharpur li	14/Jun/2017	08.41	15/Jun/2017	09.00	earthwire stringing work on multi circuit tower.
220 KV	Lamboti(solapur)-Karkamb	14/Jun/2017	08.48	15/Jun/2017	09.03	earthwire stringing work on multi circuit tower.
220 KV	New Koyna - Pedambe	14/Jun/2017	09.33		Continued.	Distance Protection
220 KV	Mumewadi -Halkarni I	14/Jun/2017	09.46	14/Jun/2017	14.58	Line Maintenance work
220 KV	Osmanabad - Barshi	14/Jun/2017	10.20	14/Jun/2017	12.00	work at barshi end.
220 KV	Patoda-Manjarsumba	14/Jun/2017	11.35	14/Jun/2017	13.05	replacement of cb ac supply contactor coil.
220 KV	Parli 3 (Oldgr)-Harangul Ckt 2	14/Jun/2017	12.00	14/Jun/2017	14.45	Distance Relay Testing Work
220 KV	Butibori - VIPL Ckt II	14/Jun/2017	13.34	14/Jun/2017	17.51	testing of vt selection relay and measurement of bc timing and replacement of mfm meter.
220 KV	Bus Coupler @ Abhijeet	14/Jun/2017	14.15	14/Jun/2017	17.00	Tan Delta Measurment of CTs
220 KV	Ambazari-Amravati	15/Jun/2017	08.48	15/Jun/2017	16.15	Repl.of damaged Disc insulator
220 KV	Nanded-Ghatodi	15/Jun/2017	08.48	15/Jun/2017	15.18	Tan Delta Measurment of CTs
220 KV	Chalisgaon -Babhaleshwar	15/Jun/2017	10.02	15/Jun/2017	16.46	Line Maintenance work
220 KV	Raymond - Washala	15/Jun/2017	10.37	15/Jun/2017	14.40	Line Maintenance work

Voltage	Name of Line	Tripping Date	Tripping Time	Synch Date	Synch Time	Reason
220 KV	Karad(400kv) - Ogalewadi Ckt 2	15/Jun/2017	10.50	15/Jun/2017	15.02	Line Maintenance work
220 KV	Lonikand-II- Kathapur	15/Jun/2017	12.10	15/Jun/2017	15.00	Half yearly maintenance work
220 KV	Parli New Tps - Beed Ckt 2	15/Jun/2017	20.10	15/Jun/2017	20.45	Distance Protection
220 KV	Bableshwar -Bhenda	16/Jun/2017	09.18	16/Jun/2017	12.30	Routine Maintenance Work
220 KV	Dasturi-Kandalgaon Line	16/Jun/2017	09.35	16/Jun/2017	19.11	REPLACEMENT OF DISC INSULATORS.
220 KV	Eklahare (Gcr) - Airolu Know Park	16/Jun/2017	11.51	16/Jun/2017	16.55	INSULATOR CLEANING
220 KV	Vilebagad-Kandalgaon(Inox tap)	16/Jun/2017	20.36	16/Jun/2017	23.36	Distance Protection
220 KV	Chikhli-Jaina-I	17/Jun/2017	03.20	17/Jun/2017	03.34	Distance Protection
220 KV	Kaiwa - Mulund 1	17/Jun/2017	06.26	17/Jun/2017	08.46	Attending Hot Spot
220 KV	Kandalgaon - Sona Alloys	17/Jun/2017	09.15	17/Jun/2017	17.40	TREE CUTTING WORK
220 KV	Bus Coupler @ Babhaleshwar	17/Jun/2017	09.59	17/Jun/2017	10.10	COMMISSIONING OF RELAY
220 KV	Ambazari-Kalmeshwar	17/Jun/2017	14.13	17/Jun/2017	17.05	Attending Hot Spot
220 KV	Pophali - Pedambe II	17/Jun/2017	17.00		Continued.	CT REPLACEMENT WORK
220 KV	Dasturi-Kandalgaon Line	18/Jun/2017	10.25	18/Jun/2017	17.35	Line Maintenance work
220 KV	Satana-Gangapur	18/Jun/2017	18.02	19/Jun/2017	12.07	Distance Protection
132 KV	Hingoli 2- Akhada Balapur	12/Jun/2017	16.14	12/Jun/2017	16.34	Distance Protection
132 KV	Harangul - Nilanga	15/Jun/2017	18.31	15/Jun/2017	18.46	Distance Protection
132 KV	Deepnagar- Muktainagar	17/Jun/2017	04.20	17/Jun/2017	04.35	Distance Protection
132 KV	Harngul - Chakur	17/Jun/2017	22.10	17/Jun/2017	22.21	Distance Protection
132 KV	Kanhan-Pardi	18/Jun/2017	18.23	18/Jun/2017	20.59	Distance Protection