

**State Load Despatch Center,Airoli (MSETCL)
Power System Position from 13/Jun/2022 to 19/Jun/2022**

Supply Position During Morning Peak (MW)

| Date | Time | MSGENCO | | | | Central Sector Receipt | Wind | CPP | SOLAR | TPCL Exch. | MSEDCL Catered Demand | Load Sheddin g(LS) | MSEDCL Demand (Incl. LS) | TPCL Gen. | R-INFRA Gen. | State Demand Met | State Demand (Incl. LS) | Freq. |
|----------------|--------|-------------|-------------|------------|-------------|------------------------|------------|-------------|-------------|--------------|-----------------------|--------------------|--------------------------|------------|--------------|------------------|-------------------------|--------------|
| | | THM | HYDRO | GAS | Total | | | | | | | | | | | | | |
| | | MW | MW | MW | MW | | | | | | | | | | | | | |
| 13-06-2022 | 12 Hrs | 6649 | 446 | 140 | 7234 | 7913 | 461 | 5127 | 1376 | -2249 | 19440 | 0 | 19440 | 831 | 221 | 23164 | 23164 | 49.88 |
| 14-06-2022 | 12 Hrs | 6788 | 392 | 140 | 7320 | 7866 | 397 | 5835 | 1413 | -2079 | 20300 | 0 | 20300 | 824 | 484 | 24139 | 24139 | 49.93 |
| 15-06-2022 | 12 Hrs | 6031 | 451 | 139 | 6621 | 9246 | 405 | 5696 | 1287 | -2097 | 20726 | 0 | 20726 | 845 | 490 | 24590 | 24590 | 49.99 |
| 16-06-2022 | 12 Hrs | 6830 | 558 | 139 | 7527 | 8533 | 256 | 5659 | 1295 | -2006 | 20855 | 0 | 20855 | 866 | 445 | 24581 | 24581 | 49.92 |
| 17-06-2022 | 12 Hrs | 7077 | 759 | 139 | 7975 | 8631 | 168 | 4995 | 1234 | -2020 | 20548 | 0 | 20548 | 839 | 494 | 24336 | 24336 | 50.00 |
| 18-06-2022 | 12 Hrs | 6921 | 1136 | 148 | 8205 | 8483 | 177 | 5456 | 1154 | -1940 | 21128 | 0 | 21128 | 747 | 446 | 24668 | 24668 | 49.85 |
| 19-06-2022 | 12 Hrs | 6051 | 920 | 128 | 7099 | 8051 | 462 | 4841 | 1080 | -1375 | 19749 | 0 | 19749 | 634 | 470 | 22637 | 22637 | 49.99 |
| Maximum | | 7077 | 1136 | 148 | 8205 | 9246 | 462 | 5835 | 1413 | -1375 | 21128 | 0 | 21128 | 866 | 494 | 24668 | 24668 | 50.00 |
| Minimum | | 6031 | 392 | 128 | 6621 | 7866 | 168 | 4841 | 1080 | -2249 | 19440 | 0 | 19440 | 634 | 221 | 22637 | 22637 | 49.85 |
| Average | | 6621 | 666 | 139 | 7426 | 8389 | 332 | 5373 | 1263 | -1967 | 20392 | 0 | 20392 | 798 | 436 | 24016 | 24016 | 49.94 |

Supply Position During Day Peak (MW)

| Date | Time | MSGENCO | | | | Central Sector Receipt | Wind | CPP | SOLAR | TPCL Exch. | MSEDCL Catered Demand | Load Sheddin g(LS) | MSEDCL Demand (Incl. LS) | TPCL Gen. | R-INFRA Gen. | State Demand Met | State Demand (Incl. LS) | Freq. |
|----------------|--------|-------------|------------|------------|-------------|------------------------|-------------|-------------|-------------|--------------|-----------------------|--------------------|--------------------------|------------|--------------|------------------|-------------------------|--------------|
| | | THM | HYDRO | GAS | Total | | | | | | | | | | | | | |
| | | MW | MW | MW | MW | | | | | | | | | | | | | |
| 13-06-2022 | 16 Hrs | 6785 | 412 | 138 | 7336 | 7711 | 628 | 5968 | 825 | -2182 | 19852 | 0 | 19852 | 920 | 236 | 23624 | 23624 | 49.79 |
| 14-06-2022 | 15 Hrs | 6858 | 271 | 138 | 7267 | 7854 | 659 | 6140 | 1103 | -1909 | 20707 | 0 | 20707 | 952 | 492 | 24467 | 24467 | 49.93 |
| 15-06-2022 | 15 Hrs | 6241 | 260 | 139 | 6640 | 8938 | 641 | 5984 | 1090 | -2016 | 20869 | 0 | 20869 | 910 | 496 | 24699 | 24699 | 50.03 |
| 16-06-2022 | 16 Hrs | 6726 | 294 | 138 | 7158 | 8161 | 1559 | 5616 | 714 | -2061 | 20715 | 0 | 20715 | 874 | 474 | 24556 | 24556 | 50.02 |
| 17-06-2022 | 15 Hrs | 7012 | 869 | 139 | 8020 | 8484 | 292 | 5418 | 1022 | -1981 | 20856 | 0 | 20856 | 864 | 474 | 24574 | 24574 | 50.00 |
| 18-06-2022 | 13 Hrs | 6696 | 939 | 138 | 7773 | 8925 | 257 | 5299 | 1051 | -1918 | 20995 | 0 | 20995 | 756 | 483 | 24544 | 24544 | 49.96 |
| 19-06-2022 | 13 Hrs | 6102 | 490 | 138 | 6730 | 7908 | 468 | 5432 | 1138 | -1350 | 19916 | 0 | 19916 | 646 | 491 | 22813 | 22813 | 50.14 |
| Maximum | | 7012 | 939 | 139 | 8020 | 8938 | 1559 | 6140 | 1138 | -1350 | 20995 | 0 | 20995 | 952 | 496 | 24699 | 24699 | 50.14 |
| Minimum | | 6102 | 260 | 138 | 6640 | 7711 | 257 | 5299 | 714 | -2182 | 19852 | 0 | 19852 | 646 | 236 | 22813 | 22813 | 49.79 |
| Average | | 6631 | 505 | 138 | 7275 | 8283 | 643 | 5694 | 992 | -1917 | 20559 | 0 | 20559 | 846 | 449 | 24182 | 24182 | 49.98 |

Supply Position During Evening Peak (MW)

| Date | Time | MSGENCO | | | | Central Sector Receipt | Wind | CPP | SOLAR | TPCL Exch. | MSEDCL Catered Demand | Load Sheddin g(LS) | MSEDCL Demand (Incl. LS) | TPCL Gen. | R-INFRA Gen. | State Demand Met | State Demand (Incl. LS) | Freq. |
|----------------|--------|-------------|-------------|------------|-------------|------------------------|-------------|-------------|----------|--------------|-----------------------|--------------------|--------------------------|-------------|--------------|------------------|-------------------------|--------------|
| | | THM | HYDRO | GAS | Total | | | | | | | | | | | | | |
| | | MW | MW | MW | MW | | | | | | | | | | | | | |
| 13-06-2022 | 20 Hrs | 6939 | 1078 | 141 | 8158 | 5863 | 1530 | 5997 | 0 | -1623 | 19473 | 0 | 19473 | 1114 | 248 | 22910 | 22910 | 49.97 |
| 14-06-2022 | 20 Hrs | 6652 | 380 | 141 | 7173 | 6268 | 2006 | 5960 | 0 | -1435 | 19531 | 0 | 19531 | 1106 | 488 | 23001 | 23001 | 49.93 |
| 15-06-2022 | 20 Hrs | 6393 | 318 | 152 | 6863 | 6506 | 2169 | 5985 | 0 | -1458 | 19622 | 0 | 19622 | 1156 | 478 | 23157 | 23157 | 49.90 |
| 16-06-2022 | 21 Hrs | 6990 | 823 | 141 | 7954 | 5971 | 1762 | 5984 | 0 | -1455 | 19791 | 0 | 19791 | 1097 | 446 | 23214 | 23214 | 49.99 |
| 17-06-2022 | 21 Hrs | 7001 | 680 | 141 | 7822 | 6285 | 1490 | 6001 | 0 | -1407 | 19777 | 0 | 19777 | 1075 | 493 | 23166 | 23166 | 49.97 |
| 18-06-2022 | 21 Hrs | 6278 | 442 | 153 | 6873 | 7174 | 1803 | 5536 | 0 | -1531 | 19445 | 0 | 19445 | 914 | 462 | 22762 | 22762 | 50.03 |
| 19-06-2022 | 21 Hrs | 6184 | 304 | 141 | 6629 | 5737 | 2044 | 5255 | 0 | -1236 | 18031 | 0 | 18031 | 780 | 493 | 20938 | 20938 | 50.00 |
| Maximum | | 7001 | 1078 | 153 | 8158 | 7174 | 2169 | 6001 | 0 | -1236 | 19791 | 0 | 19791 | 1156 | 493 | 23214 | 23214 | 50.03 |
| Minimum | | 6184 | 304 | 141 | 6629 | 5737 | 1490 | 5255 | 0 | -1623 | 18031 | 0 | 18031 | 780 | 248 | 20938 | 20938 | 49.90 |
| Average | | 6634 | 575 | 144 | 7353 | 6258 | 1829 | 5817 | 0 | -1449 | 19382 | 0 | 19382 | 1035 | 444 | 22736 | 22736 | 49.97 |

Supply Position During Night Off Peak (MW)

| Date | Time | MSGENCO | | | | Central Sector Receipt | Wind | CPP | SOLAR | TPCL Exch. | MSEDCL Catered Demand | Load Sheddin g(LS) | MSEDCL Demand (Incl. LS) | TPCL Gen. | R-INFRA Gen. | State Demand Met | State Demand (Incl. LS) | Freq. |
|----------------|--------|-------------|------------|------------|-------------|------------------------|-------------|-------------|----------|--------------|-----------------------|--------------------|--------------------------|------------|--------------|------------------|-------------------------|--------------|
| | | THM | HYDRO | GAS | Total | | | | | | | | | | | | | |
| | | MW | MW | MW | MW | | | | | | | | | | | | | |
| 13-06-2022 | 4 Hrs | 6605 | 286 | 145 | 7036 | 5278 | 885 | 5780 | 0 | -1042 | 17636 | 0 | 17636 | 860 | 241 | 20080 | 20080 | 49.95 |
| 14-06-2022 | 4 Hrs | 6909 | 361 | 145 | 7415 | 5514 | 554 | 6249 | 0 | -905 | 18516 | 0 | 18516 | 892 | 493 | 21117 | 21117 | 49.98 |
| 15-06-2022 | 5 Hrs | 6534 | 460 | 143 | 7137 | 6318 | 1076 | 6038 | 0 | -997 | 19249 | 0 | 19249 | 820 | 485 | 21874 | 21874 | 50.02 |
| 16-06-2022 | 4 Hrs | 7030 | 360 | 144 | 7534 | 6084 | 1096 | 6077 | 0 | -1241 | 19254 | 0 | 19254 | 733 | 391 | 21915 | 21915 | 49.95 |
| 17-06-2022 | 5 Hrs | 7002 | 264 | 145 | 7411 | 6795 | 687 | 5651 | 0 | -1184 | 19046 | 0 | 19046 | 594 | 469 | 21607 | 21607 | 50.00 |
| 18-06-2022 | 4 Hrs | 6958 | 333 | 154 | 7445 | 6895 | 843 | 5578 | 0 | -1254 | 19204 | 0 | 19204 | 588 | 489 | 21838 | 21838 | 49.99 |
| 19-06-2022 | 23 Hrs | 6140 | 298 | 143 | 6581 | 6190 | 1856 | 5252 | 0 | -1520 | 17994 | 0 | 17994 | 589 | 364 | 20832 | 20832 | 50.02 |
| Maximum | | 7030 | 460 | 154 | 7534 | 6895 | 1856 | 6249 | 0 | -905 | 19254 | 0 | 19254 | 892 | 493 | 21915 | 21915 | 50.02 |
| Minimum | | 6140 | 264 | 143 | 6581 | 5278 | 554 | 5252 | 0 | -1520 | 17636 | 0 | 17636 | 588 | 241 | 20080 | 20080 | 49.95 |
| Average | | 6740 | 338 | 146 | 7223 | 6153 | 1000 | 5804 | 0 | -1163 | 18700 | 0 | 18700 | 725 | 419 | 21323 | 21323 | 49.99 |

Details of Supply Position (MUs)

| Date | MSGENCO | | | | Pench (MS) | Central Sector Receipt | Central Sector Share | WIND | CPP | SOLAR | TPCL Gen. | R-INFRA Gen. | TPCL Exch. | Energy Requirement | | |
|----------------|----------------|---------------|--------------|----------------|--------------|------------------------|----------------------|----------------|----------------|---------------|---------------|---------------|----------------|--------------------|---------------|----------------|
| | THM | HYDRO | GAS | Total | | | | | | | | | | MSEDCL | MUMBAI | STATE |
| | Mus | Mus | Mus | Mus | | | | | | | | | | Mus | Mus | Mus |
| 13-06-2022 | 160.550 | 11.159 | 3.445 | 175.154 | 0.234 | 154.555 | 158.981 | 21.872 | 137.259 | 10.336 | 21.820 | 6.489 | -38.928 | 450.847 | 67.237 | 527.485 |
| 14-06-2022 | 163.071 | 10.528 | 3.458 | 177.057 | 0.377 | 157.500 | 158.969 | 22.276 | 145.691 | 10.570 | 22.471 | 11.814 | -35.223 | 468.258 | 69.508 | 547.379 |
| 15-06-2022 | 152.957 | 11.450 | 3.432 | 167.839 | 0.218 | 173.497 | 174.717 | 29.626 | 142.358 | 9.999 | 22.176 | 11.565 | -37.223 | 476.659 | 70.965 | 557.061 |
| 16-06-2022 | 165.859 | 12.768 | 3.412 | 182.039 | 0.171 | 164.863 | 166.519 | 27.278 | 141.087 | 9.175 | 21.335 | 10.756 | -37.795 | 477.296 | 69.883 | 556.530 |
| 17-06-2022 | 168.503 | 15.168 | 3.447 | 187.118 | 0.000 | 172.623 | 173.496 | 17.472 | 134.359 | 9.606 | 20.234 | 11.477 | -37.952 | 473.854 | 69.663 | 552.889 |
| 18-06-2022 | 157.910 | 14.755 | 3.446 | 176.111 | 0.000 | 185.123 | 186.879 | 22.927 | 130.194 | 8.301 | 17.033 | 11.140 | -38.424 | 475.099 | 66.597 | 550.829 |
| 19-06-2022 | 144.289 | 9.929 | 3.420 | 157.638 | 0.000 | 172.015 | 178.025 | 29.762 | 122.656 | 8.265 | 15.267 | 10.946 | -31.543 | 449.846 | 57.756 | 516.549 |
| Maximum | 168.503 | 15.168 | 3.458 | 187.118 | 0.377 | 185.123 | 186.879 | 168.503 | 145.691 | 10.570 | 22.471 | 11.814 | -31.543 | 477.296 | 70.965 | 557.061 |
| Minimum | 144.289 | 9.929 | 3.412 | 157.638 | 0.000 | 154.555 | 158.969 | 144.289 | 122.656 | 8.265 | 15.267 | 6.489 | -38.928 | 449.846 | 57.756 | 516.549 |
| Average | 159.020 | 12.251 | 3.437 | 174.708 | 0.143 | 168.596 | 171.084 | 159.020 | 136.229 | 9.465 | 20.048 | 10.598 | -36.727 | 467.408 | 67.373 | 544.103 |

Details of Koyna Water Consumption (in TMC)

| Date | For the Day | For the Month | Balance |
|------------|-------------|---------------|---------|
| 13-06-2022 | 0.124 | 1.971 | 65.529 |
| 14-06-2022 | 0.110 | 2.082 | 65.418 |
| 15-06-2022 | 0.135 | 2.217 | 65.283 |
| 16-06-2022 | 0.148 | 2.365 | 65.135 |
| 17-06-2022 | 0.211 | 2.575 | 64.925 |
| 18-06-2022 | 0.187 | 2.762 | 64.738 |
| 19-06-2022 | 0.089 | 2.851 | 64.649 |

**State Load Despatch Center, Airoli (MSETCL)
Central Sector Share/Drawal from 13/Jun/2022 to 19/Jun/2022**

| Date | DAY | Central Sector Share | | Total Interstate | | Total Share | | Total Drawal | | Overdrawal(+)/ | |
|--------------|-----------|----------------------|---------|------------------|---------|-----------------|---------|-----------------|---------|----------------|---------|
| | | MUs | Avg. MW | MUs | Avg. MW | MUs | Avg. MW | MUs | Avg. MW | MUs | Avg. MW |
| | | 1 | | 2 | | 1+2=3 | | 4 | | 3-4=5 | |
| 13-06-2022 | MONDAY | 91.180 | 6556 | 67.801 | 2825 | 158.981 | 6624 | 154.555 | 6440 | -4.426 | -184 |
| 14-06-2022 | TUESDAY | 94.533 | 6559 | 64.436 | 2685 | 158.969 | 6624 | 157.500 | 6562 | -1.469 | -61 |
| 15-06-2022 | WEDNESDAY | 75.362 | 7181 | 99.355 | 4140 | 174.717 | 7280 | 173.497 | 7229 | -1.220 | -51 |
| 16-06-2022 | THURSDAY | 81.636 | 6853 | 84.883 | 3537 | 166.519 | 6938 | 164.863 | 6869 | -1.656 | -69 |
| 17-06-2022 | FRIDAY | 86.411 | 7142 | 87.085 | 3629 | 173.496 | 7229 | 172.623 | 7193 | -0.873 | -36 |
| 18-06-2022 | SATURDAY | 95.746 | 7695 | 91.133 | 3797 | 186.879 | 7787 | 185.123 | 7713 | -1.756 | -73 |
| 19-06-2022 | SUNDAY | 90.413 | 7330 | 87.612 | 3651 | 178.025 | 7418 | 172.015 | 7167 | -6.010 | -250 |
| Total | | 615.281 | | 582.305 | | 1197.586 | | 1180.175 | | -17.411 | |

| Generator Unit Outages/Trippings from 13.06.2022 to 19.06.2022 | | | | | | |
|--|------------|-----------|------------|------------|---|-------------|
| Name of Unit | Date Trip | Time Trip | Date Sync | Time Sync | Reason | Outage Type |
| Khaparkheda Unit 4 | 05-06-2022 | 00:07 | | Continued. | Annual Overhaul | PLANNED |
| Koyna STG-IV Unit-2 | 13-06-2022 | 00:00 | | Continued. | Commissioning and installation of New TSLG governor | PLANNED |
| RPL(AMT) U-5 | 15-06-2022 | 00:00 | | Continued. | Annual Overhaul | PLANNED |
| Koyna Unit 9 | 15-06-2022 | 08:00 | | Continued. | Capital Overhaul | PLANNED |
| SWPGPL U-1 | 16-02-2016 | 17.09 | | Continued. | No PPA. | FORCED |
| PGPL U1 | 07-02-2017 | 17.3 | | Continued. | No Schedule (NO PPA) | FORCED |
| PGPL U2 | 07-02-2017 | 17.3 | | Continued. | No Schedule.(NO PPA) | FORCED |
| IEPL Unit 1 | 28-08-2018 | 21.26 | | Continued. | No PPA | FORCED |
| VIPL U-1 | 29-12-2018 | 0.3 | | Continued. | Coal Shortage. (NO PPA From 20.05.2019) | FORCED |
| VIPL U-2 | 17-01-2019 | 0.15 | | Continued. | Coal shortage.(NO PPA From 20.05.2019) | FORCED |
| Tarapur 1 | 08-01-2020 | 10:37 | | Continued. | Refueling. While refueling preparation, some repair works identified which are being executed before refueling. | FORCED |
| Uran Unit 7 | 25-05-2020 | 12.51 | | Continued. | Turbine Blade Failure | FORCED |
| Tarapur 2 | 13-07-2020 | 04:38 | | Continued. | For cleaning of clogged basket strainer of cooling water system due to heavy ingress of debris from sea. The outage extended for repair and re-fueling. | FORCED |
| Koradi Unit 7 | 27-04-2021 | 20.03 | | Continued. | Retired (04/08/2021 At 00.00) | FORCED |
| JSW (J) U1 | 16-03-2022 | 23:16 | | Continued. | Turbine Vibration | FORCED |
| Ghatghar Unit-1 | 20-04-2022 | 00:35 | | Continued. | Stator Earth Fault | FORCED |
| RPL(AMT) U-4 | 31-05-2022 | 01:15 | 13-06-2022 | 17:41 | Ash Conveyer problem.(Coal shortage From Dt 02.06.2022 @ 02.00 hrs) | FORCED |
| Chandrapur Unit 9 | 09-06-2022 | 08:46 | 13-06-2022 | 08:17 | Boiler Tube Leakage | FORCED |
| Koyna Unit 12 | 09-06-2022 | 07:40 | 13-06-2022 | 18:20 | TO ATTEND BUTTERFLY VALVE PROBLEM. | FORCED |
| SWPGPL U-4 | 10-06-2022 | 23:00 | 13-06-2022 | 13:09 | Boiler Bottom Ash System problem. | FORCED |
| Uran Unit 5 | 11-06-2022 | 14:29 | | Continued. | Gas shortage | FORCED |
| AEML Unit 1 | 11-06-2022 | 23:53 | 13-06-2022 | 02:09 | Boiler Tube Leakage | FORCED |
| Ghatghar Unit-2 | 12-06-2022 | 11:45 | 14-06-2022 | 12:30 | CW Pump having heavy Vibration and Water leakage. | FORCED |
| Koradi Unit 6 | 13-06-2022 | 10:17 | 13-06-2022 | 13:01 | Flame Failure | FORCED |
| Uran Unit 6 | 13-06-2022 | 00:25 | | Continued. | Gas shortage | FORCED |
| Uran Unit A0 | 13-06-2022 | 00:25 | | Continued. | Gas shortage | FORCED |
| Chandrapur Unit 7 | 15-06-2022 | 05:01 | | Continued. | Turbine Gland steam temperature not maintained | FORCED |
| Paras Unit 3 | 15-06-2022 | 11:05 | 15-06-2022 | 13:52 | Furnace Pressure High | FORCED |
| Nasik Unit 5 | 16-06-2022 | 13:15 | 16-06-2022 | 17:35 | due to sudden closed of ESV & IV Valves | FORCED |
| RPL(AMT) U-3 | 18-06-2022 | 16:50 | 18-06-2022 | 18:24 | turbine overspeed relay operated | FORCED |
| Chandrapur Unit 4 | 18-06-2022 | 00:05 | | Continued. | Ash handling problem. | FORCED |
| Chandrapur Unit 6 | 18-06-2022 | 12:53 | 22-06-2022 | 22:03 | Boiler Tube Leakage | FORCED |
| Parli Unit 6 | 18-06-2022 | 18:37 | 21-06-2022 | 17:22 | Boiler Tube Leakage | FORCED |
| Trombay 7A | 18-06-2022 | 04:12 | | Continued. | Gas shortage | FORCED |
| Trombay 7B | 18-06-2022 | 03:55 | | Continued. | Gas shortage | FORCED |

Transmission Line Outages/Trippings from 13.06.2022 to 19.06.2022

| Name of Line | Date Trip | Time Trip | Date Sync | Time Sync | Reason | Outage Type | Voltage |
|--|------------|-----------|------------|-----------|---|-------------|---------|
| 765/400KV 500MVA SPARE ICT UNIT @ EKTUNI | 14-06-2022 | 09:57 | 14-06-2022 | 18:53 | "Diagnostic Testing of CT, CB & Routine Maintenance. | PO | 765 KV |
| TIE BAY (708) of KORADI - 3 CKT - 2 & EKTUNI CKT - 2 @ AKOLA 2 | 14-06-2022 | 10:12 | 14-06-2022 | 14:11 | Circuit Breaker SF6 gas analysis | PO | 765 KV |
| DHULE - SSNNL CKT - 1 | 12-06-2022 | 19:27 | 13-06-2022 | 17:27 | TRIPPED ON DISTANCE PROTECTION | T | 400 KV |
| DHULE - SSNNL CKT - 2 | 12-06-2022 | 18:02 | 13-06-2022 | 13:45 | TRIPPED ON DISTANCE PROTECTION | T | 400 KV |
| 400/220 125MVAR BUS REACTOR @ LAMBOTI | 13-06-2022 | 11:02 | 13-06-2022 | 13:30 | Diagnostic Testing Work | PO | 400 KV |
| 400/220/33 KV 500 MVA ICT - 3 @ DHULE | 13-06-2022 | 20:05 | 14-06-2022 | 05:35 | TRIPPED ON NDR | T | 400 KV |
| BUS COUPLER @ LONIKAND-1 | 13-06-2022 | 19:09 | 14-06-2022 | 04:50 | To attend hotspots on 29A Y ph (temp:158deg) and B ph (temp:>160deg) | EO | 400 KV |
| MAIN BUS - 1 @ KARAD | 13-06-2022 | 12:28 | 13-06-2022 | 18:42 | During PID testing of 400 kV Bus I gantry Disc Insulator strings in May-2022, it is observed that 03 Nos of Disc Insulator strings found faulty Above faulty Disc | PO | 400 KV |
| 400/220/33 KV 500MVA ICT - 1 @ KORADI 2 | 14-06-2022 | 11:19 | 14-06-2022 | 15:32 | 1) Premonsoon maintenance work & 2) Tan delta measurement of Synchronising CVT. | PO | 400 KV |
| CHANDRAPUR 2- KUMBHARGAON (NANDED) CKT - 1 | 15-06-2022 | 09:53 | 15-06-2022 | 23:29 | For replacement of faulty PID Disc Insulator | PO | 400 KV |
| DHULE - KHANDWA CKT - 2 | 15-06-2022 | 10:53 | 15-06-2022 | 21:09 | For Line Bay AMP. | PO | 400 KV |
| 400/220KV 315 MVA ICT - 2 @ NEW KOYNA | 15-06-2022 | 18:20 | 16-06-2022 | 01:00 | For attending hotspot | EO | 400 KV |
| DEEPNAGAR - THAPTI TANDA | 15-06-2022 | 12:13 | 15-06-2022 | 16:50 | Relay Testing Work & Quarterly Maintenance work. | PO | 400 KV |
| MAIN BAY (409) OF KORADI 3 CKT- 1 @ KORADI 2 | 15-06-2022 | 10:02 | 15-06-2022 | 15:39 | Diagnostic testing of CB 409-Q52 | PO | 400 KV |
| TBC @ KORADI-1 | 15-06-2022 | 09:34 | 15-06-2022 | 19:01 | CT TAN Delta, Differential Protection | PO | 400 KV |
| 400/132 KV 200 MVA ICT - 1 @ KHADKA | 16-06-2022 | 11:43 | 16-06-2022 | 13:57 | 400/132 KV 200 MVA ICT-1 HV side Red hot found on connecting clamp of Y phase Auxiliary BUS PG Isolator and IPS tube of Transformer side isolator. | EO | 400 KV |
| 400/220 KV 315MVA ICT - 2 @ KARAD | 16-06-2022 | 11:44 | 16-06-2022 | 18:12 | For replacement of Bus-1 R ph PG isolator operating assembly due to jammed old assembly | PO | 400 KV |
| BABLESHWAR- AURANGABAD (WALUJ) | 16-06-2022 | 09:08 | 16-06-2022 | 18:24 | Chemical Cleaning of Insulator string and Routine Line maintenance work | PO | 400 KV |
| LONIKAND II - LONIKAND I (INTERCONNECTOR) - 2 | 16-06-2022 | 17:48 | 16-06-2022 | 23:30 | Half yearly DT and maintenance work | PO | 400 KV |
| MAIN BAY (431) OF 167 MVA SPARE ICT @ KORADI II | 16-06-2022 | 11:23 | | | 1) Premonsoon maintenance work & 2) Routine Bay Maintenance. | PO | 400 KV |
| PARLI(MS) - PARLI (PG) CKT - 1 | 17-06-2022 | 07:25 | 17-06-2022 | 20:38 | Rotary insulator of Y phase 29B isolator is broken & to be replaced. No outage of PGCIL circuit-1 is required. Both PGCIL circuit-1 & 2 will be in circuit. Only permission for 29A & 29B Main Bus-1 & 2 isolator operation / trials is required. 400kV PGCIL ckt-1 is on TBC.M/s Siemens representative is arriving for rectification of PG isolator problem | EO | 400 KV |
| 400 KV WALUJ (400 KV) - BABHALESHWAR CKT | 17-06-2022 | 09:29 | 17-06-2022 | 19:11 | Routine Maintenance work & Diagnostic Testing | PO | 400 KV |
| 400/220/33 KV 315MVA ICT - 2 @ BABHALESHWAR | 17-06-2022 | 23:20 | 18-06-2022 | 04:22 | Attending DC leakage in NIFPS of ICT 2 | EO | 400 KV |
| 400KV 125MVAR BUS REACTOR @ CHANDRAPUR 2 | 17-06-2022 | 08:54 | 17-06-2022 | 23:13 | Diagnostic testing and allied bay maintenance work | PO | 400 KV |

Transmission Line Outages/Trippings from 13.06.2022 to 19.06.2022

| Name of Line | Date Trip | Time Trip | Date Sync | Time Sync | Reason | Outage Type | Voltage |
|--|------------|-----------|------------|-----------|---|-------------|---------|
| BABLESHWAR- AURANGABAD (WALUJ) | 17-06-2022 | 09:29 | 17-06-2022 | 19:11 | Chemical Cleaning of Insulator string and Routine Line maintenance work | PO | 400 KV |
| LONIKAND I -JEJURI | 17-06-2022 | 18:43 | 17-06-2022 | 19:32 | TRIPPED ON DIST.PTROTECTION | T | 400 KV |
| MAIN BAY (410) OF FUTURE BAY @ JEJURI | 17-06-2022 | 13:00 | 18-06-2022 | 21:28 | For stringing work from gantry at 400 kv jehuri s/s to L.N.1 of LILO on 400 kv Lonikand-Karad line for 400 kv jehuri s/s. | PO | 400 KV |
| MAIN BUS - 2 @ KARAD | 17-06-2022 | 07:43 | 17-06-2022 | 15:39 | During PID testing of 400 kv Bus II gantry Disc Insulator strings in May-2022, it is observed that 03 Nos of Disc Insulator strings found faulty. Above faulty Disc Insulator strings are to be replaced by Outside | PO | 400 KV |
| TIE BAY (409) OF FUTURE BAY AND ICT - 3 @ JEJURI | 17-06-2022 | 12:58 | 18-06-2022 | 21:29 | For stringing work from gantry at 400 kv jehuri s/s to L.N.1 of LILO on 400 kv Lonikand-Karad line for 400 kv jehuri s/s. | PO | 400 KV |
| CHANDRAPUR 2- KUMBHARGAON (NANDED) CKT - 1 | 18-06-2022 | 19:17 | 20-06-2022 | 06:55 | Distance Protection | T | 400 KV |
| DHULE - KHANDWA CKT - 1 | 18-06-2022 | 15:31 | 18-06-2022 | 20:22 | Emergency outage at Khandwa end | HT | 400 KV |
| DHULE - KHANDWA CKT - 2 | 18-06-2022 | 02:15 | 18-06-2022 | 09:52 | DP | T | 400 KV |
| KORADI - KHAPERKHEDA CKT - 2 | 18-06-2022 | 13:16 | 18-06-2022 | 21:34 | H/T DUE TO HEAVY SPARKING AT KORADI END | HT | 400 KV |
| 400/220 KV 500MVA ICT - 4 @ KALWA | 18-06-2022 | 05:35 | 18-06-2022 | 08:20 | Premonsoon maintenance work. | PO | 400 KV |
| 500 MVA 400/220 KV ICT - II @ CHANDRAPUR 2 | 18-06-2022 | 09:23 | 18-06-2022 | 13:58 | For premonsoon activities and allied bay maintenance work | PO | 400 KV |
| BUS COUPLER @ CHAKAN | 18-06-2022 | 13:03 | 18-06-2022 | 16:05 | For attending Hotspots at Y phase 89 A PG Isolators IPS Tube L clamp of 400 KV Bus coupler bay. | EO | 400 KV |
| KORADI - BHILAI | 18-06-2022 | 15:52 | 19-06-2022 | 00:01 | CT cable found broken | HT | 400 KV |
| KALWA - TALEGAON (PG) | 19-06-2022 | 06:21 | 19-06-2022 | 18:50 | 1) Cold line cleaning, Chemical cleaning of Insulators and addition jumpuring work by fire wedge connector. 2) Additional work to replace existing disc type insulator strings with Anti fog long rod insulator in D/C portion. | PO | 400 KV |
| 400/220 KV 3X105 MVA ICT - 1 @ KHARGHAR | 19-06-2022 | 19:15 | 20-06-2022 | 02:56 | "For attending 220kV side Y phase Stub Bus Hot spot attending work. | EO | 400 KV |
| 400/220 KV 3X105 MVA ICT - 1 @ PADGHE | 19-06-2022 | 13:08 | 19-06-2022 | 14:06 | 220KV Bus Fault at Padghe | T | 400 KV |
| 400/220 KV 500 MVA ICT - 5 @ PADGHE | 19-06-2022 | 13:08 | 19-06-2022 | 14:13 | 220KV Bus Fault at Padghe | T | 400 KV |
| 400/220/33 KV 315 MVA ICT - 2 @ PADGHE | 19-06-2022 | 13:08 | 19-06-2022 | 14:08 | 220KV Bus Fault at Padghe | T | 400 KV |
| 400/220/33 KV 315 MVA ICT - 2 @ WALUJ | 19-06-2022 | 15:38 | 19-06-2022 | 16:47 | To close 89L R-ph (ICT-2 HV) to proper position (Tilted to opening side due to stormy winds) | EO | 400 KV |
| 400/220/33 KV 315 MVA ICT - 3 @ PADGHE | 19-06-2022 | 13:08 | 19-06-2022 | 14:30 | 220KV Bus Fault at Padghe | T | 400 KV |
| MUDSHINGI - CHIKODI | 06-06-2022 | 09:18 | 14-06-2022 | 21:50 | Line reorientation work from D/C towers (Loc. 320 to 312 to M/C-9)) to M/C towers (Guide-D/C- M/C 3 to M/C 9) . | PO | 220 KV |

Transmission Line Outages/Trippings from 13.06.2022 to 19.06.2022

| Name of Line | Date Trip | Time Trip | Date Sync | Time Sync | Reason | Outage Type | Voltage |
|--|------------|-----------|------------|-----------|--|-------------|---------|
| THEUR-JEJURI | 09-06-2022 | 09:20 | 13-06-2022 | 16:09 | 1)L.N.-9 old tower dismantling work , Errection of New tower, Destrtring between L.N.- 8 to 9 & 9 to 10 , Stringing between L.N.- 8 to 9 & 9 to 10 (As L.N.- 9 bended & new tower foundation work completed) 2)L.N.-11, B, Pahgse,L.N.-18, B Phase, L.N.- 21, B Phase 220 kV Jejuri Phursungi ckt I Double Jump ring work due to Hot spot Restrtring between L.N.- 70 to 76 & 76 to 79 of 220 kV Theur Jejuri due to increased sag & ground clearance reduced | PO | 220 KV |
| AAREY - AEML SAKI CKT - 2 | 13-06-2022 | 10:31 | 15-06-2022 | 16:03 | Repair / restoration of 220 kV R-Phase cable with additional Joint. | PO | 220 KV |
| APTA - KALWA | 13-06-2022 | 16:02 | 13-06-2022 | 17:36 | Removal of Neelgiri tree found tilt in between Loc. No. 77 & 78. | EO | 220 KV |
| PHURSUNGI-PARVATI | 13-06-2022 | 10:18 | 14-06-2022 | 18:05 | CB overhauling work | PO | 220 KV |
| TILLARI - AMONA LINE | 13-06-2022 | 12:50 | 13-06-2022 | 14:30 | TRIPPED ON DISTANCE PROTECTION | T | 220 KV |
| 220/22 KV 50 MVA PTR 1 @ KALWA | 13-06-2022 | 11:35 | 13-06-2022 | 15:00 | Outage required for Safety precaution for firewall construction work. | PO | 220 KV |
| 220/33kV 100 MVA TF 3 @ GHODBUNDER | 13-06-2022 | 14:43 | 13-06-2022 | 16:03 | For completing Pre monsoon activities | PO | 220 KV |
| 220/33kV 125 MVA TF 1 @ GORAI | 13-06-2022 | 09:42 | 13-06-2022 | 16:46 | Pre monsoon activities and annual maintenance. | PO | 220 KV |
| 220/33kV 125 MVA TF 2 @ BORIVALI (AEML) | 13-06-2022 | 10:42 | 13-06-2022 | 12:37 | Checking and attending issue of "CB Trip circuit supervision relay" not getting resetted as Negative supply of TC-1 is not getting extended from CB compartement of 220kV GIS to LCC. | PO | 220 KV |
| BUS SECTION - 1 @ BIDRI | 13-06-2022 | 09:35 | 13-06-2022 | 17:55 | QMW | PO | 220 KV |
| BUS SECTION BREAKER-3 @ TROMBAY | 13-06-2022 | 17:07 | 13-06-2022 | 17:24 | RAISING SF6 GAS PRESSURE | EO | 220 KV |
| NEW KOYNA - LOTEPARSHURAM | 13-06-2022 | 17:40 | 13-06-2022 | 21:46 | For attending hotspot at loc no.00 & 01 | EO | 220 KV |
| PT BAY NO.1 @ BHOSARI | 13-06-2022 | 11:22 | 13-06-2022 | 17:10 | Tan delta testing of PT and maintenance work | PO | 220 KV |
| SALSETTE - SAKI -7 | 13-06-2022 | 00:04 | 13-06-2022 | 02:10 | for attending Hot Spot at Salsette | PO | 220 KV |
| BHUGAON - WARDHA (PG) | 14-06-2022 | 09:44 | 15-06-2022 | 18:12 | Routine line maintenance work | PO | 220 KV |
| BOISAR - VERSOVA | 15-06-2022 | 06:51 | | | Bunching on Tower no BTL 16, to facilitate Modification / relocation of existing tower no BTL 13 to BTL 15 for NHRCL projectNote: Post bunching of line, the configuration of line will change as below:1.220 kV Dahanu - Virar and 220 kV Viraj - Versova. 2.MSETCL Boisar will be disconnected from the AEML Versova and MSETCL Viraj for a period of 10 days (i.e.from 15/06/2022 to 24/06/2022). 3.Normalization of bunching shall be carried out on 25/06/2022 | PO | 220 KV |
| NIGADE- PETH LINE | 15-06-2022 | 07:50 | 15-06-2022 | 10:04 | Fixing of suspension clamp of pilot string at Loc No.60 & 119. Fixing of repair sleeve on damaged conductor between Loc No.60-61 B Ph. | PO | 220 KV |

Transmission Line Outages/Trippings from 13.06.2022 to 19.06.2022

| Name of Line | Date Trip | Time Trip | Date Sync | Time Sync | Reason | Outage Type | Voltage |
|------------------------------------|------------|-----------|------------|-----------|---|-------------|---------|
| PADGHE - TEMGHAR - 1 | 15-06-2022 | 00:39 | 15-06-2022 | 03:47 | Bunching of 220KV Padgha-Temghar -1 & 2 line at Loc no. 80 and jumper removing at Loc. no.80 & 81 for diversion of 220KV Padgha-Temghar 2 line bay to 220KV Padgha-Temghar-1 line bay at Padgha S/s by availing simultaneous outages on 220KV Padgha-Temghar -1 & 2 line. | PO | 220 KV |
| PADGHE - TEMGHAR - 2 | 15-06-2022 | 00:11 | | | Bunching of 220KV Padgha-Temghar -1 & 2 line at Loc no. 80 and jumper removing at Loc. no.80 & 81 for diversion of 220KV Padgha-Temghar 2 line bay to 220KV Padgha-Temghar-1 line bay at Padgha S/s by availing simultaneous outages on 220KV Padgha-Temghar -1 & 2 line. | PO | 220 KV |
| URAN - ONGC URAN | 15-06-2022 | 14:20 | 15-06-2022 | 16:40 | Tripped from Uran end only.TC-1 secondary short, control cable faulty | T | 220 KV |
| VERSOVA - GORAI | 15-06-2022 | 11:17 | 15-06-2022 | 12:10 | Premonsoon maintenance work | PO | 220 KV |
| 220/100 KV 200 MVA ICT 1 @ PADGHE | 15-06-2022 | 16:03 | 15-06-2022 | 19:22 | contacts of REF relay found closed | T | 220 KV |
| 220/132 KV 100 MVA ICT - 1 @KALWAN | 15-06-2022 | 12:00 | 15-06-2022 | 17:36 | For Relay Testing work & SCADA upgrading work | PO | 220 KV |
| AUXILARY BUS @ VAIRAG | 15-06-2022 | 10:38 | 15-06-2022 | 19:23 | Outage is required for Quarterly Maintenance | PO | 220 KV |
| BOISAR II - VIRAJ | 15-06-2022 | 07:06 | | | Bunching on Tower no BTL 16, to facilitate Modification / relocation of existing tower no BTL 13 to BTL 15 for NHSRCL project>Note: Post bunching of line, the configuration of line will change as below:1.220 kV Dahanu - Viraj and 220 kV Viraj - Versova. 2.MSETCL Boisar will be disconnected from the AEML Versova and MSETCL Viraj for a period of 10 days (i.e.from 15/06/2022 to 24/06/2022). 3.Normalization of bunching shall be carried out on 25/06/2022 | PO | 220 KV |
| BUS SECTION-4 @ TEMGHAR | 15-06-2022 | 04:38 | 15-06-2022 | 04:57 | For closing Bus section isolator 3 at 220kv Temghar ss(Reason: As Padgha Temghar 2 line will be under outage, taken by Line sub dn. kalwa hence there will be single source of 220kv Kalwa Temghar line on 220kv Bus section 4) | PO | 220 KV |
| EKLAHARA(GCR)(NASIK)-BABLESHWAR 2 | 15-06-2022 | 11:34 | 15-06-2022 | 19:16 | 220Kv BBLR Nashik line ckt No.2, 230-Y ph Nsk side. LOC 187 Y ph nasik side as detected in the thermovision carried on dated 10.06.2022. | PO | 220 KV |
| KHARGHAR - TOPWORTH | 15-06-2022 | 12:03 | 15-06-2022 | 18:06 | Replacement of faulty disc insulator found during PID testing at Loc No. 600 (Middle phase) & Loc no. 617 (Bottom phase) | PO | 220 KV |
| LAMBOTI - VAIRAG | 15-06-2022 | 10:38 | 15-06-2022 | 19:22 | Outage is required for Quarterly Maintenance | PO | 220 KV |
| MAHAD-KALAMBANI(TSS) | 15-06-2022 | 12:36 | 15-06-2022 | 19:40 | Flashover string replacement work at Loc.No.11 (R Ph) and Loc.No.231 (Y Ph) and other line maintenance work. | PO | 220 KV |
| MAIN BUS @ VAIRAG | 15-06-2022 | 10:38 | 15-06-2022 | 19:23 | Outage is required for Quarterly Maintenance | PO | 220 KV |
| PANDHARPUR - BHALVANI | 15-06-2022 | 11:30 | 15-06-2022 | 13:59 | Outage is required for Quarterly Maintenance | PO | 220 KV |

Transmission Line Outages/Trippings from 13.06.2022 to 19.06.2022

| Name of Line | Date Trip | Time Trip | Date Sync | Time Sync | Reason | Outage Type | Voltage |
|--------------------------------------|------------|-----------|------------|-----------|--|-------------|---------|
| TBC @ GHODBUNDER | 15-06-2022 | 10:07 | 15-06-2022 | 15:17 | For completing Pre-Monsoon activities. | PO | 220 KV |
| TBC @ PARVATI | 15-06-2022 | 10:20 | 16-06-2022 | 16:17 | CB overhauling work | PO | 220 KV |
| BOMBAY DYEING - SAHARA | 16-06-2022 | 12:15 | 16-06-2022 | 19:20 | Replacement of flashover strings loc-89,92,94 and cold washing loc 92-97 | PO | 220 KV |
| KHARGHAR - NERUL | 16-06-2022 | 09:50 | 16-06-2022 | 14:15 | To attend hotspot on R phase bus side conductor crimp and Y phase bus side jaw | EO | 220 KV |
| PANDHARPUR - MALINAGAR | 16-06-2022 | 11:12 | 16-06-2022 | 18:23 | Outage is required for changing / replacement of faulty string at loc no. LILO Portion - 76, 79, 81, 82. | PO | 220 KV |
| 220/132-110KV 200MVA ICT 2 @ MIRAJ | 16-06-2022 | 10:54 | 16-06-2022 | 15:04 | For relay testing work | PO | 220 KV |
| 220/22KV 50MVA PTR 2 @ RANJANGAON | 16-06-2022 | 10:10 | 16-06-2022 | 15:00 | For HV side 29D Isolator Box replacement & general bay maintenance | PO | 220 KV |
| 220/33 KV 50MVA PTR - 1 @ KALWAN | 16-06-2022 | 12:25 | 16-06-2022 | 21:05 | Relay testing and SCADA Upgrading | PO | 220 KV |
| BUS SECTION - 1 @ KHAREPATAN | 16-06-2022 | 09:23 | 16-06-2022 | 13:58 | For chemical washing of bus & Line insulator strings in 220 KV bus section- I at Kharepatan end by agency. | PO | 220 KV |
| BUS SECTION - 2 @ KHAREPATAN | 16-06-2022 | 15:20 | 16-06-2022 | 17:19 | For Chemical washing of bus & line insulators strings in the 220 KV bus section- II at Kharepatan end by agency. | PO | 220 KV |
| FLAGSHIP-CHINCHWAD | 16-06-2022 | 09:04 | 16-06-2022 | 17:50 | 1) Half yearly bay maintenance work. 2) Y and B ph Bottom CT painting work. | PO | 220 KV |
| PHALTAN MIDC - CSSK BHAVANI NAGAR | 16-06-2022 | 09:55 | 16-06-2022 | 14:40 | For CT Tan delta measurement & configuration of Busbar PU relay at 220 kV Phaltan MIDC S/S | PO | 220 KV |
| PHALTAN MIDC - WALCHANDNAGAR | 16-06-2022 | 16:00 | 16-06-2022 | 17:55 | Busbar PU relay replacement work of Walchandnagar bay at 220 kV Phaltan MIDC S/s | PO | 220 KV |
| APTA - TALOJA | 17-06-2022 | 16:08 | 17-06-2022 | 18:40 | To Attend hot spot on R-ph. CT | EO | 220 KV |
| JAMBHUL - ANANDNAGAR | 17-06-2022 | 07:05 | 17-06-2022 | 11:29 | 1)Routine Maintenance works 2)CT Capacitance & Tan Delta Test 3)Premonsoon Maintenance Work | PO | 220 KV |
| MALINAGAR - TEMBHURNI | 17-06-2022 | 10:42 | 17-06-2022 | 19:45 | Outage is required 1) For changing / replacement of faulty string at loc no. 74, 81, 82. 2) Disc Cleaning work from loc no. 70 to 82. | PO | 220 KV |
| NAGOTHANE - POSCO | 17-06-2022 | 11:10 | 17-06-2022 | 16:20 | For extension of conductor near to CC at 220 kV POSCO end. | PO | 220 KV |
| TALANDAGE - FIVE STAR MIDC 1 | 17-06-2022 | 10:13 | 17-06-2022 | 18:33 | For replacement of weak insulator strings observed in PID testing at tower loc. No. 11 (Y&B Ph.) & 1(R&B Ph) | PO | 220 KV |
| URAN - ONGC URAN | 17-06-2022 | 11:33 | 17-06-2022 | 19:38 | Breaker to Relay Panel Cable Replacement at Uran End. | EO | 220 KV |
| 220/100 KV 200 MVA ICT 2 @ PADGHE | 17-06-2022 | 15:26 | 17-06-2022 | 18:48 | For replacement of 19 Core 2.5 sq mm Cable due to grounding. | EO | 220 KV |
| 220/132 KV 100 MVA ICT 1 | 17-06-2022 | 11:04 | 17-06-2022 | 19:15 | ICT 1 = Quarterly maintenance, oil leakage attending & oil top tan delta testing of ICT | PO | 220 KV |
| 220/132 KV 200 MVA ICT 1 @ BOISAR-II | 17-06-2022 | 10:59 | 17-06-2022 | 14:47 | Pre Monsoon Maintenance, Diagnostic work & Hot spot attending. | PO | 220 KV |
| 220/22 KV 50 MVA PTR 2 @ ANANDNAGAR | 17-06-2022 | 12:59 | 17-06-2022 | 13:49 | Pre-monsoon maintenance work | PO | 220 KV |

Transmission Line Outages/Trippings from 13.06.2022 to 19.06.2022

| Name of Line | Date Trip | Time Trip | Date Sync | Time Sync | Reason | Outage Type | Voltage |
|---------------------------------------|------------|-----------|------------|-----------|---|-------------|---------|
| 220/22 KV 50 MVA PTR 3 @ MAHAPE | 17-06-2022 | 08:57 | 17-06-2022 | 22:16 | Modification of Header and Flanges of Adiham make Advanced Transformer Oil Cooling system and connection of centralized monitoring system | PO | 220 KV |
| 220/22 KV 50 MVA PTR 1 @ ANANDNAGAR | 17-06-2022 | 12:01 | 17-06-2022 | 12:46 | Pre-monsoon maintenance work | PO | 220 KV |
| 220/22 KV 50 MVA PTR 2 @ BHANDUP GIS | 17-06-2022 | 06:09 | 17-06-2022 | 08:42 | BUS BAR RELAY COMMISSIONING WORK. | PO | 220 KV |
| 220/33KV 25MVA PTR 2 | 17-06-2022 | 10:10 | 17-06-2022 | 15:16 | For erection of 220kv (HV) CTs & Bus Isolator blade for 25MVA 220/33kv TF-I bay. | PO | 220 KV |
| 220/33KV 25MVA PTR 1 | 17-06-2022 | 10:00 | 17-06-2022 | 15:16 | For erection of 220kv (HV) CTs & Bus Isolator blade for 25MVA 220/33kv TF-I bay. | PO | 220 KV |
| BHAVEGHAR - ROMA | 17-06-2022 | 09:28 | 17-06-2022 | 17:58 | Replacement of PID Faulty insulator strings at loc.No10 (B-Ph),32 (Y-Ph),38(R-Ph),67(Y-Ph). | PO | 220 KV |
| DAHANU - GHODBUNDER CKT - 1 | 17-06-2022 | 08:27 | 17-06-2022 | 20:38 | Project activity Modification / relocation of existing tower no LS 191 to 194 at Virar for DFCCIL project. Details of activity to be carried out: Re-stringing of conductors & OPGW cable. | PO | 220 KV |
| KHADKI- CENTURY ENKA | 17-06-2022 | 11:15 | 17-06-2022 | 19:20 | To attend Y ph auxiliary contact problem for spring charge | PO | 220 KV |
| LONIKAND1-LONIKAND2 (INTER CONNECTOR) | 17-06-2022 | 17:26 | 17-06-2022 | 18:33 | Implementing of Line Differential Protection scheme by retrofitting of Line Differential Relays at both 400kv Lonikand II and 400kv Lonikand-I end | PO | 220 KV |
| NANDED CITY - PARVATI | 17-06-2022 | 10:27 | 17-06-2022 | 19:11 | CB Overhauling work | PO | 220 KV |
| NIWALI - PAWAS LINE | 17-06-2022 | 10:11 | 17-06-2022 | 15:01 | For erection of 220kv (HV) CTs & Bus Isolator blade for 25MVA 220/33kv TF-I bay. | PO | 220 KV |
| PAWAS - FINOLEX CKT - 1 | 17-06-2022 | 10:05 | 17-06-2022 | 14:15 | For erection of 220kv (HV) CTs & Bus Isolator blade for 25MVA 220/33kv TF-I bay. | PO | 220 KV |
| VITA - GHATNANDRE | 17-06-2022 | 10:10 | 17-06-2022 | 12:59 | For attending Hot spot of line bay CT & quarterly maintenance work. | PO | 220 KV |
| EKLAHARE (OCR) - PADGHE | 18-06-2022 | 12:20 | 18-06-2022 | 14:45 | For Bay maintenance & Diagnostic Testing work | PO | 220 KV |
| KANDALGAON - BHIRA | 18-06-2022 | 12:55 | 18-06-2022 | 17:42 | Outage tree cutting work and other line maintenance work. | PO | 220 KV |
| MALEGAON-SATANA | 18-06-2022 | 09:58 | 18-06-2022 | 11:13 | Outage proposal for Quarterly maint. Work. | PO | 220 KV |
| TALANDGE - SAWANTWADI | 18-06-2022 | 10:15 | 18-06-2022 | 13:25 | For fixing of repair Sleeve at loc No. 194-195 | PO | 220 KV |
| 220/132kv 200MVA ICT-2 @ KOPARGAON | 18-06-2022 | 10:02 | 18-06-2022 | 18:30 | For Attending oil leakage of Rph HV Bushing turret gasket joint | PO | 220 KV |
| 220/22KV 50 MVA PTR - 3 @ AKP | 18-06-2022 | 08:18 | 18-06-2022 | 12:40 | LV R phase 2 nos. of faulty cable rejoin and testing work. | PO | 220 KV |
| 220/33kv 50MVA TF-2 @ KOPARGAON | 18-06-2022 | 16:00 | 18-06-2022 | 20:41 | For attending oil Leakage from top plate of TF | PO | 220 KV |
| BORIVALI - BOISAR II LINE | 18-06-2022 | 14:40 | 18-06-2022 | 15:34 | 1) Moisture ingress observed in CB mechanism box & same to be attended on priority to avoid CB false tripping. 2) 220KV BORIVALI - BOISAR II will be shifted to TBC & will be in service. | EO | 220 KV |

Transmission Line Outages/Trippings from 13.06.2022 to 19.06.2022

| Name of Line | Date Trip | Time Trip | Date Sync | Time Sync | Reason | Outage Type | Voltage |
|---------------------------------------|------------|-----------|------------|-----------|---|-------------|---------|
| DAHANU - GHODBUNDER CKT - 2 | 18-06-2022 | 08:05 | 18-06-2022 | 20:22 | Project activity Modification / relocation of existing tower no LS 191 to 194 at Virar for DFCCIL project. Details of activity to be carried out: Re-stringing of conductors & OPGW cable. | PO | 220 KV |
| KARAD - KADEGAON | 18-06-2022 | 16:13 | 18-06-2022 | 19:45 | To attend hot spot at loc. Y phase CT P1 side & B phase CT P2 side. | EO | 220 KV |
| NEW KOYNA - NIWALI | 18-06-2022 | 09:45 | 18-06-2022 | 18:31 | For replacement of electro mechanical backup relay by numerical relay | PO | 220 KV |
| TROMBAY - ANTOP HILL CKT - 2 | 18-06-2022 | 08:19 | 18-06-2022 | 17:50 | CVT and Protection Testing AT TROMBAY | PO | 220 KV |
| VITTAL SUGAR CO GEN (VSSK) - KARKAMBH | 18-06-2022 | 10:22 | 18-06-2022 | 18:38 | Outage is required for 1) For changing / replacement of faulty string at loc no. 114, 116, 117, 119, 121. | PO | 220 KV |
| WAGHIVALI - DHARAVI 8 | 18-06-2022 | 00:04 | 18-06-2022 | 04:57 | FOR TWFL COMMISSIONING | PO | 220 KV |
| PANDHARPUR - MALINAGAR | 19-06-2022 | 16:28 | 19-06-2022 | 19:27 | Outage is required for For changing / replacement of faulty string at loc no. 37, 38, 48 and 51. | PO | 220 KV |
| 220/100 KV 200 MVA ICT 1 @ PADGHE | 19-06-2022 | 13:08 | 19-06-2022 | 14:16 | 220KV Bus Fault at Padghe | T | 220 KV |
| 220/100 KV 200 MVA ICT 2 @ PADGHE | 19-06-2022 | 13:08 | 19-06-2022 | 14:14 | 220KV Bus Fault at Padghe | T | 220 KV |
| 220/100 KV 200 MVA ICT 3 @ PADGHE | 19-06-2022 | 13:08 | 19-06-2022 | 14:15 | 220KV Bus Fault at Padghe | T | 220 KV |
| 220/100 KV 200 MVA ICT 4 @ PADGHE | 19-06-2022 | 13:08 | 19-06-2022 | 14:18 | 220KV Bus Fault at Padghe | T | 220 KV |
| 220/22 KV 50 MVA PTR 1 @ PADGHE | 19-06-2022 | 13:08 | 19-06-2022 | 18:50 | 220KV Bus Fault at Padghe | T | 220 KV |
| 220/22 KV 50 MVA PTR 2 @ PADGHE | 19-06-2022 | 13:08 | 19-06-2022 | 14:20 | 220KV Bus Fault at Padghe | T | 220 KV |
| BUS - A @ PADGHE | 19-06-2022 | 13:08 | 19-06-2022 | 14:06 | 220KV Bus Fault at Padghe | T | 220 KV |
| PADGHE - JAMBHUL 1 | 19-06-2022 | 13:08 | 19-06-2022 | 14:17 | 220KV Bus Fault at Padghe | T | 220 KV |
| PADGHE - PAL DOMBIVALI | 19-06-2022 | 13:08 | 19-06-2022 | 14:17 | 220KV Bus Fault at Padghe | T | 220 KV |
| SALSETTE - SAHAR CKT | 19-06-2022 | 06:27 | 19-06-2022 | 09:01 | REPAIR TO SLEEVE ON C PHASE CONDUCTOR IN SPAN -27-28 | PO | 220 KV |
| TROMBAY CARNAC - 5 | 19-06-2022 | 09:17 | 19-06-2022 | 15:42 | FOR CVT AND PROTECTION TESTING AT TROMBAY | PO | 220 KV |
| KALYAN KALWA SALSETTE 1 | 18-06-2022 | 09:06 | 18-06-2022 | 20:30 | THIRD PARTY WORK-DFCC LINE SHIFTING WORK AT LOC-30 | PO | 110 KV |