

State Load Despatch Center,Airoli (MSETCL)
Power System Position from 13/Jul/2015 to 19/Jul/2015

Supply Position During Morning Peak (MW)

Date	Time	MSGENCO				Central Sector Receipt	Wind	CPP	SOLAR	TPCL Exch.	MSEDCL Catered Demand	Load Shedding(LS)	MSEDCL Demand (Incl. LS)	TPCL Gen.	R-INFRA Gen.	State Demand Met	State Demand (Incl. LS)	Freq.
		THM	HYDRO	GAS	Total													
		MW	MW	MW	MW	MW	MW	MW	MW	MW	MW	MW	MW	MW	MW	MW	MW	Hzs
13/07/2015	12 Hrs	3822	1621	270	5713	7079	394	4611	135	-1749	16183	560	16743	1219	258	19409	19969	49.82
14/07/2015	12 Hrs	3727	1668	270	5665	7222	402	3774	153	-1575	15641	1250	16891	1418	257	18891	20141	49.82
15/07/2015	12 Hrs	3854	1385	270	5509	7404	1036	3818	152	-1364	16555	135	16690	1358	515	19792	19927	49.98
16/07/2015	12 Hrs	3794	580	270	4644	7776	1599	3689	116	-1492	16332	129	16461	1229	507	19560	19689	49.96
17/07/2015	11 Hrs	3867	218	264	4349	7902	1590	3181	104	-1396	15730	388	16118	1228	517	18871	19259	49.94
18/07/2015	11 Hrs	4573	190	276	5039	6483	1851	3342	108	-1247	15576	166	15742	938	517	18278	18444	49.95
19/07/2015	9 Hrs	4101	381	134	4616	6050	1731	2698	28	-885	14238	210	14448	750	394	16267	16477	50.03
Maximum		4573	1668	276	5713	7902	1851	4611	153	-885	16555	1250	16891	1418	517	19792	20141	50
Minimum		3727	190	134	4349	6050	394	2698	28	-1749	14238	129	14448	750	257	16267	16477	50
Average		3963	863	251	5076	7131	1229	3588	114	-1387	15751	129	16156	1163	424	18724	19129	50

Supply Position During Day Peak (MW)

Date	Time	MSGENCO				Central Sector Receipt	Wind	CPP	SOLAR	TPCL Exch.	MSEDCL Catered Demand	Load Shedding(LS)	MSEDCL Demand (Incl. LS)	TPCL Gen.	R-INFRA Gen.	State Demand Met	State Demand (Incl. LS)	Freq.
		THM	HYDRO	GAS	Total													
		MW	MW	MW	MW	MW	MW	MW	MW	MW	MW	MW	MW	MW	MW	MW	MW	Hzs
13/07/2015	13 Hrs	3911	1565	270	5746	7034	362	4611	143	-1630	16266	640	16906	1309	258	19463	20103	49.92
14/07/2015	16 Hrs	3936	1168	273	5377	6663	881	4246	102	-1551	15718	1235	16953	1378	258	18905	20140	49.94
15/07/2015	13 Hrs	3925	1453	269	5647	7111	1106	3824	162	-1388	16462	221	16683	1331	517	19698	19919	49.95
16/07/2015	15 Hrs	4065	113	270	4448	7389	1562	3803	97	-1463	15836	99	15935	1227	515	19041	19140	49.91
17/07/2015	13 Hrs	3882	133	263	4278	7302	1741	3067	119	-1432	15075	417	15492	1230	516	18253	18670	49.97
18/07/2015	13 Hrs	4325	110	277	4712	6294	1952	3392	100	-1334	15116	67	15183	908	516	17874	17941	49.96
19/07/2015	13 Hrs	4087	173	133	4393	6093	1886	2632	68	-1201	13871	54	13925	626	395	16093	16147	49.98
Maximum		4325	1565	277	5746	7389	1952	4611	162	-1201	16462	1235	16953	1378	517	19698	20140	50
Minimum		3882	110	133	4278	6093	362	2632	68	-1630	13871	54	13925	626	258	16093	16147	50
Average		4019	674	251	4943	6841	1356	3654	113	-1428	15478	54	15868	1144	425	18475	18866	50

Supply Position During Evening Peak (MW)

Date	Time	MSGENCO				Central Sector Receipt	Wind	CPP	SOLAR	TPCL Exch.	MSEDCL Catered Demand	Load Shedding(LS)	MSEDCL Demand (Incl. LS)	TPCL Gen.	R-INFRA Gen.	State Demand Met	State Demand (Incl. LS)	Freq.
		THM	HYDRO	GAS	Total													
		MW	MW	MW	MW	MW	MW	MW	MW	MW	MW	MW	MW	MW	MW	MW	MW	Hzs
13/07/2015	21 Hrs	3930	667	270	4867	5817	1324	4051	0	-1269	14790	96	14886	1268	259	17586	17682	49.88
14/07/2015	21 Hrs	4150	828	272	5250	5434	1463	4289	0	-1348	15088	89	15177	1227	257	17920	18009	49.95
15/07/2015	20 Hrs	3994	400	272	4666	6144	1444	4044	0	-1257	15041	70	15111	1145	516	17959	18029	49.94
16/07/2015	21 Hrs	4142	371	270	4783	6117	1412	3706	0	-1162	14856	64	14920	1175	517	17710	17774	49.95
17/07/2015	21 Hrs	3907	293	270	4470	5849	1879	3153	0	-1287	14064	203	14267	978	519	16848	17051	49.92
18/07/2015	21 Hrs	4230	180	239	4649	5727	1980	2637	0	-1235	13758	67	13825	789	518	16300	16367	49.96
19/07/2015	21 Hrs	4076	328	135	4539	5378	2054	2757	0	-1304	13424	35	13459	632	394	15754	15789	49.93
Maximum		4230	828	272	5250	6144	2054	4289	0	-1162	15088	203	15177	1268	519	17959	18029	50
Minimum		3907	180	135	4470	5378	1324	2637	0	-1348	13424	35	13459	632	257	15754	15789	50
Average		4061	438	247	4746	5781	1651	3520	0	-1266	14432	35	14521	1031	426	17154	17243	50

Supply Position During Night Off Peak (MW)

Date	Time	MSGENCO				Central Sector Receipt	Wind	CPP	SOLAR	TPCL Exch.	MSEDCL Catered Demand	Load Shedding(LS)	MSEDCL Demand (Incl. LS)	TPCL Gen.	R-INFRA Gen.	State Demand Met	State Demand (Incl. LS)	Freq.
		THM	HYDRO	GAS	Total													
		MW	MW	MW	MW	MW	MW	MW	MW	MW	MW	MW	MW	MW	MW	MW	MW	Hzs
13/07/2015	5 Hrs	3963	52	273	4288	4725	1191	4611	0	-849	13966	45	14011	888	258	15961	16006	49.92
14/07/2015	4 Hrs	3832	1059	272	5163	4978	1117	3615	0	-710	14163	305	14468	1065	259	16197	16502	49.93
15/07/2015	4 Hrs	4132	204	273	4609	5731	1266	3805	0	-605	14806	50	14856	1076	414	16901	16951	49.92
16/07/2015	5 Hrs	3812	63	271	4146	5800	1363	3524	0	-656	14177	61	14238	901	517	16251	16312	49.96
17/07/2015	23 Hrs	3997	52	268	4317	5935	1842	3202	0	-1333	13963	164	14127	809	518	16623	16787	49.88
18/07/2015	24 Hrs	4054	137	134	4325	5584	1869	2643	0	-1198	13223	67	13290	728	517	15666	15733	50.00
19/07/2015	4 Hrs	3998	116	135	4249	4973	1904	2651	0	-880	12897	43	12940	734	396	14907	14950	49.99
Maximum		4132	1059	273	5163	5935	1904	4611	0	-605	14806	305	14856	1076	518	16901	16951	50
Minimum		3812	52	134	4146	4725	1117	2643	0	-1333	12897	43	12940	728	258	14907	14950	50
Average		3970	240	232	4442	5389	1507	3436	0	-890	13885	43	13990	886	411	16072	16177	50

Details of Supply Position (MUs)

Date	MSGENCO				Pench (MS)	Central Sector Receipt	Central Sector Share	WIND	CPP	SOLAR	TPCL Gen.	R-INFRA Gen.	TPCL Exch.	Energy Requirement		
	THM	HYDRO	GAS	Total										MSEDCL	MUMBAI	STATE
	Mus	Mus	Mus	Mus	Mus	Mus	Mus	Mus	Mus	Mus	Mus	Mus	Mus	Mus	Mus	Mus
13/07/2015	93.651	21.607	6.521	121.779	0.394	142.977	125.952	21.641	105.130	1.102	27.447	6.196	-30.910	361.720	64.556	426.276
14/07/2015	93.708	27.108	6.507	127.323	0.703	143.600	128.420	23.933	94.440	1.186	30.023	6.192	-28.763	361.720	64.976	426.696
15/07/2015	94.974	16.917	6.499	118.390	0.130	156.224	141.788	30.328	92.717	1.230	28.290	11.474	-25.907	372.983	65.673	438.656
16/07/2015	94.009	7.435	6.493	107.937	0.389	158.404	155.475	34.233	91.161	1.024	25.569	12.357	-27.743	365.016	65.667	430.683
17/07/2015	95.010	3.551	6.488	105.049	0.216	156.474	150.735	40.041	78.378	0.992	24.374	12.297	-28.215	352.719	64.885	417.604
18/07/2015	102.274	3.920	6.106	112.300	0.025	141.052	138.591	44.525	72.429	0.899	19.516	12.414	-26.641	344.564	58.571	403.135
19/07/2015	97.537	3.563	3.211	104.311	0.084	132.934	127.737	44.150	63.992	0.502	15.537	9.571	-26.831	319.058	51.939	370.997
Maximum	102.274	27.108	6.521	127.323	0.703	158.404	155.475	102.274	105.130	1.230	30.023	12.414	-25.907	372.983	65.673	438.656
Minimum	93.651	3.551	3.211	104.311	0.025	132.934	125.952	93.651	63.992	0.502	15.537	6.192	-30.910	319.058	51.939	370.997
Average	95.880	12.014	5.975	113.870	0.277	147.381	138.385	95.880	85.464	0.991	15.537	10.072	-27.859	353.969	62.324	416.292

Details of Koyna Water Consumption (in TMC)

Date	For the Day	For the Month	Balance
13/07/2015	0.473	2.344	60.886
14/07/2015	0.610	2.954	60.276
15/07/2015	0.360	3.314	59.916
16/07/2015	0.117	3.431	59.799
17/07/2015	0.067	3.498	59.732
18/07/2015	0.067	3.565	59.665
19/07/2015	0.044	3.609	59.621

State Load Despatch Center, Airoli (MSETCL)
Central Sector Share/Drawal from 13/Jul/2015 to 19/Jul/2015

Date	DAY	Central Sector Share		Total Interstate Bilateral Purchase		Total Share		Total Drawal		Overdrawal(+) / UnderDrawal(-)	
		MUs	Avg. MW	MUs	Avg. MW	MUs	Avg. MW	MUs	Avg. MW	MUs	Avg. MW
		1		2		1+2=3		4		3-4=5	
13/07/2015	MONDAY	93.418	5215	32.534	1356	125.952	5248	142.977	5957	17.025	709
14/07/2015	TUESDAY	101.348	5324	27.072	1128	128.420	5351	143.600	5983	15.180	632
15/07/2015	WEDNESDA	99.706	5866	42.082	1753	141.788	5908	156.224	6509	14.436	602
16/07/2015	THURSDAY	98.917	6422	56.558	2357	155.475	6478	158.404	6600	2.929	122
17/07/2015	FRIDAY	93.504	6223	57.231	2385	150.735	6281	156.474	6520	5.739	239
18/07/2015	SATURDAY	93.736	5730	44.855	1869	138.591	5775	141.052	5877	2.461	103
19/07/2015	SUNDAY	86.797	5281	40.940	1706	127.737	5322	132.934	5539	5.197	217
Total		667.426		301.272		968.698		1031.665		62.967	

Weekly Unit Outages for Various Generating Stations from 13.07.2015 to 19.07.2015

Generating Company	Name of Generating Unit	Capacity	Tripped Date	Tripped Time	Sync.Date	Sync. Time	Reason of Outage
PLANNED OUTAGE							
CENT.SECTOR	Tarapur 1	160	12/10/2014	22:39		Continued.	Refuelling work
MSPGCL	Chandrapur Unit 6	500	09/06/2015	23.58		Continued.	COH
MSPGCL	Khaparkhedra Unit 4	210	19/06/2015	23.57	17/07/2015	01.34	Annual Overhaul
MSPGCL	Nasik Unit 5	210	30/06/2015	23.50		Continued.	Annual Overhaul
IPP	VIPL U-1	300	14/07/2015	23.58		Continued.	AOH.
TPC-G	Trombay 7B	60	17/07/2015	20.00		Continued.	Gas Path Inspection
TPC-G	Trombay 7A	120	17/07/2015	20.38		Continued.	Gas path Inspection and Rotor replacement
FORCED OUTAGE							
RGPPPL	Dabhol 1B	230	28/05/2013	22:02		Continued.	Gas Shortage.
RGPPPL	Dabhol 3A	230	06/06/2013	08.28		Continued.	Gas Shortage
RGPPPL	Dabhol 2A	230	06/06/2013	09.10		Continued.	Gas Shortage
RGPPPL	Dabhol 1X	290	27/06/2013	21.46		Continued.	Gas Shortage
RGPPPL	Dabhol 1A	230	27/06/2013	21.47		Continued.	Gas Shortage
RGPPPL	Dabhol 2X	290	15/07/2013	15.09		Continued.	Gas Shortage
RGPPPL	Dabhol 2B	230	08/08/2013	15.03		Continued.	Gas Shortage
RGPPPL	Dabhol 3X	290	29/12/2013	05.47		Continued.	Gas Shortage
RGPPPL	Dabhol 3B	230	29/12/2013	06.14		Continued.	Gas Shortage
IPP	Dhariwal	300	28/05/2014	02.27		Continued.	No schedule
MSPGCL	Chandrapur Unit 1	210	28/08/2014	07:15		Continued.	Economic Shutdown.
MSPGCL	Bhusawal Unit 2	210	13/09/2014	12.43		Continued.	Economic shutdown
MSPGCL	Koradi Unit 6	210	20/03/2015	01.02		Continued.	Economic shutdown
MSPGCL	Chandrapur Unit-8	500	29/03/2015	18.26		Continued.	Withdrawn
MSPGCL	Koradi Unit-8	660	30/03/2015	20.22	19/07/2015	03.25	BLR Tripped.
MSPGCL	Uran Unit 6	108	01/04/2015	16.35		Continued.	Gas shortage
IPP	RPL(AMT) U-5	270	03/04/2015	14.22		Continued.	turbine Shaft Vibration high.
MSPGCL	Uran Unit 7	108	17/04/2015	00.07		Continued.	Gas turbine problem
TPC-G	Trombay 6	500	05/06/2015	05.59	13/07/2015	11.50	Economic Shutdown.
MSPGCL	Koyna STG- IV Unit - 1	250	09/06/2015	14.22		Continued.	Excitation T/F Burst
MSPGCL	Parli Unit 3	210	14/06/2015	12.58		Continued.	Water Shortage
IPP	WPCL U-2	135	16/06/2015	00.00		Continued.	No Schdule
CPP	WPCL U-1	135	16/06/2015	00.00	11/07/2015	10.54	No Schdule
MSPGCL	Parli Unit 6	250	25/06/2015	15.03		Continued.	Water Shortage
IPP	Adani U-3	660	04/07/2015	15:03		Continued.	Super heater drain leakage.
MSPGCL	Parli Unit 4	210	05/07/2015	18.45		Continued.	Water Shortage
IPP	RPL(AMT) U-1	270	06/07/2015	00.37	19/07/2015	17.53	Furnace Pressure High

Generating Company	Name of Generating Unit	Capacity	Tripped Date	Tripped Time	Sync.Date	Sync. Time	Reason of Outage
MSPGCL	Parli Unit 5	210	06/07/2015	14.55		Continued.	Water Shortage.
MSPGCL	Parli Unit 7	250	08/07/2015	12.08		Continued.	Water Shortage
MSPGCL	Koradi Unit 5	200	09/07/2015	19.19	17/07/2015	04.53	ID Fan Problem
RINFRA-G	REL Unit 1	250	10/07/2015	04.57	14/07/2015	02.07	Boiler Tube Leakage
MSPGCL	Chandrapur Unit 5	500	11/07/2015	04.43	14/07/2015	12.51	Boiler Tube Leakage
CPP	WPCL U-4	135	11/07/2015	06.58		Continued.	ID Fan Vibration High
CPP	WPCL U-1	135	12/07/2015	10.01	13/07/2015	22.14	NO PPA.
IPP	Adani U-4	660	13/07/2015	17.14		Continued.	Boiler Tube Leakage
IPP	RPL(AMT) U-3	270	14/07/2015	03.55	14/07/2015	13.21	Low furnace pressure
MSPGCL	Khaparkheda Unit 2	210	14/07/2015	07.02	14/07/2015	10.15	Flame Failure
MSPGCL	Koyna Unit 7	80	14/07/2015	16.40	14/07/2015	18.40	Injector Wall Work.
MSPGCL	Bhusawal Unit 3	210	15/07/2015	09.08	17/07/2015	19.25	Boiler Tube Leakage
IPP	RPL(AMT) U-2	270	15/07/2015	09.15	15/07/2015	11.28	Flame Failure
TPC-G	Trombay 6	500	15/07/2015	17.08		Continued.	Economic shutdown
MSPGCL	Bhusawal Unit 4	500	15/07/2015	20.54	16/07/2015	03.14	steam leakage
IPP	RPL(AMT) U-3	270	16/07/2015	18.26		Continued.	PA Fan problem
MSPGCL	Paras Unit 4	250	17/07/2015	00.18	17/07/2015	02.11	Furnace Pressure High
MSPGCL	Khaparkheda Unit 4	210	17/07/2015	03.40	17/07/2015	17.56	turbine shaft vibration high
CPP	WPCL U-1	135	18/07/2015	00.00		Continued.	FD Fan Problem.
IPP	RPL(AMT) U-4	270	18/07/2015	18.15		Continued.	ID Fan Problem
MSPGCL	Koradi Unit 5	200	18/07/2015	20.57		Continued.	ID Fan Problem
MSPGCL	Uran Unit 5	108	18/07/2015	21.20		Continued.	Boiler Validity Extension
MSPGCL	Koradi Unit-8	660	19/07/2015	08.18		Continued.	Due to Bypass Valve Stucked up.

Weekly line outages from 13.07.2015 to 19.07.2015

Voltage Level	Name	Trip Date	Trip Time	Synchronisation Date	Synchronisation Time	Outage Type	Reason
765 KV	Wardha PG - Aurangabad PG IV	13/Jul/2015	07.19		Continued.	HT	To Control Padgha-BBLR Line Loading.
400 KV	Dabhol Nagothane I	30/Jun/2015	16.53	14/Jul/2015	13.38	HT	Over Voltage
400 KV	400/220/33 Kv 315 Mva Ict 1 @Dhule	04/Jul/2015	14.32	14/Jul/2015	03.16	PO	Commissioning Of Spare ICT In Place Of R-Ph Unit.
400 KV	Karad -kolhapur-I	12/Jul/2015	16.06	13/Jul/2015	08.24	HT	Over Voltage
400 KV	Karad - Jaigad - II	12/Jul/2015	16.10	13/Jul/2015	08.27	HT	Over Voltage
400 KV	Kolhapur Mapusa II	12/Jul/2015	16.22	13/Jul/2015	06.20	HT	Over Voltage
400 KV	Khadka-Aurangabad (Waluj)	12/Jul/2015	18.00	13/Jul/2015	06.21	HT	Over Voltage
400 KV	Bhusawal-Aurangabad	12/Jul/2015	18.00	13/Jul/2015	06.21	HT	Over Voltage
400 KV	Kolhapur Solapur(PG) I	12/Jul/2015	18.19	13/Jul/2015	05.27	HT	Over Voltage
400 KV	Dhule Sar'Sarovar I	12/Jul/2015	21.17	14/Jul/2015	06.58	HT	Over Voltage
400 KV	Babhleshwar - Padghe-II	13/Jul/2015	00.51	13/Jul/2015	13.46	Tripped	Distance Protection
400 KV	Karad - Lonikand I	13/Jul/2015	06.34	13/Jul/2015	07.02	Tripped	Distance Protection
400 KV	Babhleshwar-Taptitanda ckt-II	13/Jul/2015	09.24	13/Jul/2015	17.31	HT	Over Voltage
400 KV	Karad -kolhapur-I	13/Jul/2015	16.32	14/Jul/2015	06.30	HT	Over Voltage
400 KV	Kolhapur Mapusa II	13/Jul/2015	17.12	14/Jul/2015	06.47	HT	Over Voltage
400 KV	Karad-Jaigad - I	13/Jul/2015	17.37	14/Jul/2015	08.25	HT	Over Voltage
400 KV	Bhusawal-Aurangabad	13/Jul/2015	17.45	14/Jul/2015	06.11	HT	Over Voltage
400 KV	Lonikand I - Koyna stage-IV	14/Jul/2015	02.02	14/Jul/2015	06.55	HT	Over Voltage
400 KV	Babhleshwar - Padghe-II	14/Jul/2015	03.35	14/Jul/2015	19.56	Tripped	Distance Protection
400 KV	Padghe - Talegaon (PG)	14/Jul/2015	05.59	14/Jul/2015	06.52	Tripped	Distance Protection
400 KV	Babhleshwar-Taptitanda ckt-II	14/Jul/2015	08.48	23/Jul/2015	05.53	HT	Over Voltage
400 KV	Nagothane - Dabhol-II	14/Jul/2015	12.33		Continued.	Tripped	Distance Protection
400 KV	Karad -kolhapur-I	14/Jul/2015	17.04	15/Jul/2015	07.22	HT	Over Voltage
400 KV	Kolhapur Mapusa II	14/Jul/2015	17.18	14/Jul/2015	07.11	HT	Over Voltage
400 KV	Karad - Jaigad - II	14/Jul/2015	17.59	15/Jul/2015	07.25	HT	Over Voltage
400 KV	400/220/33 Kv 315 Mva Ict 2 @Girwali	14/Jul/2015	22.17	14/Jul/2015	02.05	PO	To attend Hot Spot
400 KV	Akola-Nandgaonpeth (RPL)	15/Jul/2015	09.12	15/Jul/2015	18.59	PO	Annual Maintenance Work
400 KV	Koradi-Khaparkheda II	15/Jul/2015	09.15	15/Jul/2015	13.52	PO	Replacement work
400 KV	400/220/33 Kv 315 Mva Ict 1 @Dhule	15/Jul/2015	10.15	15/Jul/2015	12.43	HT	Air release purpose
400 KV	400/220/33 Kv 315 MVA ICT- 2 @Nagothane	15/Jul/2015	11.22	15/Jul/2015	19.15	PO	Attending Hot Spot
400 KV	Padghe - Talegaon (PG)	15/Jul/2015	11.50	15/Jul/2015	19.25	PO	Annual Maintenance Work
400 KV	Akola Aurangabad(PG) II	15/Jul/2015	11.57	15/Jul/2015	20.22	PO	Testing Work
400 KV	Karad -kolhapur-II	15/Jul/2015	17.00	16/Jul/2015	06.25	HT	Over Voltage
400 KV	400/220/33 Kv 315 MVA ICT II @Babhleshwar	15/Jul/2015	17.20	18/Jul/2015	17.02	PO	Attending Oil Leakage
400 KV	Karad-Jaigad - I	15/Jul/2015	17.30	16/Jul/2015	06.38	HT	Over Voltage
400 KV	Kolhapur Mapusa I	15/Jul/2015	21.40	16/Jul/2015	06.57	HT	Over Voltage
400 KV	Lonikand I - Koyna stage-IV	15/Jul/2015	23.26	16/Jul/2015	11.58	Tripped	Distance Protection
400 KV	Jejuri- Koynastage-IV	16/Jul/2015	03.24	16/Jul/2015	11.28	Tripped	Distance Protection
400 KV	Babhleshwar - Padghe-I	16/Jul/2015	04.29	20/Jul/2015	16.25	Tripped	Distance Protection
400 KV	Nagothane - Dabhol I	16/Jul/2015	11.29	16/Jul/2015	13.35	Tripped	dabhol bus fault
400 KV	New Koyna - Dabhol-I	16/Jul/2015	11.58	16/Jul/2015	13.56	Tripped	force hand tripped due to bus operated
400 KV	Kolhapur Mapusa I	16/Jul/2015	16.40	17/Jul/2015	08.07	HT	Over Voltage
400 KV	Karad -kolhapur-II	16/Jul/2015	17.07	17/Jul/2015	06.26	HT	Over Voltage
400 KV	Karad - Jaigad - II	16/Jul/2015	17.09	17/Jul/2015	06.27	HT	Over Voltage
400 KV	400/220kv 315 Mva ICT I @Karad	16/Jul/2015	17.30	16/Jul/2015	18.44	Tripped	NDR protection
400 KV	Akola II - Akola I Ckt-II	16/Jul/2015	20.55	17/Jul/2015	06.31	EO	To attend sparking of Isolator
400 KV	Main Bus-II @ Akola	16/Jul/2015	20.56	17/Jul/2015	06.20	PO	Attending Sparking of isolator
400 KV	Lonikand I - Koyna stage-IV	17/Jul/2015	04.28	17/Jul/2015	18.20	Tripped	Distance Protection
400 KV	400/220 KV 500 MVA ICT- I @Warora	17/Jul/2015	07.48	17/Jul/2015	19.50	PO	Testing Work
400 KV	Parli(MS)-Parli (PG) II	17/Jul/2015	14.32	17/Jul/2015	17.32	EO	To attend Hot Spot
400 KV	Karad -kolhapur-I	17/Jul/2015	16.34	18/Jul/2015	06.26	HT	Over Voltage
400 KV	Karad-Jaigad - I	17/Jul/2015	16.36	18/Jul/2015	06.29	HT	Over Voltage
400 KV	Kolhapur Mapusa II	17/Jul/2015	16.37	18/Jul/2015	06.42	HT	Over Voltage
400 KV	Dhule Sar'Sarovar I	17/Jul/2015	20.39	18/Jul/2015	07.15	HT	Over Voltage
400 KV	Kolhapur Mapusa I	18/Jul/2015	16.55	19/Jul/2015	11.37	HT	Over Voltage
400 KV	Dhule Sar'Sarovar I	18/Jul/2015	17.31	18/Jul/2015	21.20	HT	Over Voltage
400 KV	Bhusawal-Aurangabad	18/Jul/2015	18.10	19/Jul/2015	06.51	HT	Over Voltage
400 KV	Karad -kolhapur-II	18/Jul/2015	18.22	19/Jul/2015	07.04	HT	Over Voltage
400 KV	Karad-Jaigad - I	19/Jul/2015	00.40	20/Jul/2015	09.23	HT	Over Voltage
400 KV	400/220 Kv 600 MVA ICT-II @Kalwa	19/Jul/2015	05.47	19/Jul/2015	20.48	EO	Isolator Scissor Blade replacement
400 KV	Lonikand I - Koyna stage-IV	19/Jul/2015	10.54	19/Jul/2015	11.21	Tripped	Distance Protection
400 KV	400/220/33 Kv 315 MVA ICT II @Babhleshwar	19/Jul/2015	14.10	19/Jul/2015	17.32	PO	For Relasing Air Accumulate due to Buchholz Relay.
400 KV	Karad -kolhapur-I	19/Jul/2015	15.48	20/Jul/2015	09.02	HT	Over Voltage
400 KV	Karad - Jaigad - II	19/Jul/2015	16.49	20/Jul/2015	10.01	HT	Over Voltage
400 KV	Bhusawal-Aurangabad	19/Jul/2015	17.11	20/Jul/2015	06.43	HT	Over Voltage
400 KV	Dhule Sar'Sarovar I	19/Jul/2015	17.17	20/Jul/2015	07.21	HT	Over Voltage
400 KV	Kolhapur Mapusa II	19/Jul/2015	18.06	20/Jul/2015	07.27	HT	Over Voltage
220 KV	220/100 Kv 200 MVA ICT III @Borivali	21/Sep/2014	09.16		Continued.	Tripped	Internal Fault
220 KV	Chandrapur GCR - Warora - I	05/Apr/2015	09.13		Continued.	PO	Bunching of conductor Loc no 86 Disconnecting of jumer at Loc no 86 & 107 and deenergising the line bet.86 to 107.
220 KV	Chandrapur GCR - Wani	05/Apr/2015	09.15		Continued.	PO	Bunching of conductor Loc no 86 Disconnecting of jumer at Loc no 86 & 107 and deenergising the line bet.86 to 107.
220 KV	Boisar Versova Line	05/Jul/2015	08.08	16/Jul/2015	01.37	PO	Making LILo for 220KV Viraj S/S
220 KV	REL Borivali TPC Borivali line	10/Jul/2015	16.22		Continued.	Tripped	Distance Protection
220 KV	Pedambe-Pophali	13/Jul/2015	08.50	13/Jul/2015	14.05	PO	B-Ph CT Vertical Conductor found cut and Unwound.
220 KV	Borivali - Tarapur	13/Jul/2015	11.37	13/Jul/2015	12.05	Tripped	Distance Protection
220 KV	Borivali - Tarapur	13/Jul/2015	12.32	13/Jul/2015	13.21	Tripped	Distance Protection
220 KV	Deoli(Pgcl)-Badnera	13/Jul/2015	14.00	13/Jul/2015	15.11	HT	As Per WRLDC Instructions to control OD.
220 KV	Borivali - Tarapur	13/Jul/2015	14.45	13/Jul/2015	14.58	HT	As Per WRLDC Instructions to control OD.
220 KV	Arey - TPC Borivali	14/Jul/2015	01.38	14/Jul/2015	03.05	PO	To Attending Hot Spot at Borivali Gangry.
220 KV	Khaparkheda-Kanhan	14/Jul/2015	06.16	14/Jul/2015	09.10	PO	Attending Hot Spot
220 KV	220/132 Kv 100 Mva Ict 1 @Tuljapur	14/Jul/2015	08.47	14/Jul/2015	12.13	PO	Quarterly Maintanance Work
220 KV	Vita - Miraj	14/Jul/2015	10.15	14/Jul/2015	16.45	PO	Insulator Replacement Work
220 KV	220/132kv 100MVA ICT @ Parli-I	14/Jul/2015	10.18	14/Jul/2015	15.28	PO	Routine Maintenance Work
220 KV	Nasik Navsari I	14/Jul/2015	10.52	14/Jul/2015	14.33	HT	Over Voltage
220 KV	Miraj - Mhaishal	14/Jul/2015	11.00	14/Jul/2015	16.40	HT	For Outage on Vita.
220 KV	Babhleshwar -Rhenda	16/Jul/2015	01.37	16/Jul/2015	04.25	HT	TO control over loading of BBLR icts
220 KV	Raymond - Washala	16/Jul/2015	02.41	16/Jul/2015	17.56	Tripped	Distance Protection

Voltage Level	Name	Trip Date	Trip Time	Synchronisation Date	Synchronisation Time	Outage Type	Reason
220 KV	Eklahara(Gcr)(Nasik)- Bableshtar 2	16/Jul/2015	03.30	16/Jul/2015	04.29	Tripped	Distance Protection
220 KV	Nashik-Padgha	16/Jul/2015	04.54	16/Jul/2015	18.10	HT	over loading of bblsr icts
220 KV	Nashik-Airoli Knowledge Park	16/Jul/2015	06.29	16/Jul/2015	18.17	HT	control over loading of bblr icts
220 KV	Pedhambe - Oni	16/Jul/2015	08.15	16/Jul/2015	17.25	PO	R M W work
220 KV	Taloja II - OCIL-I	16/Jul/2015	08.53	16/Jul/2015	17.59	PO	P M work
220 KV	Miraj - Mhaishal	16/Jul/2015	11.51	16/Jul/2015	15.53	Tripped	Distance Protection
220 KV	Apta - Taloja	16/Jul/2015	11.59	16/Jul/2015	13.04	PO	Attending Hot Spot
220 KV	Theur-Jejuri	16/Jul/2015	12.25	16/Jul/2015	14.50	Tripped	Distance Protection
220 KV	Uran - Apta 3	16/Jul/2015	14.07	16/Jul/2015	16.27	PO	Attending Hot Spot
220 KV	Eklahara(Gcr)(Nasik)- Bableshtar 2	16/Jul/2015	18.15	16/Jul/2015	19.49	PO	Annual Maintenance Work
220 KV	Mudshingi - Chikodi	17/Jul/2015	04.59	17/Jul/2015	05.36	Tripped	Tripped at chikodi end only
220 KV	Ranjangaon-Lonikand	17/Jul/2015	07.24	17/Jul/2015	07.43	Tripped	Distance Protection
220 KV	Deepnagar Bambhori	17/Jul/2015	09.30	17/Jul/2015	17.25	PO	To attend Hot Spot
220 KV	220/110 Kv 200 Mva Vel Ptr 2 @Kolhapur-Ii (Mudshingi)	17/Jul/2015	10.04	17/Jul/2015	17.43	PO	Testing Work
220 KV	ACCIL - Apta	17/Jul/2015	11.04	17/Jul/2015	15.05	EO	To attend Hot Spot
220 KV	Nasik Navsari I	18/Jul/2015	06.20	18/Jul/2015	14.07	Tripped	R Phase to E/F
220 KV	Main Bus-II @ Kharghar	18/Jul/2015	10.28	19/Jul/2015	23.52	PO	Jumpering of 220KV B Bus to Isolator of 315MVA ICT-III(new)
220 KV	Centuri Enka- Bhosari	18/Jul/2015	11.00	18/Jul/2015	12.06	PO	Installation of Summation type ABT Meter
220 KV	512 Khadki- Century Enka	18/Jul/2015	13.40	18/Jul/2015	16.30	PO	Installation of Summation type ABT Meter
220 KV	Parli 3 (Old Gcr)-Girwali Ckt 2	18/Jul/2015	18.24	18/Jul/2015	21.21	PO	To attend Hot Spot
220 KV	220/132 kv 200MVA ICT II @ Girwali	18/Jul/2015	19.13	18/Jul/2015	21.40	PO	To attend Hot Spot
220 KV	220/132 Kv 200 MVA ICT-I @ Malegaon	19/Jul/2015	01.05	19/Jul/2015	01.45	EO	To attend Hot Spot
220 KV	Parli 3 (Old Gcr)-Girwali Ckt 2	19/Jul/2015	08.11	19/Jul/2015	11.34	HT	Given in Parli Parbhani,Hingoli and Latur Area.
220 KV	Mahape - TfipI	19/Jul/2015	10.43	19/Jul/2015	12.32	PO	Removal of Bird Nest on B/S Isolator Gantry R-Ph And.
132 KV	Lonand - Wai	16/Jul/2015	22.00	17/Jul/2015	03.45	Tripped	Distance Protection
132 KV	Narsi - Degloor	18/Jul/2015	15.45	18/Jul/2015	20.44	Tripped	Distance Protection