

State Load Despatch Center,Airoli (MSETCL)
Power System Position from 18/Sep/2017 to 24/Sep/2017

Supply Position During Morning Peak (MW)

Date	Time	MSGENCO				Central Sector Receipt	Wind	CPP	SOLAR	TPCL Exch.	MSEDCL Catered Demand	Load Shedding(LS)	MSEDCL Demand (Incl. LS)	TPCL Gen.	R-INFRA Gen.	State Demand Met	State Demand (Incl. LS)	Freq.
		THM	HYDRO	GAS	Total													
		MW	MW	MW	MW	MW	MW	MW	MW	MW	MW	MW	MW	MW	MW	MW	MW	Hzs
18/09/2017	11 Hrs	4371	216	432	5019	5065	1526	3448	239	-1628	13669	0	13669	1017	374	16688	16688	50.01
19/09/2017	12 Hrs	4399	349	416	5164	4834	1489	3634	268	-1669	13720	0	13720	1125	374	16888	16888	50.02
20/09/2017	11 Hrs	4102	379	269	4750	4942	1496	3517	234	-1568	13371	0	13371	745	374	16058	16058	50.02
21/09/2017	11 Hrs	4451	338	269	5058	4760	784	4230	202	-1745	13289	0	13289	766	376	16176	16176	50.00
22/09/2017	12 Hrs	4070	465	260	4795	4912	849	3790	292	-2051	12587	0	12587	750	196	15584	15584	49.97
23/09/2017	12 Hrs	4381	313	258	4952	4872	325	4831	358	-1562	13776	0	13776	1039	250	16627	16627	49.99
24/09/2017	12 Hrs	4305	258	258	4821	5413	121	4784	339	-1373	14105	0	14105	767	193	16438	16438	50.02
Maximum		4451	465	432	5164	5413	1526	4831	358	-1373	14105	0	14105	1125	376	16888	16888	50.02
Minimum		4070	216	258	4750	4760	121	3448	202	-2051	12587	0	12587	745	193	15584	15584	49.97
Average		4297	331	309	4937	4971	941	4034	276	-1657	13502	0	13502	887	305	16351	16351	50.00

Supply Position During Day Peak (MW)

Date	Time	MSGENCO				Central Sector Receipt	Wind	CPP	SOLAR	TPCL Exch.	MSEDCL Catered Demand	Load Shedding(LS)	MSEDCL Demand (Incl. LS)	TPCL Gen.	R-INFRA Gen.	State Demand Met	State Demand (Incl. LS)	Freq.
		THM	HYDRO	GAS	Total													
		MW	MW	MW	MW	MW	MW	MW	MW	MW	MW	MW	MW	MW	MW	MW	MW	Hzs
18/09/2017	13 Hrs	4422	136	417	4975	4815	1456	3494	288	-1842	13186	0	13186	842	375	16245	16245	49.99
19/09/2017	13 Hrs	4225	290	416	4931	4696	1311	3581	224	-1716	13027	0	13027	1035	373	16151	16151	50.01
20/09/2017	13 Hrs	4132	265	267	4664	4488	1457	3481	208	-1626	12672	0	12672	732	374	15404	15404	50.00
21/09/2017	13 Hrs	4350	174	284	4808	4554	880	4317	106	-1696	12969	0	12969	870	375	15910	15910	49.98
22/09/2017	18 Hrs	4282	315	259	4856	4486	876	4189	32	-1769	12670	0	12670	840	196	15475	15475	49.90
23/09/2017	13 Hrs	4291	248	257	4796	4849	263	4870	298	-1510	13566	0	13566	1046	250	16372	16372	49.97
24/09/2017	13 Hrs	4312	231	265	4808	4937	150	4717	330	-1334	13608	0	13608	795	193	15930	15930	50.00
Maximum		4422	315	417	4975	4937	1457	4870	330	-1334	13608	0	13608	1046	375	16372	16372	50.01
Minimum		4132	136	257	4664	4486	150	3481	32	-1842	12670	0	12670	732	193	15404	15404	49.90
Average		4288	237	309	4834	4689	913	4093	212	-1642	13100	0	13100	880	305	15927	15927	49.98

Supply Position During Evening Peak (MW)

Date	Time	MSGENCO				Central Sector Receipt	Wind	CPP	SOLAR	TPCL Exch.	MSEDCL Cateder Demand	Load Shedding(LS)	MSEDCL Demand (Incl. LS)	TPCL Gen.	R-INFRA Gen.	State Demand Met	State Demand (Incl. LS)	Freq.
		THM	HYDRO	GAS	Total													
		MW	MW	MW	MW	MW	MW	MW	MW	MW	MW	MW	MW	MW	MW	MW	MW	Hzs
18/09/2017	20 Hrs	4586	159	430	5175	4522	1463	4028	0	-1274	13914	693	14607	1096	498	16782	17475	50.01
19/09/2017	20 Hrs	4365	334	396	5095	4540	1517	4300	0	-943	14509	0	14509	1144	497	17093	17093	49.99
20/09/2017	20 Hrs	4519	343	137	4999	4508	1497	4055	0	-1255	13803	0	13803	784	374	16216	16216	50.00
21/09/2017	20 Hrs	4196	543	267	5006	4297	1268	4553	0	-1240	13884	0	13884	1105	499	16728	16728	49.97
22/09/2017	20 Hrs	4448	947	274	5669	4740	783	4891	0	-1579	14504	0	14504	1016	249	17348	17348	49.99
23/09/2017	20 Hrs	4478	1842	260	6580	4992	287	4870	0	-1322	15407	0	15407	1229	248	18206	18206	49.96
24/09/2017	20 Hrs	4410	1704	271	6385	4459	344	4913	0	-1231	14870	0	14870	925	251	17277	17277	50.00
Maximum		4586	1842	430	6580	4992	1517	4913	0	-943	15407	693	15407	1229	499	18206	18206	50.01
Minimum		4196	159	137	4999	4297	287	4028	0	-1579	13803	0	13803	784	248	16216	16216	49.96
Average		4429	839	291	5558	4580	1023	4516	0	-1263	14413	99	14512	1043	374	17093	17192	49.99

Supply Position During Night Off Peak (MW)

Date	Time	MSGENCO				Central Sector Receipt	Wind	CPP	SOLAR	TPCL Exch.	MSEDCL Cateder Demand	Load Shedding(LS)	MSEDCL Demand (Incl. LS)	TPCL Gen.	R-INFRA Gen.	State Demand Met	State Demand (Incl. LS)	Freq.
		THM	HYDRO	GAS	Total													
		MW	MW	MW	MW	MW	MW	MW	MW	MW	MW	MW	MW	MW	MW	MW	MW	Hzs
18/09/2017	3 Hrs	4207	82	425	4714	3605	850	3246	0	-798	11617	0	11617	620	375	13410	13410	50.04
19/09/2017	4 Hrs	4127	105	421	4653	3370	1392	3539	0	-838	12117	0	12117	621	377	13953	13953	50.04
20/09/2017	3 Hrs	4154	138	198	4490	2898	1419	3295	0	-657	11446	0	11446	638	375	13116	13116	50.01
21/09/2017	4 Hrs	4127	316	269	4712	3108	740	3321	0	-602	11279	0	11279	616	376	12873	12873	49.99
22/09/2017	3 Hrs	4057	150	242	4449	3259	1137	3465	0	-890	11420	0	11420	604	196	13110	13110	49.99
23/09/2017	4 Hrs	4130	130	269	4529	3821	438	3927	0	-921	11794	0	11794	602	192	13509	13509	50.00
24/09/2017	5 Hrs	4411	125	278	4814	4023	130	4639	0	-952	12654	0	12654	605	193	14404	14404	49.97
Maximum		4411	316	425	4814	4023	1419	4639	0	-602	12654	0	12654	638	377	14404	14404	50.04
Minimum		4057	82	198	4449	2898	130	3246	0	-952	11279	0	11279	602	192	12873	12873	49.97
Average		4173	149	300	4623	3441	872	3633	0	-808	11761	0	11761	615	298	13482	13482	50.01

Details of Supply Position (MUs)

Date	MSGENCO				Pench (MS)	Central Sector Receipt	Central Sector Share	WIND	CPP	SOLAR	TPCL Gen.	R-INFRA Gen.	TPCL Exch.	Energy Requirement		
	THM	HYDRO	GAS	Total										MSEDCL	MUMBAI	STATE
	Mus	Mus	Mus	Mus	Mus	Mus	Mus	Mus	Mus	Mus	Mus	Mus	Mus	Mus	Mus	Mus
18/09/2017	104.585	3.378	10.175	118.138	0.035	106.482	107.799	31.694	86.149	1.691	20.010	9.434	-31.635	312.519	61.079	373.598
19/09/2017	102.871	5.224	9.159	117.254	0.000	104.093	105.798	34.507	88.213	1.942	19.018	8.506	-32.006	314.003	59.530	373.533
20/09/2017	100.199	6.460	5.484	112.143	0.000	96.626	98.293	36.556	84.391	1.680	16.742	8.867	-27.286	304.111	52.898	357.009
21/09/2017	101.685	7.272	6.401	115.358	0.000	99.498	103.444	22.458	95.492	1.130	18.269	9.230	-30.083	303.853	57.585	361.438
22/09/2017	99.958	8.107	6.333	114.398	0.000	102.010	102.202	21.733	97.083	2.004	17.851	4.986	-35.584	301.644	58.423	360.067
23/09/2017	104.982	8.836	6.359	120.177	0.069	110.030	110.716	7.631	109.625	2.400	21.842	5.519	-29.633	320.230	56.994	377.224
24/09/2017	104.790	8.707	6.354	119.851	0.000	111.261	112.678	5.870	113.222	2.443	17.032	5.095	-29.225	323.422	51.352	374.774
Maximum	104.982	8.836	10.175	120.177	0.069	111.261	112.678	104.982	113.222	2.443	21.842	9.434	-27.286	323.422	61.079	377.224
Minimum	99.958	3.378	5.484	112.143	0.000	96.626	98.293	99.958	84.391	1.130	16.742	4.986	-35.584	301.644	51.352	357.009
Average	102.724	6.855	7.181	116.760	0.015	104.286	105.847	102.724	96.311	1.899	18.681	7.377	-30.779	311.397	56.837	368.235

Details of Koyna Water Consumption (in TMC)

Date	For the Day	For the Month	Balance
18/09/2017	0.029	6.067	52.479
19/09/2017	0.034	6.101	52.445
20/09/2017	0.033	6.134	52.412
21/09/2017	0.050	6.184	52.362
22/09/2017	0.093	6.277	52.269
23/09/2017	0.132	6.409	52.137
24/09/2017	0.138	6.547	51.999

State Load Despatch Center,Airoli (MSETCL)
Central Sector Share/Drawal from 18/Sep/2017 to 24/Sep/2017

Date	DAY	Central Sector Share		Total Interstate Bilateral Purchase		Total Share		Total Drawal		Overdrawal(+) / UnderDrawal(-)	
		MUs	Avg. MW	MUs	Avg. MW	MUs	Avg. MW	MUs	Avg. MW	MUs	Avg. MW
		1		2		1+2=3		4		3-4=5	
18/09/2017	MONDAY	92.744	4477	15.055	627	107.799	4492	106.482	4437	-1.317	-55
19/09/2017	TUESDAY	91.203	4394	14.595	608	105.798	4408	104.093	4337	-1.705	-71
20/09/2017	WEDNESDA	82.864	4080	15.429	643	98.293	4096	96.626	4026	-1.667	-69
21/09/2017	THURSDAY	93.142	4300	10.302	429	103.444	4310	99.498	4146	-3.946	-164
22/09/2017	FRIDAY	87.427	4244	14.775	616	102.202	4258	102.010	4250	-0.192	-8
23/09/2017	SATURDAY	91.432	4594	19.284	803	110.716	4613	110.030	4585	-0.686	-29
24/09/2017	SUNDAY	93.130	4675	19.548	814	112.678	4695	111.261	4636	-1.417	-59
Total		631.942		108.988		740.930		730.000		-10.930	

GENERATING UNITS OUTAGES FOR THE WEEK FROM 18/09/2017 TO 24/09/2017							
Generator	Generating Unit	Capacity	Tripped Date	Tripped Time	Synch. Date	Synch Time	Reason
PLANNED OUTAGES							
IPP	Tata Trombay 6	500MW	15/Jul/2015	17.08		Continued.	Economic shutdown(Converted to AOH for 30 Days from 00.00Hrs 06-03-2016)
CS	TARAPUR 4	540MW	23/Apr/2017	19:55		Continued.	Annual Maintenance
CS	Tarapur 1	160MW	04/Jun/2017	19.09		Continued.	3 months outage for refuelling.
CS	TARAPUR-3	540MW	11/Jul/2017	16.30		Continued.	Reactor Inspection Work
MSPGCL	Khaparkheda Unit 4	210MW	13/Jul/2017	03.36		Continued.	Drum level low. on Dated 14.07.2017 converted to zero schedule. Converted into COH from 00:00Hrs of 02.08.2017
MSPGCL	Nasik Unit 3	210MW	10/Aug/2017	00.00		Continued.	Withdrawn for maintenance work Converted to COH from 15.08.2017.
MSPGCL	Chandrapur Unit 4	210MW	22/Aug/2017	23.56		Continued.	Annual Overhaul
FORCED OUTAGES							
RGPL	Dabhol Dabhol 1B	230MW	28/May/2013	22:02		Continued.	Gas Shortage.
RGPL	Dabhol Dabhol 1X	230MW	27/Jun/2013	21.46		Continued.	Gas Shortage
RGPL	Dabhol Dabhol 1A	230MW	27/Jun/2013	21.47		Continued.	Gas Shortage
MSPGCL	Koradi Unit 6	210MW	20/Mar/2015	01.02		Continued.	EE R&M LE Work
IPP	SWPGL U-1	135MW	16/Feb/2016	17.09		Continued.	Change Over , No Schedule
IPP	SWPGL U-2	135MW	29/Feb/2016	21.46		Continued.	Change over against Unit III
MSPGCL	Parli Unit 4	210MW	01/Apr/2016	00.00		Continued.	Economic shutdown
MSPGCL	Parli Unit 5	210MW	01/Apr/2016	00.00		Continued.	Economic shutdown
MSPGCL	Bhusawal Unit 2	210MW	14/Jun/2016	19.35		Continued.	Boiler Tube Leakage(Converted to Zero Shedule By MSEDCL. from 00.00Hrs dt.19-6-16)
MSPGCL	Uran Unit 8	108MW	14/Aug/2016	07.56		Continued.	Maintenance work
RGPL	Dabhol 2A	230MW	24/Aug/2016	13.31		Continued.	Change Over.
MSPGCL	Koradi Unit 5	200MW	05/Sep/2016	00.21		Continued.	ID Fan problem. Converted to Zero Schedule By MSEDCL from 00.00hrs/22-9-16. Shutdown taken on 18.10.2016 at 00:00Hrs for Turbine inspection and maintenance work
IPP	PGPL U1	262MW	07/Feb/2017	17.30		Continued.	No Schedule
IPP	PGPL U2	126MW	07/Feb/2017	17.30		Continued.	No Schedule
IPP	Dharwal	300MW	01/Jun/2017	00.01		Continued.	NO SCHEDULE.
IPP	VIPL U-1	300MW	13/Jun/2017	08.30		Continued.	GT WORK
MSPGCL	Parli Unit 8	250MW	17/Jun/2017	00.08		Continued.	Zero Schedule by MSEDCL, scheduled issued on 08.08.2017 but synchronization delayed.
MSPGCL	Ghatghar Unit-2	125MW	28/Jul/2017	00.00		Continued.	due to common pressure shaft with unit 1.
MSPGCL	Ghatghar Unit-1	125MW	28/Jul/2017	00.00		Continued.	RBDV leakage attending work.
IPP	Adani U-2	660MW	11/Aug/2017	16.49	18/Sep/2017	23.41	Furnace Pressure High
IPP	SWPGL U-3	135MW	26/Aug/2017	17.40		Continued.	Boiler Tube Leakage
MSPGCL	Bhusawal Unit 3	210MW	27/Aug/2017	07.43		Continued.	Coal Shortage From 29.08.2017.
MSPGCL	Khaparkheda Unit 5	500MW	01/Sep/2017	18.29	23/Sep/2017	22.37	Due to shaft vibration High.
IPP	Adani U-4	660MW	06/Sep/2017	21.47		Continued.	Changeover from U-4 to U1
MSPGCL	Koradi Unit 9	660MW	07/Sep/2017	00.38		Continued.	Coal shortage form 12.09.2017.
MSPGCL	Khaparkheda Unit 1	210MW	08/Sep/2017	12.23		Continued.	Coal Shortage
MSPGCL	Chandrapur Unit 6	500MW	09/Sep/2017	04.40		Continued.	Coal Shortage form 12.09.2017.
MSPGCL	Koradi Unit 7	210MW	12/Sep/2017	00.12		Continued.	Coal Shortage
MSPGCL	Khaparkheda Unit 3	210MW	12/Sep/2017	00.00		Continued.	Coal Shortage
MSPGCL	Chandrapur Unit 3	210MW	12/Sep/2017	00.00		Continued.	Coal Shortage
IPP	SWPGL U-4	135MW	17/Sep/2017	22.17	18/Sep/2017	00.28	Flame Failure
IPP	RPL(AMT) U-5	270MW	17/Sep/2017	02.01		Continued.	Coal Shortage
IPP	RPL(AMT) U-3	270MW	17/Sep/2017	00.02		Continued.	Coal Shortage
IPP	RPL(AMT) U-1	270MW	18/Sep/2017	00.01		Continued.	Coal Shortage
MSPGCL	Uran Unit A0	120MW	19/Sep/2017	20.17	20/Sep/2017	04.11	UAT Buchholz Relay operated
MSPGCL	Uran Unit 6	108MW	19/Sep/2017	22.52	20/Sep/2017	00.54	Boiler protection Operated
MSPGCL	Uran Unit 5	108MW	19/Sep/2017	22.52		Continued.	Boiler protection Operated
IPP	REL Unit 2	250MW	19/Sep/2017	20.32	19/Sep/2017	23.59	Generator Elect. Fault
MSPGCL	Uran Unit B0	120MW	20/Sep/2017	18.32	20/Sep/2017	23.17	Feed Pump Problem
IPP	SWPGL U-4	135MW	20/Sep/2017	00.00	22/Sep/2017	01.35	ID Fan Vibration High
MSPGCL	Uran Unit 7	108MW	20/Sep/2017	18.32	20/Sep/2017	21.07	Due To Boiler Protection Trip
MSPGCL	Khaparkheda Unit 2	210MW	22/Sep/2017	13.06	22/Sep/2017	16.47	Flame Failure
MSPGCL	Koyna STG- IV Unit - 1	250MW	22/Sep/2017	04.14	22/Sep/2017	05.10	Sensor Mal Function
IPP	REL Unit 2	250MW	22/Sep/2017	00.11		Continued.	Coal Shortage

LINE OUTAGES AND RIPPING FOR THE WEEK FROM 18/09/2017 TO 24/09/2017

Voltage	Name of Line	Tripping Date	Tripping Time	Synch Date	Synch Time	Reason
400 KV	Karad Solapur (PG)	03/May/2017	11:49		Continued.	Line converted as 220 kV Solapur (PG)- Jeur from LOC 403
400 KV	Karad-Jaigad - I	08/Sep/2017	00.47	18/Sep/2017	09.22	Over Voltage
400 KV	karad -kolhapur-II	09/Sep/2017	17.21	18/Sep/2017	10.12	Over Voltage
400 KV	Ektuni-Bableshtar ckt I	15/Sep/2017	19.16		Continued.	Attending Hot Spot
400 KV	Dhule Sar'Sarovar I	15/Sep/2017	19.30	21/Sep/2017	11.20	Over Voltage
400 KV	Dhule Khandwa II	16/Sep/2017	08.06	18/Sep/2017	08.42	Replacement of conventional Insulators with polymer insulators.
400 KV	Bhusawal-Aurangabad	16/Sep/2017	21.42	18/Sep/2017	09.09	Over Voltage
400 KV	Chandrapur-II - Nanded ckt II	17/Sep/2017	23.00		Continued.	Over Voltage
400 KV	Lonikand I - Koyna stage-IV	17/Sep/2017	23.37	18/Sep/2017	07.09	Over Voltage
400 KV	Kolhapur Solapur (PG) II	18/Sep/2017	02.09	18/Sep/2017	08.37	Over Voltage
400 KV	Kolhapur Solapur(PG) I	18/Sep/2017	02.09	18/Sep/2017	08.37	Over Voltage
400 KV	Bableshtar- Aurangabad (Waluj)	18/Sep/2017	09.34	18/Sep/2017	17.30	Testing Work
400 KV	Jaigad-New Koyna Ckt-I	18/Sep/2017	10.07	18/Sep/2017	10.27	Annual Maintenance Work
400 KV	Dhule Khandwa I	18/Sep/2017	10.42	19/Sep/2017	09.09	REPLACEMENT OF CONVENTIONAL INSULATOR WITH POLYMER INSULATOR.
400 KV	Bus Coupler @ Padgha	18/Sep/2017	15.37	18/Sep/2017	15.47	Red Hot Spot Attending Work.
400 KV	Bhusawal-Aurangabad	18/Sep/2017	19.25		Continued.	Over Voltage
400 KV	karad -kolhapur-II	18/Sep/2017	21.43	19/Sep/2017	09.15	Over Voltage
400 KV	Karad - Jaigad - II	19/Sep/2017	00.39	19/Sep/2017	09.33	Over Voltage
400 KV	Dhule Khandwa II	19/Sep/2017	10.03	20/Sep/2017	08.45	Outage by WRLDC (RFC 20.40Hrs)
400 KV	Lonikand 1 - Chakan	19/Sep/2017	11.18	19/Sep/2017	12.01	Tripped Without Any Indication
400 KV	Akola II - RPL(Rattanindia) Ckt-II	19/Sep/2017	13.25	19/Sep/2017	18.01	Line Maintenance work
400 KV	karad -kolhapur-I	19/Sep/2017	20.43		Continued.	Over Voltage
400 KV	Karad - Jaigad - II	19/Sep/2017	22.58		Continued.	Over Voltage
400 KV	Dhule Khandwa II	20/Sep/2017	08.46	21/Sep/2017	08.02	Line Is Already Out,Code For Outage
400 KV	Akola Aurangabad(PG) II	20/Sep/2017	09.38	20/Sep/2017	16.58	Routine Maintenance Work
400 KV	Chandrapur II - Chandrapur SW Ckt II	20/Sep/2017	10.47	20/Sep/2017	19.10	Routine Maintenance Work And Diagnostic Work
400 KV	Dhule Khandwa I	21/Sep/2017	08.46	21/Sep/2017	19.36	outage by WRLDC
400 KV	Dhule Sar'Sarovar II	21/Sep/2017	16.03	23/Sep/2017	09.23	Over Voltage
400 KV	New Koyna - Koyna Stage IV-II	22/Sep/2017	04.14	22/Sep/2017	06.58	Over Voltage
400 KV	Karad Solapur (PG)	22/Sep/2017	11.00		Continued.	Replacement Of Earth Wire,RFC 17.05HRS cODE 1885FOR Over Voltage
400 KV	Babhaleshtar - Padgha-I	22/Sep/2017	11.02	22/Sep/2017	19.34	To attend Hot Spot
400 KV	Nagothane - Dabhol-II	22/Sep/2017	11.51	22/Sep/2017	17.04	To attend Hot Spot
400 KV	Dhule Khandwa I	22/Sep/2017	13.45	24/Sep/2017	12.16	Outage By Wrldc(Code2149 For Converting For Over Voltage)RFC(20.32)
400 KV	Akola Wardha I	23/Sep/2017	13.46	23/Sep/2017	18.30	amp of bay.
400 KV	Akola Aurangabad(PG) I	23/Sep/2017	16.10	23/Sep/2017	17.15	commissioning of stu abt meter.
400 KV	Akola Aurangabad(PG) II	23/Sep/2017	17.20	23/Sep/2017	18.02	commissioning of stu abt meter.
400 KV	Dhule Sar'Sarovar II	23/Sep/2017	20.41		Continued.	Over Voltage
400 KV	Koradi 2-IEPL	24/Sep/2017	07.27	24/Sep/2017	19.04	crossing work.
400 KV	koaradi II - Wardha(PG)	24/Sep/2017	08.00	24/Sep/2017	19.14	crossing work.
400 KV	Dhule Khandwa II	24/Sep/2017	12.41	25/Sep/2017	06.47	replacement of conventional insulator with polymer insulator. (RFC.24.09.2017-19.13)
220 KV	Chandrapur GCR - Warora - I	05/Apr/2015	09.13		Continued.	Bunching of conductor Loc no 86 Disconnecting of jumper at Loc no 86 & 107 and de-energising the line bet.86 to 107.
220 KV	Chandrapur GCR - Wani	05/Apr/2015	09.15		Continued.	Bunching of conductor Loc no 86 Disconnecting of jumper at Loc no 86 & 107 and de-energising the line bet.86 to 107.
220 KV	Talandage - Chikodi	01/Jun/2017	00.01		Continued.	NO SCHEDULE.
220 KV	Mudshingi - Chikodi	01/Jun/2017	00.06		Continued.	NO SCHEDULE.
220 KV	Pusad - Hingoli	11/Sep/2017	20.06		Continued.	Distance Relay Faulty at pusad end
220 KV	Butibori - Wardha	17/Sep/2017	14.28	18/Sep/2017	18.48	Distance Protection
220 KV	Apta - Tambati	18/Sep/2017	07.35	18/Sep/2017	09.21	Oil Top Up In CT.
220 KV	Pedambe-Pophali	18/Sep/2017	08.30	18/Sep/2017	20.25	Due To Sparking.
220 KV	Pedambe-Nerle	18/Sep/2017	10.04	18/Sep/2017	14.35	Distance Protection
220 KV	karad - Dasgaon	18/Sep/2017	10.40	18/Sep/2017	13.28	Jumper Open At Dasgaon.
220 KV	New Koyna - Pedambe	18/Sep/2017	14.12	18/Sep/2017	20.28	Bus SEction-1 Outage.
220 KV	Mahad - Pedambe	18/Sep/2017	14.15	18/Sep/2017	20.10	Bus SEction-1 Outage.
220 KV	Kolhapur-Bidri	18/Sep/2017	14.15	18/Sep/2017	16.53	Tree Cutting.
220 KV	Sawantwadi-Bidri	18/Sep/2017	14.35	18/Sep/2017	15.57	Tree Cutting.
220 KV	Boisar(MS) - Boisar (PG) II	18/Sep/2017	21.28	18/Sep/2017	22.47	Distance Protection
220 KV	Boisar(MS) - Boisar (PG) - I	18/Sep/2017	21.28	19/Sep/2017	03.52	Distance Protection
220 KV	Boisar Tarapur	18/Sep/2017	21.28	18/Sep/2017	23.16	Distance Protection
220 KV	Siemens - Mahape	19/Sep/2017	08.36	19/Sep/2017	23.02	Lilo Arrangement at Reliance GIS Stn.
220 KV	Gcr Chandrapur - Grace Ltd	19/Sep/2017	10.43	19/Sep/2017	12.50	CT Tan Delta Test
220 KV	Nanded-Waghale II	19/Sep/2017	11.54	19/Sep/2017	16.16	To attend Hot Spot
220 KV	Pandharpur - Hiwarwada	19/Sep/2017	12.20	19/Sep/2017	14.50	Bus Bar Relay replacement work
220 KV	Nanded- Bhokar I	19/Sep/2017	13.48	19/Sep/2017	15.52	Relay Card replacement work
220 KV	Pandarpur-Khanapur	19/Sep/2017	15.11	19/Sep/2017	16.52	Bus Bar Relay replacement work
220 KV	Trombay - Mulund	19/Sep/2017	17.14	19/Sep/2017	22.08	Distance Protection
220 KV	Trombay MSETCL Tie 1	19/Sep/2017	17.14	19/Sep/2017	18.41	Tripped and DT received
220 KV	Trombay - Mulund	19/Sep/2017	22.17	20/Sep/2017	20.29	Line Maintenance work
220 KV	Mahalakshmi Amona	20/Sep/2017	03.26	20/Sep/2017	09.53	Tripped At Amona End
220 KV	Bhandara-Sunflag 2	20/Sep/2017	06.59	20/Sep/2017	07.29	Backup Protection
220 KV	Ghatghar - Jindal	20/Sep/2017	07.45	20/Sep/2017	10.10	Distance Protection
220 KV	Colourchem - Temghar	20/Sep/2017	09.50	20/Sep/2017	17.38	Distance Protection
220 KV	Padgha - Temghar I	20/Sep/2017	09.50	20/Sep/2017	15.24	Distance Protection
220 KV	Paranda-Barshi	20/Sep/2017	10.00	20/Sep/2017	11.25	Routine Maintenance Work
220 KV	Patoda-Manjarsumba	20/Sep/2017	11.10	20/Sep/2017	13.00	Replacement Of Defective Spring Charging Motor Of CB
220 KV	Pandharpur - Malinagar	20/Sep/2017	12.05	20/Sep/2017	15.05	New Bus Bar Prot.Work

Voltage	Name of Line	Tripping Date	Tripping Time	Synch Date	Synch Time	Reason
220 KV	K'Kheda- Suryalakshmi	20/Sep/2017	12.33	20/Sep/2017	16.49	Replacement Of Abt Meter Measurement Of Tan Delta Of CT
220 KV	Bhandara-Sunflag 2	20/Sep/2017	15.12	20/Sep/2017	21.10	Insulator Replacement Work
220 KV	Lamboti - Pandharpur li	20/Sep/2017	15.39	20/Sep/2017	20.18	New Bus Bar Prot.Work
220 KV	Pandharpur - Malinagar	20/Sep/2017	17.37	20/Sep/2017	20.18	New Bus Bar Prot.Work
220 KV	Koradi-Butibori Rly Tss	20/Sep/2017	20.20	20/Sep/2017	21.16	PT Burst At Butibori Tss End
220 KV	Baramati- Kalyani	21/Sep/2017	10.05	21/Sep/2017	12.20	Testing Work
220 KV	Bombay Dyeing - Sahara	21/Sep/2017	10.38	21/Sep/2017	19.20	Line Maintenance work
220 KV	Parli 3 (Old Gcr)-Osmanabad	21/Sep/2017	11.02	21/Sep/2017	16.03	To attend Hot Spot
220 KV	Nanded-Parbhani	21/Sep/2017	11.13	21/Sep/2017	14.27	Tan Delta Measurment of CTs
220 KV	Kanhan-Suryalakshmi	21/Sep/2017	13.20	21/Sep/2017	15.52	ABT Meter Installation work
220 KV	Babhaleshwar - Degaon Rangari	21/Sep/2017	15.00	21/Sep/2017	17.14	To attend Hot Spot
220 KV	Eklahara(Ocr)-Raymond (Padagha-I)	22/Sep/2017	04.07	22/Sep/2017	19.12	Distance Protection
220 KV	Nasik - Raymond	22/Sep/2017	04.07	22/Sep/2017	19.12	Distance Protection
220 KV	220KV Chalisagaon-Kopergaon	22/Sep/2017	08.25	22/Sep/2017	11.16	Line Maintenance work
220 KV	Pusad - Hingoli	22/Sep/2017	09.13	22/Sep/2017	12.48	To Attend B-H CT Oil Leakage
220 KV	Pedhambe - Oni	22/Sep/2017	09.23	22/Sep/2017	10.45	To Attend CB Air Pressure Low Work
220 KV	Wpcl-Warora 1	22/Sep/2017	10.05	22/Sep/2017	18.40	Tan Delta Measurment of CTs
220 KV	Wardha - Wardha Rly Tss 2	22/Sep/2017	10.08	22/Sep/2017	13.50	Tan Delta Measurment of CTs
220 KV	Apta - Talaja	22/Sep/2017	11.05	22/Sep/2017	16.08	Line Maintenance work
220 KV	Aurangabad (Waluj)-Bhenda	22/Sep/2017	11.57	22/Sep/2017	16.02	Maintenance Work
220 KV	Pedambe-Nerle	23/Sep/2017	00.50		Continued.	B Phase CT Burst at Pedambe End
220 KV	Mahalakshmi Amona	23/Sep/2017	04.25	23/Sep/2017	06.47	Over Voltage
220 KV	Tillari Amona	23/Sep/2017	04.25	23/Sep/2017	06.44	Over Voltage
220 KV	Wpcl-Warora 2	23/Sep/2017	09.25	23/Sep/2017	17.19	Tan Delta Measurment of CTs
220 KV	ACCIL - Apta	23/Sep/2017	10.32	23/Sep/2017	18.15	Attending Hot Spot
220 KV	Nashik-Padgha	23/Sep/2017	11.19	23/Sep/2017	13.35	Attending Hot Spot
220 KV	Trombay - Mulund	23/Sep/2017	14.23	24/Sep/2017	00.37	isolator work.
220 KV	Chalisgaon - Babhaleshwar	23/Sep/2017	14.41	23/Sep/2017	16.03	remove earth wire.
220 KV	TATA Tie I	23/Sep/2017	15.33	24/Sep/2017	00.41	isolator work.
220 KV	New Koyna - Niwali	24/Sep/2017	16.33	24/Sep/2017	17.54	Distance Protection
132 KV	Parbhani-Bageshwari	19/Sep/2017	19.57	19/Sep/2017	20.40	Distance Protection
132 KV	Padegaon - Canpack	20/Sep/2017	16.40	20/Sep/2017	18.56	Distance Protection
132 KV	Bhandara-Madgi-li	21/Sep/2017	04.47	21/Sep/2017	09.03	Distance Protection
132 KV	Amalner(220kv)-Amalner (132 Kv)	21/Sep/2017	09.57	21/Sep/2017	10.15	Tripped Without Any Indication
132 KV	Parvati-Gis Rastapeth	21/Sep/2017	14.39	24/Sep/2017	22.10	Distance Protection
132 KV	Deulgaon Mahi-Dusarbid	21/Sep/2017	20.30	21/Sep/2017	20.40	Distance Protection
132 KV	Himayatnagar - Tamsa	22/Sep/2017	13.25	22/Sep/2017	13.30	Distance Protection
132 KV	Partur - Jalna (Old)	22/Sep/2017	22.30	22/Sep/2017	22.50	Distance Protection
132 KV	Himayatnagar - Tamsa	23/Sep/2017	03.07	23/Sep/2017	03.38	Distance Protection