

State Load Despatch Center,Airoli (MSETCL)
Power System Position from 14/Dec/2015 to 20/Dec/2015

Supply Position During Morning Peak (MW)

Date	Time	MSGENCO				Central Sector Receipt	Wind	CPP	SOLAR	TPCL Exch.	MSEDCL Catered Demand	Load Shedding(LS)	MSEDCL Demand (Incl. LS)	TPCL Gen.	R-INFRA Gen.	State Demand Met	State Demand (Incl. LS)	Freq.
		THM	HYDRO	GAS	Total													
		MW	MW	MW	MW	MW	MW	MW	MW	MW	MW	MW	MW	MW	MW	MW	MW	Hzs
14/12/2015	12 Hrs	6157	614	286	7057	5202	42	4958	182	-1031	16410	22	16432	1180	517	19138	19160	49.93
15/12/2015	11 Hrs	5830	973	138	6941	4843	45	5708	163	-1034	16666	21	16687	1173	515	19388	19409	49.89
16/12/2015	11 Hrs	6074	525	226	6825	4773	41	6069	142	-1146	16704	21	16725	1135	511	19496	19517	49.94
17/12/2015	11 Hrs	5787	498	306	6591	4753	29	5930	151	-998	16456	20	16476	1113	515	19082	19102	49.91
18/12/2015	11 Hrs	5416	470	302	6188	4752	229	5698	152	-1234	15785	20	15805	916	404	18339	18359	49.94
19/12/2015	12 Hrs	5465	322	335	6122	4969	108	5428	173	-1161	15639	15	15654	998	404	18202	18217	49.94
20/12/2015	11 Hrs	5285	789	448	6522	4671	50	5171	137	-764	15787	14	15801	876	407	17834	17848	49.94
Maximum		6157	973	448	7057	5202	229	6069	182	-764	16704	22	16725	1180	517	19496	19517	49.94
Minimum		5285	322	138	6122	4671	29	4958	137	-1234	15639	14	15654	876	404	17834	17848	49.89
Average		5716	599	292	6607	4852	78	5566	157	-1053	16207	19	16226	1056	468	18783	18802	49.93

Supply Position During Day Peak (MW)

Date	Time	MSGENCO				Central Sector Receipt	Wind	CPP	SOLAR	TPCL Exch.	MSEDCL Catered Demand	Load Shedding(LS)	MSEDCL Demand (Incl. LS)	TPCL Gen.	R-INFRA Gen.	State Demand Met	State Demand (Incl. LS)	Freq.
		THM	HYDRO	GAS	Total													
		MW	MW	MW	MW	MW	MW	MW	MW	MW	MW	MW	MW	MW	MW	MW	MW	Hzs
14/12/2015	13 Hrs	6178	392	296	6866	5165	30	4907	201	-1080	16089	22	16111	1122	513	18804	18826	49.97
15/12/2015		5860	477	139	6476	4611	34	5971	187	-1134	16145	21	16166	1131	508	18918	18939	49.88
16/12/2015		6053	292	206	6551	4794	28	5649	171	-1150	16043	21	16064	1229	418	18840	18861	49.87
17/12/2015		5848	163	297	6308	4951	27	5554	175	-1103	15912	20	15932	1100	404	18519	18539	49.98
18/12/2015		5384	298	283	5965	4968	67	5431	173	-1285	15319	20	15339	909	405	17918	17938	49.96
19/12/2015		5354	263	344	5961	5069	74	5273	165	-1212	15330	15	15345	940	407	17889	17904	49.93
20/12/2015		5326	298	415	6039	4672	76	5084	158	-819	15210	14	15224	838	406	17273	17287	49.90
Maximum		6178	477	415	6866	5165	76	5971	201	-819	16145	22	16166	1229	513	18918	18939	49.98
Minimum		5326	163	139	5961	4611	27	4907	158	-1285	15210	14	15224	838	404	17273	17287	49.87
Average		5715	312	283	6309	4890	48	5410	176	-1112	15721	19	15740	1038	437	18309	18328	49.93

Supply Position During Evening Peak (MW)

Date	Time	MSGENCO				Central Sector Receipt	Wind	CPP	SOLAR	TPCL Exch.	MSEDCL Catered Demand	Load Shedding(LS)	MSEDCL Demand (Incl. LS)	TPCL Gen.	R-INFRA Gen.	State Demand Met	State Demand (Incl. LS)	Freq.
		THM	HYDRO	GAS	Total													
		MW	MW	MW	MW	MW	MW	MW	MW	MW	MW	MW	MW	MW	MW	MW	MW	Hzs
14/12/2015	19 Hrs	6049	385	141	6575	4850	133	4686	0	-1257	14987	13	15000	994	401	17639	17652	50.00
15/12/2015	19 Hrs	5766	294	145	6205	4153	73	5755	0	-1263	14923	13	14936	1094	405	17685	17698	49.91
16/12/2015	19 Hrs	5808	421	195	6424	4440	63	5200	0	-1339	14788	13	14801	939	406	17472	17485	49.94
17/12/2015	19 Hrs	5115	559	308	5982	4616	79	5183	0	-1336	14524	12	14536	829	403	17092	17104	49.94
18/12/2015	19 Hrs	5287	231	293	5811	4490	164	4939	0	-1358	14046	11	14057	848	405	16657	16668	49.96
19/12/2015	19 Hrs	5188	430	432	6050	5041	80	4683	0	-1307	14547	13	14560	826	406	17086	17099	49.95
20/12/2015	19 Hrs	5342	157	442	5941	3939	184	4703	0	-1019	13748	13	13761	674	404	15845	15858	49.94
Maximum		6049	559	442	6575	5041	184	5755	0	-1019	14987	13	15000	1094	406	17685	17698	50.00
Minimum		5115	157	141	5811	3939	63	4683	0	-1358	13748	11	13761	674	401	15845	15858	49.91
Average		5508	354	279	6141	4504	111	5021	0	-1268	14509	13	14522	886	404	17068	17081	49.95

Supply Position During Night Off Peak (MW)

Date	Time	MSGENCO				Central Sector Receipt	Wind	CPP	SOLAR	TPCL Exch.	MSEDCL Catered Demand	Load Shedding(LS)	MSEDCL Demand (Incl. LS)	TPCL Gen.	R-INFRA Gen.	State Demand Met	State Demand (Incl. LS)	Freq.
		THM	HYDRO	GAS	Total													
		MW	MW	MW	MW	MW	MW	MW	MW	MW	MW	MW	MW	MW	MW	MW	MW	Hzs
14/12/2015	3 Hrs	5606	127	311	6044	2326	113	4485	0	-474	12494	18	12512	607	401	13976	13994	50.02
15/12/2015	4 Hrs	5648	135	156	5939	2938	281	4426	0	-500	13084	17	13101	609	403	14596	14613	49.95
16/12/2015	4 Hrs	5586	124	242	5952	2607	151	4896	0	-485	13121	18	13139	623	406	14635	14653	49.86
17/12/2015	3 Hrs	5210	127	314	5651	3423	133	4330	0	-502	13035	16	13051	608	405	14550	14566	49.95
18/12/2015	4 Hrs	5286	138	313	5737	2218	477	4673	0	-353	12752	16	12768	624	406	14135	14151	49.96
19/12/2015	3 Hrs	5245	103	314	5662	1917	398	4867	0	-421	12423	11	12434	642	405	13891	13902	50.03
20/12/2015	24 Hrs	5250	101	445	5796	2641	211	4435	0	-814	12269	13	12282	658	404	14145	14158	50.00
Maximum		5648	138	445	6044	3423	477	4896	0	-353	13121	18	13139	658	406	14635	14653	50.03
Minimum		5210	101	156	5651	1917	113	4330	0	-814	12269	11	12282	607	401	13891	13902	49.86
Average		5404	122	299	5826	2581	252	4587	0	-507	12740	16	12755	624	404	14275	14291	49.97

Details of Supply Position (MUs)

Date	MSGENCO				Pench (MS)	Central Sector Receipt	Central Sector Share	WIND	CPP	SOLAR	TPCL Gen.	R-INFRA Gen.	TPCL Exch.	Energy Requirement		
	THM	HYDRO	GAS	Total										MSEDCL	MUMBAI	STATE
	Mus	Mus	Mus	Mus	Mus	Mus	Mus	Mus	Mus	Mus	Mus	Mus	Mus	Mus	Mus	Mus
14/12/2015	141.590	7.696	6.045	155.331	0.110	101.910	102.291	3.283	109.856	1.240	20.382	10.026	-22.421	349.199	52.829	402.028
15/12/2015	135.573	8.537	3.697	147.807	0.128	96.846	97.195	3.762	127.356	1.243	21.103	10.120	-23.131	353.883	54.351	408.234
16/12/2015	138.603	8.316	5.403	152.322	0.270	96.031	96.193	2.436	127.070	1.095	20.710	9.960	-23.225	355.729	53.895	409.624
17/12/2015	130.700	7.178	7.378	145.256	0.219	99.789	99.269	2.307	120.657	1.166	19.449	10.188	-21.696	347.482	51.333	398.815
18/12/2015	127.724	6.008	7.320	141.052	0.199	90.188	94.368	7.078	121.217	1.173	18.641	9.725	-22.394	338.314	50.760	389.074
19/12/2015	126.671	6.588	8.830	142.089	0.100	91.525	94.286	5.111	118.993	1.111	18.621	9.717	-22.015	336.814	50.356	387.170
20/12/2015	126.609	6.199	10.650	143.458	0.295	89.666	90.971	3.209	115.646	1.038	17.034	9.734	-17.692	335.325	44.449	379.774
Maximum	141.590	8.537	10.650	155.331	0.295	101.910	102.291	141.590	127.356	1.243	21.103	10.188	-17.692	355.729	54.351	409.624
Minimum	126.609	6.008	3.697	141.052	0.100	89.666	90.971	126.609	109.856	1.038	17.034	9.717	-23.225	335.325	44.449	379.774
Average	132.496	7.217	7.046	146.759	0.189	95.136	96.368	132.496	120.114	1.152	19.420	9.924	-21.796	345.249	51.139	396.388

Details of Koyna Water Consumption (in TMC)

Date	For the Day	For the Month	Balance
14/12/2015	0.056	1.337	39.749
15/12/2015	0.102	1.439	39.647
16/12/2015	0.093	1.532	39.554
17/12/2015	0.070	1.602	39.484
18/12/2015	0.048	1.650	39.436
19/12/2015	0.075	1.725	39.361
20/12/2015	0.061	1.786	39.300

State Load Despatch Center, Airoli (MSETCL)
Central Sector Share/Drawal from 14/Dec/2015 to 20/Dec/2015

Date	DAY	Central Sector Share		Total Interstate Bilateral Purchase		Total Share		Total Drawal		Overdrawal(+) / UnderDrawal(-)	
		MUs	Avg. MW	MUs	Avg. MW	MUs	Avg. MW	MUs	Avg. MW	MUs	Avg. MW
		1		2		1+2=3		4		3-4=5	
14/12/2015	MONDAY	82.004	4242	20.287	845	102.291	4262	101.910	4246	-0.381	-16
15/12/2015	TUESDAY	80.527	4033	16.668	694	97.195	4050	96.846	4035	-0.349	-15
16/12/2015	WEDNESDA	80.826	3993	15.367	640	96.193	4008	96.031	4001	-0.162	-7
17/12/2015	THURSDAY	85.045	4122	14.224	593	99.269	4136	99.789	4158	0.520	22
18/12/2015	FRIDAY	82.352	3920	12.016	501	94.368	3932	90.188	3758	-4.180	-174
19/12/2015	SATURDAY	84.171	3918	10.115	421	94.286	3929	91.525	3814	-2.761	-115
20/12/2015	SUNDAY	79.889	3779	11.082	462	90.971	3790	89.666	3736	-1.305	-54
Total		574.814		99.759		674.573		665.955		-8.618	

GENERATING UNITS OUTAGES FOR THE WEEK FROM 14/12/2015 TO 20/12/2015							
Generator	Generating Unit	Capacity	Tripped Date	Tripped Time	Synch. Date	Synch Time	Reason
PLANNED OUTAGES							
Cent_Sect	Tarapur 2	160MW	10/Sep/2015	12.55		Continued.	Refuelling work
FORCED OUTAGES							
RGPPL	Dabhol Dabhol 1B	230MW	28/May/2013	22:02		Continued.	Gas Shortage.
RGPPL	Dabhol Dabhol 2A	230MW	06/Jun/2013	09.10		Continued.	Gas Shortage
RGPPL	Dabhol Dabhol 3A	230MW	06/Jun/2013	08.28		Continued.	Gas Shortage
RGPPL	Dabhol Dabhol 1A	230MW	27/Jun/2013	21.47		Continued.	Gas Shortage
RGPPL	Dabhol Dabhol 1X	230MW	27/Jun/2013	21.46		Continued.	Gas Shortage
RGPPL	Dabhol Dabhol 2X	230MW	15/Jul/2013	15.09		Continued.	Gas Shortage
RGPPL	Dabhol Dabhol 2B	230MW	08/Aug/2013	15.03		Continued.	Gas Shortage
IPP	Dhariwal	300MW	28/May/2014	02.27		Continued.	No schedule
MSPGCL	Chandrapur Unit 1	210MW	28/Aug/2014	07:15		Continued.	Economic Shutdown.
MSPGCL	Koradi Unit 6	210MW	20/Mar/2015	01.02		Continued.	Economic shutdown
MSPGCL	Uran Unit 7	108MW	17/Apr/2015	00.07		Continued.	Gas turbine problem
MSPGCL	Parli Unit 3	210MW	14/Jun/2015	12.58		Continued.	Water Shortage
IPP	WPCL U-2	135MW	16/Jun/2015	00.00		Continued.	No Schdule
MSPGCL	Parli Unit 6	250MW	25/Jun/2015	15.03		Continued.	Water Shortage
MSPGCL	Parli Unit 4	210MW	05/Jul/2015	18.45		Continued.	Water Shortage
MSPGCL	Parli Unit 5	210MW	06/Jul/2015	14.55		Continued.	Water Shortage.
MSPGCL	Parli Unit 7	250MW	08/Jul/2015	12.08		Continued.	Water Shortage
IPP	Tata Trombay 6	500MW	15/Jul/2015	17.08		Continued.	Economic shutdown
IPP	WPCL U-1	135MW	23/Oct/2015	17.31		Continued.	ESP filter problem
MSPGCL	Chandrapur Unit-8	500MW	10/Nov/2015	12.10		Continued.	Drum level low
IPP	Adani U-5	660MW	22/Nov/2015	08.55	15/Dec/2015	06.58	Leakage tube oil system
MSPGCL	Uran Unit 8	108MW	09/Dec/2015	12.42	19/Dec/2015	09.18	Gas shortage
MSPGCL	Uran Unit B0	120MW	09/Dec/2015	12.34	19/Dec/2015	14.39	Gas shortage
IPP	VIPL Unit 2	300MW	09/Dec/2015	23.51	14/Dec/2015	22.20	Inspection and Testing of U-2 Boiler
IPP	RPL(AMT) U-5	270MW	12/Dec/2015	21.29	15/Dec/2015	01.23	Cooling Water Line Leakage.
MSPGCL	Uran Unit 6	108MW	14/Dec/2015	16.35	15/Dec/2015	20.53	Gas shortage
IPP	Adani U-4	660MW	14/Dec/2015	06.55		Continued.	Hot air line leakage
MSPGCL	Koradi Unit-5	200MW	15/Dec/2015	08.56	15/Dec/2015	18.34	ID Fan Problem
MSPGCL	Bhusawal Unit 2	210MW	15/Dec/2015	14.00	16/Dec/2015	00.13	Attending B ph CT Hot spot of GT2
IPP	RPL(AMT) U-4	270MW	15/Dec/2015	09.59	15/Dec/2015	12.26	Boiler Auxilary supply failure
IPP	RPL(AMT) U-2	270MW	16/Dec/2015	12.18	18/Dec/2015	07.05	Bottom Ash Problem
IPP	Adani U-5	660MW	16/Dec/2015	23.56	17/Dec/2015	08.06	Generator Prot.operated
MSPGCL	Paras Unit 4	250MW	16/Dec/2015	23.01	17/Dec/2015	09.23	Bunkering problem
MSPGCL	Chandrapur Unit-5	500MW	17/Dec/2015	17.18	17/Dec/2015	19.55	Flame Failure
MSPGCL	Bhusawal Unit 2	210MW	17/Dec/2015	01.10	20/Dec/2015	18.41	Boiler Tube Leakage
MSPGCL	Nasik Unit 4	210MW	18/Dec/2015	00.28	20/Dec/2015	02.55	Boiler Tube Leakage
MSPGCL	Khaparkheda Unit 3	210MW	19/Dec/2015	19.08		Continued.	Boiler Tube Leakage
IPP	RPL(AMT) U-4	270MW	20/Dec/2015	20.55		Continued.	ID Fan Problem
MSPGCL	Bhusawal Unit 2	210MW	20/Dec/2015	21.49	21/Dec/2015	00.31	Drum level High
IPP	RPL(AMT) U-5	270MW	20/Dec/2015	09.17		Continued.	P.A.Fan Problem

LINE OUTAGES FOR THE WEEK FROM 14/12/2015 TO 20/12/2015

Voltage	Name of Line	Tripping Date	Tripping Time	Synch Date	Synch Time	Reason
400 KV	Akola II - Taptitanda ckt-II	06/Oct/2015	09.44		Continued.	For Controlling Line Loading.
400 KV	Babhaleshwar-Taptitanda ckt-II	10/Dec/2015	06.37	19/Dec/2015	07.27	Line Rectification work(RFC 17.27Hrs)
400 KV	Karad - Lonikand I	12/Dec/2015	10.02	16/Dec/2015	18.46	Insulator Disc Replacement.
400 KV	Dhule Sar'Sarovar I	13/Dec/2015	13.40	14/Dec/2015	06.46	Over Voltage
400 KV	karad -kolhapur-II	13/Dec/2015	16.04	14/Dec/2015	09.18	Over Voltage
400 KV	Jaigad-Karad Ckt-II	13/Dec/2015	16.11	14/Dec/2015	10.11	Over Voltage
400 KV	Bhusawal-Aurangabad	13/Dec/2015	16.35	14/Dec/2015	07.12	Over Voltage
400 KV	Kolhapur Solapur (PG) II	13/Dec/2015	17.13	14/Dec/2015	06.53	Over Voltage
400 KV	Parli (Pg) Wardha (Pg) I	14/Dec/2015	10.46	14/Dec/2015	14.31	CSD COMMISSIONING
400 KV	karad -kolhapur-I	14/Dec/2015	16.35	15/Dec/2015	09.16	Over Voltage
400 KV	Karad-Jaigad - I	14/Dec/2015	16.38	15/Dec/2015	09.19	Over Voltage
400 KV	Dhule Sar'Sarovar I	14/Dec/2015	17.35	15/Dec/2015	07.02	Over Voltage
400 KV	Bhusawal-Aurangabad	14/Dec/2015	17.35	15/Dec/2015	06.58	Over Voltage
400 KV	Lonikand I - Koyna stage-IV	14/Dec/2015	21.57	15/Dec/2015	07.13	Over Voltage
400 KV	Babhaleshwar - Padghe-I	14/Dec/2015	22.07	15/Dec/2015	00.25	Brekar pole to ips tube connection
400 KV	Kolhapur Solapur(PG) I	14/Dec/2015	22.19	15/Dec/2015	07.07	Over Voltage
400 KV	New Koyna - Dabhol - li	15/Dec/2015	09.19	15/Dec/2015	19.58	CT oil leakage at dabhol end
400 KV	Akola Aurangabad(PG) I	15/Dec/2015	10.15	15/Dec/2015	19.20	commissioning of line reactor at A'bad end
400 KV	Kolhapur(M)-Kolhapur(GIS) ckt1	15/Dec/2015	10.45	15/Dec/2015	20.02	Replacement of Wavetrap Jumper
400 KV	Kolhapur Solapur(PG) I	15/Dec/2015	11.42	15/Dec/2015	13.07	While plcc work
400 KV	TBC @ chandrapur	15/Dec/2015	15.00	15/Dec/2015	16.57	CRM WORK
400 KV	karad -kolhapur-II	15/Dec/2015	16.07	16/Dec/2015	09.08	Over Voltage
400 KV	Karad - Jaigad - II	15/Dec/2015	16.29	16/Dec/2015	09.13	Over Voltage
400 KV	Dhule Sar'Sarovar I	15/Dec/2015	19.16	16/Dec/2015	06.41	Over Voltage
400 KV	Bhusawal-Aurangabad	15/Dec/2015	20.57	16/Dec/2015	07.09	Over Voltage
400 KV	Kolhapur Solapur (PG) II	15/Dec/2015	21.38	16/Dec/2015	06.23	Over Voltage
400 KV	karad -kolhapur-I	16/Dec/2015	16.34	17/Dec/2015	07.18	Over Voltage
400 KV	Bhusawal-Aurangabad	16/Dec/2015	17.10	17/Dec/2015	06.51	Over Voltage
400 KV	Karad-Jaigad - I	16/Dec/2015	17.12	17/Dec/2015	07.24	Over Voltage
400 KV	Dhule Sar'Sarovar I	16/Dec/2015	17.30	17/Dec/2015	06.42	Over Voltage
400 KV	Lonikand I - Koyna stage-IV	16/Dec/2015	21.58	17/Dec/2015	07.17	Over Voltage
400 KV	Kolhapur Solapur(PG) I	16/Dec/2015	22.08	17/Dec/2015	06.51	Over Voltage
400 KV	Kolhapur Solapur(PG) I	17/Dec/2015	07.43		Continued.	Line Rectification Work.
400 KV	Kolhapur Solapur (PG) II	17/Dec/2015	08.15		Continued.	Line Rectification Work.
400 KV	Khadka- Deepnagar Ckt 2	17/Dec/2015	08.54	17/Dec/2015	19.42	5 No's of IPS Tube Fixing & Alignment of the Isolator.
400 KV	Dhule Sar'Sarovar II	17/Dec/2015	09.02	18/Dec/2015	23.16	Maint.Work(RFC @ 17.50 Hrs).
400 KV	Main Bus-II @Deepnagar	17/Dec/2015	10.26	17/Dec/2015	19.31	Tube Fixing & Alignment of the Isolator
400 KV	Karad - Jaigad - II	17/Dec/2015	16.49	18/Dec/2015	07.31	Over Voltage
400 KV	Bhusawal-Aurangabad	17/Dec/2015	17.19	18/Dec/2015	07.21	Over Voltage
400 KV	Lonikand I - Koyna stage-IV	17/Dec/2015	17.19	18/Dec/2015	07.30	Over Voltage
400 KV	Dhule Sar'Sarovar II	18/Dec/2015	13.02	20/Dec/2015	06.52	Work @ SSNL End(Ckt RFC@19.40)
400 KV	Karad-Jaigad - I	18/Dec/2015	16.36	19/Dec/2015	09.10	Over Voltage
400 KV	Bhusawal-Aurangabad	18/Dec/2015	17.04	19/Dec/2015	06.33	Over Voltage
400 KV	Koradi-Bhusawal	18/Dec/2015	18.04	18/Dec/2015	20.26	Over Voltage
400 KV	Dhule Sar'Sarovar I	18/Dec/2015	21.56	19/Dec/2015	07.51	Over Voltage
400 KV	Lonikand I - Koyna stage-IV	18/Dec/2015	22.08	19/Dec/2015	08.15	Over Voltage
400 KV	Babhaleshwar-Taptitanda ckt-I	19/Dec/2015	07.28		Continued.	Over Voltage (RFG 17.58 Hrs)
400 KV	Akola Wardha I	19/Dec/2015	11.27	19/Dec/2015	15.18	Broken Jumper Connection.
400 KV	Main Bus-II @ Koradi	19/Dec/2015	12.06	19/Dec/2015	18.45	Jumpering Work.
400 KV	Karad - Jaigad - II	19/Dec/2015	16.38	20/Dec/2015	08.47	Over Voltage
400 KV	Bhusawal-Aurangabad	19/Dec/2015	17.14	20/Dec/2015	07.03	Over Voltage
400 KV	Lonikand I - Koyna stage-IV	19/Dec/2015	21.35	20/Dec/2015	08.35	Over Voltage
400 KV	Karad-Jaigad - I	20/Dec/2015	16.13		Continued.	Over Voltage
400 KV	Bhusawal-Aurangabad	20/Dec/2015	16.51		Continued.	Over Voltage
400 KV	Lonikand I - Koyna stage-IV	20/Dec/2015	17.13		Continued.	Over Voltage
400 KV	Dhule Sar'Sarovar I	20/Dec/2015	17.38	21/Dec/2015	06.41	Over Voltage
400 KV	Kalwa - Kharghar	21/Dec/2015	06.05		Continued.	Anticorrosiv painting work

Voltage	Name of Line	Tripping Date	Tripping Time	Synch Date	Synch Time	Reason
220 KV	Chandrapur GCR - Warora - I	05/Apr/2015	09.13		Continued.	Bunching of conductor Loc no 86 Disconnecting of jumer at Loc no 86 & 107 and de-energising the line bet.86 to 107.
220 KV	Chandrapur GCR - Wani	05/Apr/2015	09.15		Continued.	Bunching of conductor Loc no 86 Disconnecting of jumer at Loc no 86 & 107 and de-energising the line bet.86 to 107.
220 KV	Wadkhal - Ipcl 1	06/Nov/2015	11.50	18/Dec/2015	21.12	Replacement of Conductors (for 15 Days).
220 KV	Ghodbunder - Versova	07/Dec/2015	08:45		Continued.	Modification of existing towers from broad based to narrow based towers in MBMC area
220 KV	Ghodbunder - Gorai	09/Dec/2015	08:18		Continued.	Modification of existing towers from broad based to narrow based towers in MBMC area
220 KV	Halkarni-Mahalaxmilline	13/Dec/2015	15.40	14/Dec/2015	07.55	R-ph C.T.burst
220 KV	Parvati - Hybrid Pass	14/Dec/2015	08.58	14/Dec/2015	17.32	Control urse-chinchwad line loading
220 KV	Nasik Navsari I	14/Dec/2015	09.21	18/Dec/2015	19.25	Insulator Replacement Work
220 KV	Hinjawadi I- Chinchwad	14/Dec/2015	09.30	14/Dec/2015	16.35	Control urse-chinchwad line loading
220 KV	Nasik Navsari II	14/Dec/2015	09.38	18/Dec/2015	19.42	Insulator Replacement Work
220 KV	Hamidwada-Mumewadi	14/Dec/2015	09.53	14/Dec/2015	17.15	Replacement work
220 KV	New Koyna - Niwali	14/Dec/2015	10.18	14/Dec/2015	16.57	R.m.work
220 KV	Parvati - Hybrid Pass	15/Dec/2015	09.24	15/Dec/2015	16.53	control urse-chinchwad line loading
220 KV	Solapur(Bale) - Tuljapur	15/Dec/2015	09.29	15/Dec/2015	16.51	conductor stringing
220 KV	Osmanabad - Solapur (Bale)	15/Dec/2015	09.29	15/Dec/2015	16.17	conductor stringing
220 KV	Kadegaon-Miraj	15/Dec/2015	10.04	15/Dec/2015	13.41	Annual Maintenance Work
220 KV	Uran - Apta III	15/Dec/2015	10.29	15/Dec/2015	14.52	Testing Work
220 KV	Hinjawadi I- Chinchwad	15/Dec/2015	11.10	15/Dec/2015	16.19	control urse-chinchwad line loading
220 KV	Miraj - Tilwani	15/Dec/2015	14.58	15/Dec/2015	18.22	Annual Maintenance Work
220 KV	Baggaon - Kalwa	15/Dec/2015	15.34	15/Dec/2015	20.09	opening of wave trap jumper at kalwa
220 KV	Nagar-Babhaleshwar Ckt II	15/Dec/2015	21.02	15/Dec/2015	21.17	Distance Protection
220 KV	Pandharpur - Hiwarwada	16/Dec/2015	00.02	16/Dec/2015	00.15	Distance Protection
220 KV	Theur-Jejuri	16/Dec/2015	05.00	16/Dec/2015	13.30	Distance Protection
220 KV	Boisar(M) - Ghodbunder	16/Dec/2015	08.29		Continued.	Tower Erection and Stringing work
220 KV	Borivali - Tarapur	16/Dec/2015	09.34		Continued.	Tower Erection and Stringing work
220 KV	Nashik-Airoli Knowledge Park	16/Dec/2015	09.40	16/Dec/2015	18.15	Routine Maintenance Work
220 KV	Mumewadi-Belewadi	16/Dec/2015	09.40	16/Dec/2015	16.43	Insulator cleaning work
220 KV	New Koyna - Loteparshuram	16/Dec/2015	10.19	16/Dec/2015	13.45	To attend Hot Spot
220 KV	Butibori-Abhijeet	16/Dec/2015	11.52	16/Dec/2015	17.30	To attend Hot Spot
220 KV	Aurangabad - Chitegaon	16/Dec/2015	13.15	16/Dec/2015	15.01	Line Signature Test
220 KV	Warora - Hinganghat	17/Dec/2015	10.14	17/Dec/2015	19.16	Replacement of CT Due to High Tan Delta Value.
220 KV	Jejuri-Parvati	17/Dec/2015	11.13	17/Dec/2015	17.42	Relay Testing CT Testing & Q.M.Work.
220 KV	Bableshtar- Ranjangaon	17/Dec/2015	13.20	17/Dec/2015	16.39	Line Maintenance work
220 KV	Khadka-Chalisgaon-1	17/Dec/2015	16.13	17/Dec/2015	19.16	In View of Emergency Outage of 315 MVA ICT @ Bswl.
220 KV	Chalisgaon -Babhaleshwar	17/Dec/2015	16.16	17/Dec/2015	19.21	In View of Emergency Outage of 315 MVA ICT @ Bhusawal.
220 KV	Khadka-Chalisgaon-2	17/Dec/2015	16.24	17/Dec/2015	19.08	In View of Emergency Outage of 315 MVA ICT @ Bhusawal.
220 KV	Pophali - Kdph	18/Dec/2015	06.20	18/Dec/2015	18.50	Bus Section Outage for Maintenance Work.
220 KV	Pophli Pedhmbe Line- 1	18/Dec/2015	06.25	19/Dec/2015	11.20	Bus Section Outage for Maintenance Work.
220 KV	Kandalgaon - Koyna	18/Dec/2015	06.50	18/Dec/2015	18.25	Bus Section Outage for Maintenance Work.
220 KV	Bhaveghar - Kolshet	18/Dec/2015	10.00	18/Dec/2015	17.54	Testing Work Bus Bar Protection Pannel Commissioning.
220 KV	Wada - Bhaveghar	18/Dec/2015	10.10	18/Dec/2015	17.20	Testing Work Bus Bar Protection Pannel Commissioning.
220 KV	Padgha-Temghar-II	18/Dec/2015	10.15	20/Dec/2015	21.58	Routine Maintenance Work
220 KV	Shivajinagar - Malegaon	18/Dec/2015	10.21	18/Dec/2015	13.59	Isolator Maintenance Work.
220 KV	Kharepatan -Pawas Line	18/Dec/2015	10.26	18/Dec/2015	14.12	tending Oil Leakage on R Ph CT & Diagnostic Testing Wo
220 KV	Kolhapur - 5 Star Ckt I	19/Dec/2015	07.33	19/Dec/2015	16.08	Backup Protection
220 KV	Kalwa Salsette III	19/Dec/2015	08.24	20/Dec/2015	17.24	C T Replacement Work @ Kalwa.
220 KV	Nasik Navsari II	19/Dec/2015	10.00	19/Dec/2015	18.53	outage.

Voltage	Name of Line	Tripping Date	Tripping Time	Synch Date	Synch Time	Reason
220 KV	220/132 Kv 200MVA ICT II @Dhule	19/Dec/2015	10.18	19/Dec/2015	16.29	Routine Maintenance Work
220 KV	Pedambe-Pophali	19/Dec/2015	10.47	19/Dec/2015	11.10	SF6 Gas Filling.
220 KV	Wadkhal - Ipcl 2	19/Dec/2015	11.00		Continued.	Conductor Replacement Work With High Amacity Conductor.
220 KV	New Koyna - Niwali	19/Dec/2015	11.23	19/Dec/2015	13.50	Tan Delta Testing Work.
220 KV	Pedambe-Nerle	19/Dec/2015	11.35	19/Dec/2015	18.20	Attending Hot Spot
220 KV	Virur - Virur Rly Tss 2	19/Dec/2015	12.00	19/Dec/2015	15.00	Measurment of Breaker Timings,Measurment of Tandelta of CT.
220 KV	Talandage - Chikodi	19/Dec/2015	12.42	20/Dec/2015	19.26	Dist.Prot.R Ph to Earth.
220 KV	Mudshingi Chikodi	19/Dec/2015	12.55	19/Dec/2015	18.18	Dist.Prot.R & Y Ph to Earth.
220 KV	Virur - Virurlytss1	19/Dec/2015	15.20	19/Dec/2015	17.00	Measurment of Breaker Timings,Measurment of Tandelta of CT.
220 KV	Kharghar - Kalwa	20/Dec/2015	07.21		Continued.	Tapping TIFL line on kalwa- khargher
220 KV	Kalwa-TIFIL	20/Dec/2015	07.52	20/Dec/2015	19.19	Tapping TIFL line on kalwa- khargher
220 KV	Arey - TPC Borivali	20/Dec/2015	08.53		Continued.	Replacement of Hydraulic cylinder in Gis
132 KV	Indapur-Ujani	15/Dec/2015	22.55	15/Dec/2015	23.05	Distance Protection
132 KV	Paithan-Rajpimpri	19/Dec/2015	05.05	19/Dec/2015	05.20	Distance Protection Operated Zone-I.
132 KV	Deepnagar(Gcr) -New Midc Jalgaon	19/Dec/2015	13.48	19/Dec/2015	14.35	B Protn Optd @ Deepnagar,Load Shifted on Bhambori S/S
132 KV	Deepnagar- Muktainagar	19/Dec/2015	13.48	19/Dec/2015	15.20	B Protn Optd @ Deepnagar,Load Shifted on Malkapur S/S
132 KV	Khadka-Deepnagar Ckt-1	19/Dec/2015	13.48	19/Dec/2015	14.47	BB Protn Optd @ Deepnagar.
132 KV	Deepnagar- Nimbhora	19/Dec/2015	13.48	19/Dec/2015	14.58	BB Protn Optd @ Deepnagar.