

State Load Despatch Center,Airoli (MSETCL)
Power System Position from 18/Dec/2023 to 24/Dec/2023

Supply Position During Morning Peak (MW)

Date	Time	MSGENCO				Central Sector Receipt	Wind	CPP	SOLAR	TPCL Exch.	MSEDCL Catered Demand	Load Sheddin g(LS)	MSEDCL Demand (Incl. LS)	TPCL Gen.	R-INFRA Gen.	State Demand Met	State Demand (Incl. LS)	Freq.
		THM	HYDRO	GAS	Total													
		MW	MW	MW	MW	MW	MW	MW	MW	MW	MW	MW	MW	MW	MW	MW	MW	Hzs
18-12-2023	11 Hrs	6195	197	289	6681	8208	964	7734	1672	-1825	22971	0	22971	695	475	26429	26429	50.04
19-12-2023	11 Hrs	6179	227	294	6700	8409	955	7684	1845	-2068	23066	0	23066	617	340	26550	26550	50.02
20-12-2023	11 Hrs	6595	306	292	7193	8240	649	7683	1894	-1887	23337	0	23337	744	313	26716	26716	50.00
21-12-2023	11 Hrs	7111	456	288	7855	7513	337	7776	1914	-1870	23051	0	23051	886	222	26503	26503	49.99
22-12-2023	11 Hrs	7217	570	294	8081	7981	131	7861	1782	-1793	23580	0	23580	995	237	27068	27068	49.93
23-12-2023	11 Hrs	6785	432	295	7512	8059	127	7901	1948	-1702	23394	0	23394	826	243	26616	26616	50.00
24-12-2023	11 Hrs	6960	212	293	7465	7519	341	7912	1937	-1382	23364	0	23364	695	251	26120	26120	49.99
Maximum		7217	570	295	8081	8409	964	7912	1948	-1382	23580	0	23580	995	475	27068	27068	50.04
Minimum		6179	197	288	6681	7513	127	7683	1672	-2068	22971	0	22971	617	222	26120	26120	49.93
Average		6720	343	292	7355	7990	501	7793	1856	-1790	23252	0	23252	780	297	26572	26572	50.00

Supply Position During Day Peak (MW)

Date	Time	MSGENCO				Central Sector Receipt	Wind	CPP	SOLAR	TPCL Exch.	MSEDCL Catered Demand	Load Sheddin g(LS)	MSEDCL Demand (Incl. LS)	TPCL Gen.	R-INFRA Gen.	State Demand Met	State Demand (Incl. LS)	Freq.
		THM	HYDRO	GAS	Total													
		MW	MW	MW	MW	MW	MW	MW	MW	MW	MW	MW	MW	MW	MW	MW	MW	Hzs
18-12-2023	16 Hrs	5911	221	285	6417	8103	490	7652	1023	-1943	21263	0	21263	663	325	24673	24673	49.99
19-12-2023	16 Hrs	5981	182	282	6445	7889	546	7638	1128	-1944	21226	0	21226	670	381	24697	24697	49.97
20-12-2023	13 Hrs	5655	292	289	6236	7923	424	7492	2034	-2074	21571	0	21571	688	168	24965	24965	49.95
21-12-2023	13 Hrs	5893	244	281	6418	8059	208	7544	2167	-2038	21918	0	21918	731	237	25364	25364	49.99
22-12-2023	13 Hrs	6538	271	286	7095	8045	89	7767	2034	-1996	22578	0	22578	811	248	26089	26089	49.99
23-12-2023	13 Hrs	5957	132	284	6373	7900	196	7697	2182	-1963	21942	0	21942	618	228	25194	25194	50.01
24-12-2023	13 Hrs	6081	95	281	6457	7066	347	7695	2132	-1519	21765	0	21765	626	214	24537	24537	49.95
Maximum		6538	292	289	7095	8103	546	7767	2182	-1519	22578	0	22578	811	381	26089	26089	50.01
Minimum		5655	95	281	6236	7066	89	7492	1023	-2074	21226	0	21226	618	168	24537	24537	49.95
Average		6002	205	284	6492	7855	329	7641	1814	-1925	21752	0	21752	687	257	25074	25074	49.98

Supply Position During Evening Peak (MW)

Date	Time	MSGENCO				Central Sector Receipt	Wind	CPP	SOLAR	TPCL Exch.	MSEDCL Catered Demand	Load Sheddin g(LS)	MSEDCL Demand (Incl. LS)	TPCL Gen.	R-INFRA Gen.	State Demand Met	State Demand (Incl. LS)	Freq.
		THM	HYDRO	GAS	Total													
		MW	MW	MW	MW	MW	MW	MW	MW	MW	MW	MW	MW	MW	MW	MW	MW	Hzs
18-12-2023	19 Hrs	6415	441	286	7142	6983	803	7870	5	-1298	21024	0	21024	1178	484	24465	24465	50.05
19-12-2023	19 Hrs	6726	379	292	7397	7294	765	7872	0	-1333	21503	0	21503	1197	477	25002	25002	50.03
20-12-2023	19 Hrs	6958	794	293	8045	7024	542	7881	1	-1612	21388	0	21388	1085	242	24820	24820	50.02
21-12-2023	19 Hrs	7393	927	293	8613	6715	169	7832	0	-1596	21239	0	21239	1108	244	24681	24681	49.97
22-12-2023	19 Hrs	7131	762	289	8182	6726	283	7890	1	-1620	20978	0	20978	1092	250	24424	24424	49.99
23-12-2023	19 Hrs	6765	816	291	7872	7089	399	7904	0	-1481	21309	0	21309	1061	251	24576	24576	50.02
24-12-2023	19 Hrs	6500	121	289	6910	6723	872	7891	0	-1539	20397	0	20397	681	176	23253	23253	50.04
Maximum		7393	927	293	8613	7294	872	7904	5	-1298	21503	0	21503	1197	484	25002	25002	50.05
Minimum		6415	121	286	6910	6715	169	7832	0	-1620	20397	0	20397	681	176	23253	23253	49.97
Average		6841	606	290	7737	6936	548	7877	1	-1497	21120	0	21120	1057	303	24460	24460	50.02

Supply Position During Night Off Peak (MW)

Date	Time	MSGENCO				Central Sector Receipt	Wind	CPP	SOLAR	TPCL Exch.	MSEDCL Catered Demand	Load Sheddin g(LS)	MSEDCL Demand (Incl. LS)	TPCL Gen.	R-INFRA Gen.	State Demand Met	State Demand (Incl. LS)	Freq.
		THM	HYDRO	GAS	Total													
		MW	MW	MW	MW	MW	MW	MW	MW	MW	MW	MW	MW	MW	MW	MW	MW	Hzs
18-12-2023	3 Hrs	4599	187	300	5086	5792	1136	5764	0	-1017	16434	0	16434	510	319	18607	18607	50.01
19-12-2023	1 Hrs	4690	170	297	5157	5792	1352	5997	0	-1252	16649	0	16649	558	309	19165	19165	49.91
20-12-2023	1 Hrs	4908	165	295	5368	5537	1464	5973	0	-1258	16677	0	16677	558	291	19191	19191	50.01
21-12-2023	2 Hrs	4892	161	302	5355	5909	818	6646	0	-1349	17008	0	17008	473	173	19374	19374	49.98
22-12-2023	2 Hrs	5011	167	302	5480	5982	342	7266	0	-1313	17401	0	17401	498	189	19757	19757	50.00
23-12-2023	3 Hrs	5735	143	291	6169	5625	113	7286	0	-1240	17607	0	17607	439	205	19837	19837	49.97
24-12-2023	23 Hrs	4761	100	299	5160	5949	914	6620	0	-1535	16713	0	16713	490	164	19298	19298	49.99
Maximum		5735	187	302	6169	5982	1464	7286	0	-1017	17607	0	17607	558	319	19837	19837	50.01
Minimum		4599	100	291	5086	5537	113	5764	0	-1535	16434	0	16434	439	164	18607	18607	49.91
Average		4942	156	298	5396	5798	877	6508	0	-1281	16927	0	16927	504	236	19318	19318	49.98

Details of Supply Position (MUs)

Date	MSGENCO				Pench (MS)	Central Sector Receipt	Central Sector Share	WIND	CPP	SOLAR	TPCL Gen.	R-INFRA Gen.	TPCL Exch.	Energy Requirement		
	THM	HYDRO	GAS	Total										MSEDCL	MUMBAI	STATE
	Mus	Mus	Mus	Mus	Mus	Mus	Mus	Mus	Mus	Mus	Mus	Mus	Mus	Mus	Mus	Mus
18-12-2023	129.432	5.437	7.038	141.907	0.311	166.840	168.483	23.048	172.251	12.199	16.400	8.192	-35.716	470.134	60.308	540.837
19-12-2023	132.068	5.052	6.609	143.729	0.092	164.851	168.617	24.364	174.929	13.524	16.662	8.089	-35.562	475.438	60.313	546.148
20-12-2023	144.363	6.205	7.069	157.637	0.183	160.928	162.612	18.641	175.821	13.705	17.123	6.284	-36.407	479.923	59.814	550.139
21-12-2023	150.522	7.270	7.065	164.857	0.202	160.330	163.331	11.337	179.665	14.411	16.734	5.084	-38.557	481.595	60.375	552.418
22-12-2023	153.188	8.911	7.056	169.155	0.478	161.650	165.851	5.893	183.595	13.023	17.420	5.157	-38.219	484.726	60.796	555.893
23-12-2023	148.131	5.826	7.009	160.966	0.182	164.958	171.046	5.760	183.316	14.815	16.541	5.261	-35.736	483.804	57.538	551.617
24-12-2023	140.491	3.204	7.057	150.752	0.202	157.844	166.702	14.415	179.951	14.144	13.364	4.526	-33.755	473.467	51.645	534.996
Maximum	153.188	8.911	7.069	169.155	0.478	166.840	171.046	153.188	183.595	14.815	17.420	8.192	-33.755	484.726	60.796	555.893
Minimum	129.432	3.204	6.609	141.907	0.092	157.844	162.612	129.432	172.251	12.199	13.364	4.526	-38.557	470.134	51.645	534.996
Average	142.599	5.986	6.986	155.572	0.236	162.486	166.663	142.599	178.504	13.689	16.321	6.085	-36.279	478.441	58.684	547.435

Details of Koyna Water Consumption (in TMC)

Date	For the Day	For the Month	Balance
18-12-2023	0.032	0.963	38.325
19-12-2023	0.029	0.992	38.296
20-12-2023	0.041	1.034	38.254
21-12-2023	0.066	1.099	38.189
22-12-2023	0.107	1.206	38.082
23-12-2023	0.069	1.275	38.013
24-12-2023	0.035	1.311	37.977

State Load Despatch Center,Airoli (MSETCL) Central Sector Share/Drawal from 18/Dec/2023 to 24/Dec/2023

Date	DAY	Central Sector Share		Total Interstate		Total Share		Total Drawal		Overdrawal(+) /	
		MUs	Avg. MW	MUs	Avg. MW	MUs	Avg. MW	MUs	Avg. MW	MUs	Avg. MW
		1		2		1+2=3		4		3-4=5	
18-12-2023	MONDAY	77.382	6929	91.101	3796	168.483	7020	166.840	6952	-1.643	-68
19-12-2023	TUESDAY	78.876	6936	89.741	3739	168.617	7026	164.851	6869	-3.766	-157
20-12-2023	WEDNESDAY	79.621	6693	82.991	3458	162.612	6776	160.928	6705	-1.684	-70
21-12-2023	THURSDAY	87.460	6730	75.871	3161	163.331	6805	160.330	6680	-3.001	-125
22-12-2023	FRIDAY	97.275	6842	68.576	2857	165.851	6910	161.650	6735	-4.201	-175
23-12-2023	SATURDAY	97.734	7054	73.312	3055	171.046	7127	164.958	6873	-6.088	-254
24-12-2023	SUNDAY	87.381	6867	79.321	3305	166.702	6946	157.844	6577	-8.858	-369
Total		605.729		560.913		1166.642		1137.401		-29.241	

Generator Unit Outages/Trippings from 18.12.2023 to 24.12.2023						
Name of Unit	Date Trip	Time Trip	Date Sync	Time Sync	Reason	Outage Type
PGPL U2	07-02-2017	17.3		Continued.	No Schedule.(NO PPA)	FORCED
PGPL U1	07-02-2017	17.3		Continued.	No Schedule (NO PPA)	FORCED
VIPL U-1	29-12-2018	0.3		Continued.	Coal Shortage. (NO PPA From 20.05.2019)	FORCED
VIPL U-2	17-01-2019	0.15		Continued.	Coal shortage.(NO PPA From 20.05.2019)	FORCED
Tarapur 1	08-01-2020	10:37		Continued.	Refueling. While refueling preparation, some repair works identified which are being executed before refueling.	FORCED
Tarapur 2	13-07-2020	04:38		Continued.	For cleaning of clogged basket strainer of cooling water system due to heavy ingress of debris from sea. The outage extended for repair and re-fueling.	FORCED
Koradi Unit 7	27-04-2021	20.03		Continued.	Retired (04/08/2021 At 00.00)	FORCED
Uran Unit A0	07-09-2022	16:30		Continued.	TURBINE TRIPPED ON HIGH VIBRATIONS	FORCED
Uran Unit 5	12-11-2022	13:23		Continued.	Major overhaul.	PLANNED
Koyna Unit 11	10-07-2023	09:40		Continued.	COH	PLANNED
Uran Unit 6	05-10-2023	00:29		Continued.	Gas shortage	FORCED
RPL(AMT) U-2	12-10-2023	07:59	24-12-2023	06:49	Tripped Due to Electrical protection opted.	FORCED
Nasik Unit 4	19-11-2023	15:48	25-12-2023	08:15	Stator Earth Fault (Converted into AOH from 00:00 hrs dt.20/11/2023)	PLANNED
Koyna STG-IV Unit-3	24-11-2023	08:00		Continued.	Capital Overhauling	PLANNED
Tarapur 4	05-12-2023	23:47	18-12-2023	20:34	Auxiliary Secondary side feed water leakage.	FORCED
Koyna Unit 1	13-12-2023	15:54		Continued.	New excitation panel installation and commissioning work	PLANNED
Koradi Unit 8	14-12-2023	09:42	19-12-2023	15:42	Boiler Tube Leakage	FORCED
Chandrapur Unit 5	16-12-2023	08:47	18-12-2023	05:06	Boiler Tube Leakage	FORCED
Chandrapur Unit 6	18-12-2023	02:19	20-12-2023	07:33	Boiler Tube Leakage	FORCED
Bhusawal Unit 4	18-12-2023	10:05	21-12-2023	03:53	Tube leakage attending work.	FORCED
Uran Unit 7	19-12-2023	04:25	19-12-2023	06:16	Generator protection	FORCED
Parli Unit 8	19-12-2023	20:44	22-12-2023	17:36	Zero schedule	FORCED
AEML Unit 2	20-12-2023	10:54		Continued.	Annual Overhaul	PLANNED

Tarapur 4	20-12-2023	11:06	22-12-2023	03:09	Actuation of Reactor Protection system	FORCED
Trombay 7B	20-12-2023	12:37	03-01-2024	Continued.	Annual Overhaul	PLANNED
Trombay 7A	20-12-2023	12:42		Continued.	Annual Overhaul	PLANNED
Nasik Unit 3	20-12-2023	15:58	22-12-2023	12:30	Suspected BTL	FORCED
Koradi Unit 6	21-12-2023	00:24		Continued.	Multiple test	FORCED
Koradi Unit-10	21-12-2023	22:46	22-12-2023	04:19	Flame Failure	FORCED
Chandrapur Unit 4	22-12-2023	07:25	23-12-2023	20:40	Boiler Tube Leakage	FORCED
Paras Unit 3	22-12-2023	16:19		Continued.	Governing System Problem.	FORCED
Khaparkheda Unit 4	23-12-2023	01:00		Continued.	Both ID Fan tripped	FORCED
Chandrapur Unit 6	23-12-2023	09:26		Continued.	Boiler Tube Leakage	FORCED
Bhusawal Unit 3	23-12-2023	18:50	24-12-2023	02:00	Loss of fuel	FORCED
Chandrapur Unit 4	23-12-2023	20:48	23-12-2023	22:12	Generator Excitation failed	FORCED
JPL Unit 1	24-12-2023	00:00		Continued.	Unavailability of Schedule	FORCED

Transmission Line Outages/Trippings from 18.12.2023 to 24.12.2023							
Name of Line	Date Trip	Time Trip	Date Sync	Time Sync	Reason	Outage Type	Voltage
BUS REACTOR (240 MVar) @ AKOLA 2	20-12-2023	12:15	20-12-2023	19:13	Bus Reactor changeover activity as per CEA guideline R- Ph reactor taken into service in place of B- Ph reactor at Akola SS	PO	765 KV
TIE BAY (705) OF ICT - 2 & BUS REACTOR @ KORADI 3	20-12-2023	12:15	20-12-2023	17:20	Annual maintenance of CB at Koradi- III SS	PO	765 KV
AKOLA II - EKTUNI CKT - 1	22-12-2023	02:23	22-12-2023	10:48	Trip on LR B-phase Differential protection	T	765 KV
MAIN BAY (707) OF TIRORA CKT - 2	22-12-2023	11:32	22-12-2023	19:50	Annual maintenance of CB at Koradi- III SS	PO	765 KV
CHANDRAPUR - PADGHE HVDC	12-12-2023	13:40	19-12-2023	22:03	To attend the Oil Leakage of Pole II R Phase	EO	500 KV
CHANDRAPUR - PADGHE POLE 1 & 2	23-12-2023	21:08			Annual Maintenance work Earth Electrode, DC Breaker, DC Isolator, Diagnostic Testing, line Maintenance etc.	PO	500 KV
STATION TRANSFORMER - 8A @ CHANDRAPUR SWITCHING SS	01-12-2023	13:22	19-12-2023	19:01	R-PHASE BUSHING CHECKING, REPLACEMENT AND ASSOCIATED WORKS.	PO	400 KV
CHANDRAPUR GCR - CHANDRAPUR 2 CKT 2	09-12-2023	12:57	21-12-2023	12:40	Scheme work of replacement of existing 0.5 ACSR conductor by HTLS conductor	PO	400 KV

Transmission Line Outages/Trippings from 18.12.2023 to 24.12.2023

Name of Line	Date Trip	Time Trip	Date Sync	Time Sync	Reason	Outage Type	Voltage
400/220/33 KV 600 MVA ICT - 4 @ PADGHE	16-12-2023	09:12	19-12-2023	23:47	1) Replacement of B-PH Unit due to PD and Increasing key gases presence of theme fault. 2) Bay Maint work 3) MTAMC work 4) filtration of R ph & Y ph. unit 5) attending Oil leakage R & Yph. unit from various point. 6) Replacement of Differential Relay. 7) If outage not approved for replacement, TBC charging permission required for four days for CB mechanism overhauling work on HV side.	PO	400 KV
JAIGAD - KARAD CKT - 1	16-12-2023	21:58	18-12-2023	08:29	HT FOR OVERVOLTAGE CONTROL	HT	400 KV
KHADKA-AURANGABAD (WALUJ)	17-12-2023	20:21	18-12-2023	09:48	H/T For voltage Management.	HT	400 KV
PADGHE - NAGOTHANE CKT - 1	18-12-2023	01:42	18-12-2023	08:37	HT for Overvoltage	HT	400 KV
400/11.5KV STATION TRANSFORMER - 2 @ TIRORA	18-12-2023	10:36	20-12-2023	17:51	TRANSFORMER PAINTING WORK	PO	400 KV
400/220/33 KV 315MVA ICT - 3 @ KARAD	18-12-2023	10:15	18-12-2023	18:24	COLD WELDING WORK	PO	400 KV
400/220KV 315 MVA ICT - 2 @ NEW KOYNA	18-12-2023	09:36	18-12-2023	19:20	Diagnostic testing & Relay testing work , Routine maint. Work & CTR Maintenance	PO	400 KV
400KV 125 MVAR BUS REACTOR @ AKOLA	18-12-2023	11:01	18-12-2023	15:18	Attend the oil leakage in on line DGA connection		400 KV
GT-8 @ KORADI-2	18-12-2023	11:24	18-12-2023	22:30	1) Diagnostice testing of Metering CTs 2) Routine Bay Maintenance work.		400 KV
JAIGAD - KARAD CKT - 2	18-12-2023	21:24	19-12-2023	09:31	Handtripped for Over Voltage	HT	400 KV
KHADKA-AURANGABAD (WALUJ)	18-12-2023	21:46	19-12-2023	09:42	H/T For voltage management.	HT	400 KV

Transmission Line Outages/Trippings from 18.12.2023 to 24.12.2023							
Name of Line	Date Trip	Time Trip	Date Sync	Time Sync	Reason	Outage Type	Voltage
KOLHAPUR (TALANDGE) - ALKUD	18-12-2023	14:30	18-12-2023	21:57	Q/m work.	PO	400 KV
400 KV AKOLA - AURANGABAD(PG) CKT -2	19-12-2023	10:02	19-12-2023	18:44	For to OPGW Stringing work (diamond arrangement) at Aurangabad zone	PO	400 KV
400/220 KV 3X105 MVA ICT - 1 @ NAGOTHANE	19-12-2023	10:26	19-12-2023	20:00	For Diagnostic testing work	PO	400 KV
400KV MAIN BAY 407 GT 2 @ NANDGAONPETH	19-12-2023	07:10	19-12-2023	18:07	Protection trial of GT#2, UAT#2A & 2B Like, body protection, Protection trip through master relay, Rotor earth fault & Stator Earth fault protection checking & 407Bay Isolator maintenance planned & shall be carried out.	PO	400 KV
400KV TIE BAY 408 GT 2 -AKOLA CKT 1 @ NANDGAONPETH	19-12-2023	07:10	19-12-2023	18:07	Protection Trail of GT#2, UAT@2A & 2B like body protection, Tripping through master relay, Stator earth fault protection check, rotor earth fault protection check, & 408 Bay Isolator Maintenance planned & Shall be carried out.	PO	400 KV
DHULE - SSNNL CKT - 2	19-12-2023	10:05	21-12-2023	15:23	Emergency outage For replacement of B ph CT of 400KV Dhule-SSNNL-2 line due to heavy oil leakage observed in B ph CT of 400KV Dhule-SSNNL-2 line at 400KV Dhule end	EO	400 KV
JAIGAD - KARAD CKT - 1	19-12-2023	20:11	20-12-2023	09:43	H/T on Overvoltage	HT	400 KV
KHADKA-AURANGABAD (WALUJ)	19-12-2023	21:46	20-12-2023	08:18	H/T For Voltage management.	HT	400 KV
DHULE - KHANDWA CKT - 2	20-12-2023	02:47	20-12-2023	03:26	Tripped on distance protection at Dhule end only.	T	400 KV

Transmission Line Outages/Trippings from 18.12.2023 to 24.12.2023							
Name of Line	Date Trip	Time Trip	Date Sync	Time Sync	Reason	Outage Type	Voltage
PADGHE - NAGOTHANE CKT - 1	20-12-2023	10:10	20-12-2023	20:43	1.Replacement of Distance & Over Voltage Relay. 2.Bay Maintenance work. 3.Diagonostic Testing work. 4.MTAMC Work.	PO	400 KV
400 KV AKOLA - AURANGABAD(PG) CKT -1	20-12-2023	11:00	20-12-2023	19:43	For to OPGW Stringing work (diamond arrangement) at Aurangabad zone	PO	400 KV
400/220 KV 3X105 MVA ICT - 2 @ NAGOTHANE	20-12-2023	11:03	20-12-2023	19:39	For Diagnostic testing work	PO	400 KV
400KV-PARLI NEW-PARLI-M-2	20-12-2023	12:11			For ongoing project of "Upgradation of 400kV Line Bays (02 Nos) of Parli (PG) I&II at Parli (MSETCL) from existing current rating of 2000A to 3150A to suit the reconductoring with Twin HTLS�	HT	400 KV
KHADKA- DEEPNAGAR CKT 2	20-12-2023	16:36	20-12-2023	20:50	For point to point testing of visibility of existing bay signals with LD Centre.	PO	400 KV
220 KV KRUSHNOOR - KUMBHARGAON (400 KV) CKT -1	21-12-2023	11:24	21-12-2023	14:05	Annual bay maintenance and ct tan-d test.	HT	400 KV
220 KV KRUSHNOOR - KUMBHARGAON (400 KV) CKT -2	21-12-2023	14:35	21-12-2023	17:50	Annual bay maintenance and ct tan-d test.	HT	400 KV
400/11.5KV STATION TRANSFORMER - 3 @ TIRORA	21-12-2023	09:44	23-12-2023	17:51	TRANSFORMER PAINTING WORK	PO	400 KV
400kv BHUSAWAL S/S	21-12-2023	12:17	21-12-2023	19:27	For point to point testing for visibility of signals of existing bays with Id centre.	HT	400 KV
EKTUNI - BABLESHWAR CKT - 2	21-12-2023	11:54	21-12-2023	19:42	Restranging of Earth wire between span 275 to 286	PO	400 KV
JAIGAD - KARAD CKT - 2	21-12-2023	00:16	21-12-2023	10:05	H/T on overvoltage	HT	400 KV
KHADKA- DEEPNAGAR CKT 2	21-12-2023	12:17	21-12-2023	19:27	For point to point testing for visibility of signals of existing bays with LD Centre	PO	400 KV

Transmission Line Outages/Trippings from 18.12.2023 to 24.12.2023							
Name of Line	Date Trip	Time Trip	Date Sync	Time Sync	Reason	Outage Type	Voltage
KHADKA-AURANGABAD (WALUJ)	21-12-2023	00:17	21-12-2023	08:21	H/T on overvoltage	HT	400 KV
KHADKA-AURANGABAD (WALUJ)	21-12-2023	23:46	22-12-2023	08:34	H/T on overvoltage	HT	400 KV
LONIKAND II - LONIKAND I (INTERCONNECTOR) - 2	21-12-2023	14:37			DT Work & Bay Maintenance	PO	400 KV
MAIN BAY (413) OF GT - 8 @ CHANDRAPUR SWITCHING SS	21-12-2023	12:40	21-12-2023	17:00	Diagnostic testing and allied maintenance work	PO	400 KV
400/220/33 KV 500MVA ICT - 2 @ KHAPARKHEDA	22-12-2023	11:19	22-12-2023	20:22	For attending 33 kV Side PT Oil Leakage & Rutine Maintenance Work	PO	400 KV
DEEPNAGAR - THAPTI TANDA	22-12-2023	11:14	22-12-2023	18:33	For Point to point testing of visibility of bay signals with LD centre.	PO	400 KV
JAIGAD - KARAD CKT - 1	22-12-2023	00:03	22-12-2023	10:28	H/T on overvoltage	HT	400 KV
JAIGAD - KARAD CKT - 2	22-12-2023	23:11	23-12-2023	09:21	HT due to Overvoltage	HT	400 KV
KHARGHAR - VIKHROLI GIS CKT - 1	22-12-2023	15:56	22-12-2023	18:36	400KV CT (Y & B Phase) Oil Leakage Inspection & Cleaning work.	EO	400 KV
MAIN BAY (415) OF PADGHE PG CKT - 1 @ KUDUS	22-12-2023	11:49	22-12-2023	15:28	AMP of 415 bay at MSETCL Kudus	PO	400 KV
MAIN BUS - 2 @ AKOLA	22-12-2023	11:38	22-12-2023	19:37	Routine and isolator maintenance & testing work	PO	400 KV
TIE BAY (414) OF GT-8 @ CHANDRAPUR SWITCHING SS	22-12-2023	10:24	22-12-2023	15:52	Diagnostic testing and allied maintenance work	PO	400 KV
220 KV KHADKA (400 KV) - CHALISGAON CKT -3	23-12-2023	10:11	23-12-2023	17:38	Replacement of Flash over insulator string	PO	400 KV
220 KV WALUJ (400 KV) -PADEGAON CKT - I	23-12-2023	10:11	23-12-2023	14:40	R phase one string is flash over and fallen on the ground		400 KV
400/220/33KV SPARE ICT @ KORADI 2	23-12-2023	10:23	23-12-2023	16:21	for demonstration of SFRA Kit.	PO	400 KV
400220kv 167MVA SPARE ICT @ DEEPNAGAR	23-12-2023	11:01	23-12-2023	17:30	For point to point testing for visibility of signals of existing bays with LD Centre	PO	400 KV

Transmission Line Outages/Trippings from 18.12.2023 to 24.12.2023							
Name of Line	Date Trip	Time Trip	Date Sync	Time Sync	Reason	Outage Type	Voltage
CHANDRAPUR GCR - CHANDRAPUR 2 CKT 1	23-12-2023	08:10	23-12-2023	18:38	For replacement of old connectors of LA, CVT, CT Wave trap by New connectors compatible to HTLS conductors at both end substation.	PO	400 KV
GT - 6 @ KORADI-1	23-12-2023	09:55	23-12-2023	17:03	For replacement of 29D isolator mechanism box , alignment of isolator by agency.Nut bolt tightening works of bay.Routine isolator maintenance works. As GTR-6 unit is withdrawn by KTPS for 5 days from 21.12.2023 00:23Hrs to 25.12.2023 24:00Hrs.		400 KV
PADGHE (GIS) PG - KUDUS CKT - 2	23-12-2023	11:10	23-12-2023	18:34	AMP of 418L at MSETCL Kudus substation	PO	400 KV
JAIGAD - KARAD CKT - 1	24-12-2023	20:57			H/T For Voltage management.	HT	400 KV
KHADKA-AURANGABAD (WALUJ)	24-12-2023	20:03			H/T For voltage management.	HT	400 KV
SOLAPUR PG - ALKUD	24-12-2023	21:02			Line tripped on distance protection.	T	400 KV
VERSOVA - GHODBUNDER	09-12-2023	17:28	18-12-2023	11:52	To attend SF6 low pressure alarm on CB 452.	EO	220 KV
APTA - KALWA	12-12-2023	15:21	18-12-2023	19:26	For charging of newly proposed 220/22kV Print House S/stn by LILO on 220kV APTA - KALWA line	PO	220 KV
AAREY - AEML SAKI CKT - 2	14-12-2023	07:13	18-12-2023	19:58	Commissioning of new CRP, Under MERC approved AIS to GIS conversion Project.	PO	220 KV
APTA - KALWA	14-12-2023	14:19	18-12-2023	19:26	For erection of inline new 03 nos. of mono pole tower & stringing of 03 nos. of conductor between loc no. 656 to 659.		220 KV
CHITEGAON- CHITEPIMPALGAON (PG) CKT - 2	18-12-2023	11:32	18-12-2023	17:56	Stringing of OPGW	PO	220 KV

Transmission Line Outages/Trippings from 18.12.2023 to 24.12.2023

Name of Line	Date Trip	Time Trip	Date Sync	Time Sync	Reason	Outage Type	Voltage
MIRAJ - ICHALKARANJI	18-12-2023	08:00	18-12-2023	19:13	220KV Miraj Line kept off for proper load management at 220kv Tilawani S/S during outage period of outage on 220kv Talandage- Tilawani-I & 220kv Talandage-Tilawani-II	PO	220 KV
MUDSHINGI- BELEWADI LINE	18-12-2023	10:05	18-12-2023	14:19	LMU replacement work by PAC division at Mudshingi end	PO	220 KV
PIRANGUT - HINJAWADI 2	18-12-2023	23:29	19-12-2023	06:37	H/T For load management	HT	220 KV
SAHARA-URSE	18-12-2023	23:10	19-12-2023	07:13	H/T For load management	HT	220 KV
SHIVAJINAGAR-MALEGAON	18-12-2023	16:32	18-12-2023	18:10	Emergency outage for removing tad patri	HT	220 KV
TALANDGE - ICHALKARANJI 1	18-12-2023	08:22	18-12-2023	19:19	Stringing of Missing earthwire from T.L 31 to 39	PO	220 KV
TALANDGE - ICHALKARANJI 2	18-12-2023	08:22	18-12-2023	19:20	Stringing of Missing earthwire from T.L 31 to 39	PO	220 KV
TALEGAON (AMBI)-TALEGAON (PG) CKT 2	18-12-2023	23:40	19-12-2023	07:07	H/T For Emergency outage at PG end.	HT	220 KV
220 KV PARLI -U-8 - PARBHANI CKT	18-12-2023	10:05	18-12-2023	17:53	Crane movement for CB replacement	PO	220 KV
220/100 KV 200 MVA ICT 1 @ KALWA	18-12-2023	11:17	20-12-2023	17:30	LV CB pole Overhauling work .	PO	220 KV
220/132 KV 100 MVA ICT 2 @ BALAPUR	18-12-2023	09:18	18-12-2023	15:20	IR, Capacitance and tan delta measurement of CT and ICT, Auxilliary protection testing of ICT. IR, CRM and timing measurement of CB at 220kv Balapur Ss.	PO	220 KV
220/132 KV 200 MVA ICT 1 @ BEED	18-12-2023	11:00	18-12-2023	14:12	Attending oil leakage		220 KV
220/132 KV 200 MVA ICT 1 @ BEED	18-12-2023	15:35	18-12-2023	16:13	PDR Operated.	T	220 KV
220/132/11 KV 200 MVA ICT 2 @ AMRAVATI	18-12-2023	09:15	18-12-2023	17:24	ICT Painting work.	PO	220 KV
250 MVA ICT-4 @ TROMBAY	18-12-2023	12:45	18-12-2023	17:25	TREE TRIMMING IN VICINITY	PO	220 KV
250 MVA ICT-5 @ TROMBAY	18-12-2023	12:45	18-12-2023	17:25	TREE TRIMMING IN VICINITY	PO	220 KV

Transmission Line Outages/Trippings from 18.12.2023 to 24.12.2023							
Name of Line	Date Trip	Time Trip	Date Sync	Time Sync	Reason	Outage Type	Voltage
BORIVALI - BOISAR II LINE	18-12-2023	08:33	18-12-2023	17:53	Replacement of old hardware at critical locations.	PO	220 KV
GHODBUNDER - MSETCL BOISAR	18-12-2023	08:32	18-12-2023	17:41	Replacement of old hardware at critical locations	PO	220 KV
KEKATNIMBHORA - CHALISGAON CKT	18-12-2023	09:12	18-12-2023	18:09	Replacement of flashover disc and Replacement piece of the damaged conductor.	PO	220 KV
MAIN BUS @ NIWALI	18-12-2023	09:26	18-12-2023	18:45	1. 220KV Bus PID suspected insulator replacement & cold line cleaning of 220KV bus. 2. Routine maintenance work. 3. 220KV Bus PT diagnostic testing	PO	220 KV
MAIN BUS @ TILWANI	18-12-2023	08:22	18-12-2023	19:13	"1) Maintenance of 220 kV/110KV PT and all 220 KV Main Bus isolators aligement & maintenance work (inc-Line & T/F bays). 2) 220KV Main Bus section Isolator Hot spot attending work. 3) Insulator string cleaning work of main bus & allied. 4) 33KV Overhauling & Maintenance work. 5) 220/110KV Busbar Relay Testing Work. 6) Retrofitting of 220KV Line Bay Backup Relay."	PO	220 KV
NERLE- POPHALI	18-12-2023	11:15	18-12-2023	17:50	Diagnostic Testing & Quarterly Maintenance Work	PO	220 KV
PHALTAN MIDC - CSSK BHAVANI NAGAR	18-12-2023	11:02	18-12-2023	17:42	Cold line washing and cleaning of insulator from local no-56 to 106.	PO	220 KV
PHALTAN MIDC - CSSK BHAVANI NAGAR	18-12-2023	11:02	18-12-2023	17:42	Cold line washing and cleaning of insulator from local no-56 to 106.	PO	220 KV
TROMBAY - VIKHROLI (GIS) CKT - 2	18-12-2023	00:39	18-12-2023	08:18	LA REPLACEMENT AND DIFFERENTIAL STABILITY TEST	PO	220 KV

Transmission Line Outages/Trippings from 18.12.2023 to 24.12.2023							
Name of Line	Date Trip	Time Trip	Date Sync	Time Sync	Reason	Outage Type	Voltage
CHITEGAON- CHITEPIMPALGAON (PG) CKT - 1	19-12-2023	10:23	19-12-2023	16:22	Stringing of OPGW Work	PO	220 KV
CHITEGAON- CHITEPIMPALGAON (PG) CKT - 1	19-12-2023	10:23	19-12-2023	16:22	Stringing of OPGW work	PO	220 KV
GHATGHAR - JINDAL	19-12-2023	10:55	19-12-2023	18:00	Ghatghar Line Gantry disc insulator string replacement.	PO	220 KV
LONAND-BARAMATI	19-12-2023	10:05	19-12-2023	15:51	Cold line washing and cleaning of insulator strings from Loc. 33-71 and 4-24 LILO portion.	PO	220 KV
WANI-WARORA 1	19-12-2023	13:13	19-12-2023	17:56	Tan Delta Measurement	PO	220 KV
220 KV PARLI -U-8 - PARBHANI CKT	19-12-2023	11:04	19-12-2023	19:30	Replacement of 220KV Circuit Breaker	PO	220 KV
220/132 KV 100 MVA ICT-1	19-12-2023	09:31	19-12-2023	14:31	Measurement of Busing and Tan Delta	PO	220 KV
220/132/11 KV 200 MVA ICT 2 @ AMRAVATI	19-12-2023	09:23	19-12-2023	17:25	ICT painting work	PO	220 KV
AUXILIARY BUS @ PHALTAN MIDC- 220 KV	19-12-2023	11:25	19-12-2023	14:15	Jumpering work of 220kV TS Wind Line Bay	PO	220 KV
BADNERA - NANDGAON PETH	19-12-2023	10:15	19-12-2023	12:00	Replacement of Flash over Disc	PO	220 KV
KADEGAON-MIRAJ	19-12-2023	10:20	19-12-2023	13:12	Diagnostic Testing Work	PO	220 KV
KARAD - WATHAR	19-12-2023	09:10	19-12-2023	18:11	For stringing of Earth wire at tower loc no.99 to106.	PO	220 KV
KARAD -MUDSHINGI CKT- 4	19-12-2023	08:52	19-12-2023	18:33	For stringing of Earth wire at tower loc no.99 to106.	PO	220 KV
TROMBAY - CARNAC - 7	19-12-2023	23:05	20-12-2023	04:23	FOR ATTENDING HOT SPOT AT A PHASE h FRAME GANTRY , TROMBAY END	EO	220 KV
220/132/11KV 200 MVA ICT 2 @ MALINAGAR	20-12-2023	15:05	20-12-2023	18:50	Outage is required for Diagnostic Testings - Tan delta of transformer winding and bushing.	PO	220 KV
ACCIL - APTA	20-12-2023	10:15	20-12-2023	19:39	Providing of twin jumpering from Loc no. 523 to 584 on all cut point towers	PO	220 KV

Transmission Line Outages/Trippings from 18.12.2023 to 24.12.2023							
Name of Line	Date Trip	Time Trip	Date Sync	Time Sync	Reason	Outage Type	Voltage
EKLAHARE (GCR) - AIROLI KNOW PARK	20-12-2023	10:07	20-12-2023	17:21	For replacement of Flashover string at loc no.163,178,180 and route line maintenance work .	PO	220 KV
MALINAGAR - TEMBHURNI	20-12-2023	11:05	20-12-2023	13:39	Quareately Maintenance	PO	220 KV
MIRAJ - ICHALKARANJI	20-12-2023	17:04	20-12-2023	18:49	220KV Miraj Line kept off for proper load management at 220kv Tilawani S/S during outage period of outage on 220kv Talandage- Tilawani-II	EO	220 KV
ONGC URAN - JNPT	20-12-2023	12:00	20-12-2023	16:34	For Attending Breaker Y ph pole Closing Coil Problem.	PO	220 KV
TALANDGE - ICHALKARANJI 2	20-12-2023	17:08	20-12-2023	18:44	Attending hotspot at T L No-45 Rph (90C)	EO	220 KV
220 KV KAULEWADA-KORADI 2 CKT - I	20-12-2023	04:11	20-12-2023	18:52	Distance Protection	T	220 KV
220 KV PARLI -U-8 - PARBHANI CKT	20-12-2023	12:57	20-12-2023	15:45	Testing work	PO	220 KV
220/132 KV 200 MVA ICT 1 @ DHULE	20-12-2023	18:21	20-12-2023	19:12	Bus Bar Protection Operated	T	220 KV
220/132 KV 200MVA ICT 2 @ DHULE	20-12-2023	18:21	20-12-2023	19:13	Bus Bar Protection Operated	T	220 KV
220/132KV 150MVA ICT - 1 @ MALINAGAR	20-12-2023	12:16	20-12-2023	14:40	Outage is required for Diagnostic Testings - Tan delta of transformer winding and bushing.	PO	220 KV
220KV BUS SECTION BAY @ PEDAMBE	20-12-2023	11:25	20-12-2023	14:50	FOR BAY P/M WORK	PO	220 KV
220KV PARANDA -BARSHI CKT	20-12-2023	14:22	20-12-2023	17:40	Quarterly Maintenance	PO	220 KV
BUS COUPLER @ SOUTH SOLAPUR	20-12-2023	11:26	20-12-2023	14:45	Quarterly maintenance	PO	220 KV
GOREGAON - AAREY CKT - 1	20-12-2023	04:48	20-12-2023	11:54	Shifting of Link Box for erection of GIS Shed on New GIS at Aarey	PO	220 KV
MAIN BUS - 1 @ PHALTAN MIDC- 220 KV	20-12-2023	11:30	20-12-2023	13:15	Jumpering work of 220kv TS Wind line bay	PO	220 KV

Transmission Line Outages/Trippings from 18.12.2023 to 24.12.2023							
Name of Line	Date Trip	Time Trip	Date Sync	Time Sync	Reason	Outage Type	Voltage
MAIN BUS- A @ BAPGAON	20-12-2023	11:00	20-12-2023	18:22	For 220kV Bus Coupler Bay 'A' Bus Isolator Maintenance work & 220kV TBC Bay 'A' Bus Isolator Maintenance work And A bus PT Testing work.	PO	220 KV
PARANDA-BARSHI	20-12-2023	14:17	20-12-2023	17:40	Maintenance work	PO	220 KV
TROMBAY CARNAC - 5	20-12-2023	10:55	20-12-2023	19:25	Project Work-OPGW stringing in span 3 to Gantry structure-Trombay (Project work - 96 core OPGW replacement work).	PO	220 KV
GHATODI-NANDED	21-12-2023	09:17	21-12-2023	18:02	For overcrossing work of 220kv dc kumbhargaoon- kurunda ckt 1 and 2 pkg a loc number 101-102 on existing 220 ghatodi nanded.	HT	220 KV
JEJURI (400 KV)-JEJURI- I	21-12-2023	11:44	21-12-2023	15:42	Biannual CB Testing work	PO	220 KV
JEJURI (400 KV)-JEJURI- II	21-12-2023	15:56	21-12-2023	17:37	Biannual CB Testing work	PO	220 KV
KHAPARKHEDA - BUTIBORI 3	21-12-2023	08:03	21-12-2023	17:07	Stringing work between loc no 28- loc no 29 of 220kv koradi ii to butibori iii dc on mc TL.	T	220 KV
KHAPARKHEDA- BUTIBORI	21-12-2023	07:46	21-12-2023	16:52	Stringing work between loc no 28- loc no 29 of 220kv koradi ii to butibori iii dc on mc TL.	T	220 KV
KUMBHARGAON-BHOKAR CKT 1	21-12-2023	10:32	21-12-2023	16:23	Flashover disc replacement at loc.06 top phase and loc 87 top phase.	HT	220 KV
MALEGAON-SATANA	21-12-2023	14:14	22-12-2023	02:59	Tripped on distance protection	T	220 KV
MIRAJ - MHAISHAL	21-12-2023	10:35	21-12-2023	11:21	Diagnostic Testing Work	PO	220 KV
MUMEWADI -HALKARNI 2 LINE	21-12-2023	12:56	21-12-2023	17:30	Line tripped on distance protection.	HT	220 KV
SADAWAGHAPUR KARAD CKT 1	21-12-2023	10:15	21-12-2023	17:01	Replacement of Jump (R 7 Y Ph) at Loc No DP 1	PO	220 KV
TAMBATI - ADLABS	21-12-2023	11:38	21-12-2023	17:33	New Distance relay retrofitting work of GE Make at Adlabs End	PO	220 KV

Transmission Line Outages/Trippings from 18.12.2023 to 24.12.2023							
Name of Line	Date Trip	Time Trip	Date Sync	Time Sync	Reason	Outage Type	Voltage
URSE - TALEGAON (AMBI) CKT 2	21-12-2023	09:16	21-12-2023	09:45	220kV Talegaon Ckt-2 to be H/T at both ends, and Closing of 29C Auxiliary Bus Isolator of 220kV Chinchwad-1 line & 220kV Talegaon ckt-2 line for bunching through Auxiliary Bus at 220kV Urse & restoration after completion of 220kV Main Bus sec-1 outage.	PO	220 KV
220/132 KV 100 MVA ICT 1 @ SOUTH SOLAPUR	21-12-2023	09:23	21-12-2023	18:05	Outage is required for Attending leakage on CFT (Core frame tank) point on main tank & OLTC Overhauling	PO	220 KV
220/33 KV 50MVA T/F - 2 @ MIRAJ	21-12-2023	12:20	21-12-2023	13:40	Diagnostic Testing work	PO	220 KV
DAHANU - GHODBUNDER CKT - 1	21-12-2023	08:11			(1) AT DAHANU-Replacement of Bay marshalling box, LA Replacement Bay 08 Overhauling of Isolator -C Breaker PM PM & tan delta testing of Line CT / CVT. (2)High speed train project work by Project Team	PO	220 KV
MAIN BUS SECTION - 1 @ URSE	21-12-2023	08:53	21-12-2023	21:37	Work: 1) Attending SF6 Gas Leakage of Hybrid Pass at 220kV Urse S/stn. 2) Replacement of 220kV TBC Bus Isolator Urse S/stn.	PO	220 KV
NANDED CITY-FLAGSHIP	21-12-2023	10:23	21-12-2023	17:44	Half yearly Maint. Work	PO	220 KV
NEW KOYNA - PEDAMBE	21-12-2023	09:27	21-12-2023	19:04	Bay P/M work	PO	220 KV
GHATGHAR - BAPGAON	22-12-2023	11:52	22-12-2023	14:04	For Black start mock drill at Ghatghar HPS.	PO	220 KV
NAGOTHANE - ACCIL	22-12-2023	12:29	22-12-2023	17:36	Twin jumpering work at all cut point locations.	PO	220 KV

Transmission Line Outages/Trippings from 18.12.2023 to 24.12.2023							
Name of Line	Date Trip	Time Trip	Date Sync	Time Sync	Reason	Outage Type	Voltage
PADGHE - TEMGHAR - 1	22-12-2023	14:45	23-12-2023	03:29	1. Diagnostic testing work of CT, CB, CC 2. Bay maintenance work 3. Attending hotspot (If any) 4.replacement of distance protection relays	PO	220 KV
PADGHE - WADA	22-12-2023	10:48	22-12-2023	14:00	1.Hot Spot attaining work (Temperature: 85± C) and Bay Maintenance work at 220kV Wada S/S. 2.Replacement of Y-ph broken disc insulator by long rod Porcelain insulator by L (M) S/Dn. Boisar.	PO	220 KV
220/100 KV 100 MVA ICT 1 @ TALOJA	22-12-2023	09:55	22-12-2023	13:12	For attending Oil Leakage from Top Body of ICT.	PO	220 KV
220/100 KV 200 MVA ICT 3 @ APTA	22-12-2023	10:02	22-12-2023	17:40	"1. Diagnostic testing work (CT, winding, bushing C & Tan delta testing, PI & IR testing) 2.Bay maintenance work 3.Annual Relay testing work 4. RMW "	PO	220 KV
220/132 KV 100MVA ICT 2 @ SOUTH SOLAPUR	22-12-2023	08:45	22-12-2023	17:01	Outage is required for OLTC Overhauling	PO	220 KV
220/132-110 KV 100 MVA ICT 1	22-12-2023	09:55	22-12-2023	16:52	OLTC Overhauling & Diagnostic Testing Work	PO	220 KV
220/22 KV 50 MVA PTR 1 @ ANANDNAGAR	22-12-2023	09:00	22-12-2023	17:55	1) Isolator maintenance 2) Diagnostic testing 3) R&M work	PO	220 KV
BUS SETION - 2 @ KANDALGAON	22-12-2023	13:14	22-12-2023	13:44	Removing of 220 kV bus side jumper of TF-1 HV Isolator from hot line team for the work of replacement of old RCC support structure of TF-1 HV Isolator by lattice type support structure	PO	220 KV

Transmission Line Outages/Trippings from 18.12.2023 to 24.12.2023							
Name of Line	Date Trip	Time Trip	Date Sync	Time Sync	Reason	Outage Type	Voltage
BUSBAR PROTECTION @ BABHALESHWAR	22-12-2023	13:58	22-12-2023	17:58	220kv busbar protection system dc supply fail	EO	220 KV
KARAD - VITA CKT- 1	22-12-2023	06:54	22-12-2023	12:13	Cold Washing of Insulator Strings	PO	220 KV
VANKUSWADE - AJINKYATARA	22-12-2023	12:30	22-12-2023	18:05	1.Replacement damaged Y ph CT Jump 2.Quarterly Maintenance Work	PO	220 KV
VITA - HIWARWADI	22-12-2023	06:54	22-12-2023	12:13	Cold Washing of Insulator String	PO	220 KV
ACCIL - APTA	23-12-2023	09:28	23-12-2023	14:45	Providing of twin jumpering from Loc no. 523 to 584 on all cut point towers	PO	220 KV
PADGHE - TEMGHAR - 1	23-12-2023	04:25	23-12-2023	04:52	HT for attending busbar block alarm	HT	220 KV
TROMBAY - KALWA	23-12-2023	00:49	23-12-2023	04:29	Wave trap replacement work	EO	220 KV
220/132 KV 200 MVA ICT 1 @ DHULE	23-12-2023	09:15	23-12-2023	12:05	Oil leakage and Routine Maintenance work	PO	220 KV
220/132/11 KV 200 MVA ICT 1 @ AMRAVATI	23-12-2023	09:00	23-12-2023	16:49	ICT Painting work	PO	220 KV
220/33 KV 25 MVA PTR 2 @ AHMEDNAGAR	23-12-2023	11:16	23-12-2023	17:18	Quaterly maintenance ,errection of L.V 33kv L.As Attending red hots	PO	220 KV
AMRAPUR - TAPTITANDA CKT - 2	23-12-2023	12:33	23-12-2023	18:36	Outage is required for to carried out quarterly maintenance on 220 kv thaptitanda ckt 2 Bay at 220kv Amrapur S/stn	PO	220 KV
BUS COUPLER @ VERSOVA	23-12-2023	11:20	23-12-2023	14:48	FOR TESTING	PO	220 KV
INTERCONNECTOR @ KALWA	23-12-2023	05:05	23-12-2023	07:01	Replacement of damage Y-Phase jumper between CT & (52C) CB.	EO	220 KV
TBC @ MIRAJ	23-12-2023	12:10	23-12-2023	13:09	Diagnostic Testing of CB	PO	220 KV
110KV GROUP BREAKER-1 @ TROMBAY	17-12-2023	06:46	18-12-2023	03:05	110 KV BUS-3 OUTAGE AT TROMBAY	PO	110 KV
AMBERNATH - KALYAN CKT - 2	18-12-2023	10:16	18-12-2023	13:45	Closer inspection in Kalyan Section	PO	110 KV
KHOPOLI - BHOKARPADA	23-12-2023	11:53	23-12-2023	17:00	FOR R/M	PO	110 KV