

State Load Despatch Center,Airoli (MSETCL)
Power System Position from 20/Feb/2017 to 26/Feb/2017

Supply Position During Morning Peak (MW)

Date	Time	MSGENCO				Central Sector Receipt	Wind	CPP	SOLAR	TPCL Exch.	MSEDCL Cateder Demand	Load Shedding(LS)	MSEDCL Demand (Incl. LS)	TPCL Gen.	R-INFRA Gen.	State Demand Met	State Demand (Incl. LS)	Freq.
		THM	HYDRO	GAS	Total													
		MW	MW	MW	MW	MW	MW	MW	MW	MW	MW	MW	MW	MW	MW	MW	MW	Hzs
20/02/2017	12 Hrs	6603	1614	424	8641	7346	213	3582	185	-1137	18830	0	18830	1358	493	21818	21818	49.90
21/02/2017	12 Hrs	6573	579	435	7587	7308	550	3618	207	-828	18442	0	18442	1377	501	21148	21148	49.94
22/02/2017	12 Hrs	5420	1956	293	7669	8183	95	3049	194	-1025	18165	656	18821	1377	493	21060	21716	49.93
23/02/2017	12 Hrs	5750	1646	418	7814	7814	160	3502	177	-1011	18456	21	18477	1361	499	21327	21348	49.94
24/02/2017	12 Hrs	6076	996	409	7481	7611	147	3590	201	-864	18166	0	18166	1360	509	20899	20899	49.97
25/02/2017	12 Hrs	6489	1201	265	7955	7333	276	3521	196	-927	18354	0	18354	1209	503	20993	20993	49.92
26/02/2017	12 Hrs	6262	1017	419	7698	7333	202	3546	199	-738	18240	0	18240	916	504	20398	20398	49.96
Maximum		6603	1956	435	8641	8183	550	3618	207	-738	18830	656	18830	1377	509	21818	21818	49.97
Minimum		5420	579	265	7481	7308	95	3049	177	-1137	18165	0	18166	916	493	20398	20398	49.90
Average		6168	1287	380	7835	7561	235	3487	194	-933	18379	97	18476	1280	500	21092	21189	49.94

Supply Position During Day Peak (MW)

Date	Time	MSGENCO				Central Sector Receipt	Wind	CPP	SOLAR	TPCL Exch.	MSEDCL Cateder Demand	Load Shedding(LS)	MSEDCL Demand (Incl. LS)	TPCL Gen.	R-INFRA Gen.	State Demand Met	State Demand (Incl. LS)	Freq.
		THM	HYDRO	GAS	Total													
		MW	MW	MW	MW	MW	MW	MW	MW	MW	MW	MW	MW	MW	MW	MW	MW	Hzs
20/02/2017	13 Hrs	6478	1345	423	8246	7396	235	3561	198	-1158	18478	0	18478	1326	500	21462	21462	49.96
21/02/2017	13 Hrs	6584	497	438	7519	7190	467	3608	196	-798	18182	0	18182	1373	506	20859	20859	49.93
22/02/2017	16 Hrs	5916	1600	411	7927	7734	300	3177	135	-996	18277	149	18426	1281	500	21054	21203	49.96
23/02/2017	13 Hrs	5780	1631	408	7819	7605	82	3486	197	-1021	18168	21	18189	1327	506	21022	21043	50.00
24/02/2017	13 Hrs	6082	924	417	7423	7838	86	3585	194	-1040	18086	0	18086	1151	510	20787	20787	49.97
25/02/2017	13 Hrs	6338	808	271	7417	7516	202	3533	206	-927	17947	0	17947	1201	507	20582	20582	49.92
26/02/2017	13 Hrs	6300	751	399	7450	7665	131	3517	208	-734	18237	0	18237	916	506	20393	20393	49.97
Maximum		6584	1631	438	8246	7838	467	3608	208	-734	18478	149	18478	1373	510	21462	21462	50.00
Minimum		5780	497	271	7417	7190	82	3177	135	-1158	17947	0	17947	916	500	20393	20393	49.92
Average		6211	1079	395	7686	7563	215	3495	191	-953	18196	24	18221	1225	505	20880	20904	49.96

Supply Position During Evening Peak (MW)

Date	Time	MSGENCO				Central Sector Receipt	Wind	CPP	SOLAR	TPCL Exch.	MSEDCL Cateder Demand	Load Shedding(LS)	MSEDCL Demand (Incl. LS)	TPCL Gen.	R-INFRA Gen.	State Demand Met	State Demand (Incl. LS)	Freq.
		THM	HYDRO	GAS	Total													
		MW	MW	MW	MW	MW	MW	MW	MW	MW	MW	MW	MW	MW	MW	MW	MW	Hzs
20/02/2017	19 Hrs	6040	311	441	6792	6705	653	3533	0	-1313	16370	0	16370	957	387	19027	19027	49.96
21/02/2017	20 Hrs	5545	478	447	6470	6749	746	3221	0	-1030	16156	0	16156	1068	386	18640	18640	49.97
22/02/2017	20 Hrs	6124	867	363	7354	6512	289	3261	0	-891	16525	0	16525	1258	509	19183	19183	49.98
23/02/2017	20 Hrs	5939	546	435	6920	6377	326	3555	0	-870	16308	0	16308	1299	511	18988	18988	49.98
24/02/2017	20 Hrs	6464	325	423	7212	5741	130	3534	0	-1106	15511	0	15511	995	456	18068	18068	50.01
25/02/2017	20 Hrs	5893	354	418	6665	6441	220	3589	0	-1060	15855	0	15855	1117	385	18417	18417	49.96
26/02/2017	20 Hrs	5570	716	427	6713	6550	85	3573	0	-1138	15783	0	15783	695	386	18002	18002	49.99
Maximum		6464	867	447	7354	6749	746	3589	0	-870	16525	0	16525	1299	511	19183	19183	50.01
Minimum		5545	311	363	6470	5741	85	3221	0	-1313	15511	0	15511	695	385	18002	18002	49.96
Average		5939	514	422	6875	6439	350	3467	0	-1058	16073	0	16073	1056	431	18618	18618	49.98

Supply Position During Night Off Peak (MW)

Date	Time	MSGENCO				Central Sector Receipt	Wind	CPP	SOLAR	TPCL Exch.	MSEDCL Cateder Demand	Load Shedding(LS)	MSEDCL Demand (Incl. LS)	TPCL Gen.	R-INFRA Gen.	State Demand Met	State Demand (Incl. LS)	Freq.
		THM	HYDRO	GAS	Total													
		MW	MW	MW	MW	MW	MW	MW	MW	MW	MW	MW	MW	MW	MW	MW	MW	Hzs
20/02/2017	3 Hrs	5854	120	457	6431	5480	105	3350	0	-734	14632	0	14632	633	386	16385	16385	50.00
21/02/2017	4 Hrs	5653	137	458	6248	5531	699	3301	0	-656	15123	0	15123	699	387	16865	16865	49.99
22/02/2017	4 Hrs	5901	128	455	6484	5695	335	3034	0	-511	15037	0	15037	701	387	16636	16636	49.96
23/02/2017	4 Hrs	5713	90	451	6254	5185	567	3586	0	-482	15110	0	15110	702	386	16680	16680	49.98
24/02/2017	3 Hrs	5742	111	435	6288	5326	548	3554	0	-542	15174	0	15174	698	388	16802	16802	49.99
25/02/2017	4 Hrs	5857	145	434	6436	5172	511	3493	0	-516	15096	0	15096	697	387	16696	16696	49.96
26/02/2017	4 Hrs	5776	122	443	6341	5492	340	3589	0	-556	15206	0	15206	699	386	16847	16847	49.95
Maximum		5901	145	458	6484	5695	699	3589	0	-482	15206	0	15206	702	388	16865	16865	50.00
Minimum		5653	90	434	6248	5172	105	3034	0	-734	14632	0	14632	633	386	16385	16385	49.95
Average		5785	122	448	6355	5412	444	3415	0	-571	15054	0	15054	690	387	16702	16702	49.98

Details of Supply Position (MUs)

Date	MSGENCO				Pench (MS)	Central Sector Receipt	Central Sector Share	WIND	CPP	SOLAR	TPCL Gen.	R-INFRA Gen.	TPCL Exch.	Energy Requirement		
	THM	HYDRO	GAS	Total										MSEDCL	MUMBAI	STATE
	Mus	Mus	Mus	Mus	Mus	Mus	Mus	Mus	Mus	Mus	Mus	Mus	Mus	Mus	Mus	Mus
20/02/2017	147.723	15.180	10.551	173.454	0.047	157.491	158.186	8.233	83.514	1.394	22.694	10.483	-24.822	399.264	57.999	457.263
21/02/2017	145.050	8.383	10.752	164.185	0.087	153.917	154.010	14.952	82.942	1.443	23.093	10.374	-20.614	396.825	54.081	450.906
22/02/2017	142.312	22.098	9.595	174.005	0.000	161.937	160.630	7.093	76.025	1.438	24.992	11.379	-19.649	400.855	56.019	456.874
23/02/2017	139.491	19.590	10.440	169.521	0.017	156.575	160.525	7.657	84.499	1.442	24.928	11.399	-19.313	400.381	55.640	456.021
24/02/2017	144.656	11.796	10.264	166.716	0.177	154.135	162.645	6.437	85.325	1.438	23.242	11.103	-19.245	394.806	53.590	448.396
25/02/2017	147.632	10.789	9.492	167.913	0.214	153.600	157.587	8.943	84.440	1.454	22.989	10.734	-19.476	396.874	53.197	450.071
26/02/2017	142.381	10.656	10.356	163.393	0.109	157.572	157.220	4.501	85.961	1.465	19.171	10.502	-18.147	394.745	47.820	442.565
Maximum	147.723	22.098	10.752	174.005	0.214	161.937	162.645	147.723	85.961	1.465	24.992	11.399	-18.147	400.855	57.999	457.263
Minimum	139.491	8.383	9.492	163.393	0.000	153.600	154.010	139.491	76.025	1.394	19.171	10.374	-24.822	394.745	47.820	442.565
Average	144.178	14.070	10.207	168.455	0.093	156.461	158.686	144.178	83.244	1.439	23.016	10.853	-20.181	397.679	54.049	451.728

Details of Koyna Water Consumption (in TMC)

Date	For the Day	For the Month	Balance
20/02/2017	0.223	3.912	19.248
21/02/2017	0.063	3.975	19.185
22/02/2017	0.372	4.347	18.813
23/02/2017	0.305	4.652	18.508
24/02/2017	0.152	4.804	18.356
25/02/2017	0.128	4.932	18.228
26/02/2017	0.121	5.053	18.107

State Load Despatch Center, Airoli (MSETCL)
Central Sector Share/Drawal from 20/Feb/2017 to 26/Feb/2017

Date	DAY	Central Sector Share		Total Interstate Bilateral Purchase		Total Share		Total Drawal		Overdrawal(+) / UnderDrawal(-)	
		MUs	Avg. MW	MUs	Avg. MW	MUs	Avg. MW	MUs	Avg. MW	MUs	Avg. MW
		1		2		1+2=3		4		3-4=5	
20/02/2017	MONDAY	115.492	6548	42.694	1779	158.186	6591	157.491	6562	-0.695	-29
21/02/2017	TUESDAY	112.528	6376	41.482	1728	154.010	6417	153.917	6413	-0.093	-4
22/02/2017	WEDNESDA	115.233	6648	45.397	1892	160.630	6693	161.937	6747	1.307	54
23/02/2017	THURSDAY	110.208	6638	50.317	2097	160.525	6689	156.575	6524	-3.950	-165
24/02/2017	FRIDAY	113.722	6728	48.923	2038	162.645	6777	154.135	6422	-8.510	-355
25/02/2017	SATURDAY	111.712	6520	45.875	1911	157.587	6566	153.600	6400	-3.987	-166
26/02/2017	SUNDAY	117.385	6511	39.835	1660	157.220	6551	157.572	6566	0.352	15
Total		796.280		314.523		1110.803		1095.227		-15.576	

GENERATING UNITS OUTAGES FOR THE WEEK FROM 20/02/2017 TO 26/02/2017							
Generator	Generating Unit	Capacity	Tripped Date	Tripped Time	Synch. Date	Synch Time	Reason
PLANNED OUTAGES							
IPP	Tata Trombay 6	500MW	15/Jul/2015	17.08		Continued.	Economic shutdown(Converted to AOH for 30 Days from 00.00Hrs 06-03-2016)
MSPGCL	Paras Unit 3	250MW	25/Oct/2016	08.54		Continued.	Stator Fault, continued under AOH.26/10/2016 00.00hrs
MSPGCL	Chandrapur Unit 7	500MW	25/Jan/2017	19.32		Continued.	Capital Overhaul
MSPGCL	Koyna Unit 7	80MW	10/Feb/2017	11.20		Continued.	Maintenance Work.
FORCED OUTAGES							
RGPL	Dabhol Dabhol 1B	230MW	28/May/2013	22:02		Continued.	Gas Shortage.
RGPL	Dabhol Dabhol 1X	230MW	27/Jun/2013	21.46		Continued.	Gas Shortage
RGPL	Dabhol Dabhol 1A	230MW	27/Jun/2013	21.47		Continued.	Gas Shortage
IPP	Dhariwal	300MW	28/May/2014	02.27		Continued.	No schedule
MSPGCL	Koradi Unit 6	210MW	20/Mar/2015	01.02		Continued.	EE R&M LE Work
IPP	SWPGL U-1	135MW	16/Feb/2016	17.09		Continued.	Change Over , No Schedule
IPP	SWPGL U-2	135MW	29/Feb/2016	21.46		Continued.	Change over against Unit III
MSPGCL	Parli Unit 4	210MW	01/Apr/2016	00.00		Continued.	Economic shutdown
MSPGCL	Parli Unit 5	210MW	01/Apr/2016	00.00		Continued.	Economic shutdown
MSPGCL	Bhusawal Unit 2	210MW	14/Jun/2016	19.35		Continued.	Boiler Tube Leakage(Converted to Zero Shedule By MSEDCL. from 00.00Hrs dt.19-6-16)
IPP	RPL(AMT) U-3	270MW	29/Jun/2016	03.01		Continued.	Zero Shedule By MSEDCL.
MSPGCL	Uran Unit 8	108MW	14/Aug/2016	07.56		Continued.	Maintenance work
RGPL	Dabhol 2A	230MW	24/Aug/2016	13.31		Continued.	Change Over.
MSPGCL	Koradi Unit 5	200MW	05/Sep/2016	00.21		Continued.	ID Fan problem, Converted to Zero Schedule By MSEDCL from 00.00hrs/22-9-16. Shutdown taken on 18.10.2016 at 00:00Hrs for Turbine inspection and maintenance work
IPP	RPL(AMT) U-5	270MW	15/Nov/2016	20.00		Continued.	Zero schedule
IPP	RPL(AMT) U-4	270MW	16/Nov/2016	21.03		Continued.	Zero Schedule By MSEDCL.
IPP	RPL(AMT) U-2	270MW	16/Nov/2016	22.36		Continued.	Zero Schedule By MSEDCL.
IPP	JSW (J) U1		16/Nov/2016	14.38		Continued.	Due To CW Duct Leakage.
IPP	RPL(AMT) U-1	270MW	17/Nov/2016	17.23		Continued.	Zero Schedule.
MSPGCL	Parli Unit 8	250MW	18/Nov/2016	16.23		Continued.	w/dn for balance work.
IPP	JSW (J) U2	300MW	01/Dec/2016	00.00		Continued.	No Schedule.
IPP	VIPL U-1	300MW	03/Jan/2017	00.45		Continued.	Turbine bearing temprature high.
MSPGCL	Nasik Unit 4	210MW	31/Jan/2017	02.55	24/Feb/2017	10.35	WITHDRAW UNDER ZERO SCHEDULE.
MSPGCL	Koradi Unit 10	660MW	07/Feb/2017	00.10		Continued.	Work Of PG Test.
IPP	PGPL U1	262MW	07/Feb/2017	17.30		Continued.	No Schedule
IPP	PGPL U2	126MW	07/Feb/2017	17.30		Continued.	No Schedule
MSPGCL	Koyna Unit 9	80MW	14/Feb/2017	11.00	24/Feb/2017	12.40	Emergency Outage for Maintenance.
MSPGCL	Koradi Unit 7	210MW	15/Feb/2017	14.18		Continued.	Zero Schedule by MSEDCL
IPP	Adani U-1	660MW	16/Feb/2017	07.38	22/Feb/2017	14.14	Main Steam Line Drain Leakage.
MSPGCL	Parli Unit 7	250MW	20/Feb/2017	13.34	20/Feb/2017	16.17	Furnace Pressure High
MSPGCL	Bhusawal Unit 3	210MW	21/Feb/2017	03.55	22/Feb/2017	16.14	Boiler Tube Leakage
IPP	Adani U-4	660MW	21/Feb/2017	23.05	26/Feb/2017	19.26	pa duct bellow leakage
MSPGCL	Uran Unit 6	108MW	22/Feb/2017	19.27	22/Feb/2017	20.18	Turbine bearing Vabration high
MSPGCL	Chandrapur Unit 6	500MW	22/Feb/2017	08.22	24/Feb/2017	12.35	Boiler Tube Leakage
MSPGCL	Parli Unit 6	250MW	22/Feb/2017	22.10	24/Feb/2017	20.39	Air heater problem
MSPGCL	Khaparkheda Unit 5	500MW	22/Feb/2017	09.53	22/Feb/2017	11.56	Drum level low
MSPGCL	Uran Unit 5	108MW	22/Feb/2017	10.04	22/Feb/2017	13.30	Filter replacement work
MSPGCL	Nasik Unit 5	210MW	24/Feb/2017	14.30		Continued.	Zero Schedule.
MSPGCL	Chandrapur Unit 6	500MW	25/Feb/2017	11.48		Continued.	Boiler Tube Leakage
MSPGCL	Chandrapur Unit 7	500MW	25/Feb/2017	19.32		Continued.	Tripped sparking in turbine bearing.
MSPGCL	Uran Unit B0	120MW	25/Feb/2017	09.16	25/Feb/2017	14.54	Filter Replacement.
MSPGCL	Uran Unit 7	108MW	25/Feb/2017	09.12	25/Feb/2017	13.07	Filter Replacement.
MSPGCL	Koradi Unit-8	660MW	26/Feb/2017	18.36	26/Feb/2017	23.08	FD Fan Problem.

LINE OUTAGES AND RIPPING FOR THE WEEK FROM 13/02/2017 TO 19/02/2017

Voltage	Name of Line	Tripping Date	Tripping Time	Synch Date	Synch Time	Reason
400 KV	karad -kolhapur-I	19/Feb/2017	17.29	20/Feb/2017	07.37	Over Voltage
400 KV	Karad - Jaigad - II	19/Feb/2017	17.30	20/Feb/2017	06.07	Over Voltage
400 KV	Dhule Sar'Sarovar II	19/Feb/2017	17.48	20/Feb/2017	05.42	Over Voltage
400 KV	Bhusawal-Aurangabad	19/Feb/2017	17.57	20/Feb/2017	06.07	Over Voltage
400 KV	Parly(MS)- Nanded	20/Feb/2017	11.40	20/Feb/2017	13.51	Attending Hot Spot On Wave Trap.
400 KV	Dabhol Nagothane I	20/Feb/2017	12.39	20/Feb/2017	18.46	Line Signature Work.
400 KV	Ektuni - Taptitanda Ckt I	20/Feb/2017	16.28	21/Feb/2017	20.50	Isolator Alignment Work.
400 KV	karad -kolhapur-II	20/Feb/2017	17.13	21/Feb/2017	09.43	Over Voltage
400 KV	Karad-Jaigad - I	20/Feb/2017	17.15	21/Feb/2017	09.44	Over Voltage
400 KV	Dhule Sar'Sarovar II	20/Feb/2017	18.38	21/Feb/2017	06.09	Over Voltage
400 KV	Bhusawal-Aurangabad	20/Feb/2017	20.03	21/Feb/2017	06.53	Over Voltage
400 KV	karad -kolhapur-I	21/Feb/2017	16.36	22/Feb/2017	07.51	Over Voltage
400 KV	Karad - Jaigad - II	21/Feb/2017	16.38	22/Feb/2017	07.56	Over Voltage
400 KV	Bhusawal-Aurangabad	21/Feb/2017	19.16	22/Feb/2017	06.11	Over Voltage
400 KV	Dhule Sar'Sarovar II	21/Feb/2017	22.02	22/Feb/2017	06.32	Over Voltage
400 KV	Warora-Adani(Tiroda)1	22/Feb/2017	08.56	22/Feb/2017	19.35	Annual Maintenance Work
400 KV	Jaigad-New Koyna Ckt-II	22/Feb/2017	09.15	22/Feb/2017	19.00	Routine Maintenance Work
400 KV	Dabhol Nagothane II	22/Feb/2017	15.08	22/Feb/2017	19.58	Distance Protection
400 KV	Karad-Jaigad - I	22/Feb/2017	17.30	23/Feb/2017	06.45	Over Voltage
400 KV	karad -kolhapur-II	22/Feb/2017	17.34	23/Feb/2017	06.38	Over Voltage
400 KV	Girwali-Solapur (Lamboti)	22/Feb/2017	17.58	23/Feb/2017	16.08	Distance Protection
400 KV	Bhusawal-Aurangabad	22/Feb/2017	20.16	23/Feb/2017	06.27	Over Voltage
400 KV	Dhule Sar'Sarovar I	22/Feb/2017	20.16	23/Feb/2017	06.59	Over Voltage
400 KV	Khadka - Bableshtar	23/Feb/2017	10.45	23/Feb/2017	21.44	Distance Protection
400 KV	karad -kolhapur-I	23/Feb/2017	16.42	24/Feb/2017	08.15	Over Voltage
400 KV	Karad - Jaigad - II	23/Feb/2017	17.28	24/Feb/2017	08.30	Over Voltage
400 KV	Dhule Sar'Sarovar II	23/Feb/2017	17.51	24/Feb/2017	06.34	Over Voltage
400 KV	Bhusawal-Aurangabad	23/Feb/2017	18.05	24/Feb/2017	06.47	Over Voltage
400 KV	Main Bus - II @ Kalwa	24/Feb/2017	08.55		Continued.	Conductor Replacement Work.
400 KV	Dabhol Nagothane II	24/Feb/2017	11.57	24/Feb/2017	19.13	Attending Hot Spot
400 KV	karad -kolhapur-II	24/Feb/2017	16.13	25/Feb/2017	06.47	Over Voltage
400 KV	Karad-Jaigad - I	24/Feb/2017	16.16	25/Feb/2017	08.16	Over Voltage
400 KV	Dhule Sar'Sarovar I	24/Feb/2017	17.25	25/Feb/2017	06.47	Over Voltage
400 KV	Bhusawal-Aurangabad	24/Feb/2017	18.00	25/Feb/2017	06.02	Over Voltage
400 KV	Padghe - Kalwa-II	25/Feb/2017	08.17	26/Feb/2017	14.53	Replacement work
400 KV	Akola-Bhusawal(khadka) bay 410	25/Feb/2017	08.18	25/Feb/2017	20.44	Testing Work
400 KV	Dabhol Nagothane II	25/Feb/2017	14.44		Continued.	Distance Protection
400 KV	karad -kolhapur-I	25/Feb/2017	18.06	26/Feb/2017	08.50	Over Voltage
400 KV	Karad - Jaigad - II	25/Feb/2017	18.08	26/Feb/2017	08.44	Over Voltage
400 KV	Bhusawal-Aurangabad	25/Feb/2017	20.48	26/Feb/2017	07.18	Over Voltage
400 KV	Akola - Bhusawal	25/Feb/2017	21.12	25/Feb/2017	23.08	Emergency outage
400 KV	Dhule Sar'Sarovar II	25/Feb/2017	21.19	26/Feb/2017	06.52	Over Voltage
400 KV	karad -kolhapur-II	26/Feb/2017	17.07		Continued.	Over Voltage
400 KV	Dhule Sar'Sarovar II	26/Feb/2017	18.06	27/Feb/2017	06.53	Over Voltage
400 KV	Bhusawal-Aurangabad	26/Feb/2017	18.15	27/Feb/2017	06.50	Over Voltage
220 KV	Chandrapur GCR - Warora - I	05/Apr/2015	09.13		Continued.	for Loc no 86 Disconnecting of jumer at Loc no 86 & 107 and de-energising th
220 KV	Chandrapur GCR - Wani	05/Apr/2015	09.15		Continued.	for Loc no 86 Disconnecting of jumer at Loc no 86 & 107 and de-energising th
220 KV	Kalwa - Siemens	08/Jan/2017	13.48	22/Feb/2017	18.54	construction work.
220 KV	Pophli Pedhmbe Line- 2	13/Feb/2017	03.40		Continued.	Distance Protection at pedhmbe end
220 KV	Talandge(400kv)- Ichalkaranji 2	19/Feb/2017	22.45	20/Feb/2017	01.28	Attending Hot Spot
220 KV	Kalwa Salsette III	20/Feb/2017	06.33	20/Feb/2017	08.37	Line Maintenance work
220 KV	Washala - Ghatghar	20/Feb/2017	12.20	20/Feb/2017	15.45	Attending Oil Leakage
220 KV	Hamidwada-Mumewadi	20/Feb/2017	14.56	20/Feb/2017	17.20	Testing Work
220 KV	220kv Halkarni- Tillary	21/Feb/2017	08.00	21/Feb/2017	08.09	tripped only from amona end only
220 KV	Halkarni-Mahalaxmiline	21/Feb/2017	08.00	21/Feb/2017	08.11	tripped only from amona end only
220 KV	Mahad - Pedambe	22/Feb/2017	04.54	22/Feb/2017	15.10	Distance Protection
220 KV	Loteparshuram- Dasturi Line	22/Feb/2017	05.48	22/Feb/2017	10.14	Distance Protection
220 KV	New Koyna - Loteparshuram	22/Feb/2017	05.48	22/Feb/2017	10.00	Backup Protection
220 KV	Kandalgaon - Koyna	22/Feb/2017	05.55	22/Feb/2017	13.30	Distance Protection
220 KV	Adlabs - Pedambe	22/Feb/2017	06.09	22/Feb/2017	19.30	Distance Protection
220 KV	Bhaveghar - Kolshet	22/Feb/2017	08.13	22/Feb/2017	14.47	Distance Protection
220 KV	chandrapur-Tadali	22/Feb/2017	08.52	22/Feb/2017	20.14	replacement of jaw of isolator.
220 KV	Trombay MSETCL Tie 2	22/Feb/2017	09.24		Continued.	protection panel replacement work.
220 KV	Patoda-Manjarsumba	22/Feb/2017	10.03	22/Feb/2017	16.50	carrying out signature test fixing of nut bolt of suspension clamp.
220 KV	Gorai MSETCL Borivalli Line-2	22/Feb/2017	10.05	22/Feb/2017	21.47	attending sf 6 gas leakage.
220 KV	Talandge-Mudshingi Ckt-I	22/Feb/2017	10.20	22/Feb/2017	13.59	Annual Maintenance Work
220 KV	Bhugaon - Lloyed Steel	22/Feb/2017	10.29	22/Feb/2017	13.40	Line Maintenance work
220 KV	Karad(400kv) -Nigade	22/Feb/2017	12.24	22/Feb/2017	12.49	Distance Protection
220 KV	220KV Sawangi- Bhokardan	22/Feb/2017	12.30	22/Feb/2017	19.07	Distance Relay Testing Work
220 KV	Pophli Pedhmbe Line- 1	22/Feb/2017	13.35	22/Feb/2017	14.55	red hot spot attending work.
220 KV	Karad - Vita Ckt- II	22/Feb/2017	14.07	22/Feb/2017	22.04	crm work.
220 KV	Kalwa - Borivalli	22/Feb/2017	16.51	22/Feb/2017	17.18	construction work.
220 KV	Kalwa - Mulund 1	22/Feb/2017	17.48	22/Feb/2017	18.22	construction work for safety purpose.
220 KV	Chakan-Bhosari	23/Feb/2017	12.09	23/Feb/2017	12.28	Half yearly maintenance work
220 KV	Pedhambe - Oni	23/Feb/2017	13.59	24/Feb/2017	00.25	Distance Protection
220 KV	Talandge(400)- Mudshingi 2 Line	23/Feb/2017	14.52	23/Feb/2017	18.52	Routine Maintenance Work
220 KV	Boisar(MS) - Boisar (PG) - I	23/Feb/2017	15.51	23/Feb/2017	18.39	Attending Hot Spot

Voltage	Name of Line	Tripping Date	Tripping Time	Synch Date	Synch Time	Reason
220 KV	Hingoli- Girawali	23/Feb/2017	17.20	23/Feb/2017	21.17	Replacement of LA and Hot Spot Attending Work.
220 KV	Boisar Tarapur	24/Feb/2017	09.33	24/Feb/2017	15.49	Attending Hot Spot
220 KV	New Koyna - Loteparshuram	24/Feb/2017	10.34	24/Feb/2017	15.41	Attending Hot Spot
220 KV	Kalwa - Borivali	24/Feb/2017	12.06	24/Feb/2017	12.31	For Safety Purpose.
220 KV	Kalwa - Mulund 1	24/Feb/2017	12.35	24/Feb/2017	13.11	For Safety Purpose.
220 KV	Mahalakshmi Amona	25/Feb/2017	06.10	25/Feb/2017	06.40	Distance Protection
220 KV	Mahalakshmi Amona	25/Feb/2017	06.50	25/Feb/2017	14.21	Distance Protection
220 KV	Main Bus-I @ Gorai	25/Feb/2017	09.25	25/Feb/2017	19.51	To attend SF-6 gas leakage.
220 KV	200MVA ICT VI @ Nasik GCR	25/Feb/2017	09.26	25/Feb/2017	17.26	To attend oil leakage.
220 KV	Telco- Chinchwad	25/Feb/2017	10.36	25/Feb/2017	16.46	Annual Maintenance Work
220 KV	Kalwa - Taloja	25/Feb/2017	13.28	25/Feb/2017	15.07	Distance Protection
220 KV	Versova Gorai Line	25/Feb/2017	13.51	25/Feb/2017	20.07	Replacement of bus side earth switch.
220 KV	Parli 3 (Old Gcr)-Osmanabad	25/Feb/2017	16.32	25/Feb/2017	21.01	To replacement Y phase PH cross arm at LOC no.56.
220 KV	Nanded-Parbhani	25/Feb/2017	18.41	25/Feb/2017	21.32	In view of emergency outage on 220 Kv nanded kumbhargaoon.
220 KV	Vasai Boiser(PG)	26/Feb/2017	08.52	26/Feb/2017	17.17	Attending Hot Spot
220 KV	Arey - TPC Borivali	26/Feb/2017	09.02	26/Feb/2017	21.39	Annual Maintenance Work
220 KV	Padghe - Wada	26/Feb/2017	12.38	26/Feb/2017	18.59	Distance Protection
220 KV	Waluj - Chitegaon li	26/Feb/2017	13.12	26/Feb/2017	16.28	Wave Trap Jumper Work.
132 KV	Harangul-Jagruti sugar	22/Feb/2017	06.36	22/Feb/2017	06.52	Distance Protection
132 KV	Himayatnagar - Tamsa	23/Feb/2017	02.27	23/Feb/2017	02.57	Distance Protection
132 KV	Yawal - Chopda	24/Feb/2017	11.02	24/Feb/2017	16.47	Distance Protection
132 KV	Padegaon - Canpack	24/Feb/2017	15.46	24/Feb/2017	17.18	Distance Protection
132 KV	Gangapur-Canpack	24/Feb/2017	15.46	24/Feb/2017	16.11	Backup Protection