

State Load Despatch Center,Airoli (MSETCL)
Power System Position from 22/Mar/2021 to 28/Mar/2021

Supply Position During Morning Peak (MW)

Date	Time	MSGENCO				Central Sector Receipt	Wind	CPP	SOLAR	TPCL Exch.	MSEDCL Catered Demand	Load Sheddin g(LS)	MSEDCL Demand (Incl. LS)	TPCL Gen.	R-INFRA Gen.	State Demand Met	State Demand (Incl. LS)	Freq.
		THM	HYDRO	GAS	Total													
		MW	MW	MW	MW	MW	MW	MW	MW	MW	MW	MW	MW	MW	MW	MW	MW	Hzs
22-03-2021	12 Hrs	7172	620	288	8080	7003	91	5674	1010	-1331	20527	0	20527	1116	497	23471	23471	49.96
23-03-2021	12 Hrs	6710	512	267	7489	7412	626	4892	939	-1478	19880	0	19880	1134	285	22777	22777	50.03
24-03-2021	12 Hrs	6773	563	265	7601	7509	142	5938	967	-1354	20803	0	20803	1124	501	23782	23782	49.99
25-03-2021	12 Hrs	6220	1098	264	7582	7765	308	5982	982	-1281	21338	0	21338	1165	499	24283	24283	50.01
26-03-2021	12 Hrs	5878	1129	255	7262	8314	290	5908	1037	-1308	21503	0	21503	1139	499	24449	24449	50.00
27-03-2021	12 Hrs	6201	1576	242	8020	8185	186	5951	1107	-1182	22266	0	22266	1120	499	25068	25068	50.01
28-03-2021	12 Hrs	6248	1048	266	7562	8502	199	5852	1060	-1033	22142	0	22142	913	499	24587	24587	50.01
Maximum		7172	1576	288	8080	8502	626	5982	1107	-1033	22266	0	22266	1165	501	25068	25068	50.03
Minimum		5878	512	242	7262	7003	91	4892	939	-1478	19880	0	19880	913	285	22777	22777	49.96
Average		6457	935	264	7656	7813	263	5742	1015	-1281	21208	0	21208	1102	468	24059	24059	50.00

Supply Position During Day Peak (MW)

Date	Time	MSGENCO				Central Sector Receipt	Wind	CPP	SOLAR	TPCL Exch.	MSEDCL Catered Demand	Load Sheddin g(LS)	MSEDCL Demand (Incl. LS)	TPCL Gen.	R-INFRA Gen.	State Demand Met	State Demand (Incl. LS)	Freq.
		THM	HYDRO	GAS	Total													
		MW	MW	MW	MW	MW	MW	MW	MW	MW	MW	MW	MW	MW	MW	MW	MW	Hzs
22-03-2021	13 Hrs	7256	498	255	8009	6829	76	5941	1058	-1387	20526	0	20526	1044	498	23455	23455	49.92
23-03-2021	16 Hrs	6825	470	267	7562	7371	218	5739	588	-1549	19929	0	19929	988	283	22749	22749	50.04
24-03-2021	16 Hrs	6684	1076	255	8015	7503	86	6040	570	-1455	20759	0	20759	1013	500	23727	23727	49.93
25-03-2021	16 Hrs	6321	1196	243	7760	8056	149	5974	733	-1472	21200	0	21200	1010	499	24181	24181	49.94
26-03-2021	13 Hrs	5921	1241	263	7425	8258	165	5850	1049	-1429	21318	0	21318	1031	500	24278	24278	50.03
27-03-2021	16 Hrs	6229	1588	252	8068	8567	81	5797	730	-1352	21892	0	21892	1047	499	24790	24790	49.99
28-03-2021	16 Hrs	6171	943	267	7381	9143	179	5874	714	-1286	22005	0	22005	835	496	24622	24622	50.00
Maximum		7256	1588	267	8068	9143	218	6040	1058	-1286	22005	0	22005	1047	500	24790	24790	50.04
Minimum		5921	470	243	7381	6829	76	5739	570	-1549	19929	0	19929	835	283	22749	22749	49.92
Average		6487	1002	257	7746	7961	136	5888	777	-1419	21090	0	21090	995	468	23972	23972	49.98

Supply Position During Evening Peak (MW)

Date	Time	MSGENCO				Central Sector Receipt	Wind	CPP	SOLAR	TPCL Exch.	MSEDCL Catered Demand	Load Sheddin g(LS)	MSEDCL Demand (Incl. LS)	TPCL Gen.	R-INFRA Gen.	State Demand Met	State Demand (Incl. LS)	Freq.
		THM	HYDRO	GAS	Total													
		MW	MW	MW	MW	MW	MW	MW	MW	MW	MW	MW	MW	MW	MW	MW	MW	Hzs
22-03-2021	20 Hrs	6998	667	279	7944	5556	371	5417	0	-1090	18198	0	18198	1100	500	20888	20888	49.98
23-03-2021	20 Hrs	6730	468	270	7468	5820	455	6046	0	-1272	18517	0	18517	1086	297	21172	21172	50.03
24-03-2021	20 Hrs	6776	919	268	7963	5997	260	6291	0	-1145	19366	0	19366	1101	501	22113	22113	50.02
25-03-2021	20 Hrs	5920	1397	256	7573	6227	296	6306	5	-1125	19282	0	19282	1085	498	21990	21990	50.03
26-03-2021	20 Hrs	5866	1420	267	7553	6528	396	5959	0	-1099	19337	0	19337	1160	499	22095	22095	49.92
27-03-2021	20 Hrs	6192	1405	277	7874	6630	459	5935	0	-1039	19859	0	19859	1106	499	22503	22503	49.99
28-03-2021	19 Hrs	6131	434	279	6844	6743	301	5844	12	-1021	18723	0	18723	892	420	21056	21056	50.06
Maximum		6998	1420	279	7963	6743	459	6306	12	-1021	19859	0	19859	1160	501	22503	22503	50.06
Minimum		5866	434	256	6844	5556	260	5417	0	-1272	18198	0	18198	892	297	20888	20888	49.92
Average		6373	959	271	7603	6214	363	5971	2	-1113	19040	0	19040	1076	459	21688	21688	50.00

Supply Position During Night Off Peak (MW)

Date	Time	MSGENCO				Central Sector Receipt	Wind	CPP	SOLAR	TPCL Exch.	MSEDCL Catered Demand	Load Sheddin g(LS)	MSEDCL Demand (Incl. LS)	TPCL Gen.	R-INFRA Gen.	State Demand Met	State Demand (Incl. LS)	Freq.
		THM	HYDRO	GAS	Total													
		MW	MW	MW	MW	MW	MW	MW	MW	MW	MW	MW	MW	MW	MW	MW	MW	Hzs
22-03-2021	4 Hrs	6968	322	140	7430	6081	215	4456	0	-942	17240	0	17240	602	284	19068	19068	49.99
23-03-2021	4 Hrs	5641	269	283	6193	5203	1171	4403	0	-1007	15963	0	15963	576	285	17831	17831	50.03
24-03-2021	3 Hrs	6518	265	272	7055	5299	1018	4662	0	-998	17036	0	17036	605	394	19033	19033	50.00
25-03-2021	4 Hrs	6548	297	281	7126	6349	180	5765	0	-1055	18365	0	18365	622	284	20326	20326	50.04
26-03-2021	4 Hrs	5972	314	281	6567	6252	571	5975	0	-912	18453	0	18453	593	498	20456	20456	49.93
27-03-2021	3 Hrs	5898	530	270	6698	6348	578	5901	0	-761	18764	0	18764	893	500	20918	20918	50.04
28-03-2021	23 Hrs	6027	968	291	7286	6304	437	5812	0	-1021	18818	0	18818	965	498	21302	21302	50.01
Maximum		6968	968	291	7430	6349	1171	5975	0	-761	18818	0	18818	965	500	21302	21302	50.04
Minimum		5641	265	140	6193	5203	180	4403	0	-1055	15963	0	15963	576	284	17831	17831	49.93
Average		6225	424	260	6908	5977	596	5282	0	-957	17806	0	17806	694	392	19848	19848	50.01

Details of Supply Position (MUs)

Date	MSGENCO				Pench (MS)	Central Sector Receipt	Central Sector Share	WIND	CPP	SOLAR	TPCL Gen.	R-INFRA Gen.	TPCL Exch.	Energy Requirement		
	THM	HYDRO	GAS	Total										MSEDCL	MUMBAI	STATE
	Mus	Mus	Mus	Mus	Mus	Mus	Mus	Mus	Mus	Mus	Mus	Mus	Mus	Mus	Mus	Mus
22-03-2021	169.553	11.645	5.366	186.564	0.247	149.421	152.643	7.435	126.737	6.784	20.203	10.098	-28.327	448.614	58.628	507.242
23-03-2021	157.532	9.721	6.601	173.854	0.000	148.401	150.038	16.679	124.600	6.401	20.737	8.459	-29.288	440.647	58.484	499.131
24-03-2021	160.926	12.569	6.520	180.015	0.302	154.897	156.068	11.575	137.196	6.948	21.698	10.560	-27.912	462.719	60.169	522.888
25-03-2021	151.292	19.913	6.435	177.640	0.214	163.603	164.992	7.060	144.396	7.442	22.723	11.118	-26.488	473.653	60.329	533.982
26-03-2021	142.191	24.842	6.473	173.506	0.296	170.131	170.882	10.080	142.892	7.728	23.543	11.969	-25.582	478.755	61.094	539.849
27-03-2021	146.403	29.972	6.425	182.800	0.311	170.827	169.469	8.479	141.456	7.882	23.968	11.907	-23.523	487.921	59.398	547.319
28-03-2021	147.226	24.808	6.651	178.685	0.187	176.763	174.668	6.529	140.445	7.922	21.193	11.440	-23.501	486.843	56.134	542.977
Maximum	169.553	29.972	6.651	186.564	0.311	176.763	174.668	169.553	144.396	7.922	23.968	11.969	-23.501	487.921	61.094	547.319
Minimum	142.191	9.721	5.366	173.506	0.000	148.401	150.038	142.191	124.600	6.401	20.203	8.459	-29.288	440.647	56.134	499.131
Average	153.589	19.067	6.353	179.009	0.222	162.006	162.680	153.589	136.817	7.301	22.009	10.793	-26.374	468.450	59.177	527.627

Details of Koyna Water Consumption (in TMC)			
Date	For the Day	For the Month	Balance
22-03-2021	0.096	5.870	22.812
23-03-2021	0.071	5.940	22.742
24-03-2021	0.126	6.066	22.616
25-03-2021	0.264	6.330	22.352
26-03-2021	0.365	6.695	21.987
27-03-2021	0.483	7.179	21.504
28-03-2021	0.365	7.544	21.138

State Load Despatch Center,Airoli (MSETCL)
Central Sector Share/Drawal from 22/Mar/2021 to 28/Mar/2021

Date	DAY	Central Sector Share		Total Interstate		Total Share		Total Drawal		Overdrawal(+) /	
		MUs	Avg. MW	MUs	Avg. MW	MUs	Avg. MW	MUs	Avg. MW	MUs	Avg. MW
		1		2		1+2=3		4		3-4=5	
22-03-2021	MONDAY	121.957	6329	30.686	1279	152.643	6360	149.421	6226	-3.222	-134
23-03-2021	TUESDAY	119.497	6221	30.541	1273	150.038	6252	148.401	6183	-1.637	-68
24-03-2021	WEDNESDA	124.570	6471	31.498	1312	156.068	6503	154.897	6454	-1.171	-49
25-03-2021	THURSDAY	133.543	6843	31.449	1310	164.992	6875	163.603	6817	-1.389	-58
26-03-2021	FRIDAY	135.803	7085	35.079	1462	170.882	7120	170.131	7089	-0.751	-31
27-03-2021	SATURDAY	128.904	7021	40.565	1690	169.469	7061	170.827	7118	1.358	57
28-03-2021	SUNDAY	123.923	7227	50.745	2114	174.668	7278	176.763	7365	2.095	87
Total		888.197		250.563		1138.760		1134.043		-4.717	

Generating Unit Outages/Trippings from 22.03.2021 to 28.03.2021

Name of Unit	Type	Date Trip	Time Trip	Date Sync	Time Sync	Reason	Outage Type
SWPGPL U-1	U	16-02-2016	17.09		Continued.	No PPA.	FORCED
PGPL U1	U	07-02-2017	17.3		Continued.	No Schedule (NO PPA)	FORCED
PGPL U2	U	07-02-2017	17.3		Continued.	No Schedule.(NO PPA)	FORCED
IEPL Unit 1	U	28-08-2018	21.26		Continued.	No PPA	FORCED
VIPL U-1	U	29-12-2018	0.3		Continued.	Coal Shortage. (NO PPA From 20.05.2019)	FORCED
VIPL U-2	U	17-01-2019	0.15		Continued.	Coal shortage.(NO PPA From 20.05.2019)	FORCED
Uran Unit 7	U	25-05-2020	12.51		Continued.	Turbine Blade Failure	FORCED
Nasik Unit 3	U	03-12-2020	6.45		Continued.	PA Fan Problem (Under Case 4 Bidding From 11.00Hrs DT. 21-01-2021).	FORCED
Koyna Unit 11	U	19-01-2021	10.05	29-05-2021	15.2	Tripped on stator earth fault (will not be available till dt.24.05.21)	FORCED
JSW (J) U1	U	01-02-2021	18	04-05-2021	14.52	Due to turbine vibration high	FORCED
Chandrapur Unit 7	U	20-02-2021	23.43		Continued.	Generator Earth Fault.	FORCED
Adani U-2	U	04-03-2021	0.1	08-04-2021	14.31	Increase Hydrogen Consumption	FORCED
Chandrapur Unit 4	U	16-03-2021	8.08	27-05-2021	9.01	Boiler Tube Leakage(converted to Capital overhaul)	PLANNED
Uran Unit B0	U	20-03-2021	0.03	02-04-2021	22.17	Gas shortage	FORCED
Uran Unit 8	U	20-03-2021	0.05	02-04-2021	16.19	Gas shortage	FORCED
Chandrapur Unit 3	U	21-03-2021	16.12	25-03-2021	3.28	Boiler Tube Leakage	FORCED
Uran Unit 5	U	18-03-2021	14.2	22-03-2021	7.05	Gas Shortage.	FORCED
Khaparkheda Unit 1	U	22-03-2021	23.52	26-03-2021	9.43	Due To Low Vacuumed Pressure.	FORCED
Paras Unit 4	U	23-03-2021	5.18	23-03-2021	8.1	Drum level High.	FORCED
Koradi Unit 6	U	24-03-2021	10.5	24-03-2021	14.59	ID FAN PROBLEM	FORCED
Paras Unit 3	U	25-03-2021	7.2	25-03-2021	11.19	Furnace Pressure High	FORCED
Bhusawal Unit 4	U	25-03-2021	9.35	27-03-2021	1.47	Boiler Tube Leakage	FORCED
Chandrapur Unit 5	U	25-03-2021	15.51	01-04-2021	10.46	Boiler Tube Leakage	FORCED
Parli Unit 6	U	27-03-2021	2.25	30-03-2021	1.53	Coal mill problem.	FORCED
JSW (J) U2	U	26-03-2021	1.13	07-04-2021	20.53	No Schedule	FORCED
Khaparkheda Unit 1	U	26-03-2021	10.2	26-03-2021	11.25	Drum level low	FORCED
Koyna STG-IV Unit-2	U	27-03-2021	14.1	27-03-2021	16.1	Butterfly valve trouble.	FORCED
Paras Unit 3	U	27-03-2021	22.4	28-03-2021	7	Furnace Pressure High	FORCED

Transmission Line Outages/Trippings from 22.03.2021 to 28.03.2021							
Name of Line	Date Trip	Time Trip	Date Sync	Time Sync	Reason	Outage Type	Voltage
Mudshingi Chikodi	24-09-2019	17.12		Continued.	No Schedule(Charge from Mudshingi end only)	PO	220 KV
Talandage - Chikodi	01-10-2019	17.1		Continued.	No Schedule(Close at Chikodi end only)	PO	220 KV
ALKUD - MENDHEGIRI CKT - 1	07-03-2021	9.18	28-03-2021	21.21	For Erection Of 220Kv M/C Tower In R/O New 'K' Mahakal-Jath Line Near 220KV Mendhigiri-Alkud Line.	PO	220 KV
220/132kv 100mva Ptr 2 @Kharepatan	22-03-2021	8.35	22-03-2021	14.19	ICT Painting Work.	PO	220 KV
220/22 Kv 50 Mva T&R Ptr 1 @Anandnagar	22-03-2021	10.1	22-03-2021	16.05	HV CB Overhauling By Agency.	PO	220 KV
Alkud Miraj	22-03-2021	16.28	23-03-2021	12.24	Removing Bunching And Making Alkud S/S Lilo On 220KV Vita-Mahisal Line.	PO	220 KV
Boisar Versova Line	22-03-2021	10.04	24-03-2021	16.19	Overhauling Of 220KV Circuit Breaker Operation Mechanism.(In Service Through TBC)	PO	220 KV
Kharghar-Sonkhar	22-03-2021	9.06	22-03-2021	23.58	B Phase Bus Isolator Hot Spot Attending Work By Hot Line Technic.	PO	220 KV
Kolhapur-Bidri	22-03-2021	10.09	22-03-2021	17.13	Quarterly Maintenance Work	PO	220 KV
Loteparshuram- Dasturi Line	22-03-2021	10.22	22-03-2021	16	220KV Bus PT-2 Secondary Connection & 220KV Bus Jumper Connection.	PO	220 KV
Ongc Uran - Jnpt	22-03-2021	15.35	22-03-2021	19.15	Replacement Of Fiber Gear Assembly At ONGC End CB.	PO	220 KV
Padgha - Temghar I	22-03-2021	17.21	22-03-2021	17.55	Tripped on PDR	T	220 KV
Talandge-Hamidwada	22-03-2021	11.39	22-03-2021	17.27	T Jumper Removal Work. Quarterly Maintenance Work Of CB.	PO	220 KV
Uran - Ongc Uran	22-03-2021	11.05	22-03-2021	15.25	Replacement Of Fiber Gear Assembly At ONGC End CB.	PO	220 KV
Vita - Mhaishal	22-03-2021	16.41	23-03-2021	12.33	Removing Bunching And Making Alkud S/S Lilo On 220KV Vita-Mahisal Line.	PO	220 KV
Vita Alkud	22-03-2021	16.48	23-03-2021	12.33	Removing Bunching And Making Alkud S/S Lilo On 220KV Vita-Mhaishal Line.	PO	220 KV
220/132kv 100MVA ICT II @Satara Midc	23-03-2021	13.1	23-03-2021	16.23	Quarterly Maintenance Work	PO	220 KV
BHIRA (T) - KARANJADE CKT - 8	23-03-2021	8.46	23-03-2021	19.5	TLA Installation	PO	220 KV
Dhule - Malegaon	23-03-2021	17.11	23-03-2021	19.01	Tripped due to auxiliary Isolator problem	T	220 KV
Gangapur-Valve	23-03-2021	11.26	23-03-2021	14.36	Quarterly Maintenance Work	PO	220 KV
Nadgaonpeth-Amravati	23-03-2021	10.33	25-03-2021	17.2	Shifting of Old C&R panel	PO	220 KV
Nerul-Trombay	23-03-2021	8.47	28-03-2021	1.22	OPGW stringing work	PO	220 KV
REL Borivali MSETCL Borivali Line-1	23-03-2021	11.15	23-03-2021	16.41	Testing Work	PO	220 KV
220/33kV 100 MVA Transformer 3 @Ghodbunder R/S	24-03-2021	14.32	24-03-2021	18.2	CB MARSHALLING BOX HEIGHT RAISING WORK	PO	220 KV
220/33kV 100MVA Transformer 1 @Versova R/S	24-03-2021	10.04	24-03-2021	20.13	"Replacement of NGT-1 side cable support structure under 33 kV AIS to GIS Project	PO	220 KV
220/33kV 125 MVA Transformer 1 @REL Borivali	24-03-2021	8.59	24-03-2021	17.18	Annual Bay & Equipment maintenance.	PO	220 KV
BHIRA (T) - KARANJADE CKT - 8	24-03-2021	8.23	24-03-2021	13.52	TLA INSTALLATION	PO	220 KV

Transmission Line Outages/Trippings from 22.03.2021 to 28.03.2021

Name of Line	Date Trip	Time Trip	Date Sync	Time Sync	Reason	Outage Type	Voltage
Ghodbunder Gorai Line	24-03-2021	9.45	24-03-2021	14.21	CB MARSHALLING BOX HEIGHT RAISING WORK	PO	220 KV
Kharghar - Nerul	24-03-2021	11.58	24-03-2021	14.09	BUS BAR OPERATED AT NERUL	T	220 KV
Koyna (Pophali) - Kdph	24-03-2021	17.45	25-03-2021	12.4	Distance Protection	T	220 KV
Mahad - Pedambe	24-03-2021	10.35	24-03-2021	15.2	For chemical washing of insulator strings in Lote(P) MIDC area.	PO	220 KV
NERUL - SEAWOOD CABLE CKT - 1	24-03-2021	11.58	24-03-2021	14.29	BUS BAR OPERATED AT NERUL	T	220 KV
NERUL - SEAWOOD CABLE CKT - 2	24-03-2021	11.58	24-03-2021	14.32	BUS BAR OPERATED AT NERUL	T	220 KV
PARANDA BARSHI	24-03-2021	10.05	24-03-2021	22.13	Outage is Required for Quarterly Maintenance	PO	220 KV
Pedambe-Pophali	24-03-2021	9	24-03-2021	10.05	R-PH CT OIL LEAKAGE	T	220 KV
Pedhambe - Oni	24-03-2021	8.35	24-03-2021	19.05	CB mechanism overhauling work at 220kV Oni S/s.	PO	220 KV
220 KV VIRODA - AMALNER	25-03-2021	12.14	25-03-2021	16.07	Distance Protection	T	220 KV
220/110KV, 200MVA T/F-III at Mudshingi	25-03-2021	15.1	25-03-2021	15.15	Testing Work	PO	220 KV
220/132Kv 200MVA ICT-II @ Mudshingi	25-03-2021	14.55	25-03-2021	15.08	Testing Work	PO	220 KV
220/33kV 100 MVA Transformer 4 @Aarey R/S	25-03-2021	8.04	25-03-2021	22.41	Charging of 33KV GIS Board 9 section 2 through Incomer SW	PO	220 KV
Alephata-Pargaon(Kathapur)	25-03-2021	17.2	26-03-2021	2.25	For CRM&CB timing measurement work	PO	220 KV
Ambazari-Abhijeet	25-03-2021	10.49	25-03-2021	12.58	Testing Work	PO	220 KV
Aurangabad (Waluj)-Bhenda	25-03-2021	19.58	25-03-2021	21.4	Testing Work	PO	220 KV
BHIRA (T) - KARANJADE CKT - 7	25-03-2021	6.27	28-03-2021	21.34	DFCC work	PO	220 KV
Bableshtar - Bhenda	25-03-2021	14.21	25-03-2021	16.18	Faulty String replacement	EO	220 KV
Bableshtar - Bhenda	25-03-2021	18.16	25-03-2021	19.44	Testing Work	PO	220 KV
Chandrapur GCR - Sicom I	25-03-2021	12.06	25-03-2021	14.47	Meter Installation work	PO	220 KV
Chandrapur GCR - Sicom II	25-03-2021	12.07	25-03-2021	14.48	Meter Installation work	PO	220 KV
Dahanu Versova	25-03-2021	9.1	27-03-2021	14.52	220kV Circuit Breaker (252) Operating Mechanism Overhauling work of Versova- Dahanu Line Bay 2.	PO	220 KV
Dhule-Chalisagaon	25-03-2021	15.17	25-03-2021	17.16	Distance Protection	T	220 KV
Kharghar-Borivali ckt II	25-03-2021	10.01	27-03-2021	16.08	For Overhauling circuit breaker mechanism of 220kv Borivali 2 line.	PO	220 KV
Nanded - Parli Ext. Ckt I	25-03-2021	11.51	25-03-2021	14.2	Distance Protection	T	220 KV
Nerle - Dasgaon	25-03-2021	10.01	25-03-2021	18.4	Testing Work	PO	220 KV
PARLY (PG) - OSMANABAD	25-03-2021	0.29	25-03-2021	2.5	Attending Hot Spot	PO	220 KV
Parli 3 (Old Gcr)-Girwali Ckt 2	25-03-2021	10.28	16-04-2021	21.11	Railway crossing tower erection work	PO	220 KV
Pedhambe - Oni	25-03-2021	8.1	25-03-2021	20.3	CB Mechanism overhauling work	PO	220 KV
Pirangut - Hinjawadi 2	25-03-2021	9.08	25-03-2021	20.15	Restranging of conductors	PO	220 KV
220/100 Kv 100 Mva Vijai Ict 1 @Jambhul	26-03-2021	9	26-03-2021	17.12	1)Servicing of 220kV HV Isolator 2)Servicing of 100kV LV D Isolator 3)Servicing of 100kV LV C Isolator 4) Servicing of Nitrogen Injection Fire Protection System.	PO	220 KV
220/100 Kv 200 MVA ICT II @Kolshet	26-03-2021	11.56	26-03-2021	16.16	1. REF Relay Testing work by Testing Team Kalwa. 2. LV B-ph CT Oil leakage attending work. 3. TF Oil leakage attending work & RMW.	PO	220 KV
220/132KV 100MVA ICT-I@ Kathapur	26-03-2021	14.5	26-03-2021	17.43	Various DT and Routine Half Yearly Bay Maintenance work.	PO	220 KV

Transmission Line Outages/Trippings from 22.03.2021 to 28.03.2021							
Name of Line	Date Trip	Time Trip	Date Sync	Time Sync	Reason	Outage Type	Voltage
220/33kV 125 MVA Transformer 2 @REL Borivali	26-03-2021	8.49	26-03-2021	18.12	Annual Bay & Equipment maintenance.	PO	220 KV
Apta - Tambati	26-03-2021	11.15	26-03-2021	11.42	Distance Protection	T	220 KV
Bus Section II @ Kamba	26-03-2021	10.4	26-03-2021	17.2	For removal of rusted earth wire and stringing of new earth wire by agency Man power and 220 KV Kamba-Vasai line ABB make breaker overhauling.	PO	220 KV
Butibori - Khaperkheda	26-03-2021	9.55	26-03-2021	12.45	Attending Hot Spot	EO	220 KV
Khadka-Chaligaon-2	26-03-2021	14.08	26-03-2021	16.43	Distance Protection, Y-B PH.	T	220 KV
Miraj - Mhaishal	26-03-2021	16.35	26-03-2021	18.12	Line isolator maintenance & to attend the hotspot of line jump.	PO	220 KV
Nagothane - Posco	26-03-2021	9.37	26-03-2021	18.3	Insulator string replace & Line signature test.	PO	220 KV
Padgha - Temghar I	26-03-2021	9.47	26-03-2021	15.41	For testing of Relay for auto recloser operation.	PO	220 KV
Padghe - Kambha	26-03-2021	10.21	26-03-2021	18.29	Main Bus Section-2 @ kamba.	PO	220 KV
Salsette - Saki 7	26-03-2021	2.09	27-03-2021	15.57	Distance Protection	T	220 KV
Tambati - Adlabs	26-03-2021	11.15	26-03-2021	12.02	Distance Protection	T	220 KV
Vasai Kamba	26-03-2021	10.08	26-03-2021	19.03	Main Bus Section-2 @ kamba.	PO	220 KV
karad - Dasgaon	26-03-2021	10.25	26-03-2021	19.49	Relay testing & bay maintenance work.	PO	220 KV
220/132 KV 100MVA ICT-I @ Belewadi	27-03-2021	10.03	27-03-2021	13.22	Diagnostic testing work.	PO	220 KV
220/132 Kv 200 MVA ICT I @Dhule	27-03-2021	9.21	27-03-2021	11.2	Quarterly Maintainance Work	PO	220 KV
220/132 Kv 200 Mva Bbl Ict 3 @Padegaon	27-03-2021	11.55	27-03-2021	14.02	Proper tightness of HV B CT.	T	220 KV
220/132 Kv 200 Mva Vijay Ict 2 @Chaligaon	27-03-2021	10.2	27-03-2021	11.56	Attending Hot Spot	EO	220 KV
220/132KV 100MVA ICT-II@Belwandi	27-03-2021	13.4	27-03-2021	15	Diagnostic testing work.	PO	220 KV
220 KV DEEPNAGAR - VIRODA	27-03-2021	18.15	27-03-2021	21.23	LA replacement work at Viroda.	PO	220 KV
Bableshtar - Alephata ckt I	27-03-2021	14.51	27-03-2021	15.22	Distance Protection	T	220 KV
Boisar(M) - Ghodbunder I	27-03-2021	12.09	27-03-2021	19.34	Distance Protection	T	220 KV
Jamde-Dondaicha 1	27-03-2021	12.49	27-03-2021	15.44	Distance Protection	T	220 KV
Kamba - Kolshet	27-03-2021	9.5	27-03-2021	19.45	Chemical cleaning of insulator	PO	220 KV
Kolshet-Roma	27-03-2021	12.3	27-03-2021	13.01	Distance Protection	T	220 KV
Mururd - Tuljapur	27-03-2021	13.02	27-03-2021	18.55	Distance Protection	T	220 KV
Padghe - Wada	27-03-2021	12.3	27-03-2021	12.48	Distance Protection	T	220 KV
Roma-Bhavegar	27-03-2021	12.3	27-03-2021	13.01	Distance Protection	T	220 KV
Theur-Jejuri	27-03-2021	9	27-03-2021	16.17	Replacement of PID faulty insulator string.	PO	220 KV
Warora - Warora Rly Tss 2	27-03-2021	12.42	27-03-2021	13.35	ABT meter replacement work.	PO	220 KV
220/100 Kv 100 Mva Cgl Ict 1 @Taloja	28-03-2021	9.27	28-03-2021	17.12	EMCO ICT LV side CT Replacement work	PO	220 KV
Aurangabad (waluj)-Taptitanda ckt-2	28-03-2021	11.03	28-03-2021	16.13	For making LILO Arrangement At 220 KV GEORAI.	PO	220 KV
Shivajinagar - Malegaon	28-03-2021	13.26	28-03-2021	15.07	Back UP B-PH.	T	220 KV
Sonkhar - Trombay	28-03-2021	9.28	28-03-2021	17.12	For MMRDA Pile Foundation Work.	PO	220 KV
Karad Solapur (PG)	03-05-2017	11:49		Continued.	Line Converted As 220 Kv Solapur (PG)-Jeur From LOC 403	PO	400 KV
400/220kv 315 MVA ICT I @ KOLHAPUR-III (TALANDGE)	10-08-2020	9.58		Continued.	Replacement of existing 315 MVA ICT by 3*167 MVA ICT.	PO	400 KV
400/220/33 Kv 500 Mva ICT III @Aurangabad (Waluj)	15-03-2021	12.29	27-03-2021	14.55	New repaired Y phase Unit to be commissioned (kept on humming from 26.03.2021, 18.45).	PO	400 KV

Transmission Line Outages/Trippings from 22.03.2021 to 28.03.2021

Name of Line	Date Trip	Time Trip	Date Sync	Time Sync	Reason	Outage Type	Voltage
Dhule Sar'Sarovar I	21-03-2021	19.54	22-03-2021	6.44	Over Voltage	HT	400 KV
400/220/33kv 315mva Ict3 @Lonikand	22-03-2021	12.04	27-03-2021	17.58	For Servicing/Overhauling Of 400KV CGL Make C.B(In Service Through TBC)	PO	400 KV
Dhule Sar'Sarovar II	22-03-2021	22.01	23-03-2021	6.59	Over Voltage	HT	400 KV
Jaigad-Karad Ckt-I	22-03-2021	10.53	22-03-2021	14.54	Attending Hot Spot At 29B Rph IPs Clamp Towards LA Side.	EO	400 KV
Koradi-Khaperkheda li	22-03-2021	11.02	22-03-2021	13.56	Attend Red Hot Spot On 29B Isolator Fixed Contact Hanger Rod Connected To Bus By Hot Line Units.	PO	400 KV
Padgha Tarapur I	22-03-2021	17.21	22-03-2021	17.55	Tripped On PDR At Padghe End.	T	400 KV
400/220/33 315MVA ICT-III @ KHADKA	23-03-2021	9.34	23-03-2021	17.55	For attending Oil Leakage and R/M work	PO	400 KV
Dhule Sar'Sarovar I	23-03-2021	22.02	24-03-2021	6.24	Over Voltage	HT	400 KV
Warora-Adani(Tiroda)1	23-03-2021	9.32	23-03-2021	11.37	Tripped at Tiroda end only	T	400 KV
400/220kv, 500 MVA ICT-II @Deepnagar	24-03-2021	13.18	24-03-2021	20.44	for quarterly bay maint work and for ICT-II LV CB to Line isolator jumper and bus isolator (29A & B) common T jumper replacement work	PO	400 KV
Babhaleshwar - Padghe-I	24-03-2021	16.53	24-03-2021	20.13	ATTENDING HOTSPOT AT BABLESHWAR END	T	400 KV
N.Koyna-Karad -Ckt II	24-03-2021	8.24	24-03-2021	19.18	COLD WASHING OF DISC INSULATOR STRING	PO	400 KV
Solapur - Parli(PG) I	24-03-2021	11.18	24-03-2021	16.51	(1) Bushing & winding C & Tan delta, Winding resistance & IR measurement of reactor. (2)Bay maintenance work. &Hardware Tightening Work.	PO	400 KV
400/220 kV 500 MVA ICT III @ Jejuri	25-03-2021	9.51	25-03-2021	20.24	Testing Work	PO	400 KV
Dhule Khandwa I	25-03-2021	13.19	25-03-2021	20.17	Attending Insulator Flashover	PO	400 KV
Padgha - Boisar (PG)	25-03-2021	17.08	25-03-2021	18.45	Taking line Reactor In service	PO	400 KV
400/11.5 KV 90MVA Station T/F V @ Chandrapur	26-03-2021	12.32	26-03-2021	18.38	AMR Metering Work.	PO	400 KV
Dhule Sar'Sarovar II	26-03-2021	20.14	27-03-2021	7.23	Over Voltage	HT	400 KV
Dhule- Bableshwar - I	26-03-2021	17.3	26-03-2021	21.23	For attending red hot spot of 89B Isol.Yph bottom side.	EO	400 KV
Jaigad-New Koyna Ckt-II	26-03-2021	9.1	26-03-2021	16.2	For Earthing strengthening works.	PO	400 KV
N.Koyna-Karad -Ckt II	26-03-2021	8.2	26-03-2021	18.51	Routine Maintenance Work	PO	400 KV
400/220/33kv 315mva Ict3 @Lonikand	27-03-2021	12.04	27-03-2021	18	For Servicing/Overhauling of 400kv CGL Make C.B.	PO	400 KV
Dhule Sar'Sarovar I	27-03-2021	18.13	29-03-2021	6.39	Over Voltage	HT	400 KV
N.Koyna-Karad -Ckt I	27-03-2021	8.01	27-03-2021	19.19	Cold line washing of disc insulator.	PO	400 KV
Akola Wardha li	28-03-2021	22.48	29-03-2021	2.26	DT Received.	T	400 KV
Padghe - Kalwa- I	28-03-2021	4.48	28-03-2021	8.35	To attend Hot Spot	EO	400 KV
Chandrapur - Padghe Hvdc Pole 2	24-03-2021	22.2	25-03-2021	2.01	Distance Protection	T	500 KV
765/400KV 1500MVA ICT-II @ Koradi-III	25-03-2021	10.03	25-03-2021	13.01	Maintenance of ICT	PO	765 KV