

State Load Despatch Center,Airoli (MSETCL)
Power System Position from 19/Apr/2021 to 25/Apr/2021

Supply Position During Morning Peak (MW)

Date	Time	MSGENCO				Central Sector Receipt	Wind	CPP	SOLAR	TPCL Exch.	MSEDCL Catered Demand	Load Sheddin g(LS)	MSEDCL Demand (Incl. LS)	TPCL Gen.	R-INFRA Gen.	State Demand Met	State Demand (Incl. LS)	Freq.
		THM	HYDRO	GAS	Total													
		MW	MW	MW	MW	MW	MW	MW	MW	MW	MW	MW	MW	MW	MW	MW	MW	Hzs
19-04-2021	12 Hrs	6500	1333	294	8127	8179	368	5474	1132	-1116	22164	0	22164	1131	500	24911	24911	50.04
20-04-2021	12 Hrs	6024	802	284	7110	8763	488	5247	1163	-1083	21688	0	21688	1095	501	24367	24367	49.96
21-04-2021	11 Hrs	5802	1112	275	7189	9035	443	5006	952	-973	21652	0	21652	1047	501	24173	24173	50.02
22-04-2021	12 Hrs	5896	604	272	6772	9011	532	4986	1095	-1055	21342	0	21342	1075	500	23972	23972	49.99
23-04-2021	12 Hrs	5775	1024	273	7072	8409	153	5598	935	-891	21276	0	21276	1126	501	23794	23794	50.01
24-04-2021	12 Hrs	6001	517	273	6791	8614	163	5604	1107	-869	21410	0	21410	1017	392	23688	23688	49.99
25-04-2021	12 Hrs	6081	575	262	6918	7948	141	5602	1114	-863	20860	0	20860	769	406	22898	22898	49.95
Maximum		6500	1333	294	8127	9035	532	5604	1163	-863	22164	0	22164	1131	501	24911	24911	50.04
Minimum		5775	517	262	6772	7948	141	4986	935	-1116	20860	0	20860	769	392	22898	22898	49.95
Average		6011	852	276	7140	8566	327	5360	1071	-979	21484	0	21484	1037	472	23972	23972	49.99

Supply Position During Day Peak (MW)

Date	Time	MSGENCO				Central Sector Receipt	Wind	CPP	SOLAR	TPCL Exch.	MSEDCL Catered Demand	Load Sheddin g(LS)	MSEDCL Demand (Incl. LS)	TPCL Gen.	R-INFRA Gen.	State Demand Met	State Demand (Incl. LS)	Freq.
		THM	HYDRO	GAS	Total													
		MW	MW	MW	MW	MW	MW	MW	MW	MW	MW	MW	MW	MW	MW	MW	MW	Hzs
19-04-2021	15 Hrs	6452	929	273	7654	8554	437	5504	954	-1144	21959	0	21959	1090	500	24693	24693	49.87
20-04-2021	13 Hrs	6032	1086	273	7391	8370	481	5235	1136	-1070	21543	0	21543	1111	503	24227	24227	50.07
21-04-2021	15 Hrs	6004	862	274	7140	8977	472	5170	946	-984	21721	0	21721	1022	501	24228	24228	49.97
22-04-2021	15 Hrs	6071	752	282	7104	8851	94	5555	865	-1056	21414	0	21414	1072	501	24042	24042	49.89
23-04-2021	16 Hrs	5903	755	272	6930	8309	511	5651	633	-866	21168	0	21168	1106	500	23640	23640	50.01
24-04-2021	16 Hrs	5766	927	272	6965	8443	253	5518	702	-747	21134	0	21134	1062	500	23443	23443	49.96
25-04-2021	15 Hrs	5980	799	271	7050	8416	100	5614	838	-806	21212	0	21212	878	500	23396	23396	50.01
Maximum		6452	1086	282	7654	8977	511	5651	1136	-747	21959	0	21959	1111	503	24693	24693	50.07
Minimum		5766	752	271	6930	8309	94	5170	633	-1144	21134	0	21134	878	500	23396	23396	49.87
Average		6030	873	274	7176	8560	335	5464	868	-953	21450	0	21450	1049	501	23953	23953	49.97

Supply Position During Evening Peak (MW)

Date	Time	MSGENCO				Central Sector Receipt	Wind	CPP	SOLAR	TPCL Exch.	MSEDCL Catered Demand	Load Sheddin g(LS)	MSEDCL Demand (Incl. LS)	TPCL Gen.	R-INFRA Gen.	State Demand Met	State Demand (Incl. LS)	Freq.
		THM	HYDRO	GAS	Total													
		MW	MW	MW	MW	MW	MW	MW	MW	MW	MW	MW	MW	MW	MW	MW	MW	Hzs
19-04-2021	22 Hrs	6170	913	296	7379	5928	1191	5597	0	-860	19235	0	19235	1084	501	21680	21680	49.98
20-04-2021	22 Hrs	5928	629	286	6843	6684	963	5313	0	-718	19085	0	19085	1211	501	21515	21515	49.98
21-04-2021	22 Hrs	6030	751	296	7077	6416	450	5781	0	-643	19081	0	19081	1246	501	21471	21471	49.97
22-04-2021	22 Hrs	5987	484	286	6756	6491	793	5743	0	-857	18926	0	18926	1036	502	21322	21322	49.98
23-04-2021	22 Hrs	6044	559	286	6889	6376	423	5757	0	-774	18671	0	18671	1036	501	20982	20982	49.92
24-04-2021	22 Hrs	5954	692	276	6922	6570	526	5558	0	-687	18889	0	18889	1169	502	21247	21247	49.98
25-04-2021	22 Hrs	5779	276	401	6456	6448	1008	5256	0	-1218	17950	0	17950	878	286	20332	20332	49.96
Maximum		6170	913	401	7379	6684	1191	5781	0	-643	19235	0	19235	1246	502	21680	21680	49.98
Minimum		5779	276	276	6456	5928	423	5256	0	-1218	17950	0	17950	878	286	20332	20332	49.92
Average		5985	615	304	6903	6416	765	5572	0	-822	18834	0	18834	1094	471	21221	21221	49.97

Supply Position During Night Off Peak (MW)

Date	Time	MSGENCO				Central Sector Receipt	Wind	CPP	SOLAR	TPCL Exch.	MSEDCL Catered Demand	Load Sheddin g(LS)	MSEDCL Demand (Incl. LS)	TPCL Gen.	R-INFRA Gen.	State Demand Met	State Demand (Incl. LS)	Freq.
		THM	HYDRO	GAS	Total													
		MW	MW	MW	MW	MW	MW	MW	MW	MW	MW	MW	MW	MW	MW	MW	MW	Hzs
19-04-2021	4 Hrs	6161	330	288	6779	6643	1138	5523	0	-1182	18901	0	18901	538	331	20952	20952	49.98
20-04-2021	5 Hrs	6283	756	308	7347	6527	1159	5301	0	-714	19620	0	19620	784	501	21619	21619	50.01
21-04-2021	4 Hrs	5813	771	308	6892	7150	1042	5045	0	-740	19389	0	19389	786	499	21414	21414	49.90
22-04-2021	4 Hrs	5960	424	277	6662	7061	953	5707	0	-857	19526	0	19526	626	501	21510	21510	50.02
23-04-2021	4 Hrs	6041	359	288	6688	6983	525	5700	0	-645	19251	0	19251	835	501	21232	21232	50.03
24-04-2021	4 Hrs	6027	518	298	6843	6651	516	5669	0	-644	19035	0	19035	832	500	21011	21011	49.99
25-04-2021	23 Hrs	5937	374	412	6723	6738	801	5526	0	-1297	18491	0	18491	822	336	20946	20946	49.95
Maximum		6283	771	412	7347	7150	1159	5707	0	-644	19620	0	19620	835	501	21619	21619	50.03
Minimum		5813	330	277	6662	6527	516	5045	0	-1297	18491	0	18491	538	331	20946	20946	49.90
Average		6032	505	311	6848	6822	876	5496	0	-868	19173	0	19173	746	453	21240	21240	49.98

Details of Supply Position (MUs)

Date	MSGENCO				Pench (MS)	Central Sector Receipt	Central Sector Share	WIND	CPP	SOLAR	TPCL Gen.	R-INFRA Gen.	TPCL Exch.	Energy Requirement		
	THM	HYDRO	GAS	Total										MSEDCL	MUMBAI	STATE
	Mus	Mus	Mus	Mus	Mus	Mus	Mus	Mus	Mus	Mus	Mus	Mus	Mus	Mus	Mus	Mus
19-04-2021	151.760	22.375	6.794	180.929	0.135	170.772	172.924	19.849	132.710	8.410	22.587	11.518	-24.584	488.086	58.689	546.775
20-04-2021	147.097	22.789	6.818	176.704	0.000	176.696	178.628	21.841	126.530	8.668	24.100	11.957	-21.800	488.639	57.857	546.496
21-04-2021	140.960	21.505	6.831	169.296	0.107	188.720	190.995	14.537	126.667	7.819	24.001	11.590	-20.531	486.508	56.122	542.630
22-04-2021	143.655	14.791	6.750	165.196	0.066	183.285	187.664	15.227	134.355	7.998	23.052	12.013	-21.553	484.508	56.618	541.126
23-04-2021	142.375	16.983	6.792	166.150	0.048	179.246	180.642	10.859	136.000	7.409	22.982	11.411	-20.230	479.434	54.623	534.057
24-04-2021	143.934	16.229	6.808	166.971	0.271	178.933	183.074	9.974	134.755	8.311	23.664	11.498	-17.567	481.377	52.729	534.106
25-04-2021	144.191	15.560	7.342	167.093	0.245	175.225	179.987	10.531	133.440	7.694	20.416	10.604	-20.541	473.442	51.561	525.003
Maximum	151.760	22.789	7.342	180.929	0.271	188.720	190.995	151.760	136.000	8.668	24.100	12.013	-17.567	488.639	58.689	546.775
Minimum	140.960	14.791	6.750	165.196	0.000	170.772	172.924	140.960	126.530	7.409	20.416	10.604	-24.584	473.442	51.561	525.003
Average	144.853	18.605	6.876	170.334	0.125	178.982	181.988	144.853	132.065	8.044	22.972	11.513	-20.972	483.142	55.457	538.599

Details of Koyna Water Consumption (in TMC)			
Date	For the Day	For the Month	Balance
19-04-2021	0.340	6.037	14.585
20-04-2021	0.346	6.383	14.239
21-04-2021	0.322	6.705	13.917
22-04-2021	0.147	6.853	13.769
23-04-2021	0.227	7.080	13.542
24-04-2021	0.212	7.292	13.330
25-04-2021	0.192	7.484	13.138

State Load Despatch Center,Airoli (MSETCL)
Central Sector Share/Drawal from 19/Apr/2021 to 25/Apr/2021

Date	DAY	Central Sector Share		Total Interstate		Total Share		Total Drawal		Overdrawal(+) /	
		MUs	Avg. MW	MUs	Avg. MW	MUs	Avg. MW	MUs	Avg. MW	MUs	Avg. MW
		1		2		1+2=3		4		3-4=5	
19-04-2021	MONDAY	121.285	7154	51.639	2152	172.924	7205	170.772	7115	-2.152	-90
20-04-2021	TUESDAY	125.005	7389	53.623	2234	178.628	7443	176.696	7362	-1.932	-80
21-04-2021	WEDNESDAY	126.359	7893	64.636	2693	190.995	7958	188.720	7863	-2.275	-95
22-04-2021	THURSDAY	128.363	7760	59.301	2471	187.664	7819	183.285	7637	-4.379	-182
23-04-2021	FRIDAY	127.897	7474	52.745	2198	180.642	7527	179.246	7469	-1.396	-58
24-04-2021	SATURDAY	128.648	7574	54.426	2268	183.074	7628	178.933	7456	-4.141	-173
25-04-2021	SUNDAY	129.912	7449	50.075	2086	179.987	7499	175.225	7301	-4.762	-198
Total		887.470		386.444		1273.914		1252.877		-21.037	

Generator Unit Outages/Trippings from 19.04.2021 to 25.04.2021						
Name of Unit	Date Trip	Time Trip	Date Sync	Time Sync	Reason	Outage Type
SWPGPL U-1	16-02-2016	17.09		Continued.	No PPA.	FORCED
PGPL U1	07-02-2017	17.3		Continued.	No Schedule (NO PPA)	FORCED
PGPL U2	07-02-2017	17.3		Continued.	No Schedule.(NO PPA)	FORCED
IEPL Unit 1	28-08-2018	21.26		Continued.	No PPA	FORCED
VIPL U-1	29-12-2018	0.3		Continued.	Coal Shortage. (NO PPA From 20.05.2019)	FORCED
VIPL U-2	17-01-2019	0.15		Continued.	Coal shortage.(NO PPA From 20.05.2019)	FORCED
Uran Unit 7	25-05-2020	12.51		Continued.	Turbine Blade Failure	FORCED
JSW (J) U4	11-04-2021	3.02	24-05-2021	6.17	NO SCHEDULE.	FORCED
Khaparkheda Unit 2	15-04-2021	16.54	27-05-2021	14.06	Critical coal stock position	FORCED
Chandrapur Unit 6	16-04-2021	23.58	21-04-2021	12.28	Boiler validity expiry.	FORCED
Adani U-3	17-04-2021	20.55	21-04-2021	13.28	APH-A Hot Bellow leakage	FORCED
RPL(AMT) U-1	20-04-2021	1	28-04-2021	23.58	Bottom Ash System Problem.	FORCED
RPL(AMT) U-2	21-04-2021	1	29-04-2021	1.56	Due to coal issue.	FORCED
Ghatghar Unit-1	18-04-2021	18	25-04-2021	17.45	Bypass Work.	FORCED
Chandrapur Unit-8	20-04-2021	11	24-04-2021	6.05	Boiler Tube Leakage	FORCED
Koradi Unit 6	21-04-2021	4.12	23-04-2021	8.42	Boiler Tube Leakage	FORCED
Koradi Unit 10	23-04-2021	8.56	24-04-2021	12.37	Feed water Flow Low	FORCED
Koyna Unit 6	22-04-2021	12		Continued.	UGC Oil Cooler Leakage. (Converted to Capital Overhaul from 08.00Hrs DT.23-4-2021)	PLANNED
Bhusawal Unit 5	24-04-2021	10.03	26-04-2021	9.04	Boiler Tube Leakage	FORCED
Koradi Unit 9	24-04-2021	14.59	07-05-2021	6.01	Boiler Tube Leakage	FORCED
SWPGPL U-2	25-04-2021	23.51	01-05-2021	23.58	ID Fan Vibrations	FORCED
Nasik Unit 3	03-12-2020	6.45		Continued.	PA Fan Problem (Under Case 4 Bidding From 11.00Hrs DT. 21-01-2021).	FORCED
Koyna Unit 11	19-01-2021	10.05	29-05-2021	15.2	Tripped on stator earth fault (will not be available till dt.24.05.21)	FORCED
JSW (J) U1	01-02-2021	18	04-05-2021	14.52	Due to turbine vibration high	FORCED
Chandrapur Unit 7	20-02-2021	23.43		Continued.	Generator Earth Fault.	FORCED
Chandrapur Unit 4	16-03-2021	8.08	27-05-2021	9.01	Boiler Tube Leakage(converted to Capital overhaul)	PLANNED
Uran Unit 5	02-04-2021	23.19	25-04-2021	17.28	Gas shortage	FORCED

Transmission Line Outages/Trippings from 19.04.2021 to 25.04.2021

Name of Line	Date Trip	Time Trip	Date Sync	Time Sync	Reason	Outage Type	Voltage
Mudshingi Chikodi	24-09-2019	17.12		Continued.	No Schedule(Charge from Mudshingi end only)	PO	220 KV
Talandage - Chikodi	01-10-2019	17.1		Continued.	No Schedule(Close at Chikodi end only)	PO	220 KV
Trombay - Kalwa	14-04-2021	12.27	22-04-2021	18.26	Conductor replacement.	PO	220 KV
220/110 Kv 200 Mva Vel Ptr 1 @Kolhapur-Ii (Mudshingi)	19-04-2021	10	19-04-2021	15.1	Quarterly Maintainance Work	PO	220 KV
220/33kv 100 MVA Transformer 3 @Ghodbunder R/S	19-04-2021	9.43	19-04-2021	11.04	PT Fuse replacement of 33kv Sw. No. 23 (R phase).	PO	220 KV
Ambazari-Abhijeet	19-04-2021	9.29	19-04-2021	12.54	For Yearly Diagnostic testing Work.	PO	220 KV
Badnera - Nandgaonpeth	19-04-2021	6.4	19-04-2021	8.57	Replacement of flashover Discs at Location no.67 R-PH 2.Line Signature Analysis.	PO	220 KV
Hingoli- Girawali	19-04-2021	11.42	19-04-2021	12.01	Distance Protection	T	220 KV
Jejuri- Ismt- Lonand	19-04-2021	17.26	19-04-2021	20.36	Lowering of 22KV WalheAG line in span 46 to 47 of 220 kv Jejuri - Lonand line due to low clearance.	PO	220 KV
Nalasopara-Boisar	19-04-2021	9.16	19-04-2021	19.12	Pre monsoon maintenance Work & Replacement Of stub bus Conductor At 220/22 kv.	PO	220 KV
ACCIL - Apta	20-04-2021	12.25	20-04-2021	18	220kv ACCIL Busbar Protection Relay Online Testing Work.	PO	220 KV
Karad(400kv) - Ogalewadi Ckt 2	20-04-2021	10.39	20-04-2021	16.47	CT Protection and Metering Core Separation	PO	220 KV
Padgha - Temghar I	20-04-2021	19.03	20-04-2021	23.12	Replacement Of Distance Relay.	PO	220 KV
Vankuswade - Kdph	20-04-2021	9.3	20-04-2021	19.4	Main Bus outage at Vankuswade.	PO	220 KV
Vankuswadi- Ajinkyatara	20-04-2021	10.15	20-04-2021	18.55	Outage At Main Bus @ Vankuswade.	PO	220 KV
220/132 Kv 100mva Ict 2 @South Solapur (Kumbhari)	21-04-2021	11.2	21-04-2021	13	Quarterly Maintainance Work	PO	220 KV
Kamba - Kolshet	21-04-2021	9.15	21-04-2021	19.24	Online stringing of OPGW cable on 220KV Kamba Kolshet line.	PO	220 KV
Kandalgaon - Bhira	21-04-2021	12.51	21-04-2021	18.15	Jumper nut bolt tightening and hotspot attending.	PO	220 KV
Khaparkheda-Ambazari-I	21-04-2021	7.32	21-04-2021	21.47	Shifting CKT on ERS.	PO	220 KV
Khaparkheda-Kanhan	21-04-2021	7.32	21-04-2021	21.21	Shifting CKT on ERS.	PO	220 KV
Niwali - Pawas Line	21-04-2021	11.36	21-04-2021	13.49	Bypass oil leakage CC (R ph).	EO	220 KV
Osmanabad - Solapur (Bale)	21-04-2021	9.5	21-04-2021	11.29	Quarterly Maintainance Work	PO	220 KV
220/132 Kv 200 Mva Bbl Ict 1 @Beed	22-04-2021	14.05	22-04-2021	18.4	Safety valve replacement work.	PO	220 KV
ALKUD - MENDHEGIRI CKT - 2	22-04-2021	14.02	22-04-2021	15.58	Final stringing of earth wire from Loc. no -55A to 56 of 132 kv K'Mhankal-Jath line.	PO	220 KV
Bhosari- Bhosari 2	22-04-2021	10.2	22-04-2021	14.55	Attending 220k KV CB TC-1 Coil faulty problem.	PO	220 KV
KORADI 2 - KAULEWADA CKT - II	22-04-2021	7.59	22-04-2021	14.08	Replacement of b ph top broken suspension disc string at loc no. 235, 252 & for attending loose jumper nutbolt of y ph koradi end at tention loc no. 213"	PO	220 KV
Khaparkheda-Ambazari-I	22-04-2021	8.31	22-04-2021	16.52	Shifting of 220kv Kanhan & 220kv Ambazari ckt on ERS.	PO	220 KV
Nanded-Parbhani	22-04-2021	8.02	22-04-2021	11.45	Attending hot spot on yph wave trap stub bus t clamp nut bolt and yph ct p1 side nut bolted clamp."	PO	220 KV
Pophali - Pedambe II	22-04-2021	8.2	22-04-2021	18	Routine Maintenance Work	PO	220 KV

Transmission Line Outages/Trippings from 19.04.2021 to 25.04.2021							
Name of Line	Date Trip	Time Trip	Date Sync	Time Sync	Reason	Outage Type	Voltage
Sahara-Urse	22-04-2021	13.18	22-04-2021	20.21	For load management.	HT	220 KV
Urse - Talegaon (Ambi) Ckt 1	22-04-2021	12.44	22-04-2021	20.17	Distance Protection	T	220 KV
karad - Dasgaon	22-04-2021	16.29	22-04-2021	18.17	New PT extension to metering Ckt., removing of old PT and CT testing.	PO	220 KV
Adlabs - Pedambe	23-04-2021	8.35	23-04-2021	18.2	Routine Maintenance Work	PO	220 KV
Babhaleshwar - Degaon Rangari	23-04-2021	16.2	23-04-2021	19.5	Distance Protection	T	220 KV
Gadchandur - Grace	23-04-2021	8.24	23-04-2021	14.02	Quarterly Maintenance Work	PO	220 KV
Koradi-Khaperkheda	23-04-2021	10.21	23-04-2021	15.33	LA Replacement	PO	220 KV
Padghe - Wada	23-04-2021	9.57	23-04-2021	19.04	Replacement of faulty Insulator Strings	PO	220 KV
Wathar - Mudshingi 3 Line	23-04-2021	10.22	23-04-2021	12.17	Quarterly Maintenance Work	PO	220 KV
Chalisingaon -Babhaleshwar	24-04-2021	9.52	08-05-2021	22.52	For Shifting/Erection Work of monopole Tower Work For samruddhi express Highway work 4 nos of monopole erection & 2nos of tower erection work. Dismantling of 2nos of tower loc no.220-223.	PO	220 KV
MAHAPE - RELIANCE GIS	24-04-2021	10.32	24-04-2021	11.47	To attend Hot Spot	EO	220 KV
Niwali - Pawas Line	24-04-2021	9.26	24-04-2021	17.18	For Oil Leaked R PH CT Replacement, CT C & Tan delta Testing & Bay Cold Washing Work.	PO	220 KV
Solapur(Bale) - Tuljapur	24-04-2021	16.28	24-04-2021	19.43	Project work.	EO	220 KV
Jamde-Dondaicha 1	25-04-2021	12.16	25-04-2021	17.35	Distance Protection	T	220 KV
Sonkhar - Trombay	25-04-2021	6.4	25-04-2021	15.31	1.Commissioning of Islanding Panel for 220 KV Sonkhar Trombay Line & replacement of R ph LA Bottom Stag due to crack observed.	PO	220 KV
TPC Borivali Aarey Line 1	25-04-2021	14.17	25-04-2021	19.43	Islanding main-1 Relay Replacement & Testing.	PO	220 KV
Karad Solapur (PG)	03-05-2017	11:49		Continued.	Line Converted As 220 Kv Solapur (PG)-Jeur From LOC 403	PO	400 KV
400/220kv 315 MVA ICT I @ KOLHAPUR-III (TALANDGE)	10-08-2020	9.58		Continued.	Replacement of existing 315 MVA ICT by 3*167 MVA ICT.	PO	400 KV
Dhule Sar'Sarovar I	19-04-2021	18.45	20-04-2021	9.54	Over Voltage	HT	400 KV
Lonikand 1 - Talegaon(Pgcil)	19-04-2021	18.19	19-04-2021	21.1	Distance Protection	T	400 KV
Padghe - Nagothane - II	19-04-2021	9.16	19-04-2021	19.12	4 no of string replacement work done at loc no 101A.	EO	400 KV
Warora-Tirora-li	19-04-2021	13.46	19-04-2021	15.47	Warora End B-PH D=114Km If=2.84KA Tiroda End B-PH Z1 D=105 Km If=3.19 Ka.	T	400 KV
Dhule Sar'Sarovar II	20-04-2021	18.29	22-04-2021	6.05	Over Voltage	HT	400 KV
Padghe - Nagothane - II	20-04-2021	10.44	20-04-2021	16.58	String Replacement Work	EO	400 KV
Akola Wardha I	21-04-2021	9.19	05-05-2021	17.35	Line diversion works under consultancy due to upcoming Nagpur Mumbai super communication expressway (Samruddhi highway).	PO	400 KV
Akola Wardha li	21-04-2021	9.19	05-05-2021	18.35	Line diversion works under consultancy due to upcoming Nagpur Mumbai super communication expressway (Samruddhi highway)	PO	400 KV
Babhaleshwar - Padghe-I	21-04-2021	4.58	21-04-2021	7.59	Distance Protection	T	400 KV
Girwali-Solapur (Lamboti)	21-04-2021	11.1	21-04-2021	19.15	Fixing of missing VD.	PO	400 KV
Jaigad-Karad Ckt-I	21-04-2021	9.1	21-04-2021	13.23	Hotline insulator washing.	PO	400 KV

Transmission Line Outages/Trippings from 19.04.2021 to 25.04.2021

Name of Line	Date Trip	Time Trip	Date Sync	Time Sync	Reason	Outage Type	Voltage
Jaigad-Karad Ckt-II	21-04-2021	9.1	21-04-2021	13.23	Hotline insulator washing.	PO	400 KV
Padghe - Nagothane - I	21-04-2021	2.56	21-04-2021	19.16	Distance Protection	T	400 KV
Deepnagar Waluj 1	22-04-2021	23.47	23-04-2021	18.12	Distance Protection	T	400 KV
Deepnagar Waluj 1	22-04-2021	15.23	22-04-2021	22.01	Distance Protection	T	400 KV
Dhule Sar'Sarovar II	22-04-2021	18.29	22-04-2021	6.05	Over Voltage	HT	400 KV
Jaigad-Karad Ckt-II	22-04-2021	9.53	22-04-2021	17.07	Hotline insulator washing.	PO	400 KV
Karad-Jaigad - I	22-04-2021	9.53	22-04-2021	17.01	Hotline insulator washing.	PO	400 KV
400/220/33 Kv 315 MVA ICT-II @Aurangabad (Waluj)	23-04-2021	10.27	24-04-2021	16.25	Routine Maintenance Work	PO	400 KV
Dhule Sar'Sarovar I	23-04-2021	18.07	26-04-2021	7.17	Over Voltage	HT	400 KV
N.Koyna-Karad -Ckt II	23-04-2021	9.29	23-04-2021	16.49	Routine Maintenance Work	PO	400 KV
Chandrapur II- Warora ckt II	24-04-2021	7.4	24-04-2021	14.01	Diagnostic Testing Work.	PO	400 KV
Ektuni - Akola II Ckt I	06-04-2021	6.46	20-04-2021	11.58	Nagpur-Mumbai Express Highway Work.	PO	765 KV