

State Load Despatch Center,Airoli (MSETCL)
Power System Position from 25/May/2015 to 31/May/2015

Supply Position During Morning Peak (MW)

Date	Time	MSGENCO				Central Sector Receipt	Wind	CPP	SOLAR	TPCL Exch.	MSEDCL Catered Demand	Load Shedding(LS)	MSEDCL Demand (Incl. LS)	TPCL Gen.	R-INFRA Gen.	State Demand Met	State Demand (Incl. LS)	Freq.
		THM	HYDRO	GAS	Total													
		MW	MW	MW	MW	MW	MW	MW	MW	MW	MW	MW	MW	MW	MW	MW	MW	Hzs
25/05/2015	12 Hrs	4845	1980	275	7100	5382	1216	4193	169	-1562	16498	45	16543	1229	505	19794	19839	49.88
26/05/2015	12 Hrs	5084	1832	280	7196	5371	849	4225	178	-1504	16315	274	16589	1291	513	19623	19897	49.87
27/05/2015	11 Hrs	5570	1895	272	7737	5119	629	4676	151	-1423	16889	99	16988	1172	508	19992	20091	49.88
28/05/2015	12 Hrs	5575	2141	270	7986	5325	436	4594	162	-1543	16960	51	17011	1237	508	20248	20299	49.77
29/05/2015	12 Hrs	5409	1672	268	7349	5079	322	4537	184	-1525	15946	47	15993	1250	518	19239	19286	49.88
30/05/2015	12 Hrs	5811	509	279	6599	4866	312	4588	134	-1517	14982	48	15030	1063	512	18074	18122	49.92
31/05/2015	12 Hrs	5774	1259	275	7308	4214	137	4453	106	-1163	15055	48	15103	699	517	17434	17482	49.99
Maximum		5811	2141	280	7986	5382	1216	4676	184	-1163	16960	274	17011	1291	518	20248	20299	50
Minimum		4845	509	268	6599	4214	137	4193	106	-1562	14982	45	15030	699	505	17434	17482	50
Average		5438	1613	274	7325	5051	557	4467	155	-1462	16092	45	16180	1134	512	19201	19288	50

Supply Position During Day Peak (MW)

Date	Time	MSGENCO				Central Sector Receipt	Wind	CPP	SOLAR	TPCL Exch.	MSEDCL Catered Demand	Load Shedding(LS)	MSEDCL Demand (Incl. LS)	TPCL Gen.	R-INFRA Gen.	State Demand Met	State Demand (Incl. LS)	Freq.
		THM	HYDRO	GAS	Total													
		MW	MW	MW	MW	MW	MW	MW	MW	MW	MW	MW	MW	MW	MW	MW	MW	Hzs
25/05/2015	15 Hrs	5134	1663	275	7072	5536	995	4295	147	-1547	16498	38	16536	1253	505	19803	19841	49.81
26/05/2015	16 Hrs	5792	1687	280	7759	5604	1022	3795	96	-1589	16687	53	16740	1231	510	20017	20070	49.84
27/05/2015	16 Hrs	5450	1725	254	7429	5110	1179	4685	113	-1538	16978	49	17027	1240	509	20265	20314	49.85
28/05/2015	16 Hrs	5271	1955	267	7493	4996	869	4611	92	-1542	16519	45	16564	1272	512	19845	19890	49.78
29/05/2015	15 Hrs	5380	1728	268	7376	5470	508	4572	157	-1547	16536	41	16577	1305	518	19906	19947	49.91
30/05/2015	15 Hrs	5893	509	278	6680	5339	522	4574	137	-1484	15768	40	15808	1040	515	18807	18847	49.80
31/05/2015	16 Hrs	5842	856	275	6973	4457	795	4496	102	-1277	15546	40	15586	740	516	18079	18119	50.01
Maximum		5893	1955	280	7759	5604	1179	4685	157	-1277	16978	53	17027	1305	518	20265	20314	50
Minimum		5134	509	254	6680	4457	508	3795	92	-1589	15546	38	15586	740	505	18079	18119	50
Average		5537	1446	271	7255	5216	841	4433	121	-1503	16362	38	16405	1154	512	19532	19575	50

Supply Position During Evening Peak (MW)

Date	Time	MSGENCO				Central Sector Receipt	Wind	CPP	SOLAR	TPCL Exch.	MSEDCL Cateder Demand	Load Shedding(LS)	MSEDCL Demand (Incl. LS)	TPCL Gen.	R-INFRA Gen.	State Demand Met	State Demand (Incl. LS)	Freq.
		THM	HYDRO	GAS	Total													
		MW	MW	MW	MW	MW	MW	MW	MW	MW	MW	MW	MW	MW	MW	MW	MW	Hzs
25/05/2015	20 Hrs	4763	1055	274	6092	5192	1250	3966	0	-1390	15110	38	15148	1006	518	18024	18062	49.88
26/05/2015	21 Hrs	5071	634	273	5978	5481	1148	3870	0	-1380	15097	44	15141	965	519	17961	18005	49.81
27/05/2015	20 Hrs	5001	715	273	5989	4667	1602	4090	0	-1419	14929	52	14981	1009	518	17875	17927	49.88
28/05/2015	21 Hrs	5187	906	273	6366	4090	1358	4399	0	-1316	14897	49	14946	994	518	17725	17774	49.82
29/05/2015	20 Hrs	5233	778	154	6165	3536	1077	4433	0	-1541	13670	41	13711	971	442	16624	16665	49.96
30/05/2015	20 Hrs	5954	638	272	6864	4719	565	4540	0	-1367	15321	40	15361	980	517	18185	18225	49.92
31/05/2015	21 Hrs	5126	454	278	5858	4543	672	4267	0	-1086	14254	44	14298	965	514	16819	16863	50.00
Maximum		5954	1055	278	6864	5481	1602	4540	0	-1086	15321	52	15361	1009	519	18185	18225	50
Minimum		4763	454	154	5858	3536	565	3870	0	-1541	13670	38	13711	965	442	16624	16665	50
Average		5191	740	257	6187	4604	1096	4224	0	-1357	14754	38	14798	984	507	17602	17646	50

Supply Position During Night Off Peak (MW)

Date	Time	MSGENCO				Central Sector Receipt	Wind	CPP	SOLAR	TPCL Exch.	MSEDCL Cateder Demand	Load Shedding(LS)	MSEDCL Demand (Incl. LS)	TPCL Gen.	R-INFRA Gen.	State Demand Met	State Demand (Incl. LS)	Freq.
		THM	HYDRO	GAS	Total													
		MW	MW	MW	MW	MW	MW	MW	MW	MW	MW	MW	MW	MW	MW	MW	MW	Hzs
25/05/2015	5 Hrs	4633	673	275	5581	4066	1802	3662	0	-1098	14013	45	14058	661	380	16152	16197	49.91
26/05/2015	5 Hrs	4812	477	275	5564	4279	1514	4012	0	-911	14458	46	14504	736	518	16623	16669	49.90
27/05/2015	5 Hrs	4942	1176	280	6398	4450	910	4202	0	-1134	14826	53	14879	627	381	16968	17021	49.95
28/05/2015	5 Hrs	5077	495	280	5852	4624	935	4174	0	-823	14762	48	14810	834	520	16939	16987	50.00
29/05/2015	5 Hrs	5446	644	278	6368	3557	741	4397	0	-774	14289	47	14336	854	518	16435	16482	49.98
30/05/2015	5 Hrs	4984	102	277	5363	3488	919	4007	0	-1209	12568	48	12616	629	379	14785	14833	49.98
31/05/2015	8 Hrs	5248	419	276	5943	4769	717	4174	19	-889	14733	48	14781	615	518	16755	16803	50.00
Maximum		5446	1176	280	6398	4769	1802	4397	19	-774	14826	53	14879	854	520	16968	17021	50
Minimum		4633	102	275	5363	3488	717	3662	0	-1209	12568	45	12616	615	379	14785	14833	50
Average		5020	569	277	5867	4176	1077	4090	3	-977	14236	45	14283	708	459	16380	16427	50

Details of Supply Position (MUs)

Date	MSGENCO				Pench (MS)	Central Sector Receipt	Central Sector Share	WIND	CPP	SOLAR	TPCL Gen.	R-INFRA Gen.	TPCL Exch.	Energy Requirement		
	THM	HYDRO	GAS	Total										MSEDCL	MUMBAI	STATE
	Mus	Mus	Mus	Mus	Mus	Mus	Mus	Mus	Mus	Mus	Mus	Mus	Mus	Mus	Mus	Mus
25/05/2015	116.746	27.304	6.604	150.654	0.142	116.468	107.068	32.562	97.944	1.296	23.027	11.450	-32.158	366.767	66.636	433.403
26/05/2015	121.298	25.256	6.580	153.134	0.290	121.776	109.325	28.486	96.290	1.245	23.270	12.382	-31.492	369.440	67.144	436.584
27/05/2015	124.981	28.052	6.469	159.502	0.226	112.268	107.679	26.090	105.859	1.288	22.820	11.745	-31.900	373.106	66.466	439.572
28/05/2015	126.688	25.953	6.583	159.224	0.454	111.449	106.728	21.413	108.606	1.216	23.886	12.394	-30.744	371.164	67.024	438.188
29/05/2015	128.624	23.561	5.636	157.821	0.031	105.378	103.439	18.040	108.017	1.338	24.100	11.733	-31.677	358.917	67.510	426.427
30/05/2015	133.797	9.617	6.614	150.028	0.002	108.056	108.538	14.565	107.181	1.143	20.695	11.429	-32.488	348.485	64.611	413.096
31/05/2015	134.725	12.667	6.628	154.020	0.109	106.840	110.290	15.145	104.587	0.820	16.494	12.399	-28.323	353.087	57.213	410.300
Maximum	134.725	28.052	6.628	159.502	0.454	121.776	110.290	134.725	108.606	1.338	24.100	12.399	-28.323	373.106	67.510	439.572
Minimum	116.746	9.617	5.636	150.028	0.002	105.378	103.439	116.746	96.290	0.820	16.494	11.429	-32.488	348.485	57.213	410.300
Average	126.694	21.773	6.445	154.912	0.179	111.748	107.581	126.694	104.069	1.192	16.494	11.933	-31.255	362.995	65.229	428.224

Details of Koyna Water Consumption (in TMC)

Date	For the Day	For the Month	Balance
25/05/2015	0.583	10.005	1.334
26/05/2015	0.520	10.525	0.814
27/05/2015	0.556	11.081	0.258
28/05/2015	0.538	11.619	-0.280
29/05/2015	0.476	12.095	-0.756
30/05/2015	0.145	12.240	-0.901
31/05/2015	0.209	12.449	-1.110

State Load Despatch Center,Airoli (MSETCL)
Central Sector Share/Drawal from 25/May/2015 to 31/May/2015

Date	DAY	Central Sector Share		Total Interstate Bilateral Purchase		Total Share		Total Drawal		Overdrawal(+) / UnderDrawal(-)	
		MUs	Avg. MW	MUs	Avg. MW	MUs	Avg. MW	MUs	Avg. MW	MUs	Avg. MW
		1		2		1+2=3		4		3-4=5	
25/05/2015	MONDAY	88.576	4443	18.492	771	107.068	4461	116.468	4853	9.400	392
26/05/2015	TUESDAY	90.760	4537	18.565	774	109.325	4555	121.776	5074	12.451	519
27/05/2015	WEDNESDA	89.729	4469	17.950	748	107.679	4487	112.268	4678	4.589	191
28/05/2015	THURSDAY	88.093	4428	18.635	776	106.728	4447	111.449	4644	4.721	197
29/05/2015	FRIDAY	84.514	4291	18.925	789	103.439	4310	105.378	4391	1.939	81
30/05/2015	SATURDAY	90.774	4505	17.764	740	108.538	4522	108.056	4502	-0.482	-20
31/05/2015	SUNDAY	94.143	4579	16.147	673	110.290	4595	106.840	4452	-3.450	-144
Total		626.588		126.479		753.067		782.235		29.168	

GENERATING UNITS OUTAGES FOR THE WEEK FROM 25/05/2015 TO 31/05/2015							
Generator	Generating Unit	Capacity	Tripped Date	Tripped Time	Synch. Date	Synch Time	Reason
PLANNED OUTAGES							
MSPGCL	Parli Unit 4		13/Apr/2015	11:27		Continued.	Turbine vibration high. Continued to AOH w.e.f.01.05.2015
IPP	Adani U-1		01/Jun/2015	1:48		Continued.	Annual Overhaul
FORCED OUTAGES							
IPP	Dhariwal	300MW	28/May/2014	2:27		Continued.	PA Fan Vibration Problem
MSPGCL	Chandrapur Unit 1	210MW	28/Aug/2014	07:15		Continued.	Economic Shutdown.
MSPGCL	Bhusawal Unit 2	210MW	13/Sep/2014	12:43		Continued.	Economic shutdown
MSPGCL	Koradi Unit 6	210MW	20/Mar/2015	1:02		Continued.	Economic shutdown
IPP	RPL(AMT)U1	270MW	21/Mar/2015	23:28	29/May/2015	21:31	Turbine vibration high.
MSPGCL	Bhusawal Unit 3	210MW	20/Apr/2015	0:00		Continued.	no buyer as per msdcl reqirment
MSPGCL	Adani U-3	660MW	11/May/2015	0:52	31/May/2015	11:13	Main Steam Drain MIY Bonnet Leakage.
MSPGCL	JSW (J) U1	300MW	14/May/2015	19:16		Continued.	Turbine Bearing Problem
MSPGCL	Parli Unit 5	210MW	23/May/2015	20:34	28/May/2015	15:00	Boiler Tube Leakage
MSPGCL	Bhusawal Unit 5	500MW	23/May/2015	16:23	26/May/2015	8:32	Boiler Tube Leakage
MSPGCL	Parli Unit 6	250MW	25/May/2015	23:56	26/May/2015	3:21	Furnace Pressure High
MSPGCL	Koradi Unit 7	210MW	27/May/2015	3:20	29/May/2015	15:37	Boiler Tube Leakage
MSPGCL	Paras Unit 3	250MW	27/May/2015	12:30	30/May/2015	11:03	Boiler Tube Leakage
MSPGCL	Khaparkheda Unit 3	210MW	28/May/2015	12:42	20/May/2015	1:51	Boiler Tube Leakage
MSPGCL	Chandrapur Unit 2	210MW	29/May/2015	23:12	01/Jun/2015	19:20	Boiler Tube Leakage
IPP	WPCL U-2	135MW	31/May/2015	0:01		Continued.	ID Fan Problem
IPP	RPL(AMT)U2	270MW	01/Jun/2015	6:53		Continued.	Coal bunkering problem
MSPGCL	Koradi Unit 7	210MW	02/Jun/2015	11:05		Continued.	Leakage at Chimany base.
MSPGCL	Koradi Unit 5	200MW	04/Jun/2015	10:30		Continued.	I D Fan Vaibration High.
IPP	Tata Trombay 6	500MW	05/Jun/2015	5:59		Continued.	Economic Shutdown.
MSPGCL	Chandrapur Unit 7	500MW	07/Jun/2015	13:59		Continued.	Boiler Tube Leakage

LINE OUTAGES FOR THE WEEK FROM 25/05/2015 TO 31/05/2015						
Voltage	Name of Line	Tripping Date	Tripping Time	Synch Date	Synch Time	Reason
765 KV	Wardha PG -Aurangabad PG III	03/May/2015	07.24		Continued.	To Control ICT Loading.
765 KV	Wardha(PG)-Aurangabad(PG)- II	22/May/2015	16.44		Continued.	To Control ICT Loading.
765 KV	Koradi-III - Akola-II ckt-I	30/May/2015	05.24	30/May/2015	07.24	Distance Protection
765 KV	Raichur(PG)-Solapur(PG)- I	31/May/2015	17.00	31/May/2015	19.00	Distance Protection
765 KV	Raichur(PG)-Solapur(PG)- II	31/May/2015	17.00	31/May/2015	19.25	Distance Protection
400 KV	Akola II - RPL(Rattanindia) Ckt I	07/Apr/2015	00.27		Continued.	"R" Phase Metering CT Burst.
400 KV	Wardha (PG)-Warora II	20/May/2015	02.39		Continued.	Breaker Accumulator Oil Leakage
400 KV	Akola II - Taptitanda	20/May/2015	08.59		Continued.	Ckt I and Ckt 2 new charged to control BBLSR ICT loading.
400 KV	karad -kolhapur-I	24/May/2015	16.16	25/May/2015	08.38	Over Voltage
400 KV	Karad-Jaigad - I	24/May/2015	17.26	25/May/2015	08.40	Over Voltage
400 KV	Bhusawal-Aurangabad	24/May/2015	17.31	25/May/2015	08.19	Over Voltage
400 KV	Dhule Sar'Sarovar I	24/May/2015	18.04	25/May/2015	08.10	Over Voltage
400 KV	Padghe - Talegaon (PG)	25/May/2015	15.40	25/May/2015	18.15	Shifting on TBC,Hot Line Work.
400 KV	Kolhapur Mapusa I	25/May/2015	17.20	26/May/2015	08.20	Over Voltage
400 KV	karad -kolhapur-II	25/May/2015	17.26	26/May/2015	07.15	Over Voltage
400 KV	Bhusawal-Aurangabad	25/May/2015	18.00	26/May/2015	07.54	Over Voltage
400 KV	Karad-Jaigad - I	25/May/2015	18.05	26/May/2015	07.39	Over Voltage
400 KV	Dhule Sar'Sarovar I	25/May/2015	18.56	26/May/2015	08.59	Over Voltage
400 KV	Padghe - Kalwa- I	26/May/2015	06.260	26/May/2015	09.21	Transfer A to B bus through TBC.
400 KV	Padghe - Kalwa-II	26/May/2015	07.05	26/May/2015	07.27	Transfer A to B bus through TBC.
400 KV	Nagothane - Dabhol-II	26/May/2015	07.33	27/May/2015	10.34	Bay Maint Work.
400 KV	Lonikand 1 - Talegaon(Pgcil)	26/May/2015	10.09	26/May/2015	14.54	R-Ph jumper opened at Talegaon PG end.
400 KV	Kolhapur Mapusa I	26/May/2015	17.16	27/May/2015	08.29	Over Voltage
400 KV	Bhusawal-Aurangabad	26/May/2015	18.25	27/May/2015	08.21	Over Voltage
400 KV	karad -kolhapur-II	26/May/2015	18.31	27/May/2015	06.37	Over Voltage
400 KV	Padghe - Nagothane - II	27/May/2015	12.59	27/May/2015	15.03	Attending Hot Spot
400 KV	Jaigad-Karad Ckt-I	27/May/2015	14.05	28/May/2015	07.19	insulator cold washing work
400 KV	karad -kolhapur-II	27/May/2015	17.10	28/May/2015	06.15	Over Voltage
400 KV	Bhusawal-Aurangabad	27/May/2015	17.46	28/May/2015	00.30	Over Voltage
400 KV	Dhule Sar'Sarovar I	27/May/2015	18.14	28/May/2015	07.25	Over Voltage
400 KV	Kolhapur Mapusa I	27/May/2015	18.14	28/May/2015	06.31	Over Voltage
400 KV	Padghe - Kalwa-II	28/May/2015	00.17	28/May/2015	05.43	Attending Hot Spot at y phase wave trape
400 KV	Dhule- Bableshwar - I	28/May/2015	07.10	28/May/2015	18.47	A/R Out for OPGW Work.
400 KV	Dhule - Bableshwar - li	28/May/2015	07.10	28/May/2015	18.47	A/R Out for OPGW Work.
400 KV	Padghe - Talegaon (PG)	28/May/2015	10.18	28/May/2015	19.33	A/R Out for Opgw Work.
400 KV	Jaigad-New Koyna Ckt-II	28/May/2015	10.19	28/May/2015	12.58	TBC Shifting to Attend Red Hot.
400 KV	Akola II - Taptitanda	28/May/2015	12.58	28/May/2015	14.01	Shifted to Tie C B for Maint.Work on Own CB @ Taptitanda A/R Out for OPGW Work.
400 KV	karad -kolhapur-I	28/May/2015	17.15	29/May/2015	06.31	Over Voltage
400 KV	Kolhapur Mapusa II	28/May/2015	17.29	29/May/2015	07.17	Over Voltage
400 KV	Karad-Jaigad - I	28/May/2015	18.02	29/May/2015	06.32	Over Voltage
400 KV	Bhusawal-Aurangabad	28/May/2015	18.08	29/May/2015	06.32	Over Voltage
400 KV	Dabhol Nagothane II	29/May/2015	08.26	29/May/2015	19.37	Bay Maint.Work.
400 KV	Koradi-Bhusawal	29/May/2015	09.33	29/May/2015	13.54	R.M.Work.
400 KV	Akola II - Akola I Ckt-II	29/May/2015	15.05	29/May/2015	19.26	Maintenance & Diagnostic Testing.

400 KV	Akola II - RPL(Rattaniindia) Ckt-II	29/May/2015	16.08	29/May/2015	17.12	Distance Protection
400 KV	Kolhapur Mapusa II	29/May/2015	16.52	30/May/2015	10.49	Over Voltage
400 KV	karad -kolhapur-I	29/May/2015	17.09	30/May/2015	09.20	Over Voltage
400 KV	Bhusawal-Aurangabad	29/May/2015	18.05	30/May/2015	06.01	Over Voltage
400 KV	Karad-Jaigad - I	29/May/2015	18.10	30/May/2015	08.51	Over Voltage
400 KV	Dhule Sar'Sarovar I	29/May/2015	18.30	30/May/2015	08.23	Over Voltage
400 KV	Lonikand I - Koyna stage-IV	29/May/2015	21.47	30/May/2015	07.32	Over Voltage
400 KV	Girwali-Solapur (Lamboti)	29/May/2015	22.02	29/May/2015	23.16	Distance Protection
400 KV	Kolhapur Solapur(PG) I	30/May/2015	02.19	30/May/2015	08.42	Over Voltage
400 KV	Kolhapur Mapusa I	30/May/2015	17.55	31/May/2015	09.48	Over Voltage
400 KV	Dhule Sar'Sarovar I	30/May/2015	18.02	31/May/2015	09.29	Over Voltage
400 KV	Bhusawal-Aurangabad	30/May/2015	18.12	31/May/2015	09.28	Over Voltage
400 KV	Dabhol Nagothane I	31/May/2015	03.38	31/May/2015	15.24	Distance Protection
400 KV	New Koyna - Dabhol-I	31/May/2015	03.39	04/Jun/2015	10.20	Distance Protection
400 KV	Kolhapur Mapusa I	31/May/2015	16.10	01/Jun/2015	07.44	Over Voltage
400 KV	karad -kolhapur-II	31/May/2015	16.27	01/Jun/2015	08.48	Over Voltage
400 KV	Dhule Sar'Sarovar II	31/May/2015	18.46	01/Jun/2015	07.41	Over Voltage
400 KV	Koradi Bhilai	31/May/2015	19.09	01/Jun/2015	23.09	Distance Protection
400 KV	Babhaleshwar-Taptitanda ckt-II	06/Jun/2015	01.21		Continued.	To control line loading
400 KV	Koradi Bhilai	06/Jun/2015	08.49		Continued.	Annual Maintenance Work
400 KV	Kolhapur Mapusa II	06/Jun/2015	16.39		Continued.	Over Voltage
400 KV	Babhaleshwar-Taptitanda ckt-I	07/Jun/2015	04.39		Continued.	To control line loading
400 KV	Babhaleshwar - Padghe-I	07/Jun/2015	07.31		Continued.	Stringing of Insulator String.
400 KV	Dabhol Nagothane I	07/Jun/2015	13.08		Continued.	Distance Protection R Ph Earth.
400 KV	karad -kolhapur-I	07/Jun/2015	16.01		Continued.	Over Voltage
400 KV	Karad-Jaigad - I	07/Jun/2015	16.34		Continued.	Over Voltage
400 KV	Dhule Sar'Sarovar II	07/Jun/2015	17.14		Continued.	Over Voltage
400 KV	Lonikand I - Koyna stage-IV	07/Jun/2015	17.21		Continued.	Over Voltage
400 KV	Bhusawal-Aurangabad	07/Jun/2015	17.42		Continued.	Over Voltage
400 KV	Dabhol Nagothane II	08/Jun/2015	04.01		Continued.	Over Voltage
220 KV	Sahara-Urse	03/Mar/2015	11.06		Continued.	Tower erection work (90Days)
220 KV	Chandrapur GCR - Warora - I	05/Apr/2015	09.13		Continued.	Bunching of conductor Loc no 86 Disconnecting of jumer at Loc no 86 & 107 and deenergising the line bet.86 to 107.
220 KV	Chandrapur GCR - Wani	05/Apr/2015	09.15		Continued.	Bunching of conductor Loc no 86 Disconnecting of jumer at Loc no 86 & 107 and deenergising the line bet.86 to 107.
220 KV	Eklahara-(Ocr)-Navasari I	05/May/2015	23.09	28/May/2015	08.24	To control Load on Bus section at Nasik GCR
220 KV	Balapur-Akola li	25/May/2015	09.10	25/May/2015	12.13	Fixing of Y-Ph Pilot suspension string clamp.
220 KV	Butibori-Khaperkheda	25/May/2015	09.37	25/May/2015	13.45	Tan Delta Measurment of CTs
220 KV	Chikhli-Jalna-I	25/May/2015	15.11	25/May/2015	19.54	Paras-Chikhali II under outage.
220 KV	Chikhli-Jalna-II	25/May/2015	15.11	25/May/2015	19.54	Paras-Chikhali II under outage.
220 KV	Paras-Chikhali Ckt No-li	25/May/2015	15.22	25/May/2015	19.52	Repl.of old isolator jumper R,Y and B Ph.
220 KV	Wada - Kolshet	25/May/2015	15.25	25/May/2015	20.29	Construction Work.
220 KV	Hingoli- Girawali	25/May/2015	17.53	25/May/2015	20.32	Tan Delta Measurment of CTs

220 KV	Dahanu Versova	26/May/2015	06.46	26/May/2015	08.05	Repl of B-Ph insualtor string.
220 KV	Taloja li - Ocil 2	26/May/2015	07.35	26/May/2015	18.55	P.M.Work.
220 KV	Pedhambe - Oni	26/May/2015	11.34	26/May/2015	18.05	Tree cutting work.
220 KV	Lonand-Baramati	26/May/2015	16.40	27/May/2015	01.55	New CR Panel Commissioning work.
220 KV	Pusad - Hingoli	26/May/2015	18.36	26/May/2015	20.39	Measurement of tan delta of CT's and CCs.
220 KV	Vita - Mhaishal	27/May/2015	14.13	27/May/2015	20.10	Replacement of Line insulator
220 KV	Osmanabad - Solapur (Bale)	28/May/2015	00.04	28/May/2015	13.14	Y Ph Jumper of LA to CT Open @ Usmanabad End.
220 KV	Solapur(Bale) - Tuljapur	28/May/2015	05.52	28/May/2015	14.19	Due to Line Loading.
220 KV	Trombay MSETCL Tie 1	28/May/2015	07.59	28/May/2015	08.21	Bird Nest Remove.
220 KV	Trombay MSETCL Tie 2	28/May/2015	08.25	28/May/2015	08.44	Bird Nest Remove.
220 KV	Nasik Navsari II	28/May/2015	09.12	29/May/2015	15.45	Maintenance Work.
220 KV	Balapur-Akola I	28/May/2015	09.40	28/May/2015	12.51	Pilot String of R Ph Refixing Work .
220 KV	Jejuri- Ismt- Lonand	28/May/2015	11.30	28/May/2015	16.44	Maintenance Work.
220 KV	Bhugaon-Pusad	29/May/2015	00.36	29/May/2015	01.04	Distance Protection
220 KV	Jamde-Dondaicha 2	29/May/2015	07.40	29/May/2015	08.17	Hot Spot on R Ph CT @ Line Side Jumper.
220 KV	Raymond - Washala	29/May/2015	08.44	29/May/2015	18.43	R.M.Work.
220 KV	Uran - Kharghar I	29/May/2015	10.13	29/May/2015	16.48	R.M.Work.
220 KV	Chitegaon-Shendra Ckt-II	29/May/2015	10.30	29/May/2015	15.14	Half Yearly Maintenance Work.
220 KV	Bableshtar- Alephata	29/May/2015	10.59	29/May/2015	17.57	R.M.Work.
220 KV	Karad(400kv) - Ogalewadi Ckt 1	29/May/2015	13.50	29/May/2015	20.44	R.M.Work.
220 KV	Chalisgaon -Babhaleshtar	29/May/2015	14.35	29/May/2015	20.16	To Change the Ph Sequence of 220KV D/C Line for New 200kv Kopergaon S/S.
220 KV	Kalwa - Airoli Knowledge Park	29/May/2015	15.01	29/May/2015	18.03	Testing Work.
220 KV	Lamboti-Vita	29/May/2015	18.48	29/May/2015	19.09	Distance Protection
220 KV	Taloja li - Ocil 2	30/May/2015	04.51	30/May/2015	11.50	Pilat Protection Operated.
220 KV	Tata Borivli MSETCL Borivli 4	30/May/2015	07.02	30/May/2015	11.05	Premansoon Work.
220 KV	Versova Ghodbunder-II	30/May/2015	07.50	30/May/2015	10.21	To Carry Out Signature Analysis Test.
220 KV	Mumewadi-Belewadi	30/May/2015	09.47	30/May/2015	17.55	Testing & Commissioning of Scada.
220 KV	Tata Borivli MSETCL Borivli 5	30/May/2015	11.28	30/May/2015	18.24	Premonsoon Maint.
220 KV	Pigasus-Hinjewadi-II	30/May/2015	12.00	30/May/2015	14.05	Relay Testing Work.
220 KV	Boisar(MS) - Boisar (PG) II	31/May/2015	05.38	31/May/2015	19.16	Removing Jumper and Strining to Gantry at PGCIL End.
220 KV	Vasai Boiser(PG)	31/May/2015	06.08	31/May/2015	19.32	Removing Jumper @ IOC No.-17 Conceting to New Gantry @ PGCIL End.
220 KV	Chikhli-Jalna-I	03/Jun/2015	18.30		Continued.	O/L of Akola ICT.
220 KV	Chikhli-Jalna-II	03/Jun/2015	18.30		Continued.	O/L of Akola ICT.
220 KV	Parvati - Hybrid Pass	05/Jun/2015	12.13		Continued.	TO control chinchawad urse loading
220 KV	Pedhambe - Oni	07/Jun/2015	16.10		Continued.	Distance Protection
220 KV	Sonkhar - Trombay	08/Jun/2015	06.10		Continued.	Crosam Painting.
132 KV	Ambazari-Mankapur-li	28/May/2015	04.20	28/May/2015	05.41	Y & B Ph Bus PT of Section-I Caught Fired.
132 KV	Ambazari-Mankapur 1	28/May/2015	04.20	28/May/2015	05.41	Y & B Ph Bus PT of Section-I Caught Fired.
132 KV	Mankapur - Hingna-I	28/May/2015	04.20	28/May/2015	05.41	Y & B Ph Bus PT of Section-I Caught Fired.
132 KV	Mankapur-Uppalwadi	28/May/2015	04.20	28/May/2015	07.01	Y & B Ph Bus PT of Section-I Caught Fired.
132 KV	Waghala (Nanded2) - Umri 1	28/May/2015	08.26	28/May/2015	08.58	Distance Protection Operated Zone-I.
132 KV	Ashti - Mul	28/May/2015	14.15	28/May/2015	14.35	Distance Protection Operated Z-II Backup Protection Operated O/C & E/F B Ph.
132 KV	Gadchiroli - Mul	28/May/2015	14.15	28/May/2015	15.22	Backup Protection Operated O/C & E/F B Ph.
132 KV	Kurunda - Akhada Balapur	29/May/2015	16.40	29/May/2015	16.52	Distance Protection
132 KV	Dondaicha- Shahada	07/Jun/2015	21.08		Continued.	L A Brust @ Shahada.
100 KV	Pal - Kalwa	06/Jun/2015	06.52		Continued.	replacement of dp structure