

State Load Despatch Center,Airoli (MSETCL)
Power System Position from 23/May/2022 to 29/May/2022

Supply Position During Morning Peak (MW)

Date	Time	MSGENCO				Central Sector Receipt	Wind	CPP	SOLAR	TPCL Exch.	MSEDCL Catered Demand	Load Shedding(LS)	MSEDCL Demand (Incl. LS)	TPCL Gen.	R-INFRA Gen.	State Demand Met	State Demand (Incl. LS)	Freq.
		THM	HYDRO	GAS	Total													
		MW	MW	MW	MW	MW	MW	MW	MW	MW	MW	MW	MW	MW	MW	MW	MW	Hzs
23/05/2022	12 Hrs	6027	758	120	6905	8622	2084	4203	1388	-2317	20445	0	20445	674	472	24348	24348	50.03
24/05/2022	12 Hrs	6920	1184	130	8234	7849	947	5405	1212	-2298	21020	0	21020	734	468	24849	24849	49.92
25/05/2022	12 Hrs	6772	1318	140	8230	8221	350	5611	1347	-2132	21191	0	21191	875	476	25110	25110	49.96
26/05/2022	12 Hrs	6739	904	195	7838	8991	527	5595	1306	-2175	21651	0	21651	851	474	25582	25582	50.00
27/05/2022	12 Hrs	6727	979	267	7973	8432	1059	4864	1396	-2064	21232	0	21232	892	499	25115	25115	50.02
28/05/2022	12 Hrs	6938	1140	257	8336	7947	1348	4327	1431	-1899	21086	0	21086	765	491	24645	24645	50.00
29/05/2022	12 Hrs	7048	548	125	7722	7798	1312	4221	1400	-1437	20615	0	20615	665	500	23618	23618	49.92
Maximum		7048	1318	267	8336	8991	2084	5611	1431	-1437	21651	0	21651	892	500	25582	25582	50.03
Minimum		6027	548	120	6905	7798	350	4203	1212	-2317	20445	0	20445	665	468	23618	23618	49.92
Average		6739	976	176	7891	8266	1090	4890	1354	-2046	21034	0	21034	779	483	24752	24752	49.98

Supply Position During Day Peak (MW)

Date	Time	MSGENCO				Central Sector Receipt	Wind	CPP	SOLAR	TPCL Exch.	MSEDCL Catered Demand	Load Shedding(LS)	MSEDCL Demand (Incl. LS)	TPCL Gen.	R-INFRA Gen.	State Demand Met	State Demand (Incl. LS)	Freq.
		THM	HYDRO	GAS	Total													
		MW	MW	MW	MW	MW	MW	MW	MW	MW	MW	MW	MW	MW	MW	MW	MW	Hzs
23/05/2022	16 Hrs	6882	299	140	7321	7291	2573	5601	937	-2190	21070	0	21070	901	481	25105	25105	49.99
24/05/2022	16 Hrs	6857	1991	130	8978	7782	1549	5593	805	-2205	22165	0	22165	892	488	26087	26087	49.93
25/05/2022	15 Hrs	6664	1806	120	8590	8721	359	5638	1069	-2165	21805	0	21805	891	466	25734	25734	49.97
26/05/2022	16 Hrs	6869	1092	264	8224	8650	905	5604	910	-2122	21748	0	21748	924	487	25704	25704	50.03
27/05/2022	15 Hrs	7007	666	257	7930	8048	1367	5401	1227	-2110	21433	0	21433	872	499	25344	25344	49.93
28/05/2022	16 Hrs	7010	1552	246	8808	7408	1528	4949	897	-1927	21280	0	21280	824	494	24907	24907	49.94
29/05/2022	15 Hrs	7516	430	134	8080	7678	1274	4984	1218	-1552	21291	0	21291	664	500	24398	24398	50.00
Maximum		7516	1991	264	8978	8721	2573	5638	1227	-1552	22165	0	22165	924	500	26087	26087	50.03
Minimum		6664	299	120	7321	7291	359	4949	805	-2205	21070	0	21070	664	466	24398	24398	49.93
Average		6972	1119	184	8276	7940	1365	5396	1009	-2039	21542	0	21542	853	488	25326	25326	49.97

Supply Position During Evening Peak (MW)

Date	Time	MSGENCO				Central Sector Receipt	Wind	CPP	SOLAR	TPCL Exch.	MSEDCL Cateder Demand	Load Shedding(LS)	MSEDCL Demand (Incl. LS)	TPCL Gen.	R-INFRA Gen.	State Demand Met	State Demand (Incl. LS)	Freq.
		THM	HYDRO	GAS	Total													
		MW	MW	MW	MW	MW	MW	MW	MW	MW	MW	MW	MW	MW	MW	MW	MW	Hzs
23/05/2022	20 Hrs	6828	1540	130	8498	5842	2637	5656	28	-1746	20470	0	20470	921	463	24045	24045	50.03
24/05/2022	20 Hrs	6729	2183	130	9042	5654	2037	5918	0	-1675	20661	0	20661	966	497	24114	24114	49.94
25/05/2022	20 Hrs	6527	2084	120	8732	6128	1712	5947	0	-1504	20582	0	20582	1126	500	24144	24144	49.90
26/05/2022	20 Hrs	7265	810	265	8340	6025	2044	5921	1	-1434	20461	0	20461	1190	457	23978	23978	49.96
27/05/2022	21 Hrs	7456	1199	268	8923	5509	2314	5284	0	-1556	20051	0	20051	1001	499	23530	23530	49.99
28/05/2022	20 Hrs	6329	2066	267	8662	6166	2072	5022	0	-1315	20237	0	20237	1154	501	23578	23578	49.86
29/05/2022	20 Hrs	7394	1826	137	9358	5481	2112	4998	0	-1302	20234	0	20234	876	500	23324	23324	50.00
Maximum		7456	2183	268	9358	6166	2637	5947	28	-1302	20661	0	20661	1190	501	24144	24144	50.03
Minimum		6329	810	120	8340	5481	1712	4998	0	-1746	20051	0	20051	876	457	23324	23324	49.86
Average		6933	1673	188	8794	5829	2133	5535	4	-1505	20385	0	20385	1033	488	23816	23816	49.95

Supply Position During Night Off Peak (MW)

Date	Time	MSGENCO				Central Sector Receipt	Wind	CPP	SOLAR	TPCL Exch.	MSEDCL Cateder Demand	Load Shedding(LS)	MSEDCL Demand (Incl. LS)	TPCL Gen.	R-INFRA Gen.	State Demand Met	State Demand (Incl. LS)	Freq.
		THM	HYDRO	GAS	Total													
		MW	MW	MW	MW	MW	MW	MW	MW	MW	MW	MW	MW	MW	MW	MW	MW	Hzs
23/05/2022	4 Hrs	6573	358	150	7081	6386	2325	5128	0	-1488	19128	0	19128	635	355	21910	21910	50.01
24/05/2022	4 Hrs	6933	1547	140	8620	5781	2218	5386	0	-1629	20137	0	20137	561	329	22895	22895	50.00
25/05/2022	5 Hrs	6677	1856	140	8674	5850	1526	5700	0	-1278	20141	0	20141	715	472	22936	22936	49.98
26/05/2022	4 Hrs	6596	998	150	7744	6546	1704	5713	0	-1246	20163	0	20163	844	467	23018	23018	50.01
27/05/2022	4 Hrs	6814	1653	268	8735	6002	2102	4860	0	-1153	20252	0	20252	856	501	23056	23056	50.01
28/05/2022	4 Hrs	7406	1160	270	8836	5420	2257	4975	0	-968	20228	0	20228	1085	500	23073	23073	50.00
29/05/2022	8 Hrs	7452	906	137	8496	5804	1942	5016	363	-1268	19966	0	19966	585	490	22696	22696	50.02
Maximum		7452	1856	270	8836	6546	2325	5713	363	-968	20252	0	20252	1085	501	23073	23073	50.02
Minimum		6573	358	137	7081	5420	1526	4860	0	-1629	19128	0	19128	561	329	21910	21910	49.98
Average		6922	1211	179	8312	5970	2011	5254	52	-1290	20002	0	20002	754	445	22798	22798	50.00

Details of Supply Position (MUs)

Date	MSGENCO				Pench (MS)	Central Sector Receipt	Central Sector Share	WIND	CPP	SOLAR	TPCL Gen.	R-INFRA Gen.	TPCL Exch.	Energy Requirement		
	THM	HYDRO	GAS	Total										MSEDCL	MUMBAI	STATE
	Mus	Mus	Mus	Mus	Mus	Mus	Mus	Mus	Mus	Mus	Mus	Mus	Mus	Mus	Mus	Mus
23/05/2022	157.975	18.164	3.220	179.359	0.040	161.495	159.556	58.615	124.232	10.665	17.455	10.462	-44.873	479.770	72.789	562.282
24/05/2022	164.833	38.710	3.240	206.783	0.121	154.753	152.395	42.895	134.340	9.780	17.924	10.671	-44.750	496.847	73.345	577.146
25/05/2022	159.513	42.363	3.240	205.116	0.115	165.297	163.501	28.075	137.544	10.261	21.133	11.651	-40.327	496.304	73.111	579.077
26/05/2022	164.927	25.309	4.916	195.152	0.134	174.926	175.984	31.731	136.560	10.347	21.445	11.538	-40.332	498.855	73.315	581.699
27/05/2022	172.292	23.294	6.463	202.049	0.038	158.025	161.078	43.200	125.663	10.981	22.623	11.880	-38.116	492.222	72.619	574.421
28/05/2022	166.858	33.683	6.367	206.908	0.044	156.377	156.268	43.743	117.290	10.665	22.185	11.942	-34.936	491.309	69.066	569.113
29/05/2022	173.856	28.798	3.213	205.867	0.024	155.480	156.256	43.292	116.437	10.840	17.804	11.895	-33.810	489.037	63.509	561.615
Maximum	173.856	42.363	6.463	206.908	0.134	174.926	175.984	173.856	137.544	10.981	22.623	11.942	-33.810	498.855	73.345	581.699
Minimum	157.975	18.164	3.213	179.359	0.024	154.753	152.395	157.975	116.437	9.780	17.455	10.462	-44.873	479.770	63.509	561.615
Average	165.751	30.046	4.380	200.176	0.074	160.908	160.720	165.751	127.438	10.506	20.081	11.434	-39.592	492.049	71.108	572.193

Details of Koyna Water Consumption (in TMC)

Date	For the Day	For the Month	Balance
23/05/2022	0.000	0.000	0.000
24/05/2022	0.000	0.000	0.000
25/05/2022	0.000	0.000	0.000
26/05/2022	0.000	0.000	0.000
27/05/2022	0.000	0.000	0.000
28/05/2022	0.000	0.000	0.000
29/05/2022	0.000	0.000	0.000

State Load Despatch Center,Airoli (MSETCL)
Central Sector Share/Drawal from 23/May/2022 to 29/May/2022

Date	DAY	Central Sector Share		Total Interstate Bilateral Purchase		Total Share		Total Drawal		Overdrawal(+) / UnderDrawal(-)	
		MUs	Avg. MW	MUs	Avg. MW	MUs	Avg. MW	MUs	Avg. MW	MUs	Avg. MW
		1		2		1+2=3		4		3-4=5	
23/05/2022	MONDAY	53.117	6542	106.439	4435	159.556	6648	161.495	6729	1.939	81
24/05/2022	TUESDAY	58.674	6256	93.721	3905	152.395	6350	154.753	6448	2.358	98
25/05/2022	WEDNESDA	76.036	6725	87.465	3644	163.501	6813	165.297	6887	1.796	75
26/05/2022	THURSDAY	80.964	7238	95.020	3959	175.984	7333	174.926	7289	-1.058	-44
27/05/2022	FRIDAY	60.986	6611	100.092	4171	161.078	6712	158.025	6584	-3.053	-127
28/05/2022	SATURDAY	63.968	6419	92.300	3846	156.268	6511	156.377	6516	0.109	5
29/05/2022	SUNDAY	-72.257	6282	228.513	9521	156.256	6511	155.480	6478	-0.776	-32
Total		321.487		803.551		1125.038		1126.353		1.315	

Generator Unit Outages/Trippings from 23.05.2022 to 29.05.2022						
Name of Unit	Date Trip	Time Trip	Date Sync	Time Sync	Reason	Outage Type
JSW (J) U3	28-05-2022	02:09	29-05-2022	18:45	no schedule	PLANNED
Koradi Unit-10	22-05-2022	21:53	23-05-2022	02:20	for emergency outage of GT-10main bay 401 & tie bay 402 for attending hot spot.	FORCED
RPL(AMT) U-2	16-05-2022	23:53	24-05-2022	12:26	Coal Shortage	FORCED
Parli Unit 6	19-05-2022	20:00	25-05-2022	13:20	Boiler Tube Leakage	FORCED
Trombay 7A	21-05-2022	01:26	25-05-2022	17:00	Gas shortage	FORCED
Chandrapur Unit 5	23-05-2022	07:45	26-05-2022	18:00	Boiler Tube Leakage	FORCED
Nasik Unit 3	21-05-2022	17:14	26-05-2022	09:40	Boiler Tube Leakage	FORCED
Trombay 7B	16-05-2022	23:59	26-05-2022	01:25	Non availability of APM gas.	FORCED
Uran Unit 5	16-05-2022	12:59	26-05-2022	09:42	Gas shortage	FORCED
Koradi Unit 8	28-05-2022	17:27	28-05-2022	19:54	Flame Failure	FORCED
Chandrapur Unit 7	28-05-2022	12:18	29-05-2022	01:14	Air heater problem	FORCED
Koradi Unit 6	27-05-2022	06:05	29-05-2022	06:27	Boiler Tube Leakage	FORCED
Bhusawal Unit 3	24-05-2022	17:31	29-05-2022	16:55	CVSM Control Valve Problem	FORCED
RPL(AMT) U-1	11-05-2022	21:00	30-05-2022	00:00	Coal Shortage	FORCED
Tarapur 1	08-01-2020	10:37		Continued.	Refueling. While refueling preparation, some repair works identified which are being executed before refueling.	FORCED
Tarapur 2	13-07-2020	04:38		Continued.	For cleaning of clogged basket strainer of cooling water system due to heavy ingress of debris from sea. The outage extended for repair and re-fueling.	FORCED
RPL(AMT) U-3	24-05-2022	02:23		Continued.	Flame Failure	FORCED
IEPL Unit 1	28-08-2018	21.26		Continued.	No PPA	FORCED
PGPL U1	07-02-2017	17.3		Continued.	No Schedule (NO PPA)	FORCED
PGPL U2	07-02-2017	17.3		Continued.	No Schedule.(NO PPA)	FORCED
Ghatghar Unit-1	20-04-2022	00:35		Continued.	Stator Earth Fault	FORCED
Koradi Unit 7	27-04-2021	20.03		Continued.	Retired (04/08/2021 At 00.00)	FORCED
Nasik Unit 3	29-05-2022	19:00		Continued.	Boiler Tube Leakage	FORCED
Trombay 7A	29-05-2022	05:26		Continued.	Gas shortage	FORCED
Trombay 7B	29-05-2022	04:57		Continued.	Gas shortage	FORCED
JSW (J) U1	16-03-2022	23:16		Continued.	Turbine Vibration	FORCED
SWPGPL U-1	16-02-2016	17.09		Continued.	No PPA.	FORCED
Adani U-3	27-05-2022	16:13		Continued.	APH-A HOT PA BELOW LEAKAGE.	FORCED
VIPL U-1	29-12-2018	0.3		Continued.	Coal Shortage. (NO PPA From 20.05.2019)	FORCED
VIPL U-2	17-01-2019	0.15		Continued.	Coal shortage.(NO PPA From 20.05.2019)	FORCED
Uran Unit 6	29-05-2022	00:32		Continued.	Gas shortage	FORCED
Uran Unit 7	25-05-2020	12.51		Continued.	Turbine Blade Failure	FORCED
Uran Unit 8	13-05-2022	01:34		Continued.	excitation fault (unit out due to gas shortage from 02:30hrs of dt.13.05.2022)	FORCED
Uran Unit B0	13-05-2022	01:34		Continued.	excitation fault (unit out due to gas shortage from 02:30hrs of dt.13.05.2022)	FORCED

Transmission Line Outages/Trippings from 23.05.2022 to 29.05.2022							
Name of Line	Date Trip	Time Trip	Date Sync	Time Sync	Reason	Outage Type	Voltage
NAGOTHANE - DABHOL CKT - 1	22-05-2022	19:02	23-05-2022	00:30	Fixing of missing Insulators strings of B.Ph. At loc.no. 84	EO	400 KV
KARAD - LONIKAND I	23-05-2022	15:27	23-05-2022	17:01	To control line loading of Talegaon - Kharghare-Kalwa	HT	400 KV
400/220/33 KV 315MVA ICT - 1 @ AKOLA	23-05-2022	07:28	23-05-2022	17:37	Routine maintenance & testing work	PO	400 KV
400/220/33 KV 500 MVA ICT - 3 @ KOLHAPUR	23-05-2022	17:58	23-05-2022	18:40	To attend Hot spot at jack Bus above 220kV Main Bus 2	EO	400 KV
400/220KV 315 MVA ICT - 1 @ NEW KOYNA	23-05-2022	08:17	23-05-2022	17:25	For RTV coating to Tertiary 33 kv connection & Pre-Monsoon maintenance work	PO	400 KV
DHULE - SSNNL CKT - 2	23-05-2022	09:01	23-05-2022	19:58	Replacement of damaged earthwire, replacement of PID suspicious disc insulator strings and other routine maintenance work.400kV SSNNL Ckt-1 A/R switch will be kept on non auto mode.	PO	400 KV
GTR - 5 @ CHANDRAPUR SS	23-05-2022	14:15	23-05-2022	20:34	"1. Measurement of Tan Delta and capacitance of R, Y & B-ph CTs which are due for this year. 2.To attend the defects of aux. contacts of Isolators. 3.Maintenance and alignments of Isolators."	EO	400 KV
BABLESHWAR- AURANGABAD (WALUJ)	23-05-2022	21:23	24-05-2022	00:58	Attending Red Hot Spot on 29 D, Centre break isolator B phase	EO	400 KV
400/220/33 KV 500 MVA ICT - 1 @ NANDED	24-05-2022	11:12	24-05-2022	14:41	Pre Mansoon Maintanance of ICT.	PO	400 KV
400/220KV 167MVA SPARE ICT @ NANDED (KUMBHARGAON)	24-05-2022	11:14	24-05-2022	14:44	Pre monsoon Maintance work	PO	400 KV
400220kV 167MVA SPARE ICT @ DEEPNAGAR	24-05-2022	08:28	24-05-2022	17:44	FOR PRE MONSOON MAINTENANCE WORK ALONG WITH DIAGNOSTIC TESTING WORK CARRIED OUT.	PO	400 KV
DEEPNAGAR - AURANGABAD (WALUJ)	24-05-2022	08:05	24-05-2022	17:35	For replacement of Dead end & Mid span joint & Faulty insulator strings detected in PID.	PO	400 KV
TIE BAY (403) OF ICT - 1 & AURANGABAD CKT - 1 @ AKOLA	24-05-2022	09:43	24-05-2022	15:29	Routine maintenance & testing work	PO	400 KV
PADGHE - TARAPUR CKT - 1	23-05-2022	09:06	25-05-2022	19:16	CB, ES, DS, LA, CT, LA, WT, CVT Annual PM	PO	400 KV
125MVAr BUS REACTOR @ WARORA	25-05-2022	08:21	25-05-2022	15:29	Premonsoon Maintenance work. Routine maintenance and DCRM/CRM/CB Timings Testing works and isolater maintenance work .	PO	400 KV
400/220/33 KV 500MVA ICT - 3 @ NAGOTHANE	25-05-2022	02:33	25-05-2022	10:11	Tripped on NDR Stage-1. Heavy Rain with High Speed Winds reported.	T	400 KV
400/220/33KV 500 MVA ICT - 1 @ KUDUS	25-05-2022	10:38	25-05-2022	19:16	Outage required for completion of pending work of 400/220/33 kV ICT-2 and 33 kV station T/F -2 Bay	EO	400 KV
400/220KV 315 MVA ICT - 2 @ NEW KOYNA	25-05-2022	08:19	25-05-2022	18:30	For RTV coating to Tertiary 33 kv connection & Pre-Monsoon maintenance	PO	400 KV
400KV NANDED(KUMBHARGAON)- PARLY CKT 2	25-05-2022	06:22	25-05-2022	16:51	To attend broken conductor strands bet loc no 86_87,116_117	PO	400 KV
DEEPNAGAR - AURANGABAD (WALUJ)	25-05-2022	06:20	25-05-2022	14:58	For replacement of Dead end & Mid span joint & Faulty insulator strings detected in PID.	PO	400 KV
PADGHE - NAGOTHANE CKT - 2	26-05-2022	12:25	26-05-2022	13:33	For jumper tightning work and emergency tree cutting work	PO	400 KV

Transmission Line Outages/Trippings from 23.05.2022 to 29.05.2022							
Name of Line	Date Trip	Time Trip	Date Sync	Time Sync	Reason	Outage Type	Voltage
400 KV KARAD - SOLAPUR (PG) LR	26-05-2022	08:37	26-05-2022	19:11	For attending oil leakages through PRV by replacing new PRV and replacement of RTD sensor with CCU of WTI & OTI and attending problem of motorised 400 kV Reactor isolator problem	PO	400 KV
400/220/33 KV 315MVA ICT - 2 @ AKOLA	26-05-2022	12:07	26-05-2022	19:58	Routine Maintenance & testing work	PO	400 KV
400/220/33 KV 500 MVA ICT - 3 @ PARLI	26-05-2022	08:54	26-05-2022	18:12	(1) SFRA measurement ICT Units. (2) Bay maintenance work.	PO	400 KV
400/220/33KV 500 MVA ICT - 1 @ KUDUS	26-05-2022	11:50	26-05-2022	17:57	E/O AVAILED BY PG	HT	400 KV
DEEPNAGAR - AURANGABAD (WALUJ)	26-05-2022	06:06	26-05-2022	16:47	For replacement of Dead end & Mid span joint & Faulty insulator strings detected in PID.	PO	400 KV
TBC @ PADGHE	26-05-2022	10:12	26-05-2022	17:15	1) Bay Maint work 2) MTAMC work	PO	400 KV
KARAD - LONIKAND I	26-05-2022	23:42	27-05-2022	02:08	load management	HT	400 KV
400/220/33 KV 500 MVA ICT - 2 @ JEJURI	26-05-2022	22:05	27-05-2022	05:58	For pre-monsoon maintenance,CTR work & testing work.	PO	400 KV
AURANGABAD(MS) - PUNE (GIS) CKT - 2	26-05-2022	11:07	27-05-2022	16:31	H/T FOR LOAD MANAGEMENT	HT	400 KV
KHARGHAR - TALEGAON (PG)	26-05-2022	23:42	27-05-2022	01:59	Line Maintenance at Loc No-100	HT	400 KV
KARAD - TALANDGE CKT - 2	27-05-2022	14:45	27-05-2022	19:04	Replacement of Decapped cut point string at loc no 30.	PO	400 KV
NEW KOYNA-KARAD CKT - 1	27-05-2022	19:32	27-05-2022	23:24	attending hot spot at Y ph 29B PG isolator IPS clamp towards LA side having Temp 167 Degree	EO	400 KV
400/220/33 KV 315 MVA ICT - 1 @ LONIKAND	27-05-2022	14:46	27-05-2022	17:23	For cleaning of tertiary winding external delta of 400/220/33kv 3*105MVA ICT-1 to avoid NDR tripping.	PO	400 KV
400/220/33 KV 500 MVA ICT - 3 @ WALUJ	27-05-2022	09:37	27-05-2022	17:48	1. To carry out DFRA Test on Yph Unit 2. Diagnostic Testing Work 3. Maintenance Work.	PO	400 KV
AURANGABAD(MS) - PUNE (GIS) CKT - 1	27-05-2022	16:21	27-05-2022	18:22	TRIPPED ON DIST.PROTECTION	T	400 KV
DEEPNAGAR - AURANGABAD (WALUJ)	27-05-2022	06:21	27-05-2022	16:32	For replacement of Dead end & Mid span joint & Faulty insulator strings detected in PID.	PO	400 KV
DHULE - SSNNL CKT - 1	27-05-2022	12:06	27-05-2022	18:12	Replacement of damaged earthwire, replacement of PID suspicious disc insulator strings and other routine maintenance work.400kv SSNNL Ckt-2 A/R switch will be kept on non auto mode.	PO	400 KV
LONIKAND I - KOYNA STAGE-IV	27-05-2022	09:43	27-05-2022	10:30	Tripped on Distance protection.	T	400 KV
DEEPNAGAR - AURANGABAD (WALUJ)	28-05-2022	06:14	28-05-2022	17:47	For replacement of Dead end & Mid span joint & Faulty insulator strings detected in PID.	PO	400 KV
400/220/33 KV 500MVA ICT - 2 @ LONIKAND 2	29-05-2022	17:48	29-05-2022	23:15	For pre-monsoon maintenance activities and diagnostic testing,cleaning of tertiary to avoid tripping of ICT on NDR.	PO	400 KV
400/220/33 KV 500MVA ICT - 2 @ LONIKAND 2	29-05-2022	17:25	30-05-2022	02:23	For pre-monsoon maintenance activities and diagnostic testing,cleaning of tertiary to avoid tripping of ICT on NDR.	PO	400 KV
400/220/33 KV 315 MVA ICT - 1 @ DHULE	28-05-2022	09:54			Work of Overhauling of OLTC of 315 MVA ICT-1	PO	400 KV
VSNL - STT GIS CKT - 1	20-05-2022	11:01	23-05-2022	13:02	Addition of New 02 Nos of GIS T/F Bay to existing 220kv Bus 1 at 220KV STT GIS Substation end.	PO	220 KV
BOMBAY DYEING - SAHARA	23-05-2022	05:03	23-05-2022	17:09	TRIPPED ON DIST.PROTECTION	T	220 KV

Transmission Line Outages/Trippings from 23.05.2022 to 29.05.2022							
Name of Line	Date Trip	Time Trip	Date Sync	Time Sync	Reason	Outage Type	Voltage
CHINCHWAD- PARVATI	23-05-2022	09:32	23-05-2022	18:09	Replacement of R, Y & B ph CT due to higher Tandelta values	PO	220 KV
EKLAHARE (OCR) - PADGHE	23-05-2022	19:44	23-05-2022	22:07	For load management	HT	220 KV
MIRAJ - ICHALKARANJI	23-05-2022	09:07	23-05-2022	12:38	1) Hot spot attending work	PO	220 KV
MUDSHINGI - CHIKODI	23-05-2022	12:05	23-05-2022	19:11	Earth wire stringing work at T.L. no. M/C-16 to M/C-18.	PO	220 KV
OSMANABAD - SOLAPUR (BALE)	23-05-2022	10:28	23-05-2022	14:56	Conductor Mid span joint work at location No. 86-87 R phase, DI replacement 91 B phase	PO	220 KV
TALANDGE - MUDSHINGI CKT - 1	23-05-2022	11:53	23-05-2022	18:53	For stringing of earth wire between tower location no. M/C-18 to M/C-18 .	PO	220 KV
TROMBAY - KALWA	23-05-2022	17:53	23-05-2022	18:50	R-ph CC to LMU cable broken. Need to be connected immediately otherwise it will result in damage to CC.	EO	220 KV
220/110 kV 200 MVA ICT 1 @ MUDSHINGI	23-05-2022	09:00	23-05-2022	18:40	For 1)Transformer diagnostic testing work 2) Premansoon maintenance of ICT (3) Quarterly main work	PO	220 KV
220/132 KV 200 MVA ICT 1 @ MALEGAON	23-05-2022	08:34	23-05-2022	10:32	Pre monsoon maintenance work.	PO	220 KV
220/132 KV 200 MVA ICT 2 @ MALEGAON	23-05-2022	13:02	23-05-2022	14:56	Pre monsoon maintenance work.	PO	220 KV
220/132kV 200MVA ICT-2 @ KOPARGAON	23-05-2022	11:16	23-05-2022	14:50	For Pre-monsoon Maintenance work and testing work	PO	220 KV
220/33kV 100 MVA TF 2 @ GHODBUNDER	23-05-2022	08:40	23-05-2022	17:53	Annual/premonsoon maintenance	PO	220 KV
220/33kV 125 MVA TF 2 @ AAREY	23-05-2022	10:25	23-05-2022	12:10	Premonsoon maintenance of Transformer, NGT and Bay Equipments	PO	220 KV
EKLAHARA(OCR)-RAYMOND	23-05-2022	07:33	23-05-2022	09:12	Attending red hot on R ph wave trap bottom side	EO	220 KV
MAIN BUS - 2 @ TALANDGE	23-05-2022	17:58	23-05-2022	22:49	To attend Hot spot at ICT-3 above Main Bus 2	EO	220 KV
MAIN BUS-1 @ TALANDGE(5* MIDC KAGAL)	23-05-2022	10:00	23-05-2022	14:53	For shifting of 220KV Bus A load(TF1 and Talandage ckt-II) on 220KV Bus B as augmentation of 220/33KV,50MVA transformer in in process at 220 kV Five Star MIDC S/Stn.	PO	220 KV
TBC @ GHODBUNDER	23-05-2022	08:45	23-05-2022	18:06	For safety purpose during outage of 100 MVA TR-2	PO	220 KV
METERING BAY (CONSUMER) - 2 @ SERUM	23-05-2022	16:05	24-05-2022	21:41	Replacement of 06 Nos. of 75/1 A CT to New 100/1 A CT	EO	220 KV
ALEPHATA-PARGAON(KATHAPUR)	24-05-2022	12:18	24-05-2022	18:59	replacement of R Y B Ph CT of 220kV Alephata-Kathapur line due to high tan delta	PO	220 KV
EKLAHARE (OCR) - PADGHE	24-05-2022	17:02	24-05-2022	19:03	To control line loading	HT	220 KV
POPHLI PEDHMBE LINE- 1	24-05-2022	08:40	24-05-2022	17:25	For Bay R/M work.	PO	220 KV
220/100 KV 100 MVA ICT 1 @ KANDALGAON	24-05-2022	12:10	24-05-2022	19:20	Diagnostic Testing	PO	220 KV
220/100 KV 200 MVA ICT 2 @ KALWA	24-05-2022	09:40	24-05-2022	18:13	Fixing of aircell in the conservator tank.	PO	220 KV
220/132 KV 150 MVA ICT 3 @ EKLAHRE (OCR)	24-05-2022	10:35	24-05-2022	12:22	Premansoon & Bay maintenance work	PO	220 KV
220/22 KV 50 MVA PTR 1 @ TALOJA	24-05-2022	15:45	24-05-2022	20:16	50MVA CGL make TF-1 LV side shifting in GIS	PO	220 KV
220/33 KV 50MVA PTR NO 1 @ ALEPHATA	24-05-2022	11:28	24-05-2022	16:59	for quartly maintenance	PO	220 KV
220/33KV 50MVA BBL T/F @ OGLEWADI	24-05-2022	10:35	24-05-2022	15:07	Premonsoon maintenance work	PO	220 KV
AEML BORIVALI - TPC BORIVALI LINE	24-05-2022	16:43	24-05-2022	20:48	Outage required as safety precaution for work of Modular Cut out Sealing System.	PO	220 KV

Transmission Line Outages/Trippings from 23.05.2022 to 29.05.2022							
Name of Line	Date Trip	Time Trip	Date Sync	Time Sync	Reason	Outage Type	Voltage
ALKUD - VITA	24-05-2022	10:45	24-05-2022	18:22	Replacement of distance protection relay of line bay at 220kV Vita S/s	PO	220 KV
EKLAHARE (OCR) - NAVASARI CKT - 2	24-05-2022	10:09	24-05-2022	16:41	FOR SRI REPLACEMENT WORK AT LOC 20 S	PO	220 KV
VSNL - STT GIS CKT - 2	24-05-2022	10:43	25-05-2022	15:55	Addition of New 02 Nos of GIS T/F Bay to existing 220kv Bus 2 at 220 KV STT GIS Substation end.	PO	220 KV
NAGOTHANE - IPCL	25-05-2022	02:34	25-05-2022	16:48	Tripped HeavyRains with speedy Winds reported.	T	220 KV
NAGOTHANE - POSCO	25-05-2022	13:38	25-05-2022	19:57	Outage tree cutting work at various location and other line maintenance work.	PO	220 KV
SADAWAGHAPUR KARAD CKT 1	25-05-2022	10:03	25-05-2022	18:18	For taking C & Tan Delta and CB CRM, Timing Measurement.	PO	220 KV
220/100 KV 125 MVA ICT 2 @ JAMBHUL	25-05-2022	07:48	25-05-2022	13:16	1)Routine Maintenance works Measurement of Neutral Earth Pit Resistance. 3) Premonsoon Maintenance Work	PO	220 KV
220/100 KV 200 MVA ICT 2 @ PAL-DOMBIVALI	25-05-2022	10:12	25-05-2022	15:24	Pre-monsoon RM work. Earth pit resistance measurement work.	PO	220 KV
220/132 KV 100 MVA ICT 1 @ LONIKAND 2	25-05-2022	21:29	25-05-2022	23:32	For carrying out Pre-monsoon activities.	PO	220 KV
220/132 KV 150 MVA ICT 2 @ EKLAHRE (GCR)	25-05-2022	10:38	25-05-2022	19:03	Diagnosis of Testing work and pre-monsoon maintenance work.	PO	220 KV
220/132KV 200MVA PTR 1 @ LONAND	25-05-2022	09:37	25-05-2022	11:04	Premonsoon maintenance work	PO	220 KV
220/132KV 200MVA PTR 2 @ LONAND	25-05-2022	16:34	25-05-2022	17:55	Premonsoon maintenance work	PO	220 KV
220/22 KV 25 MVA PTR 2 @ WASHALA	25-05-2022	10:10	25-05-2022	14:50	CB CRM & TIMING, IR Measurement works, Bay Maintenance work	PO	220 KV
220/33kv 100 MVA TF 1 @ AAREY	25-05-2022	09:09	25-05-2022	18:33	Annual and Premonsoon maintenance of Transformer, NGT and Bay Equipments	PO	220 KV
220/33kv 100 MVA TF 3 @ GHODBUNDER	25-05-2022	07:54	25-05-2022	17:26	Annual & premonsoon maintenance	PO	220 KV
LAMBOTI - KARKAMB	25-05-2022	10:28	25-05-2022	18:34	Outage is required for 1) For changing / replacement of faulty string at loc no. 12, 18, 69, 80 & 89. 2) Disc cleaning work from loc 24 to 75 (Pandharpur - Karkamb section)	PO	220 KV
PARLI (OLD GCR) - PARLI (PG) CKT 2	25-05-2022	08:43	25-05-2022	19:49	Hardware Tightening & Fitting work	PO	220 KV
TBC @ AAREY	25-05-2022	09:10	25-05-2022	17:55	For safety purpose while working on 100MVA TR-1	PO	220 KV
BORIVALI - TARAPUR	18-05-2022	14:36	26-05-2022	22:12	Replacement of existing 0.5 ACSR MOOSE Conductor at loc. No. 11- 28, replacement of heavily Rusted Hardware , heavily rusted earth wire and all insulator strings of the line.	PO	220 KV
PADGHE - TEMGHAR - 2	20-05-2022	00:02	26-05-2022	07:20	Bunching at Loc no.82 and jumper opening at Loc.no. 80.	PO	220 KV
BUS SECTION-4 @ TEMGHAR	20-05-2022	07:23	26-05-2022	07:21	220KV Temghar -Padghe 1 & 220KV Temghar-Colourchem line will be in service. Load of T/F no.4 will be shifted to T/F no. 2. Load of T/F no.5 will be shifted to T/F no. 1 & 3.	PO	220 KV
JEJURI - KONDHWA	24-05-2022	10:41	26-05-2022	11:18	220 kV Jejuri-Kondhwa bay CB mechanism overhauling work and attend of SF6 gas leakage of Y phase pole of CB.	PO	220 KV

Transmission Line Outages/Trippings from 23.05.2022 to 29.05.2022							
Name of Line	Date Trip	Time Trip	Date Sync	Time Sync	Reason	Outage Type	Voltage
PADGHE - TEMGHAR - 1	26-05-2022	00:07	26-05-2022	03:27	For removing of bunching arrangement between 220KV Padgha-Temghar 1 & 2 line at Loc no.82 and re-fixing of jumper at Loc. no. 80.	PO	220 KV
PANDHARPUR - MALINAGAR	26-05-2022	16:30	26-05-2022	18:56	Outage is required For changing / replacement of faulty string at loc no. Main line - 1CP4, CP 11, CP, 19, 47 LILO Portion - 25, 39, 41.	PO	220 KV
220/100 KV 200 MVA ICT 1 @ PAL-DOMBIVALI	26-05-2022	10:02	26-05-2022	13:44	Premonsoon RM work Earth pit resistance measurement	PO	220 KV
220/132 KV 100 MVA ICT - 1 @ ALEPHATA	26-05-2022	21:10	26-05-2022	22:50	For Pre-monsoon maintenance work.	PO	220 KV
220/132 KV 100MVA ICT - 1 @ MANMAD	26-05-2022	10:05	26-05-2022	11:50	Testing of relays & misc. maintenance work.	PO	220 KV
220/132 KV 100MVA ICT - 2 @ MANMAD	26-05-2022	12:26	26-05-2022	13:41	Testing of relays & misc. maintenance work.	PO	220 KV
220/132 KV 200MVA ICT 3@ BALE(SOLAPUR)	26-05-2022	09:36	26-05-2022	18:41	Outage is required for Oil leakage attending work to be carried out by agency.	PO	220 KV
220/132KV 100MVA ICT 2 @ KATHAPUR	26-05-2022	11:10	26-05-2022	17:40	Pre monsoon Maintenance Work	PO	220 KV
220/132KV 100MVA ICT-1 @ WALCHANDNAGAR	26-05-2022	13:07	26-05-2022	17:03	PRE MONSOON MAINTENANCE WORK	PO	220 KV
220/132KV 200MVA ICT 4 @ EKLAHARE (OCR)	26-05-2022	10:10	26-05-2022	11:38	Premonsoon & Bay maintenance work	PO	220 KV
220/22KV 50MVA PTR 1 @ CHAKAN PHASE II	26-05-2022	10:17	26-05-2022	13:33	Pre monsoon maintenance work .	PO	220 KV
220/22KV 50MVA PTR 2 @ RANJANGAON	26-05-2022	11:16	26-05-2022	17:13	For Pre monsoon work	PO	220 KV
220/33-33 KV 100 MVA PTR 2 @ BOISAR-II	26-05-2022	10:21	26-05-2022	15:26	Pre monsoon maintenance work & diagnostic testing works	PO	220 KV
220/33KV 50MVA PTR -2 @ KURKUMBH	26-05-2022	13:15	26-05-2022	17:20	PRE MONSOON MAINTENANCE WORK.	PO	220 KV
220/33KV 50MVA PTR 1 @ KURKUMBH	26-05-2022	09:20	26-05-2022	13:01	PREMONSOON MAINTENANCE WORK	PO	220 KV
220/33kV 100 MVA TF 1 @ GHODBUNDER	26-05-2022	09:22	26-05-2022	11:28	Premonsoon Maintenance	PO	220 KV
220/33kV 100 MVA TF 3 @ AAREY	26-05-2022	08:59	26-05-2022	17:50	Annual and Premonsoon maintenance of Transformer, NGT and Bay Equipments	PO	220 KV
220/33kV 125 MVA TF 4 @ GHODBUNDER	26-05-2022	11:59	26-05-2022	13:44	Premonsoon Maintenance	PO	220 KV
CHAKAN-BHOSARI 1	26-05-2022	11:36	26-05-2022	18:56	Double Jumpering Work	PO	220 KV
TBC @ AAREY	26-05-2022	09:00	26-05-2022	17:50	For Safety Purpose	PO	220 KV
TBC @ GHODBUNDER	26-05-2022	09:22	26-05-2022	11:28	For Safety purpose	PO	220 KV
220/132 KV 100 MVA ICT - 2 @ ALEPHATA	26-05-2022	22:57	27-05-2022	01:24	For Pre-monsoon maintenance work.	PO	220 KV
PANDHARPUR - MALINAGAR	27-05-2022	16:32	27-05-2022	21:07	For changing / replacement of faulty string at loc no. Main line - 1,4,7,15,16,19,22,69.	EO	220 KV
220/100 KV 100 MVA ICT 1 @ TALOJA	27-05-2022	08:12	27-05-2022	12:51	100 kV Bus Section-1 (100KV DFPCL,100KV FGIL,200MVA EMCO ICT)	PO	220 KV
220/100 KV 200 MVA ICT 2 @ TALOJA	27-05-2022	14:32	27-05-2022	19:11	100 KV BUS SECTION-2 (100KV TALOJA LINE-2, 100KV BOC,200MVA ADITYA ICT)	PO	220 KV
220/132 KV 200 MVA ICT 2@ BALE(SOLAPUR)	27-05-2022	09:31	27-05-2022	15:45	Outage is required for Oil leakage attending work to be carried out by agency.	PO	220 KV
220/132 KV 200MVA ICT 2 @ KURKUMBH	27-05-2022	11:30	27-05-2022	13:10	PRE MONSOON MAINTENANCE WORK	PO	220 KV

Transmission Line Outages/Trippings from 23.05.2022 to 29.05.2022							
Name of Line	Date Trip	Time Trip	Date Sync	Time Sync	Reason	Outage Type	Voltage
220/132KV 200MVA ICT 1 @ KURKUMBH	27-05-2022	09:05	27-05-2022	11:20	PRE MONSOON MAINTENANCE WORK.	PO	220 KV
220/132KV 200MVA ICT 5 @ EKLAHARE (OCR)	27-05-2022	09:55	27-05-2022	11:12	Premansoon & Bay maintenance work	PO	220 KV
220/22 KV 50 MVA PTR 1 @ MAHAPE	27-05-2022	14:31	27-05-2022	18:07	Power Transformer Pre-Monsoon Maintenance work and Bay Maintenance works along with hotspot attending work	PO	220 KV
220/22 KV 50 MVA PTR 1 @ PAL-DOMBIVALI	27-05-2022	10:07	27-05-2022	14:11	1)Pre-monsoon Maintenance work 2)Earth pit Resistance Measurement Work..	PO	220 KV
220/22 KV 50 MVA PTR 2 @ MAHAPE	27-05-2022	07:20	27-05-2022	11:36	Power Transformer Pre-Monsoon Maintenance work and Bay Maintenance works along with hotspot attending work	PO	220 KV
220/22 KV 50 MVA PTR 2 @ PAL-DOMBIVALI	27-05-2022	14:38	27-05-2022	17:45	1)Pre-monsoon Maintenance work 2)Earth pit Resistance Measurement Work..	PO	220 KV
220/22 KV 50 MVA PTR 2 @ TEMGHAR	27-05-2022	09:20	27-05-2022	18:50	For pre-monsoon and diagnostic testing work	PO	220 KV
220/22 KV 50 MVA PTR 2 @ KAMBA	27-05-2022	14:20	27-05-2022	15:52	1) Pre-monsoon maintenance work 2) Cooling fan maintenance work	PO	220 KV
220/22 KV 50 MVA PTR 3 @ KAMBA	27-05-2022	09:30	27-05-2022	12:23	1) Pre-monsoon maintenance work 2) Cooling fan maintenance work	PO	220 KV
220/22 KV 50 MVA PTR 3 @ KOLSHET	27-05-2022	10:07	27-05-2022	13:24	1)Pre-monsoon maintenance work. 2)Removal of Bird nest near Buchholz. 3)LV B ph bushing red hot attending work.	PO	220 KV
220/22-22 KV 100 MVA PTR 1 @ WADA	27-05-2022	14:10	27-05-2022	19:42	For replacement of Differential relay and Bay maintenance work	PO	220 KV
220/33 KV 50 MVA PTR 1 @ MALEGAON	27-05-2022	08:25	27-05-2022	09:40	For pre-monsoon work activity	PO	220 KV
220/33 KV 50 MVA PTR @ PHALTAN MIDC	27-05-2022	09:05	27-05-2022	17:04	For tan delta testing, SFRA of transformer & tan delta testing of HV CTs, quarterly and premonsoon maintenance work	PO	220 KV
DAHANU - GHODBUNDER CKT - 2	27-05-2022	17:06	27-05-2022	18:18	TRIPPED ON DIST.PROTECTION	T	220 KV
KHARGHAR - NERUL	27-05-2022	22:37	28-05-2022	00:51	To attend hotspot on B ph CB pole to D isolator jumper by replacing twin Jumper	EO	220 KV
BOISAR II - BOISAR (PG) CKT - 2	28-05-2022	05:46	28-05-2022	06:30	Hot spot attending work 1. Bph T-Jumper crimping at A-Isolator end. (128.8 OC, Image.IR00550) 2.Yph T-Jumper crimping at A-Isolator end.(113 OC, Img.IR00551)	EO	220 KV
BOISAR II - BOISAR (PG) CKT - 2	28-05-2022	03:27	28-05-2022	05:46	Hot spot attending work Yph CT to D-Isolator jumper crimping at D-Isolator end. (102.9 OC, Image.IR00549)	EO	220 KV
PANDHARPUR - MALINAGAR	28-05-2022	16:20	28-05-2022	21:26	Outage is required for For changing / replacement of faulty string at loc no. Main line - 1,4,7,15,16,19,22,69.	PO	220 KV
PEDHAMBE ONI LINE	28-05-2022	09:30	28-05-2022	17:05	Outage for attending Hot spot at Loc. no. 141 Pedhambe side Y phase	EO	220 KV
220 / 110 / 23kv 250 MVA ICT 3 @ SALSETTE	28-05-2022	08:07	28-05-2022	12:01	Attending Oil leakage from conservator flange	PO	220 KV
220/132 KV 100 MVA ICT - 1 @KALWAN	28-05-2022	13:21	28-05-2022	16:05	For Premansoon maintenance work.	PO	220 KV
220/132 KV 100 MVA ICT 2 @ LONIKAND 2	28-05-2022	08:16	28-05-2022	14:53	For Half yearly maintenance and diagnostic testing work.	PO	220 KV

Transmission Line Outages/Trippings from 23.05.2022 to 29.05.2022							
Name of Line	Date Trip	Time Trip	Date Sync	Time Sync	Reason	Outage Type	Voltage
220/132 KV 200 MVA ICT 1 @ RAYMOND	28-05-2022	09:45	28-05-2022	18:55	PREMONSOON MAINTENANCE AND 2. BAY MAINTENANCE WORK	PO	220 KV
220/132 KV 200 MVA ICT 2 @ RAYMOND	28-05-2022	14:35	28-05-2022	14:35	ATTENDING RED HOT SPOTS 2. BALANCE PREMONSOON MAINTENANCE WORK	PO	220 KV
220/132 KV 200 MVA ICT 1 @ AHMEDNAGAR	28-05-2022	14:47	28-05-2022	16:01	Pre monsoon work, i.e. cleaning of bushings, tightening of N&B ,& various related work before monsoon.	PO	220 KV
220/132 KV 200 MVA ICT 1 @ EKLHARE(GCR)	28-05-2022	09:25	28-05-2022	17:15	Diagnosis of testing work and pre-monsoon maintenance work	PO	220 KV
220/132 KV 200 MVA ICT 2 @ AHMEDNAGAR	28-05-2022	11:15	28-05-2022	13:05	Pre monsoon work, i.e. cleaning of bushings, tightening of N&B ,& various related work before monsoon.	PO	220 KV
220/132 KV 200 MVA ICT 3 @ AHMEDNAGAR	28-05-2022	08:36	28-05-2022	10:50	Pre monsoon work, i.e. cleaning of bushings, tightening of N&B ,& various related work before monsoon	PO	220 KV
220/132KV 100MVA ICT-1 @ WALCHANDNAGAR	28-05-2022	13:10	28-05-2022	16:51	PRE MONSOON MAINTENANCE WORK	PO	220 KV
220/22 KV 50 MVA PTR 1 @ AIROLI KNOWLEDGE PARK	28-05-2022	08:36	28-05-2022	11:12	Pre monsoon maintenance & Hotspot attending work	PO	220 KV
220/22 KV 50 MVA PTR 1 @ KALWA	28-05-2022	14:25	28-05-2022	16:57	For replacement of 22kv main bus isolator & RM Work at MSEDCL END.	PO	220 KV
220/22KV 50MVA PTR - 1 @ PALAVA	28-05-2022	09:38	28-05-2022	12:19	Pre-monsoon maintenance work and neutral earth pit resistance measurement work.	PO	220 KV
220/22KV 50MVA PTR - 2 @ PALAVA	28-05-2022	12:31	28-05-2022	15:25	Pre-monsoon maintenance work and neutral earth pit resistance measurement work.	PO	220 KV
220/33 KV 25 MVA PTR 2 @ AHMEDNAGAR	28-05-2022	16:22	28-05-2022	17:19	Pre monsoon work, i.e. cleaning of bushings, tightening of N&B ,& various related work before monsoon.	PO	220 KV
220/33 KV 50 MVA PTR 1 @ BHENDA	28-05-2022	13:50	28-05-2022	15:45	Quarterly maintenance work / Pre Monsoon maintenance work and oil leakage attend of PTR-1 & PTR-2 from top side.	PO	220 KV
220/33 KV 50 MVA PTR 2 @ BHENDA	28-05-2022	08:00	28-05-2022	12:30	Quarterly maintenance work / pre monsoon maintenance work and oil leakage attend of PTR-1 & PTR-2 from top side.	PO	220 KV
220/33 KV 50 MVA PTR 3 @ BHENDA	28-05-2022	16:01	28-05-2022	17:51	Quarterly maintenance work/ pre monsoon maintenance work and oil leakage attend of PTR-1 & PTR-2	PO	220 KV
220/33 KV 50 MVA TF - 1@BELWANDI	28-05-2022	10:15	28-05-2022	11:35	Pre-Monsoon Maintenance Work	PO	220 KV
220/33 KV 50MVA PTR @ KALWAN	28-05-2022	09:03	28-05-2022	11:50	for premonsoon maintenance work	PO	220 KV
CHAKAN-BHOSARI 1	28-05-2022	13:19	28-05-2022	19:08	Double Jumpering Work	PO	220 KV
PARLI (OLD GCR) - PARLI (PG) CKT 2	28-05-2022	11:58	28-05-2022	19:34	For attending low line clearance at loc 5 6	EO	220 KV
BOISAR II - BOISAR (PG) CKT - 2	29-05-2022	01:07	29-05-2022	01:52	Hot spot attending work- 220kV A Bus Isolator's. @ Jaw towards B Bus.	EO	220 KV
DASTURI-KANDALGAON LINE	29-05-2022	05:55	29-05-2022	14:52	Outage tree cutting work at various location and other line maintenance work.	PO	220 KV
PANDHARPUR - MALINAGAR	29-05-2022	16:22	29-05-2022	21:22	Outage is required for For changing / replacement of faulty string at loc no. Main line - 1,4,7,15,16,19,22,69.	PO	220 KV
220 / 110 / 33kv 250MVA ICT 8 @ DHARAVI	29-05-2022	09:50	29-05-2022	14:52	Routine Maintenance	PO	220 KV

Transmission Line Outages/Trippings from 23.05.2022 to 29.05.2022							
Name of Line	Date Trip	Time Trip	Date Sync	Time Sync	Reason	Outage Type	Voltage
220/132KV 100MVA ICT 1 @ CHAKAN PHASE II	29-05-2022	20:49	29-05-2022	20:49	Half yearly maintenance and pre monsoon maintenance.	PO	220 KV
220/22 KV 50 MVA PTR 3 @ NALASOPARA	29-05-2022	07:30	29-05-2022	15:15	1. 80 MVA 220/22-22 kV PTR-3 for attending PTR LV Bushing oil leakage (minor) attending work. 2. Pre monsoon maintenance work. 3. OLTC overhauling of PTR.	PO	220 KV
220/22 KV 50 MVA PTR 2 @ VASAI	29-05-2022	14:50	29-05-2022	19:34	Hot spot attending by replacement of 22kV Bph bushing of 50MVA, 220/22kV PTR-2 by Agency & Pre monsoon maintenance work & Diagnostic testing.	PO	220 KV
220/132KV 100MVA ICT 1 @ SATARA MIDC	25-05-2022	10:38			Transformer painting work	PO	220 KV
220/132KV 100MVA ICT 1 @ SATARA MIDC	25-05-2022	10:38			Transformer painting work	PO	220 KV
TBC @ GHODBUNDER	25-05-2022	07:55		17:27	For safety purpose while doing maintenance of 100MVA TR-3	PO	220 KV
NAGAR - SUPA	28-05-2022	15:41	28-05-2022	19:05	Outage Proposal of 132kV Ahmednagar-supra line for Removing of bunching arrangement between Loc 70-71	PO	132 KV
TATA BORIVLI MSETCL BORIVLI 1	28-05-2022	13:49	28-05-2022	18:47	For attending to hot-spot at loc-14	PO	110 KV