

State Load Despatch Center,Airoli (MSETCL)
Power System Position from 24/Jul/2017 to 30/Jul/2017

Supply Position During Morning Peak (MW)

Date	Time	MSGENCO				Central Sector Receipt	Wind	CPP	SOLAR	TPCL Exch.	MSEDCL Catered Demand	Load Shedding(LS)	MSEDCL Demand (Incl. LS)	TPCL Gen.	R-INFRA Gen.	State Demand Met	State Demand (Incl. LS)	Freq.
		THM	HYDRO	GAS	Total													
		MW	MW	MW	MW	MW	MW	MW	MW	MW	MW	MW	MW	MW	MW	MW	MW	Hzs
24/07/2017	9 Hrs	3866	332	366	4564	5271	2713	3151	102	-1549	14252	0	14252	661	385	16847	16847	50.06
25/07/2017	9 Hrs	3464	315	379	4158	5030	2794	3815	114	-1359	14552	0	14552	768	483	17162	17162	50.04
26/07/2017	9 Hrs	3945	217	268	4430	5580	2645	3844	119	-1133	15485	0	15485	954	494	18066	18066	50.03
27/07/2017	9 Hrs	4172	128	409	4709	5313	2461	3829	86	-1120	15278	0	15278	927	497	17822	17822	49.99
28/07/2017	9 Hrs	4391	397	405	5193	5499	1717	3708	70	-1262	14925	0	14925	934	498	17619	17619	50.00
29/07/2017	12 Hrs	4568	291	408	5267	5359	1565	3630	286	-1459	14648	0	14648	1183	374	17664	17664	49.94
30/07/2017	12 Hrs	4599	629	411	5639	5436	1180	3470	273	-875	15123	0	15123	977	498	17473	17473	49.99
Maximum		4599	629	411	5639	5580	2794	3844	286	-875	15485	0	15485	1183	498	18066	18066	50.06
Minimum		3464	128	268	4158	5030	1180	3151	70	-1549	14252	0	14252	661	374	16847	16847	49.94
Average		4144	330	378	4851	5356	2154	3635	150	-1251	14895	0	14895	915	461	17522	17522	50.01

Supply Position During Day Peak (MW)

Date	Time	MSGENCO				Central Sector Receipt	Wind	CPP	SOLAR	TPCL Exch.	MSEDCL Catered Demand	Load Shedding(LS)	MSEDCL Demand (Incl. LS)	TPCL Gen.	R-INFRA Gen.	State Demand Met	State Demand (Incl. LS)	Freq.
		THM	HYDRO	GAS	Total													
		MW	MW	MW	MW	MW	MW	MW	MW	MW	MW	MW	MW	MW	MW	MW	MW	Hzs
24/07/2017	13 Hrs	3467	180	369	4016	4690	2832	3100	178	-1768	13048	0	13048	902	385	16103	16103	50.02
25/07/2017	13 Hrs	3476	140	374	3990	5235	2760	2914	196	-1742	13354	0	13354	898	384	16378	16378	50.01
26/07/2017	13 Hrs	3513	241	257	4011	5544	2804	3118	251	-1833	13895	0	13895	879	374	16981	16981	50.03
27/07/2017	13 Hrs	4250	135	405	4790	4792	2606	3601	193	-1836	14146	0	14146	861	371	17214	17214	50.01
28/07/2017	13 Hrs	3804	419	395	4618	5501	1956	3139	127	-1822	13519	0	13519	924	374	16639	16639	50.04
29/07/2017	13 Hrs	4651	108	407	5166	4989	1727	3662	221	-1537	14228	0	14228	1069	373	17207	17207	49.96
30/07/2017	13 Hrs	4612	454	407	5473	5434	1269	3470	219	-842	15023	0	15023	980	495	17340	17340	50.01
Maximum		4651	454	407	5473	5544	2832	3662	251	-842	15023	0	15023	1069	495	17340	17340	50.04
Minimum		3467	108	257	3990	4690	1269	2914	127	-1836	13048	0	13048	861	371	16103	16103	49.96
Average		3968	240	373	4581	5169	2279	3286	198	-1626	13888	0	13888	930	394	16837	16837	50.01

Supply Position During Evening Peak (MW)

Date	Time	MSGENCO				Central Sector Receipt	Wind	CPP	SOLAR	TPCL Exch.	MSEDCL Cateder Demand	Load Shedding(LS)	MSEDCL Demand (Incl. LS)	TPCL Gen.	R-INFRA Gen.	State Demand Met	State Demand (Incl. LS)	Freq.
		THM	HYDRO	GAS	Total													
		MW	MW	MW	MW	MW	MW	MW	MW	MW	MW	MW	MW	MW	MW	MW	MW	Hzs
24/07/2017	20 Hrs	3629	357	362	4348	4611	2516	3388	0	-1403	13460	0	13460	972	385	16220	16220	49.94
25/07/2017	20 Hrs	3981	280	373	4634	5064	2316	3526	0	-1319	14221	0	14221	1090	384	17014	17014	49.93
26/07/2017	21 Hrs	3895	822	267	4984	5212	1956	3812	0	-1212	14753	0	14753	1134	372	17471	17471	49.93
27/07/2017	20 Hrs	4147	469	407	5023	4901	1914	3221	0	-1496	13563	0	13563	915	372	16346	16346	49.88
28/07/2017	20 Hrs	4281	388	411	5080	4932	1666	3585	0	-1427	13836	0	13836	1002	374	16639	16639	49.96
29/07/2017	21 Hrs	4577	690	409	5676	4580	1344	3647	0	-858	14389	0	14389	1306	503	17056	17056	49.90
30/07/2017	21 Hrs	4809	332	412	5553	4656	1169	3476	0	-675	14179	0	14179	1193	494	16541	16541	49.89
Maximum		4809	822	412	5676	5212	2516	3812	0	-675	14753	0	14753	1306	503	17471	17471	49.96
Minimum		3629	280	267	4348	4580	1169	3221	0	-1496	13460	0	13460	915	372	16220	16220	49.88
Average		4188	477	377	5043	4851	1840	3522	0	-1199	14057	0	14057	1087	412	16755	16755	49.92

Supply Position During Night Off Peak (MW)

Date	Time	MSGENCO				Central Sector Receipt	Wind	CPP	SOLAR	TPCL Exch.	MSEDCL Cateder Demand	Load Shedding(LS)	MSEDCL Demand (Incl. LS)	TPCL Gen.	R-INFRA Gen.	State Demand Met	State Demand (Incl. LS)	Freq.
		THM	HYDRO	GAS	Total													
		MW	MW	MW	MW	MW	MW	MW	MW	MW	MW	MW	MW	MW	MW	MW	MW	Hzs
24/07/2017	3 Hrs	3468	86	375	3929	3057	2667	2867	0	-777	11743	0	11743	589	386	13495	13495	50.04
25/07/2017	4 Hrs	3038	127	365	3530	3652	2521	2907	0	-772	11839	0	11839	599	387	13597	13597	49.99
26/07/2017	3 Hrs	3377	94	258	3729	3921	2280	3166	0	-868	12228	0	12228	593	385	14074	14074	49.99
27/07/2017	3 Hrs	3741	231	395	4367	3869	2059	3206	0	-893	12608	0	12608	591	376	14468	14468	50.01
28/07/2017	3 Hrs	3842	88	405	4335	3800	1909	3109	0	-881	12272	0	12272	589	373	14115	14115	49.96
29/07/2017	4 Hrs	4113	166	414	4693	3873	1371	3218	0	-796	12359	0	12359	640	373	14168	14168	49.96
30/07/2017	3 Hrs	3810	272	404	4486	3988	1137	3770	0	-539	12842	0	12842	867	497	14745	14745	50.01
Maximum		4113	272	414	4693	3988	2667	3770	0	-539	12842	0	12842	867	497	14745	14745	50.04
Minimum		3038	86	258	3530	3057	1137	2867	0	-893	11743	0	11743	589	373	13495	13495	49.96
Average		3627	152	374	4153	3737	1992	3178	0	-789	12270	0	12270	638	397	14095	14095	49.99

Details of Supply Position (MUs)

Date	MSGENCO				Pench (MS)	Central Sector Receipt	Central Sector Share	WIND	CPP	SOLAR	TPCL Gen.	R-INFRA Gen.	TPCL Exch.	Energy Requirement		
	THM	HYDRO	GAS	Total										MSEDCL	MUMBAI	STATE
	Mus	Mus	Mus	Mus	Mus	Mus	Mus	Mus	Mus	Mus	Mus	Mus	Mus	Mus	Mus	Mus
24/07/2017	85.304	5.709	8.963	99.976	0.000	102.086	99.648	64.432	73.907	1.542	18.835	9.242	-31.665	310.278	59.742	370.020
25/07/2017	81.503	5.862	9.012	96.377	0.018	113.066	107.963	62.921	76.003	1.649	19.640	9.553	-31.350	318.666	60.543	379.209
26/07/2017	86.680	8.038	6.280	100.998	0.025	119.053	116.351	56.465	81.856	1.558	20.367	9.437	-31.321	328.609	61.125	389.734
27/07/2017	97.748	6.134	9.522	113.404	0.079	111.165	112.023	52.615	81.096	1.386	19.871	9.444	-31.463	328.203	60.775	388.978
28/07/2017	97.730	6.478	9.779	113.987	0.020	113.220	110.011	43.941	80.240	1.169	20.232	9.335	-31.529	321.028	61.096	382.124
29/07/2017	105.245	6.872	9.850	121.967	0.085	113.347	110.947	35.605	84.769	1.923	23.041	10.054	-25.874	331.737	58.969	390.706
30/07/2017	107.065	7.219	9.896	124.180	0.021	113.440	109.850	28.944	85.797	1.972	22.786	10.946	-17.658	336.675	51.390	388.065
Maximum	107.065	8.038	9.896	124.180	0.085	119.053	116.351	107.065	85.797	1.972	23.041	10.946	-17.658	336.675	61.125	390.706
Minimum	81.503	5.709	6.280	96.377	0.000	102.086	99.648	81.503	73.907	1.169	18.835	9.242	-31.665	310.278	51.390	370.020
Average	94.468	6.616	9.043	110.127	0.035	112.197	109.542	94.468	80.524	1.600	20.682	9.716	-28.694	325.028	59.091	384.119

Details of Koyna Water Consumption (in TMC)

Date	For the Day	For the Month	Balance
24/07/2017	0.053	2.363	63.080
25/07/2017	0.056	2.419	63.024
26/07/2017	0.128	2.547	62.896
27/07/2017	0.073	2.620	62.823
28/07/2017	0.084	2.704	62.739
29/07/2017	0.075	2.779	62.664
30/07/2017	0.083	2.862	62.581

State Load Despatch Center, Airoli (MSETCL)
Central Sector Share/Drawal from 24/Jul/2017 to 30/Jul/2017

Date	DAY	Central Sector Share		Total Interstate Bilateral Purchase		Total Share		Total Drawal		Overdrawal(+) / UnderDrawal(-)	
		MUs	Avg. MW	MUs	Avg. MW	MUs	Avg. MW	MUs	Avg. MW	MUs	Avg. MW
		1		2		1+2=3		4		3-4=5	
24/07/2017	MONDAY	92.340	4145	7.308	305	99.648	4152	102.086	4254	2.438	102
25/07/2017	TUESDAY	93.687	4484	14.276	595	107.963	4498	113.066	4711	5.103	213
26/07/2017	WEDNESDA	103.004	4835	13.347	556	116.351	4848	119.053	4961	2.702	113
27/07/2017	THURSDAY	98.486	4654	13.537	564	112.023	4668	111.165	4632	-0.858	-36
28/07/2017	FRIDAY	91.695	4565	18.316	763	110.011	4584	113.220	4718	3.209	134
29/07/2017	SATURDAY	93.972	4606	16.975	707	110.947	4623	113.347	4723	2.400	100
30/07/2017	SUNDAY	80.999	4548	28.851	1202	109.850	4577	113.440	4727	3.590	150
Total		654.184		112.609		766.793		785.376		18.583	

GENERATING UNITS OUTAGES FOR THE WEEK FROM 24/07/2017 TO 30/07/2017							
Generator	Generating Unit	Capacity	Tripped Date	Tripped Time	Synch. Date	Synch Time	Reason
PLANNED OUTAGES							
IPP	Tata Trombay 6	500MW	15/Jul/2015	17.08		Continued.	Economic shutdown(Converted to AOH for 30 Days from 00.00Hrs 06-03-2016)
CS	TARAPUR 4	540MW	23/Apr/2017	19:55		Continued.	Annual Maintenance
CS	Tarapur 1	160MW	04/Jun/2017	19.09		Continued.	3 months outage for refuelling.
MSPGCL	Chandrapur Unit 3	210MW	05/Jun/2017	23.24	24/Jul/2017	16.18	AOH.
MSPGCL	Khaparkheda Unit 2	210MW	14/Jun/2017	23.16		Continued.	Annual Overhaul
MSPGCL	Koradi Unit 7	210MW	21/Jun/2017	01.24		Continued.	COH.
IPP	JSW (J) U4	300MW	04/Jul/2017	20.41	04/Aug/2017	12.30	Annual Overhaul
CS	TARAPUR-3	540MW	11/Jul/2017	16.30		Continued.	Reactor Inspection Work
IPP	Adani U-3	660MW	14/Jul/2017	23.48	01/Aug/2017	00.04	Annual Overhaul
MSPGCL	Bhusawal Unit 5	500MW	15/Jul/2017	05.59			Zero Schedule By MSEDCL (Converted to AOH from 00.00Hrs of 20.07.2017)
MSPGCL	Khaparkheda Unit 4	210MW	13/Jul/2017	03.36		Continued.	on Dated 14.07.2017 converted to zero schedule. Converted into COH from 00:00Hrs of 02.08.2017
FORCED OUTAGES							
RGPL	Dabhol Dabhol 1B	230MW	28/May/2013	22:02		Continued.	Gas Shortage.
RGPL	Dabhol Dabhol 1X	230MW	27/Jun/2013	21.46		Continued.	Gas Shortage
RGPL	Dabhol Dabhol 1A	230MW	27/Jun/2013	21.47		Continued.	Gas Shortage
MSPGCL	Koradi Unit 6	210MW	20/Mar/2015	01.02		Continued.	EE R&M LE Work
IPP	SWPGL U-1	135MW	16/Feb/2016	17.09		Continued.	Change Over , No Schedule
IPP	SWPGL U-2	135MW	29/Feb/2016	21.46		Continued.	Change over against Unit III
MSPGCL	Parli Unit 4	210MW	01/Apr/2016	00.00		Continued.	Economic shutdown
MSPGCL	Parli Unit 5	210MW	01/Apr/2016	00.00		Continued.	Economic shutdown
MSPGCL	Bhusawal Unit 2	210MW	14/Jun/2016	19.35		Continued.	Boiler Tube Leakage(Converted to Zero Shedule By MSEDCL. from 00.00Hrs dt.19-6-16)
MSPGCL	Uran Unit 8	108MW	14/Aug/2016	07.56		Continued.	Maintenance work
RGPL	Dabhol 2A	230MW	24/Aug/2016	13.31		Continued.	Change Over.
MSPGCL	Koradi Unit 5	200MW	05/Sep/2016	00.21		Continued.	ID Fan problem, Converted to Zero Schedule By MSEDCL from 00.00hrs/22-9-16. Shutdown taken on 18.10.2016 at 00:00Hrs for Turbine inspection and maintenance work
IPP	PGPL U1	262MW	07/Feb/2017	17.30		Continued.	No Schedule
IPP	PGPL U2	126MW	07/Feb/2017	17.30		Continued.	No Schedule
IPP	RPL(AMT) U-1	270MW	24/May/2017	03.27		Continued.	Flame Failure
IPP	JSW (J) U2	300MW	31/May/2017	23.58		Continued.	NO SCHEDULE.
IPP	Dharwal	300MW	01/Jun/2017	00.01		Continued.	NO SCHEDULE.
IPP	RPL(AMT) U-3	270MW	05/Jun/2017	14.31		Continued.	swaping with unit-5.
IPP	RPL(AMT) U-5	270MW	09/Jun/2017	01.39		Continued.	Zero Schedule by MSEDCL
IPP	RPL(AMT) U-2	270MW	09/Jun/2017	04.24		Continued.	Zero Schedule by MSEDCL
IPP	RPL(AMT) U-4	270MW	09/Jun/2017	00.20		Continued.	Zero Schedule by MSEDCL
MSPGCL	Parli Unit 7	250MW	13/Jun/2017	00.04		Continued.	Zero Schedule By MSEDCL
MSPGCL	Bhusawal Unit 3	210MW	13/Jun/2017	06.01		Continued.	Zero Schedule By MSEDCL
IPP	VIPL U-1	300MW	13/Jun/2017	08.30		Continued.	GT WORK
MSPGCL	Parli Unit 6	250MW	14/Jun/2017	00.02		Continued.	Zero schedule by MSEDCL.
MSPGCL	Parli Unit 8	250MW	17/Jun/2017	00.08		Continued.	Zero Schedule by MSEDCL
MSPGCL	Nasik Unit 4	210MW	10/Jul/2017	14.28		Continued.	Boiler validity extention on date 12/07/2017 converted zero schedule
MSPGCL	Khaparkheda Unit 1	210MW	11/Jul/2017	23.53	07/Aug/2017	04.06	Zero Schedule By MSEDCL
MSPGCL	Khaparkheda Unit 3	210MW	12/Jul/2017	08.40		Continued.	Boiler Tube Leakage. on date 13.07.2017 converted to zero schedule.
MSPGCL	Nasik Unit 5	210MW	16/Jul/2017	00.00		Continued.	Zero Schedule By MSEDCL
MSPGCL	Bhusawal Unit 4	500MW	17/Jul/2017	23.46	31/Jul/2017	11.59	Zero Schedule By MSEDCL
IPP	Trombay 7B	60MW	21/Jul/2017	23.20	28/Jul/2017	22.09	Gas Path Inspection and CW Tunnel repairs (For 8 Days)
MSPGCL	Chandrapur Unit 5	500MW	22/Jul/2017	22.39	26/Jul/2017	16.20	Air Pre-Heater Basket Replacement.
IPP	Trombay 7A	120MW	22/Jul/2017	02.51	28/Jul/2017	12.27	Gas Path Inspection and CW Tunnel repairs (For 8 Days)
IPP	SWPGL U-4	135MW	24/Jul/2017	10.26	24/Jul/2017	11.17	Turbine Problem.
MSPGCL	Khaparkheda Unit 5	500MW	25/Jul/2017	00.00	30/Jul/2017	19.27	Zero Schedule By MSEDCL
MSPGCL	Chandrapur Unit 4	210MW	26/Jul/2017	13.36	28/Jul/2017	23.49	Boiler Tube Leakage
MSPGCL	Uran Unit 6	108MW	26/Jul/2017	00.45	26/Jul/2017	23.09	Air filter replacement work.
MSPGCL	Koradi Unit-8	660MW	26/Jul/2017	16.32	26/Jul/2017	18.20	electrical turbine protection operated.
IPP	SWPGL U-3	135MW	27/Jul/2017	13.00	01/Aug/2017	15.12	ID Fan Problem
MSPGCL	Ghatghar Unit-2	125MW	28/Jul/2017	00.00		Continued.	due to common pressure shaft with unit 1.
MSPGCL	Ghatghar Unit-1	125MW	28/Jul/2017	00.00		Continued.	rbtv leakage attending work.
MSPGCL	Koradi Unit 10	660MW	29/Jul/2017	23.15	30/Jul/2017	02.50	Generator Elect. Fault
IPP	VIPL U-2	300MW	30/Jul/2017	11.02	02/Aug/2017	04.27	Boiler Tube Leakage

LINE OUTAGES AND RIPPING FOR THE WEEK FROM 24/07/2017 TO 30/07/2017

Voltage	Name of Line	Tripping Date	Tripping Time	Synch Date	Synch Time	Reason
400 KV	Karad -Solapur (PG)	03/May/2017	11:49		Continued.	Line converted as 220 kv Solapur (PG)- Jeur from LOC 403
400 KV	Karad - Jaigad - II	08/Jul/2017	21.48	26/Jul/2017	06.41	Over Voltage
400 KV	Dhule Sar'Sarovar II	12/Jul/2017	20.45	25/Jul/2017	08.02	Over Voltage
400 KV	Ektuni-Bableshtar ckt II	16/Jul/2017	16.05		Continued.	To control load
400 KV	karad -kolhapur-I	20/Jul/2017	09.38	29/Jul/2017	10.51	Over Voltage
400 KV	Lonikand I - Koyana stage-IV	24/Jul/2017	00.51	24/Jul/2017	07.32	Over Voltage
400 KV	Kolhapur(M)-Kolhapur(GIS) ckt1	24/Jul/2017	01.02	24/Jul/2017	09.39	Over Voltage
400 KV	Chandrapur-II - Nanded ckt I	24/Jul/2017	11.58	24/Jul/2017	15.07	Quarterly Maintenance Work
400 KV	New Koyana Main Bus 1	24/Jul/2017	12.04	24/Jul/2017	19.34	Replacement of CVT
400 KV	koaradi II - Wardha(PG)	24/Jul/2017	22.03	24/Jul/2017	23.50	Isolator Maintenance Work
400 KV	Kalwa - Kharghar	25/Jul/2017	00.38	25/Jul/2017	16.28	Heavy Sparking
400 KV	Padghe - Kalwa-II	25/Jul/2017	07.20	25/Jul/2017	08.00	Attending Hot Spot
400 KV	Lonikand 1 -Jejuri	25/Jul/2017	07.25	25/Jul/2017	19.17	AR out.
400 KV	Padghe - Kalwa-II	25/Jul/2017	08.00	25/Jul/2017	09.28	Taken on TBC.
400 KV	Padghe(HVDC)- Padghe(HVAC)-I	25/Jul/2017	12.30	25/Jul/2017	14.46	heavy spark on HVDC.
400 KV	Akola II - RPL(Rattanindia) Ckt-II	25/Jul/2017	13.26	27/Jul/2017	06.29	Distance Protection
400 KV	Akud-Kolhapur(Talandage)	25/Jul/2017	15.05	25/Jul/2017	18.50	MAIN BUS 1 OUTAGE.
400 KV	Dhule Sar'Sarovar I	25/Jul/2017	17.06	27/Jul/2017	06.58	Over Voltage
400 KV	Babhaleshwar - Padghe-II	25/Jul/2017	18.47	25/Jul/2017	13.42	Taken on TBC.
400 KV	Padghe - Kalwa-II	26/Jul/2017	05.52	26/Jul/2017	09.39	Attending Hot Spot
400 KV	Jaigad-New Koyana Ckt-I	26/Jul/2017	10.20	26/Jul/2017	19.05	RFC,cvt replacement at jaigad end.
400 KV	Ektuni-Taptitanda II	26/Jul/2017	11.37	26/Jul/2017	15.39	Attending Hot Spot
400 KV	Dhule Khandwa II	26/Jul/2017	12.24	27/Jul/2017	11.35	Distance Protection
400 KV	Nagothane - Dabhol I	27/Jul/2017	11.15	27/Jul/2017	20.24	Insulator string Replacement Work.
400 KV	Dhule Sar'Sarovar II	27/Jul/2017	13.13	29/Jul/2017	10.16	Over Voltage
400 KV	Jaigad-Karad Ckt-I	27/Jul/2017	17.46	28/Jul/2017	06.42	Over Voltage
400 KV	Jaigad-New Koyana Ckt-II	28/Jul/2017	06.02	28/Jul/2017	10.02	Distance Protection
400 KV	Karad-Jaigad - I	28/Jul/2017	17.00	02/Aug/2017	10.47	Over Voltage
400 KV	Dhule Sar'Sarovar I	29/Jul/2017	18.07	31/Jul/2017	18.34	Over Voltage
400 KV	karad -kolhapur-I	29/Jul/2017	19.55	02/Aug/2017	09.07	Over Voltage
400 KV	Lonikand I - Koyana stage-IV	30/Jul/2017	03.20	30/Jul/2017	06.39	Over Voltage
400 KV	Babhaleshwar - Padghe-II	30/Jul/2017	10.30	30/Jul/2017	15.25	Jumper Tightening and Fixing of Nut Bolts
400 KV	Dabhol Nagothane II	30/Jul/2017	12.52	30/Jul/2017	13.39	Tripped from Dabhol end only
400 KV	Karad - Jaigad - II	03/Aug/2017	13.08		Continued.	Over Voltage
220 KV	Chandrapur GCR - Warora - I	05/Apr/2015	09.13		Continued.	Bunching of conductor Loc no 86 Disconnecting of jumer at Loc no 86 & 107
220 KV	Chandrapur GCR - Wani	05/Apr/2015	09.15		Continued.	Bunching of conductor Loc no 86 Disconnecting of jumer at Loc no 86 & 107
220 KV	Talandage - Chikodi	01/Jun/2017	00.01		Continued.	NO SCHEDULE.
220 KV	Mudshingi - Chikodi	01/Jun/2017	00.06		Continued.	NO SCHEDULE.
220 KV	Kharghar-Borivali ckt II	07/Jun/2017	12.23		Continued.	Distance Protection
220 KV	Vita - Mhaishal	01/Jul/2017	14.19		Continued.	Bunching Work
220 KV	Vita - Miraj	01/Jul/2017	14.53		Continued.	bunching work.
220 KV	Nanded-Ghatodi	05/Jul/2017	16.34	25/Jul/2017	10.54	HT in view of partly ICT U/O.
220 KV	Karad - Sadawagpur I	21/Jul/2017	11.07	29/Jul/2017	19.40	Distance Protection
220 KV	Umred-Kanhan 2	24/Jul/2017	09.12	24/Jul/2017	17.08	Replacement of Jumper
220 KV	Khaparkheda-Ambazari-II	24/Jul/2017	10.26	24/Jul/2017	19.05	Distance Protection
220 KV	Parli 3 (Old Gcr)-Osmanabad	24/Jul/2017	11.27	24/Jul/2017	16.12	Replacement of R Phase Vibration Damper
220 KV	Kanhan-Bhandara I	24/Jul/2017	11.47	24/Jul/2017	13.44	To attend Hot Spot
220 KV	Kalwa - Siemens	24/Jul/2017	12.45	24/Jul/2017	16.56	Line Maintenance work
220 KV	Padghe - Jindal	24/Jul/2017	12.48	24/Jul/2017	16.09	To attend Hot Spot
220 KV	Padghe - Jambhul 1	24/Jul/2017	13.17	24/Jul/2017	15.45	Quarterly Maintenance Work
220 KV	Tillari Amona	24/Jul/2017	13.25	24/Jul/2017	18.20	To attend Hot Spot
220 KV	Shivajinagar-Gangapur	24/Jul/2017	15.24	25/Jul/2017	14.41	Tripped at Gangapur end
220 KV	Bombay Dyeing - Sahara	24/Jul/2017	21.15	25/Jul/2017	17.06	Distance Protection
220 KV	Kalwa - Siemens	25/Jul/2017	09.02	25/Jul/2017	17.18	making scaffolding.
220 KV	Pusad-Ghatodi	25/Jul/2017	10.18	25/Jul/2017	19.41	In view of 220kv yavatmal-pusad ckt U/O.
220 KV	Adlabs - Pedambe	25/Jul/2017	11.05	25/Jul/2017	18.38	Emergency tree cutting work.
220 KV	Yeatmal- Pusad	25/Jul/2017	11.05	25/Jul/2017	19.31	fixing of r- ph.
220 KV	Gadchandur - Virur-I	25/Jul/2017	11.30	25/Jul/2017	14.00	Replacement of flasher disk.
220 KV	Gadchandur - Grace	26/Jul/2017	02.47	26/Jul/2017	05.10	Distance Protection
220 KV	Kolhapur-Bidri	26/Jul/2017	09.06	26/Jul/2017	15.17	Line Maintenance work
220 KV	Osmanabad - Barshi	26/Jul/2017	10.00	26/Jul/2017	12.20	Quarterly Maintenance Work
220 KV	Paranda-Barshi	26/Jul/2017	10.00	26/Jul/2017	12.20	Quarterly Maintenance Work
220 KV	Kalwa - Siemens	26/Jul/2017	10.20	26/Jul/2017	16.58	safety purpose for construction work.
220 KV	Karad(400kv) - Wathar	26/Jul/2017	10.46	26/Jul/2017	17.21	string replacement.
220 KV	Osmanabad - Solapur (Bale)	26/Jul/2017	14.26	26/Jul/2017	16.45	Routine Maintenance Work
220 KV	Parli 2(Girwali) - Murud	26/Jul/2017	17.02	27/Jul/2017	10.39	to control partly ict loading.
220 KV	Jejuri (400 Kv)-Phursungi	27/Jul/2017	09.38	27/Jul/2017	15.49	Routine Maintenance Work
220 KV	Kalwa - Siemens	27/Jul/2017	09.56	27/Jul/2017	17.29	safety purpose for construction work.
220 KV	Uran - Kharghar I	27/Jul/2017	10.58	27/Jul/2017	16.14	Attending Hot Spot
220 KV	Chakan-Bhosari	27/Jul/2017	11.06	27/Jul/2017	20.58	Routine Maintenance Work
220 KV	Tillari Amona	27/Jul/2017	12.56	27/Jul/2017	17.07	Distance Relay Testing Work
220 KV	Pedambe-Nerle	27/Jul/2017	16.16	28/Jul/2017	14.06	Distance Protection
220 KV	Parli 3 (Oldgcr)-Harangul Ckt 2	27/Jul/2017	18.10	27/Jul/2017	21.00	Isolator jaw Replacement work.
220 KV	Jejuri- Ismt- Lonand	27/Jul/2017	19.16	27/Jul/2017	17.43	Replacement of Line Isolator
220 KV	Versova Aarey Line 1	28/Jul/2017	09.43	28/Jul/2017	19.33	Isolator Maintenance work.
220 KV	Mahape - TIFIL	28/Jul/2017	11.00	28/Jul/2017	16.50	Attending Hot Spot
220 KV	Jejuri-Phursungi 2	28/Jul/2017	12.41	28/Jul/2017	13.35	shifted on TBC at phursungi end
220 KV	Jambhul - Pal	28/Jul/2017	14.48	28/Jul/2017	17.37	Attending Hot Spot
220 KV	Pedambe-Nerle	28/Jul/2017	15.00	29/Jul/2017	16.45	Distance Protection
220 KV	Bhaveghar - Kolshet	29/Jul/2017	09.31	29/Jul/2017	18.43	Lilo work
220 KV	Bableshtar - Bableshtar-I	29/Jul/2017	09.38	29/Jul/2017	10.52	Attending Hot Spot
220 KV	Pedambe-Nerle	29/Jul/2017	09.45	29/Jul/2017	16.45	Routine Maintenance Work
220 KV	220KV Chalisagaon-Kopergaon	29/Jul/2017	10.05	29/Jul/2017	17.40	Routine Maintenance Work
220 KV	Osmanabad - Solapur (Bale)	29/Jul/2017	10.10	29/Jul/2017	17.25	Attending Hot Spot

Voltage	Name of Line	Tripping Date	Tripping Time	Synch Date	Synch Time	Reason
220 KV	Bableshtar- Bableshtar-II	29/Jul/2017	11.05	29/Jul/2017	14.10	Attending Hot Spot
220 KV	Akola-Paras Ckt No-II	29/Jul/2017	11.15	29/Jul/2017	15.50	Tan Delta Measurment of CTs
220 KV	Nadgaonpeth-Amravati	29/Jul/2017	12.10	29/Jul/2017	16.38	recommissioning of control and bay unit.
220 KV	Nanded- Bhokar I	29/Jul/2017	12.39	29/Jul/2017	13.07	Distance Protection
220 KV	New Koyna - Pedambe	04/Aug/2017	15.10		Continued.	cb overhauling work.
132 KV	Amalner(220kv)-Chopda	25/Jul/2017	10.10	25/Jul/2017	15.50	To connect jumper to newly constructed ckt.
132 KV	Pusad-Jambazar	25/Jul/2017	10.20	25/Jul/2017	19.46	In view of 220kv pusad -yavatmal ckt U/O.
132 KV	Cosmofilms-Badnapur	25/Jul/2017	11.40	25/Jul/2017	11.50	Distance Protection
132 KV	Kardha-Asgaon	27/Jul/2017	19.12	27/Jul/2017	19.34	Distance Protection
132 KV	Waghala (Nanded2) - Narsi	27/Jul/2017	19.27	27/Jul/2017	19.40	Distance Protection
132 KV	Ambazari-Arvi	29/Jul/2017	20.44	29/Jul/2017	21.07	Distance Protection
132 KV	Bambwade-Tap On Shirala Chikhali	29/Jul/2017	23.26	30/Jul/2017	02.12	Distance Protection