

State Load Despatch Center,Airoli (MSETCL)
Power System Position from 24/Aug/2015 to 30/Aug/2015

Supply Position During Morning Peak (MW)

Date	Time	MSGENCO				Central Sector Receipt	Wind	CPP	SOLAR	TPCL Exch.	MSEDCL Catered Demand	Load Shedding(LS)	MSEDCL Demand (Incl. LS)	TPCL Gen.	R-INFRA Gen.	State Demand Met	State Demand (Incl. LS)	Freq.
		THM	HYDRO	GAS	Total													
		MW	MW	MW	MW	MW	MW	MW	MW	MW	MW	MW	MW	MW	MW	MW	MW	Hzs
24/08/2015	11 Hrs	3917	596	278	4791	6204	922	5232	126	-1489	15786	21	15807	1144	509	18928	18949	49.91
25/08/2015	11 Hrs	3917	596	278	4791	6204	922	5232	126	-1489	15786	21	15807	1144	509	18928	18949	49.91
26/08/2015	12 Hrs	4199	780	256	5235	6483	469	5006	118	-1496	15815	31	15846	1128	512	18951	18982	49.86
27/08/2015	10 Hrs	4254	652	257	5163	6443	426	5154	99	-1294	15991	28	16019	1069	512	18866	18894	49.81
28/08/2015	10 Hrs	4207	666	271	5144	5550	676	5222	36	-1225	15403	26	15429	1062	516	18206	18232	49.95
29/08/2015	11 Hrs	4080	257	267	4604	6376	612	4192	44	-1116	14712	21	14733	1080	517	17425	17446	49.93
30/08/2015	12 Hrs	4012	699	271	4982	5187	800	4916	132	-830	15187	23	15210	849	517	17383	17406	49.84
Maximum		4254	780	278	5235	6483	922	5232	132	-830	15991	31	16019	1144	517	18951	18982	50
Minimum		3917	257	256	4604	5187	426	4192	36	-1496	14712	21	14733	849	509	17383	17406	50
Average		4084	607	268	4959	6064	690	4993	97	-1277	15526	21	15550	1068	513	18384	18408	50

Supply Position During Day Peak (MW)

Date	Time	MSGENCO				Central Sector Receipt	Wind	CPP	SOLAR	TPCL Exch.	MSEDCL Catered Demand	Load Shedding(LS)	MSEDCL Demand (Incl. LS)	TPCL Gen.	R-INFRA Gen.	State Demand Met	State Demand (Incl. LS)	Freq.
		THM	HYDRO	GAS	Total													
		MW	MW	MW	MW	MW	MW	MW	MW	MW	MW	MW	MW	MW	MW	MW	MW	Hzs
24/08/2015	13 Hrs	3900	416	277	4593	6499	828	5199	131	-1499	15751	21	15772	1147	513	18910	18931	49.90
25/08/2015	13 Hrs	3900	416	277	4593	6499	828	5199	131	-1499	15751	21	15772	1147	513	18910	18931	49.90
26/08/2015	16 Hrs	4219	401	254	4874	5908	868	5015	114	-1438	15341	25	15366	1079	515	18373	18398	49.93
27/08/2015	13 Hrs	4176	383	253	4812	6216	469	5079	121	-1434	15263	28	15291	1125	517	18339	18367	49.93
28/08/2015	13 Hrs	4063	724	265	5052	5630	483	4756	39	-1391	14569	26	14595	1148	517	17625	17651	49.93
29/08/2015	13 Hrs	4110	511	257	4878	5562	693	4521	60	-1136	14578	32	14610	1051	517	17282	17314	49.92
30/08/2015	13 Hrs	3995	632	272	4899	4771	692	4834	126	-866	14456	24	14480	827	516	16665	16689	49.87
Maximum		4219	724	277	5052	6499	868	5199	131	-866	15751	32	15772	1148	517	18910	18931	50
Minimum		3900	383	253	4593	4771	469	4521	39	-1499	14456	21	14480	827	513	16665	16689	50
Average		4052	498	265	4814	5869	694	4943	103	-1323	15101	21	15127	1075	515	18015	18040	50

Supply Position During Evening Peak (MW)

Date	Time	MSGENCO				Central Sector Receipt	Wind	CPP	SOLAR	TPCL Exch.	MSEDCL Cateder Demand	Load Shedding(LS)	MSEDCL Demand (Incl. LS)	TPCL Gen.	R-INFRA Gen.	State Demand Met	State Demand (Incl. LS)	Freq.
		THM	HYDRO	GAS	Total													
		MW	MW	MW	MW	MW	MW	MW	MW	MW	MW	MW	MW	MW	MW	MW	MW	Hzs
24/08/2015	20 Hrs	3790	333	272	4395	4665	1419	5210	0	-1273	14416	27	14443	1082	519	17290	17317	49.83
25/08/2015	20 Hrs	3790	333	272	4395	4665	1419	5210	0	-1273	14416	27	14443	1082	519	17290	17317	49.83
26/08/2015	20 Hrs	3972	613	262	4847	4755	1441	4969	0	-1280	14732	28	14760	1049	519	17580	17608	49.89
27/08/2015	20 Hrs	4362	208	262	4832	4895	970	5097	0	-1388	14406	30	14436	994	516	17304	17334	49.96
28/08/2015	20 Hrs	4340	107	267	4714	4344	859	4958	0	-1227	13648	28	13676	1047	516	16438	16466	49.95
29/08/2015	20 Hrs	4001	319	260	4580	4381	1080	4572	0	-1332	13281	32	13313	688	516	15817	15849	49.94
30/08/2015	20 Hrs	3847	710	272	4829	4368	1169	4291	0	-963	13694	24	13718	735	517	15909	15933	49.91
Maximum		4362	710	272	4847	4895	1441	5210	0	-963	14732	32	14760	1082	519	17580	17608	50
Minimum		3790	107	260	4395	4344	859	4291	0	-1388	13281	24	13313	688	516	15817	15849	50
Average		4015	375	267	4656	4582	1194	4901	0	-1248	14085	24	14113	954	517	16804	16832	50

Supply Position During Night Off Peak (MW)

Date	Time	MSGENCO				Central Sector Receipt	Wind	CPP	SOLAR	TPCL Exch.	MSEDCL Cateder Demand	Load Shedding(LS)	MSEDCL Demand (Incl. LS)	TPCL Gen.	R-INFRA Gen.	State Demand Met	State Demand (Incl. LS)	Freq.
		THM	HYDRO	GAS	Total													
		MW	MW	MW	MW	MW	MW	MW	MW	MW	MW	MW	MW	MW	MW	MW	MW	Hzs
24/08/2015	4 Hrs	3677	160	274	4111	4235	1582	3938	0	-843	13023	21	13044	583	396	14845	14866	49.95
25/08/2015	4 Hrs	3677	160	274	4111	4235	1582	3938	0	-843	13023	21	13044	583	396	14845	14866	49.95
26/08/2015	4 Hrs	4053	121	266	4440	4009	898	4817	0	-798	13366	26	13392	585	399	15148	15174	49.93
27/08/2015	4 Hrs	4176	92	261	4529	4154	820	4981	0	-542	13942	25	13967	785	518	15787	15812	49.94
28/08/2015	4 Hrs	4237	104	278	4619	3669	770	5097	0	-758	13397	23	13420	581	517	15253	15276	49.97
29/08/2015	5 Hrs	4205	103	276	4584	3551	716	4760	0	-705	12906	21	12927	635	517	14763	14784	49.88
30/08/2015	4 Hrs	3784	127	266	4177	4448	830	4159	0	-754	12860	20	12880	582	396	14592	14612	49.91
Maximum		4237	160	278	4619	4448	1582	5097	0	-542	13942	26	13967	785	518	15787	15812	50
Minimum		3677	92	261	4111	3551	716	3938	0	-843	12860	20	12880	581	396	14592	14612	50
Average		3973	124	271	4367	4043	1028	4527	0	-749	13217	20	13239	619	448	15033	15056	50

Details of Supply Position (MUs)

Date	MSGENCO				Pench (MS)	Central Sector Receipt	Central Sector Share	WIND	CPP	SOLAR	TPCL Gen.	R-INFRA Gen.	TPCL Exch.	Energy Requirement		
	THM	HYDRO	GAS	Total										MSEDCL	MUMBAI	STATE
	Mus	Mus	Mus	Mus	Mus	Mus	Mus	Mus	Mus	Mus	Mus	Mus	Mus	Mus	Mus	Mus
24/08/2015	91.223	7.490	6.573	105.286	0.645	123.388	120.283	30.305	115.614	1.028	21.987	11.839	-28.160	347.461	61.988	409.449
25/08/2015	91.892	8.951	6.544	107.387	0.580	119.586	118.025	27.575	116.985	1.057	22.318	12.414	-26.250	346.337	60.982	407.319
26/08/2015	98.244	6.839	6.240	111.323	0.311	123.565	118.790	22.040	118.733	1.026	21.673	11.955	-27.765	348.921	61.392	410.313
27/08/2015	102.086	6.178	6.223	114.487	0.500	120.557	119.751	19.785	121.101	1.056	22.350	12.391	-27.253	349.729	61.994	411.723
28/08/2015	100.968	7.199	6.463	114.630	0.416	114.091	116.970	16.893	116.973	0.304	21.682	12.407	-26.558	336.333	60.647	396.980
29/08/2015	98.759	5.239	6.413	110.411	0.701	110.462	114.228	18.736	111.893	0.426	18.275	12.407	-24.973	326.955	55.655	382.610
30/08/2015	93.074	7.030	6.435	106.539	0.803	110.503	110.577	21.305	106.923	1.081	16.232	11.226	-20.991	325.360	48.446	373.806
Maximum	102.086	8.951	6.573	114.630	0.803	123.565	120.283	102.086	121.101	1.081	22.350	12.414	-20.991	349.729	61.994	411.723
Minimum	91.223	5.239	6.223	105.286	0.311	110.462	110.577	91.223	106.923	0.304	16.232	11.226	-28.160	325.360	48.446	373.806
Average	96.607	6.989	6.413	110.009	0.565	117.450	116.946	96.607	115.460	0.854	16.232	12.091	-25.993	340.157	58.729	398.886

Details of Koyna Water Consumption (in TMC)

Date	For the Day	For the Month	Balance
24/08/2015	0.089	2.689	56.080
25/08/2015	0.131	2.820	55.949
26/08/2015	0.091	2.911	55.858
27/08/2015	0.071	2.982	55.787
28/08/2015	0.083	3.065	55.704
29/08/2015	0.069	3.134	55.635
30/08/2015	0.079	3.213	55.556

State Load Despatch Center, Airoli (MSETCL)
Central Sector Share/Drawal from 24/Aug/2015 to 30/Aug/2015

Date	DAY	Central Sector Share		Total Interstate Bilateral Purchase		Total Share		Total Drawal		Overdrawal(+) / UnderDrawal(-)	
		MUs	Avg. MW	MUs	Avg. MW	MUs	Avg. MW	MUs	Avg. MW	MUs	Avg. MW
		1		2		1+2=3		4		3-4=5	
24/08/2015	MONDAY	97.213	4989	23.070	961	120.283	5012	123.388	5141	3.105	129
25/08/2015	TUESDAY	94.937	4895	23.088	962	118.025	4918	119.586	4983	1.561	65
26/08/2015	WEDNESDA	94.909	4926	23.881	995	118.790	4950	123.565	5149	4.775	199
27/08/2015	THURSDAY	97.309	4967	22.442	935	119.751	4990	120.557	5023	0.806	34
28/08/2015	FRIDAY	98.924	4856	18.046	752	116.970	4874	114.091	4754	-2.879	-120
29/08/2015	SATURDAY	93.228	4738	21.000	875	114.228	4760	110.462	4603	-3.766	-157
30/08/2015	SUNDAY	98.386	4595	12.191	508	110.577	4607	110.503	4604	-0.074	-3
Total		674.907		143.717		818.624		822.152		3.528	

GENERATING UNITS OUTAGES FOR THE WEEK FROM 24/08/2015 TO 30/08/2015							
Generator	Generating Unit	Capacity	Tripped Date	Tripped Time	Synch. Date	Synch Time	Reason
PLANNED OUTAGES							
IPP	Tata Trombay 7B	60MW	17/Jul/2015	20:00		Continued.	Gas Path Inspection
MSPGCL	Bhusawal Unit 5	500MW	29/Jul/2015	6:29		Continued.	Annual Overhaul
MSPGCL	Chandrapur Unit 4	210MW	29/Aug/2015	23:55		Continued.	Annual Overhaul
FORCED OUTAGES							
IPP	Dhariwal	300MW	28/May/2014	2:27		Continued.	No schedule
MSPGCL	Chandrapur Unit 1	210MW	28/Aug/2014	7:15		Continued.	Economic Shutdown.
MSPGCL	Bhusawal Unit 2	210MW	13/Sep/2014	12:43		Continued.	Economic shutdown
MSPGCL	Koradi Unit 6	210MW	20/Mar/2015	1:02		Continued.	Economic shutdown
MSPGCL	Parli Unit 3	210MW	14/Jun/2015	12:58		Continued.	Water Shortage
IPP	WPCL U-2	135MW	16/Jun/2015	0:00		Continued.	No Schdule
MSPGCL	Parli Unit 6	250MW	25/Jun/2015	15:03		Continued.	Water Shortage
MSPGCL	Parli Unit 4	210MW	05/Jul/2015	18:45		Continued.	Water Shortage
MSPGCL	Parli Unit 5	210MW	06/Jul/2015	14:55		Continued.	Water Shortage.
MSPGCL	Parli Unit 7	250MW	08/Jul/2015	12:08		Continued.	Water Shortage
IPP	Tata Trombay 6	500MW	15/Jul/2015	17:08		Continued.	Economic shutdown
IPP	WPCL U-4	135MW	01/Aug/2015	21:57		Continued.	Vibration problem in ID Fan
IPP	Adani U-2	660MW	04/Aug/2015	0:03		Continued.	ID Fan Problem
MSPGCL	Khaparkheda Unit 4	210MW	16/Aug/2015	13:10	25/Aug/2015	8:43	Turbine bearing Vabration high
IPP	RPL(AMT)U2	270MW	22/Aug/2015	15:52	24/Aug/2015	3:19	PSM Vibration High
MSPGCL	Khaparkheda Unit 5	500MW	23/Aug/2015	7:51	26/Aug/2015	4:27	Boiler Tube Leakage
MSPGCL	Khaparkheda Unit 4	210MW	25/Aug/2015	12:59	25/Aug/2015	15:09	Turbine Tripped on Reverse power Contro Valve.
IPP	WPCL U-1	135MW	25/Aug/2015	19:18		Continued.	Maintenance work
MSPGCL	Koradi Unit 5	200MW	26/Aug/2015	16:50	26/Aug/2015	22:10	Flame Failure
MSPGCL	Bhusawal Unit 3	210MW	26/Aug/2015	9:51	28/Aug/2015	12:18	Boiler Tube Leakage

LINE OUTAGES FOR THE WEEK FROM 17/08/2015 TO 23/08/2015

Voltage	Name of Line	Tripping Date	Tripping Time	Synch Date	Synch Time	Reason
400 KV	Akola II - Taptitanda ckt-II	20/Jul/2015	17.29		Continued.	Over Voltage
400 KV	Kolhapur Mapusa II	22/Aug/2015	16.43	24/Aug/2015	07.46	Over Voltage(Line crossing work of 765KV Kurgi-Kolhapur line from 06.26Hrs Dt.23-08-2015)
400 KV	karad -kolhapur-II	23/Aug/2015	16.09	24/Aug/2015	06.40	
400 KV	Karad - Jaigad - II	23/Aug/2015	16.54	24/Aug/2015	09.08	Over Voltage
400 KV	Babhaleshwar - Padghe-I	23/Aug/2015	17.41	24/Aug/2015	00.54	Distance Protection
400 KV	Bhusawal-Aurangabad	23/Aug/2015	18.13	24/Aug/2015	06.41	Over Voltage
400 KV	Kolhapur Solapur (PG) II	23/Aug/2015	18.16	24/Aug/2015	06.32	Over Voltage
400 KV	Lonikand I - Koyna stage-IV	23/Aug/2015	18.16	24/Aug/2015	09.00	Over Voltage
400 KV	400/220 KV 500 MVA ICT-II @Warora	24/Aug/2015	08.43	24/Aug/2015	22.02	HV Side CRM Work ICT on NO Load.
400 KV	karad -kolhapur-I	24/Aug/2015	16.32	25/Aug/2015	07.02	Over Voltage
400 KV	Karad-Jaigad - I	24/Aug/2015	16.34	25/Aug/2015	06.54	Over Voltage
400 KV	Kolhapur Mapusa I	24/Aug/2015	17.16	26/Aug/2015	06.58	Over Voltage
400 KV	Bhusawal-Aurangabad	24/Aug/2015	18.25	25/Aug/2015	06.32	Over Voltage
400 KV	Lonikand I - Koyna stage-IV	25/Aug/2015	02.12	25/Aug/2015	09.30	Over Voltage
400 KV	Wardha (Pg) Warora I	25/Aug/2015	09.05	25/Aug/2015	18.11	Line Singature & Tree cutting Work.
400 KV	400/220kv 315MVA ICT-I@Parly	25/Aug/2015	11.52	25/Aug/2015	16.17	Attending Hot Spot
400 KV	Kolhapur Mapusa II	25/Aug/2015	16.12	26/Aug/2015	06.47	Over Voltage
400 KV	karad -kolhapur-I	25/Aug/2015	17.05	26/Aug/2015	06.50	Over Voltage
400 KV	Karad - Jaigad - II	25/Aug/2015	17.58	26/Aug/2015	06.35	Over Voltage
400 KV	Lonikand I - Koyna stage-IV	25/Aug/2015	21.38	26/Aug/2015	09.00	Over Voltage
400 KV	karad -kolhapur-I	26/Aug/2015	06.52	27/Aug/2015	07.08	Distance Protection (RFC at 17:00 Hrs)
400 KV	Nagothane - Dabhol-II	26/Aug/2015	10.23	27/Aug/2015	10.29	To attend Hot Spot
400 KV	Karad-Jaigad - I	26/Aug/2015	10.29	27/Aug/2015	11.49	R.M.Work & Testing Work (RFC at 19:30 Hrs)
400 KV	Babhaleshwar-Taptitanda ckt-II	26/Aug/2015	11.36	26/Aug/2015	21.48	Opportunity Outage for Rectification Work of Line .(RFC at 21:48 Hrs)
400 KV	Girwali-Solapur (Lamboti)	26/Aug/2015	12.18	26/Aug/2015	19.46	Crossing of 765KV D/C Solapur-Aurangabad line.
400 KV	Main Bus-I @ Koradi-II	26/Aug/2015	15.02	26/Aug/2015	21.05	Dropper Connection 400kv DIA 7 with Main Bus-1.
400 KV	Padghe - Nagothane - I	26/Aug/2015	17.03	26/Aug/2015	20.57	Insulator String Replacement.
400 KV	Babhaleshwar-Taptitanda ckt-I	26/Aug/2015	17.08	27/Aug/2015	01.31	To Control Over loading of 400kv padghe -BBLSR CKT-2.
400 KV	Babhaleshwar - Padghe-I	26/Aug/2015	17.43	27/Aug/2015	01.03	Attending Hot Spot
400 KV	Khadka-Aurangabad (Waluj)	26/Aug/2015	18.08	27/Aug/2015	06.18	Over Voltage
400 KV	Karad-Jaigad - I	26/Aug/2015	19.30	27/Aug/2015	11.49	Over Voltage
400 KV	Lamboti - Solapur (PG)	26/Aug/2015	21.30	26/Aug/2015	21.51	Distance Protection
400 KV	400/220kv 315MVA ICT-III @ Kharghar	27/Aug/2015	05.55	27/Aug/2015	09.52	oltc oil sampling work
400 KV	Khadka- Deepnagar Ckt 1	27/Aug/2015	09.07	27/Aug/2015	15.46	Tighting nut bolt of line
400 KV	Akola Wardha I	27/Aug/2015	09.31	27/Aug/2015	18.12	R.M.Work
400 KV	400/220/33kv 315mva Ict3 @Lonikand	27/Aug/2015	10.36	27/Aug/2015	19.30	Half yearly maintenance work
400 KV	Babhaleshwar-Taptitanda ckt-II	27/Aug/2015	11.20		Continued.	opportunity outage for line rectification in work (RFC 16.50)
400 KV	Girwali - Lonikand 1	27/Aug/2015	12.58	27/Aug/2015	20.11	765kv A'bad-Solapur PG line crossing work
400 KV	Girwali- Lonikand 2	27/Aug/2015	13.19	27/Aug/2015	20.15	765kv A'bad-Solapur PG line crossing work
400 KV	karad -kolhapur-II	27/Aug/2015	16.11	28/Aug/2015	14.25	Over Voltage
400 KV	Karad - Jaigad - II	27/Aug/2015	16.34	28/Aug/2015	07.27	Over Voltage
400 KV	Kolhapur Mapusa I	27/Aug/2015	16.49	28/Aug/2015	06.58	Over Voltage
400 KV	Khadka-Aurangabad (Waluj)	27/Aug/2015	22.19	28/Aug/2015	06.52	Over Voltage
400 KV	Akola Wardha li	28/Aug/2015	09.05	28/Aug/2015	19.06	Routine Maintenance Work
400 KV	Khadka- Deepnagar Ckt 2	28/Aug/2015	09.15	28/Aug/2015	15.53	Various Line Hardware Work.
400 KV	400/220kv 315 Mva ICT I @Karad	28/Aug/2015	16.11	28/Aug/2015	16.53	Bus-I Tripped.
400 KV	karad -kolhapur-I	28/Aug/2015	16.11		Continued.	R Ph Pole Breaker Burst.
400 KV	N.Koyna-Karad -Ckt II	28/Aug/2015	16.11	29/Aug/2015	07.08	Bus-I Tripped RFC-1653 Hrs.
400 KV	Karad - Jaigad - II	28/Aug/2015	16.11	29/Aug/2015	06.32	Bus-I Tripped RFC-1653 Hrs.
400 KV	karad -kolhapur-II	28/Aug/2015	16.12	30/Aug/2015	07.45	Over Voltage

Voltage	Name of Line	Tripping Date	Tripping Time	Synch Date	Synch Time	Reason
400 KV	Koradi-Bhusawal	28/Aug/2015	16.24	28/Aug/2015	19.02	Taking Line Reactor in Service @ Koradi End.
400 KV	Padghe - Kharghar	28/Aug/2015	16.37	28/Aug/2015	23.12	Wavetrap String Broken.
400 KV	Bhusawal-Aurangabad	28/Aug/2015	17.38	29/Aug/2015	07.30	Over Voltage
400 KV	Kalwa - Kharghar	28/Aug/2015	19.19	28/Aug/2015	20.53	Taken on TBC For Attending Hot Spot.
400 KV	Lonikand I - Koyna stage-IV	28/Aug/2015	22.10	29/Aug/2015	09.33	Over Voltage
400 KV	Girwali-Solapur (Lamboti)	29/Aug/2015	06.22	29/Aug/2015	07.03	Distance Protection
400 KV	Akola-Nandgaonpeth (RPL)	29/Aug/2015	08.48	30/Aug/2015	00.05	Testing Work
400 KV	400/220kV 315MVA ICT-III @ Kharghar	29/Aug/2015	14.14	29/Aug/2015	15.02	To attend Hot Spot
400 KV	Bhusawal-Aurangabad	29/Aug/2015	17.04	30/Aug/2015	06.41	Over Voltage
400 KV	Lonikand I - Koyna stage-IV	29/Aug/2015	17.09	30/Aug/2015	09.24	Over Voltage
400 KV	Kolhapur Mapusa I	29/Aug/2015	17.10	30/Aug/2015	07.00	Over Voltage
400 KV	Dhule Sar'Sarovar I	29/Aug/2015	17.31		Continued.	Over Voltage
400 KV	N.Koyna-Karad - Ckt II	29/Aug/2015	18.23	30/Aug/2015	09.02	Over Voltage
400 KV	Kolhapur Mapusa II	30/Aug/2015	08.54		Continued.	Over Voltage
400 KV	Kolhapur Mapusa I	30/Aug/2015	09.35	30/Aug/2015	15.46	765KV KUDGI-Kolhapur line crossing work
400 KV	Karad-Jaigad - I	30/Aug/2015	16.03		Continued.	Over Voltage
400 KV	Bhusawal-Aurangabad	30/Aug/2015	17.14		Continued.	Over Voltage
400 KV	Lonikand I - Koyna stage-IV	30/Aug/2015	17.14		Continued.	Over Voltage
220 KV	220/100 Kv 200 MVA ICT III @Borivali	21/Sep/2014	09.16		Continued.	Internal Fault
220 KV	Chandrapur GCR - Warora - I	05/Apr/2015	09.13		Continued.	Bunching of conductor Loc no 86 Disconnecting of jumer at Loc no 86 & 107 and deenergising the line bet.86 to 107.
220 KV	Chandrapur GCR - Wani	05/Apr/2015	09.15		Continued.	Bunching of conductor Loc no 86 Disconnecting of jumer at Loc no 86 & 107 and deenergising the line bet.86 to 107.
220 KV	REL Borivali TPC Borivali line	10/Jul/2015	16.22		Continued.	Distance Protection
220 KV	Padghe - Vasai	15/Aug/2015	08.35		Continued.	Removal of jumper & bunching work at Loc No. 51/1 & 35 (charged up to Loc No. 51/1 from Padghe end only)
220 KV	Kalwa - Borivali	16/Aug/2015	08.00		Continued.	Erection of Loc.No.12 and shifting of conductor on NER M/C Tower
220 KV	Kalwa - Mulund 1	22/Aug/2015	07.35		Continued.	Mumbai Strengthening work
220 KV	New Koyna - Loteparshuram	24/Aug/2015	09.08	24/Aug/2015	16.58	Hot Spot Attending on Y Ph Wave Trap.
220 KV	Nanded - Parli Ext. Ckt I	24/Aug/2015	10.51	24/Aug/2015	16.18	Jumper Cone Single Bolt to Adding 3 No.Nut Bolts.
220 KV	Theur-Jejuri	24/Aug/2015	12.16	24/Aug/2015	16.54	CT Tan Delta Measurment Work.
220 KV	220/33kV 100 MVATransformer 2 @Versova R/S	25/Aug/2015	02.00	25/Aug/2015	04.29	To Work on Spout.
220 KV	Trombay - Mulund	25/Aug/2015	06.02	25/Aug/2015	09.06	TO Attend Hot Spot on Line.
220 KV	Wadkhal - NDIL-III	25/Aug/2015	10.50	25/Aug/2015	18.33	For safety Purpose at NDIL end.
220 KV	220/132kv 100mva Vijai Ptr No 1 @Baramati	25/Aug/2015	11.15	25/Aug/2015	14.55	Tan Delta Measurment of CTs
220 KV	Karad -Mudshingi Ckt- IV	25/Aug/2015	14.08	25/Aug/2015	17.56	Attending Sparking on Isolater.
220 KV	220/132kV 100MVA ICT-2 @ Baramati	25/Aug/2015	15.30	25/Aug/2015	18.32	Tan Delta Measurment of CTs
220 KV	Mudshingi - Chikodi	26/Aug/2015	07.20	26/Aug/2015	14.16	Distance Protection
220 KV	Talandge-Mudshingi Ckt-I	26/Aug/2015	07.28	26/Aug/2015	08.28	Distance Protection
220 KV	Khaparkheda-Kaulewada-I	26/Aug/2015	10.23	26/Aug/2015	13.35	Line Singnature Work.
220 KV	Butibori - Purti	26/Aug/2015	10.39	26/Aug/2015	19.04	Replacement of Auxillary Drum of Circuit Breaker.
220 KV	Mahad - Posco	26/Aug/2015	10.50	26/Aug/2015	14.04	Distance Protection
220 KV	Karkamb - Jeur	26/Aug/2015	10.54	26/Aug/2015	16.52	Replacement of Coupling Capacitor.
220 KV	Beed-Patoda Ckt 2	26/Aug/2015	13.05	26/Aug/2015	16.23	Quarterly Maintainance Work
220 KV	Khaparkheda-Kaulewada-II	26/Aug/2015	14.19	26/Aug/2015	15.52	Line Singnature Work.
220 KV	Chalisgaon -Babhaleshwar	26/Aug/2015	15.26	26/Aug/2015	19.25	Testing Work
220 KV	New Koyna - Niwali	26/Aug/2015	17.08	26/Aug/2015	19.06	Attending Hot Spot
220 KV	220/132 Kv 200 Mva Vijay lct 2 @Chalisgaon	26/Aug/2015	18.33	26/Aug/2015	20.20	Routine Maintenance Work
220 KV	220/132 Kv 100 Mva Cgl lct 1 @Dondaicha	26/Aug/2015	20.13	26/Aug/2015	20.43	Back up Protection Optd.
220 KV	Padegaon-Sawangi	26/Aug/2015	21.28	26/Aug/2015	21.47	Distance Protection
220 KV	Sonkhar - Trombay	27/Aug/2015	00.15	27/Aug/2015	01.32	Attending Hot Spot
220 KV	100 MVA T/F I @ Oglewadi	27/Aug/2015	10.15	27/Aug/2015	16.25	Testing Work

Voltage	Name of Line	Tripping Date	Tripping Time	Synch Date	Synch Time	Reason
220 KV	Centuri Enka- Bhosari	27/Aug/2015	10.30	27/Aug/2015	14.50	Installtion of summesion type meter
220 KV	Kalyani - Baramati Agro	27/Aug/2015	11.00	27/Aug/2015	19.00	Relay work
220 KV	Tillari Amona	27/Aug/2015	11.35	27/Aug/2015	14.00	Annual Maintenance Work
220 KV	Bombay Dyeing - Sahara	27/Aug/2015	12.19	27/Aug/2015	13.56	Attending Hot Spot
220 KV	Mahalakshmi Amona	27/Aug/2015	13.13	27/Aug/2015	13.57	Annual Maintenance Work
220 KV	512 Khadki- Century Enka	27/Aug/2015	15.05	27/Aug/2015	18.00	Instalation of summation type meter
220 KV	Talandage - Chikodi	27/Aug/2015	15.08	27/Aug/2015	19.25	Jumper Replacement work
220 KV	Parvati - Hybrid Pass	28/Aug/2015	08.48	28/Aug/2015	16.23	To Control Chinchwad-Urse Loading.
220 KV	Jambhul - Anandnagar	28/Aug/2015	09.45	28/Aug/2015	12.50	Attending Hot Spot
220 KV	Padghe - Jambhul 1	28/Aug/2015	10.28	28/Aug/2015	15.28	To Attend Hot Spot @ Isolator & Breaker.
220 KV	Talandge-Mudshingi Ckt-I	28/Aug/2015	10.57	28/Aug/2015	14.52	To Attend Hot Spot @ Wave Trap.
220 KV	Kamba - Kolshet	28/Aug/2015	12.04	28/Aug/2015	16.21	CT Tan Delta Measurment.
220 KV	Uran - Kharghar I	28/Aug/2015	13.12	28/Aug/2015	14.42	Attending Hot Spot
220 KV	220/132 Kv 200 Mva Bbl lct 1 @Beed	28/Aug/2015	14.21	28/Aug/2015	17.35	Testing of CT Knee Point Voltage,Bus Bar Analysis & Other Testing Work.
220 KV	Jejuri-Phursungi 1	28/Aug/2015	15.28	28/Aug/2015	20.16	Distance Protection R Ph IB.
220 KV	Kandalgaon - Sona Alloys	28/Aug/2015	16.28	28/Aug/2015	20.35	Scada Work.
220 KV	Talandge(400kv)- Ichalkaranji 2	29/Aug/2015	04.53	29/Aug/2015	11.14	Problem at Talandage End.
220 KV	Vsnl-512 Khadki	29/Aug/2015	08.10	29/Aug/2015	13.52	To attend Hot Spot
220 KV	Talandage - Chikodi	29/Aug/2015	09.57	29/Aug/2015	14.00	Maintenance work and Hot Spot
220 KV	Mudshingi Chikodi	29/Aug/2015	09.58	29/Aug/2015	14.00	Maintenance work and Hot Spot
220 KV	Flagship-Chinchwad	29/Aug/2015	11.07	29/Aug/2015	13.50	Line Maintenance work
220 KV	220/132 Kv 200 Mva Bbl lct 2 @Beed	29/Aug/2015	11.14	29/Aug/2015	14.21	Testing Work
220 KV	Kandalgaon - Sona Alloys	29/Aug/2015	12.40	29/Aug/2015	17.34	Line Maintenance work
220 KV	Lonikand-VSNL	29/Aug/2015	15.14	29/Aug/2015	19.30	To attend Hot Spot
220 KV	Borivali - Tarapur	30/Aug/2015	08.53	30/Aug/2015	14.04	Jumper replacement work
220 KV	Paras Ext. - Balapur	30/Aug/2015	14.56	30/Aug/2015	17.56	Distance Protection
220 KV	Yeotmal- Pusad	30/Aug/2015	15.15	30/Aug/2015	15.45	Distance Protection
132 KV	Chikhali-Deulgaon Mahi	24/Aug/2015	19.25	24/Aug/2015	19.36	Distance Protection
132 KV	Mankapur-Uppalwadi	26/Aug/2015	06.32	26/Aug/2015	18.33	Outage on 132kv Ambazari-Hingna CKT-1.
132 KV	Ambazari-Hingna 1	26/Aug/2015	06.34	26/Aug/2015	18.31	Replacement of ACSR Conductor with high Ampacity conductor.
132 KV	Amravati-Chandur-Bazar	26/Aug/2015	09.36	26/Aug/2015	19.07	Stringing work of Lilo of 220kv Amaravati-Badnera line for 220kv Nandgaonpeth.
132 KV	Amravati-Achalpur	26/Aug/2015	09.37	26/Aug/2015	19.05	Stringing work of Lilo of 220kv Amaravati-Badnera line for 220kv Nandgaonpeth.
132 KV	Deepnagar- Yawal	26/Aug/2015	09.51	26/Aug/2015	10.19	Load Trimming optd.
132 KV	Deepnagar- Nimbhora	26/Aug/2015	09.51	26/Aug/2015	10.25	Load Trimming optd.
132 KV	Georai - Mahakala	26/Aug/2015	10.15	26/Aug/2015	13.55	Quarterly Maintainance Work
132 KV	Telgaon - Majalgaon	26/Aug/2015	10.15	26/Aug/2015	15.45	Quarterly Maintainance Work
132 KV	Deepnagar (Gcr) - Pachora	26/Aug/2015	16.14	26/Aug/2015	17.04	Relay Testing Work
132 KV	Dondaicha(220kv) - Dondaicha (132k	26/Aug/2015	20.13	26/Aug/2015	22.30	Back up Protection optd.
132 KV	Dondaicha- Shahada	26/Aug/2015	20.38	26/Aug/2015	22.35	To control on Shahada Ckt loading.
132 KV	Theur-Sanaswadi	27/Aug/2015	22.56	28/Aug/2015	00.45	Annual Maintenance Work
132 KV	Theur-Kharadi	27/Aug/2015	23.09	28/Aug/2015	06.02	Annual Maintenance Work
132 KV	Raimoha - Pathardi	28/Aug/2015	05.06	28/Aug/2015	13.00	Distance Protection Operated Zone-I B Ph,Bph String Flash Over.
132 KV	Dondaicha(220kv) - Dondaicha (132k	28/Aug/2015	05.25	28/Aug/2015	05.50	Ckt Tripped on 33KV Discom Feeder.
132 KV	Naldurg - Ujani	28/Aug/2015	09.15	28/Aug/2015	13.54	For Crossing Work of 765KV Aurangabad-Solapur Line.
132 KV	Solapur II(Bale)-Naldurg	28/Aug/2015	09.20	28/Aug/2015	13.53	For Crossing Work of 765KV Aurangabad-Solapur Line.
132 KV	Partur-Mantha	29/Aug/2015	03.01	29/Aug/2015	03.15	Distance Protection
132 KV	Paras-Patur	30/Aug/2015	20.38	30/Aug/2015	20.50	Distance Protection