

State Load Despatch Center,Airoli (MSETCL)
Power System Position from 20/Sep/2021 to 26/Sep/2021

Supply Position During Morning Peak (MW)

Date	Time	MSGENCO				Central Sector Receipt	Wind	CPP	SOLAR	TPCL Exch.	MSEDCL Catered Demand	Load Shedding (LS)	MSEDCL Demand (Incl. LS)	TPCL Gen.	R-INFRA Gen.	State Demand Met	State Demand (Incl. LS)	Freq.
		THM	HYDRO	GAS	Total													
		MW	MW	MW	MW													
20-09-2021	12 Hrs	3998	2106	228	6332	8676	339	3909	818	-1534	18540	0	18540	931	497	21502	21502	50.02
21-09-2021	10 Hrs	4395	1277	237	5909	9231	413	3944	408	-1268	18637	0	18637	966	495	21366	21366	50.04
22-09-2021	10 Hrs	3791	991	239	5021	9533	396	3748	472	-1180	17990	0	17990	1055	495	20720	20720	50.02
23-09-2021	11 Hrs	4192	1209	230	5631	8852	289	3619	688	-1426	17653	0	17653	981	496	20556	20556	49.98
24-09-2021	10 Hrs	3925	963	238	5126	8796	233	3755	664	-1237	17337	0	17337	995	500	20069	20069	50.00
25-09-2021	10 Hrs	4499	701	248	5448	8562	309	3678	516	-1075	17438	0	17438	968	500	19981	19981	50.05
26-09-2021	11 Hrs	4589	369	237	5195	8096	427	3783	638	-1062	17077	0	17077	781	490	19410	19410	50.02
Maximum		4589	2106	248	6332	9533	427	3944	818	-1062	18637	0	18637	1055	500	21502	21502	50.05
Minimum		3791	369	228	5021	8096	233	3619	408	-1534	17077	0	17077	781	490	19410	19410	49.98
Average		4198	1088	237	5523	8821	344	3777	601	-1255	17810	0	17810	954	496	20515	20515	50.02

Supply Position During Day Peak (MW)

Date	Time	MSGENCO				Central Sector Receipt	Wind	CPP	SOLAR	TPCL Exch.	MSEDCL Catered Demand	Load Shedding (LS)	MSEDCL Demand (Incl. LS)	TPCL Gen.	R-INFRA Gen.	State Demand Met	State Demand (Incl. LS)	Freq.
		THM	HYDRO	GAS	Total													
		MW	MW	MW	MW													
20-09-2021	13 Hrs	4074	1840	226	6140	8065	379	3917	877	-1379	17999	0	17999	1064	496	20938	20938	49.96
21-09-2021	13 Hrs	4194	676	229	5099	8179	783	4010	746	-1409	17408	0	17408	1007	490	20314	20314	50.03
22-09-2021	13 Hrs	3712	481	197	4390	8434	734	3527	895	-1399	16581	0	16581	975	494	19449	19449	49.97
23-09-2021	13 Hrs	4108	799	229	5136	8240	340	3596	655	-1463	16504	0	16504	946	495	19408	19408	50.07
24-09-2021	13 Hrs	3932	699	226	4857	7875	133	3808	765	-1565	15873	0	15873	846	500	18784	18784	49.98
25-09-2021	13 Hrs	4576	445	236	5257	8127	281	3529	653	-1314	16533	0	16533	912	502	19261	19261	50.03
26-09-2021	13 Hrs	4531	395	216	5142	7833	368	3741	714	-1473	16325	0	16325	527	321	18646	18646	50.00
Maximum		4576	1840	236	6140	8434	783	4010	895	-1314	17999	0	17999	1064	502	20938	20938	50.07
Minimum		3712	395	197	4390	7833	133	3527	653	-1565	15873	0	15873	527	321	18646	18646	49.96
Average		4161	762	223	5146	8108	431	3733	758	-1429	16746	0	16746	897	471	19543	19543	50.01

Supply Position During Evening Peak (MW)

Date	Time	MSGENCO				Central Sector Receipt	Wind	CPP	SOLAR	TPCL Exch.	MSEDCL Catered Demand	Load Shedding (LS)	MSEDCL Demand (Incl. LS)	TPCL Gen.	R-INFRA Gen.	State Demand Met	State Demand (Incl. LS)	Freq.
		THM	HYDRO	GAS	Total													
		MW	MW	MW	MW													
20-09-2021	19 Hrs	4150	1891	235	6276	7285	1007	4006	0	-994	17580	0	17580	1206	497	20277	20277	49.91
21-09-2021	20 Hrs	4251	2166	230	6647	6452	1066	3816	0	-914	17067	0	17067	1176	497	19654	19654	50.07
22-09-2021	19 Hrs	3866	2304	220	6390	7111	752	3761	4	-1031	16987	0	16987	1104	498	19620	19620	49.96
23-09-2021	20 Hrs	4335	2429	228	6992	6512	842	3814	0	-984	17176	0	17176	1187	497	19844	19844	50.04
24-09-2021	20 Hrs	4574	2182	310	7066	6623	399	4008	0	-859	17237	0	17237	1337	501	19934	19934	49.87
25-09-2021	19 Hrs	4894	1448	302	6644	6990	807	3936	5	-912	17470	0	17470	1178	501	20061	20061	50.02
26-09-2021	20 Hrs	5002	1311	305	6618	6322	435	3866	0	-561	16680	0	16680	1236	497	18974	18974	50.03
Maximum		5002	2429	310	7066	7285	1066	4008	5	-561	17580	0	17580	1337	501	20277	20277	50.07
Minimum		3866	1311	220	6276	6322	399	3761	0	-1031	16680	0	16680	1104	497	18974	18974	49.87
Average		4439	1962	261	6662	6756	758	3887	1	-894	17171	0	17171	1203	498	19766	19766	49.99

Supply Position During Night Off Peak (MW)

Date	Time	MSGENCO				Central Sector Receipt	Wind	CPP	SOLAR	TPCL Exch.	MSEDCL Catered Demand	Load Sheddin g(LS)	MSEDCL Demand (Incl. LS)	TPCL Gen.	R-INFRA Gen.	State Demand Met	State Demand (Incl. LS)	Freq.
		THM	HYDRO	GAS	Total													
		MW	MW	MW	MW													
20-09-2021	3 Hrs	4175	256	251	4682	6058	659	3919	0	-517	14801	0	14801	838	497	16653	16653	50.03
21-09-2021	3 Hrs	4359	669	239	5267	5579	448	4057	0	-656	14695	0	14695	769	489	16609	16609	50.01
22-09-2021	2 Hrs	3905	315	240	4460	5900	859	3672	0	-577	14314	0	14314	829	495	16215	16215	50.02
23-09-2021	3 Hrs	4144	567	230	4941	6174	321	3396	0	-519	14313	0	14313	812	496	16140	16140	50.00
24-09-2021	3 Hrs	3681	984	230	4895	6194	292	3521	0	-564	14338	0	14338	806	502	16210	16210	49.99
25-09-2021	2 Hrs	4212	1104	240	5556	5083	573	3863	0	-505	14570	0	14570	1012	500	16587	16587	50.03
26-09-2021	3 Hrs	4657	538	210	5405	5351	501	3802	0	-594	14465	0	14465	851	494	16404	16404	50.02
Maximum		4657	1104	251	5556	6194	859	4057	0	-505	14801	0	14801	1012	502	16653	16653	50.03
Minimum		3681	256	210	4460	5083	292	3396	0	-656	14313	0	14313	769	489	16140	16140	49.99
Average		4162	633	234	5029	5763	522	3747	0	-562	14499	0	14499	845	496	16403	16403	50.01

Details of Supply Position (MUs)

Date	MSGENCO				Pench (MS)	Central Sector Receipt	Central Sector Share	WIND	CPP	SOLAR	TPCL Gen.	R-INFRA Gen.	TPCL Exch.	Energy Requirement		
	THM	HYDRO	GAS	Total										MSEDCL	MUMBAI	STATE
	Mus	Mus	Mus	Mus										Mus	Mus	Mus
20-09-2021	100.327	31.922	5.592	137.841	0.075	173.328	174.717	16.434	94.411	6.401	23.376	11.888	-23.032	405.383	58.296	463.679
21-09-2021	102.073	22.615	5.543	130.231	0.267	170.864	172.563	18.949	92.869	5.060	22.454	11.884	-23.284	394.689	57.622	452.311
22-09-2021	92.243	22.008	5.084	119.335	0.385	178.281	180.042	17.913	87.937	5.656	22.256	11.590	-23.190	385.932	57.036	442.968
23-09-2021	98.758	27.589	5.611	131.958	0.318	170.504	171.174	13.365	86.142	5.265	23.238	11.931	-22.618	384.616	57.787	442.403
24-09-2021	95.885	30.360	5.782	132.027	0.318	167.418	169.394	8.250	89.981	6.053	24.191	12.011	-22.174	381.555	58.376	439.931
25-09-2021	109.009	24.710	5.678	139.397	0.025	162.161	163.719	12.636	89.981	5.170	23.601	12.002	-20.775	388.570	56.377	444.947
26-09-2021	112.620	16.511	5.378	134.509	0.081	156.391	159.579	11.344	90.606	4.869	20.289	10.983	-19.769	377.950	51.041	428.991
Maximum	112.620	31.922	5.782	139.397	0.385	178.281	180.042	112.620	94.411	6.401	24.191	12.011	-19.769	405.383	58.376	463.679
Minimum	92.243	16.511	5.084	119.335	0.025	156.391	159.579	92.243	86.142	4.869	20.289	10.983	-23.284	377.950	51.041	428.991
Average	101.559	25.102	5.524	132.185	0.210	168.421	170.170	101.559	90.275	5.496	22.772	11.756	-22.120	388.385	56.648	445.033

Details of Koyna Water Consumption (in TMC)			
Date	For the Day	For the Month	Balance
20-09-2021	0.545	3.603	51.809
21-09-2021	0.334	3.936	51.476
22-09-2021	0.295	4.232	51.180
23-09-2021	0.429	4.661	50.751
24-09-2021	0.474	5.135	50.277
25-09-2021	0.350	5.485	49.927
26-09-2021	0.184	5.669	49.743

**State Load Despatch Center,Airoli (MSETCL)
Central Sector Share/Drawal from 20/Sep/2021 to 26/Sep/2021**

Date	DAY	Central Sector Share		Total Interstate		Total Share		Total Drawal		Overdrawal(+)/	
		MUs	Avg. MW	MUs	Avg. MW	MUs	Avg. MW	MUs	Avg. MW	MUs	Avg. MW
		1		2		1+2=3		4		3-4=5	
20-09-2021	MONDAY	111.531	7217	63.186	2633	174.717	7280	173.328	7222	-1.389	-58
21-09-2021	TUESDAY	109.646	7127	62.917	2622	172.563	7190	170.864	7119	-1.699	-71
22-09-2021	WEDNESDAY	106.074	7428	73.968	3082	180.042	7502	178.281	7428	-1.761	-73
23-09-2021	THURSDAY	102.895	7064	68.279	2845	171.174	7132	170.504	7104	-0.670	-28
24-09-2021	FRIDAY	101.370	6990	68.024	2834	169.394	7058	167.418	6976	-1.976	-82
25-09-2021	SATURDAY	106.443	6764	57.276	2386	163.719	6822	162.161	6757	-1.558	-65
26-09-2021	SUNDAY	104.804	6594	54.775	2282	159.579	6649	156.391	6516	-3.188	-133
Total		742.763		448.425		1191.188		1178.947		-12.241	

Generator Unit Outages/Trippings from 20.09.2021 to 26.09.2021

Name of Unit	Date Trip	Time Trip	Date Sync	Time Sync	Reason	Outage Type
RPL(AMT) U-4	02-09-2021	0	24-09-2021	1.44	Annual Overhaul	PLANNED
Chandrapur Unit 3	04-09-2021	23.58		Continued.	Annual Overhaul	PLANNED
Koyna STG-IV Unit-4	24-09-2021	17.3	24-09-2021	21	Rotor earth fault.	FORCED
RPL(AMT) U-3	22-09-2021	3.54		Continued.	Coal Shortage	FORCED
IEPL Unit 1	28-08-2018	21.26		Continued.	No PPA	FORCED
Koradi Unit 9	15-09-2021	5.19	26-09-2021	19.12	Air pre-heater work.	FORCED
PGPL U1	07-02-2017	17.3		Continued.	No Schedule (NO PPA)	FORCED
PGPL U2	07-02-2017	17.3		Continued.	No Schedule.(NO PPA)	FORCED
RPL(AMT) U-5	23-09-2021	0.44		Continued.	Bottom Ash Problem	FORCED
Khaparkheda Unit 1	11-09-2021	19.37	24-09-2021	11.28	Coal Shortage.	FORCED
Khaparkheda Unit 2	12-09-2021	21.59	24-09-2021	10.33	Coal Shortage	FORCED
Chandrapur Unit 4	15-09-2021	23.54		Continued.	Poor coal receipt	FORCED
Chandrapur Unit 5	20-09-2021	10.25	20-09-2021	20.37	Furnace Pressure High	FORCED
Koradi Unit 6	25-09-2021	23.15	26-09-2021	2.06	Flame Failure	FORCED
Koradi Unit 7	27-04-2021	20.03		Continued.	Retired (04/08/2021 At 00.00)	FORCED
Bhusawal Unit 3	18-09-2021	3.3		Continued.	Coal Shortage	FORCED
Bhusawal Unit 5	18-09-2021	21	22-09-2021	19.16	Coal Shortage	FORCED
Nasik Unit 3	30-08-2021	22.51		Continued.	Against case 4.which was outage on Loss of Fuel(From 19.44Hrs DT.26-08-2021	FORCED
Nasik Unit 5	19-09-2021	20.5		Continued.	Coal Shortage.	FORCED
Parli Unit 6	26-08-2021	21.06		Continued.	Coal Shortage (Converted to AOH 00.00Hrs from Dt.01/09/2021)	FORCED
Paras Unit 3	21-09-2021	21.3	25-09-2021	3.45	Turbine bearing Vabration high	FORCED
Paras Unit 3	06-09-2021	9.2	21-09-2021	6.07	Turbine bearing Vabration high	FORCED
Paras Unit 4	26-09-2021	7.47		Continued.	Coal Shortage	FORCED
Trombay 7A	22-09-2021	14.04	22-09-2021	17.42	Gas shortage	FORCED
Trombay 7B	22-09-2021	13.54	22-09-2021	20.58	Gas shortage	FORCED
JSW (J) U1	02-09-2021	8.41		Continued.	Turbine vibrations high.	FORCED
JSW (J) U3	07-09-2021	10.2		Continued.	Non availability of load scheduling.	FORCED
SWPGPL U-1	16-02-2016	17.09		Continued.	No PPA.	FORCED
SWPGPL U-4	05-08-2021	3.04		Continued.	Turbine Vibration High.	FORCED
Adani U-5	19-09-2021	3.47		Continued.	Abnormal Sound in Turbine governing system.	FORCED
VIPL U-1	29-12-2018	0.3		Continued.	Coal Shortage. (NO PPA From 20.05.2019)	FORCED
VIPL U-2	17-01-2019	0.15		Continued.	Coal shortage.(NO PPA From 20.05.2019)	FORCED
Uran Unit 5	26-09-2021	20.23		Continued.	Gas shortage.	FORCED
Uran Unit 5	25-09-2021	20.04	26-09-2021	18.17	Gas shortage	FORCED
Uran Unit 5	17-09-2021	12.09	25-09-2021	17.53	Tripped On Under exciter Protection.	FORCED
Uran Unit 6	22-09-2021	12.58	22-09-2021	17.28	Gas shortage	FORCED
Uran Unit 7	25-05-2020	12.51		Continued.	Turbine Blade Failure	FORCED
Uran Unit A0	10-09-2021	1.54		Continued.	Turbine bearing Vabration high	FORCED

Transmission Line Outages/Trippings from 20.09.2021 to 26.09.2021

Name of Line	Date Trip	Time Trip	Date Sync	Time Sync	Reason	Outage Type	Voltage
Tata Borivli MSETCL Borivli 2	23-09-2021	9.55	23-09-2021	17.44	For 3rd party work in vicinity.	PO	110 KV
Mudshingi Chikodi	24-09-2019	17.12		Continued.	No Schedule(Charge from Mudshingi end only)	PO	220 KV
Talandage - Chikodi	01-10-2019	17.1		Continued.	No Schedule(Close at Chikodi end only)	PO	220 KV
220/132 Kv 100 Mva Ict 1 @South Solapur (Kumbhari)	20-09-2021	11	20-09-2021	15.39	Testing Work	PO	220 KV
220/132 Kv 100mva Ict 2 @South Solapur (Kumbhari)	20-09-2021	15.42	20-09-2021	17.45	Testing Work	PO	220 KV
220/132KV 200MVA ICT-II @ Miraj	20-09-2021	8.51	20-09-2021	17	Winding resistance measurement work	PO	220 KV
Adlabs - Pedambe	20-09-2021	10.43	20-09-2021	17.3	Distance Protection	T	220 KV
Eklahara-(Ocr)(Nashik)-Navasari I	20-09-2021	10.04	20-09-2021	16.27	Replacement of Old Disc Insulator	PO	220 KV
Karad - Kadegaon	20-09-2021	15.25	20-09-2021	17.58	To attend Hot Spot	EO	220 KV
Khadka-Chalisingaon-1	20-09-2021	9.25	20-09-2021	16.57	Routine Maintenance Work	PO	220 KV
Loteparshuram- Dasturi Line	20-09-2021	10.3	20-09-2021	14.17	Bus outage at Lote s/stn	PO	220 KV
New Koyna - Loteparshuram	20-09-2021	10.4	20-09-2021	19.1	CC Replacement	PO	220 KV
Parli 2-(Girwali) -Murud	20-09-2021	10.55	20-09-2021	18.51	Isolator alignment work	PO	220 KV
Uran - Kharghar I	20-09-2021	15.24	25-09-2021	12.42	Cable charging and connection (RFC 02.15)	PO	220 KV
Badnera Tss-li	21-09-2021	22.55	22-09-2021	23.48	R-Ph metering CT burst.	T	220 KV
Chalisingaon -Babhaleshwar	21-09-2021	9.46	21-09-2021	13.51	RED hot attend on B phase wave trap.	EO	220 KV
Kharghar - Tss Panvel	21-09-2021	5.25	21-09-2021	22.1	Distance Protection	T	220 KV
Nagothane - Ipcl	21-09-2021	9.05	21-09-2021	13.4	Emergency tree cutting work.	PO	220 KV
Nigade- Peth Line	21-09-2021	10	21-09-2021	15.19	Diagnostic testing work, B ph CT oil leakage attending work. replacement of window Annunciation and confirmation of auto re-close operation of CB.	PO	220 KV
satara MIDC- Malharpeth	21-09-2021	9.25	21-09-2021	17.47	Replacement of Long rod polymer insulator strings near.	PO	220 KV
220/132 KV 100MVA ICT-I @ Walchandnagar	22-09-2021	10.28	22-09-2021	19.31	OLTC Overhauling work.	PO	220 KV
Abhijeet-Wardha-li	22-09-2021	10.2	22-09-2021	12.03	Master Tripped	T	220 KV
Ambazari-Abhijeet	22-09-2021	10.2	22-09-2021	12	Master Tripped	T	220 KV
PANDHARPUR BHALVANI	22-09-2021	16.15	22-09-2021	16.45	Testing Work	PO	220 KV
Parli New Tps - Beed Ckt 1	22-09-2021	10.33	22-09-2021	15.03	Replacement of Disc Insulator String	PO	220 KV
Parli New Tps - Beed Ckt 2	22-09-2021	15.25	22-09-2021	17.15	Replacement of Disc Insulator String	PO	220 KV
Trombay-Salsette II	22-09-2021	23.47	23-09-2021	4	Metro work in vicinity.	PO	220 KV
Trombay-Salsette II	22-09-2021	9.39	22-09-2021	16.25	Work in vicinity	PO	220 KV
Tuljapur-Lamboti(Tap to Vairag s/st.)	22-09-2021	12.54	22-09-2021	15.3	Quarterly Maintenance Work	PO	220 KV
satara MIDC- Malharpeth	22-09-2021	9.11	22-09-2021	13.25	Replacement of Long Rod polymer Insulator strings	PO	220 KV
220/132 KV 100MVA ICT-II @ Walchandnagar	23-09-2021	10.1	23-09-2021	17.05	OLTC Overhauling Work.	PO	220 KV
220/132 kv 200 MVA ICT- I @ Nanded	23-09-2021	10.34	23-09-2021	12.25	For CTR Fire Survival cable Inspection/Replacement by M/S CTR PUNE.	PO	220 KV
Abhijeet-Wardha-li	23-09-2021	12.21	23-09-2021	13.01	Distance Protection	T	220 KV
Ambazari-Kalmeshwar	23-09-2021	9.58	23-09-2021	16.32	For replacement of flashed over string various locations.	PO	220 KV
Bhugaon-Ugml	23-09-2021	10.25	23-09-2021	17.42	Measurement of Tan Delta & IR Value of CT & IR Value of PT Measurement of CB TIMING, CRM.	PO	220 KV
Chandrapur GCR - Cpurrlytss1	23-09-2021	9.22	23-09-2021	23.07	Diagnostic Testing Work & Routine maintenance work.	PO	220 KV

Transmission Line Outages/Trippings from 20.09.2021 to 26.09.2021

Name of Line	Date Trip	Time Trip	Date Sync	Time Sync	Reason	Outage Type	Voltage
Kalmeshwar-Kalmeshwar Rly Tss 1	23-09-2021	14.33	24-09-2021	19.29	For Replacement of drop Jumpers of DPI/S5 & S3 at RAILWAY TSS end, damaged due to lightning. As per their letter DTD 23.09.2021.	EO	220 KV
Phulambri-Bhokardan	23-09-2021	5.36	23-09-2021	5.38	R PH, Z1, 2.23KA,23 KM. CKT Tripped at end only.	T	220 KV
Trombay-Salsette II	23-09-2021	23.47	23-09-2021	4	Metro Work In Vicinity.	PO	220 KV
Versova Gorai Line	23-09-2021	10.58	23-09-2021	15.11	Attending and rectification of hotspot (160 dec) on R-ph LA termination at CTT tower LS 303A.	EO	220 KV
220/132 Kv 100 Mva lct 1 @Tuljapur	24-09-2021	15.4	24-09-2021	16.09	PRV Relay testing, TNC Switch replacement.	EO	220 KV
220/66 Kv 150 Mva Emco lct 2 @Gadchandur	24-09-2021	16.48	24-09-2021	19.32	For replacement of differential relay having display problem.	EO	220 KV
A'bad(PG)-Shendra Ckt II	24-09-2021	11.22	24-09-2021	17.13	Diagnostic testing work. CBT,CRM,TAN D	PO	220 KV
Bhugaon- Wardha	24-09-2021	18.39	24-09-2021	20.17	Line opening due to O/D at low frequency.	HT	220 KV
Devgaon - Rangari	24-09-2021	10.44	24-09-2021	14.38	Routine maintenance & Diagnostic testing work.	PO	220 KV
EKLAHARE (OCR) Nasik Navsari II	24-09-2021	9.58	24-09-2021	20.53	Line work:For replacement of old disk insulator by porcelain long rod, Diagnostic testing,broken/flash over string replacement found during monkey patrolling, signature analysis, TLS fixing if issued.	PO	220 KV
PARLY (PG) - OSMANABAD	24-09-2021	19.15	24-09-2021	20.16	Line opening due to O/D at low frequency.	HT	220 KV
Parli 3 (Old Gcr)-Girwali Ckt 2	24-09-2021	18.39	24-09-2021	20.17	Line opening due to O/D at low frequency.	HT	220 KV
Pusad-WardhaPG(Deoli)	24-09-2021	19.11	24-09-2021	20.06	Line opening due to O/D at low frequency.	HT	220 KV
Umred-Kanhan 2	24-09-2021	17.07	24-09-2021	17.34	B/UP,Y-B PH,2.18KA,	T	220 KV
220/132 Kv 100 Mva lct 1 @Sawangi	25-09-2021	11.35	25-09-2021	17.32	Attending Oil Leakage	PO	220 KV
Badnera - Nandgaonpeth	25-09-2021	12.08	25-09-2021	14.56	Line Maintenance work	PO	220 KV
Dondaicha- Shahada	25-09-2021	10.16	25-09-2021	18.07	Replacement of Jumper CT	PO	220 KV
Nadgaonpeth-Amravati	25-09-2021	6.56	25-09-2021	11.58	To attend Hot Spot	EO	220 KV
PANDHARPUR BHALVANI	25-09-2021	13.53	25-09-2021	14.5	Emergency Tree cutting	EO	220 KV
Theur-Jejuri	25-09-2021	10.52	25-09-2021	14.34	Half yearly maintenance work	PO	220 KV
220/22kv 100MVA T/F-I @ Nalasopara	26-09-2021	10.16	26-09-2021	13.05	Repl. of deteriorated HV CB to Isolator-D Y-ph. Jumper & attending hot Spot of LV-2 B-Ph drop jumper.	PO	220 KV
PAL DOMBIVALI - PALAVA	26-09-2021	10.2	26-09-2021	13.15	Providing Additional Jumpers To Cut-point locations.	PO	220 KV
Tata Borivli MSETCL Borivli 4	26-09-2021	20.49		Continued.	for shifting to Spare bay in GIS.	PO	220 KV
Urse-Chinchwad (ST tap)	26-09-2021	13.4	26-09-2021	19.55	Relay Testing Work.	PO	220 KV
Karad Solapur (PG)	03-05-2017	11:49		Continued.	Line Converted As 220 Kv Solapur (PG)-Jeur From LOC 403	PO	400 KV
400/220/33 Kv 500 Mva lct 1 @ CHANDRAPUR 2	07-09-2021	20.23		Continued.	Differential protection.	T	400 KV
Bus Coupler @ Lonikand	16-09-2021	9.48	21-09-2021	22.04	CB overhauling work.	PO	400 KV
Karad-Jaigad - I	19-09-2021	20.56	20-09-2021	8.59	Over Voltage	HT	400 KV
Khadka-Aurangabad (Waluj)	19-09-2021	18.08	20-09-2021	8.52	Over Voltage	HT	400 KV
Ektuni-Bableshtar ckt II	20-09-2021	9.22	20-09-2021	19.22	To replace Disc Insulators	PO	400 KV
Khadka-Aurangabad (Waluj)	20-09-2021	20.18	21-09-2021	8.17	Over Voltage	HT	400 KV
Parli(MS)-Parli (PG) I	20-09-2021	16.4	20-09-2021	18.02	Sparking on Y phase Isolator	HT	400 KV
Pune(GIS)-A'bad(Waluj) Ckt 1	20-09-2021	11.53	20-09-2021	20.13	Rectifying line defects	PO	400 KV

Transmission Line Outages/Trippings from 20.09.2021 to 26.09.2021

Name of Line	Date Trip	Time Trip	Date Sync	Time Sync	Reason	Outage Type	Voltage
Pune(GIS)-Parli(PG) Ckt 1	20-09-2021	22.47	20-09-2021	0.23	Hotspot of 384 Deg at Expansion clamp of R phase CT in TBC bay.	EO	400 KV
400/220KV 500MVA ICT-I @Nanded	21-09-2021	10.54	21-09-2021	17.34	For CTR testing & replacement of faulty parts.Annul Tan-d & bay maintenance.	PO	400 KV
Karad - Jaigad - II	21-09-2021	20.16	22-09-2021	10.1	Over Voltage	HT	400 KV
Karad - Talandge Ckt 2	21-09-2021	8.29	21-09-2021	10.5	Attending Hot Spot	PO	400 KV
Khadka-Aurangabad (Waluj)	21-09-2021	19.16	23-09-2021	8.29	Over Voltage	HT	400 KV
Koradi Bhilai	21-09-2021	9.17	21-09-2021	21.41	For Line Bay AMP work.	PO	400 KV
Lonikand2-Lonikand1 (Intrconector)	21-09-2021	0.4	21-09-2021	3.07	Attending Hot Spot	EO	400 KV
400/220 KV 500MVA ICT II @ Nanded	22-09-2021	11.17	22-09-2021	18.35	Testing Work	PO	400 KV
400/220 Kv 500 Mva Ict 1 @Lamboti	22-09-2021	12.4	22-09-2021	14.58	Testing Work	PO	400 KV
400/220KV 500MVA ICT 2@koradi 2	22-09-2021	13.09	22-09-2021	16.29	Tan Delta Measurment of CTs	PO	400 KV
Akola II - RPL(Rattanindia) Ckt I	22-09-2021	9.09	22-09-2021	19.47	Replacement of Metering CVT	PO	400 KV
Koradi-Bhusawal	22-09-2021	10.1	22-09-2021	14.45	To attend Hot Spot	EO	400 KV
Parli(MS)-Parli (PG) I	22-09-2021	12.22	22-09-2021	16.27	29B, Y Phase Isolator work	EO	400 KV
Bhusawal-Aurangabad	23-09-2021	20.37	24-09-2021	7.27	Over Voltage	HT	400 KV
Dhule Khandwa I	23-09-2021	22.36	23-09-2021	23.03	Distance Protection	T	400 KV
Ict Spare Single Unit 167 Mva Ict @Jejuri	23-09-2021	10.28	23-09-2021	18.27	For confirmation of HV bushing Tan Delta value and CTR repair work.	PO	400 KV
Jaigad-Karad Ckt-II	23-09-2021	10.55	23-09-2021	17.36	For additional earthing.	PO	400 KV
Padghe - Nagothane - I	23-09-2021	10.37	23-09-2021	22.26	For shifting of 400 kv NGTN-Padghe I on TBC on dt.23.09.21.	EO	400 KV
Pune(GIS)-A'bad(Waluj) Ckt 2	23-09-2021	8.55	23-09-2021	19.34	Work at PGCL end PUNE.	PO	400 KV
400/220KV 315MVA ICT-II @Akola (M)	24-09-2021	10.02	24-09-2021	13.51	Routine maintenance & Diagnostic testing work.	PO	400 KV
Bhusawal-Aurangabad	24-09-2021	20.22	25-09-2021	9.3	Over Voltage	HT	400 KV
Alkud-Kolhapur(Talandage)	25-09-2021	0.14	25-09-2021	11.11	Distance Protection	T	400 KV
Karad - Talandge Ckt 2	25-09-2021	9.55	25-09-2021	14.36	Attending Hot Spot	EO	400 KV
Khadka- Deepnagar Ckt 1	25-09-2021	10.03	25-09-2021	19.02	Testing Work	PO	400 KV
Khadka-Aurangabad (Waluj)	25-09-2021	20.27		Continued.	Over Voltage	HT	400 KV
Koradi Satpur	25-09-2021	11.06	25-09-2021	23.58	Line Maintenance work	PO	400 KV
Koradi 2-IEPL	26-09-2021	7		Continued.	For for height raising work across.	PO	400 KV
koaradi II - Wardha(PG)	26-09-2021	7.29		Continued.	For height raising work across Samruddhi highway at chainage No.23+650 (tower no 192 & 193)	PO	400 KV
Khadka-Aurangabad (Waluj)	31-12-2020	17.33		Continued.	Over Voltage	HT	400 KV
Chandrapur - Padghe Hvdc Pole 2	21-09-2021	3.36	21-09-2021	10.04	Tripped on Line Fault	T	500 KV
Chandrapur - Padghe Hvdc Pole 1	23-09-2021	22.29	24-09-2021	0.54	Work AT PADGHE End.	EO	500 KV