

**State Load Despatch Center,Airoli (MSETCL)**  
**Power System Position from 21/Oct/2019 to 27/Oct/2019**

**Supply Position During Morning Peak (MW)**

| Date           | Time   | MSGENCO     |            |            |             | Central Sector Receipt | Wind        | CPP         | SOLAR      | TPCL Exch.   | MSEDCL Catered Demand | Load Shedding( LS) | MSEDCL Demand (Incl. LS) | TPCL Gen.   | R-INFRA Gen. | State Demand Met | State Demand (Incl. LS) | Freq.        |
|----------------|--------|-------------|------------|------------|-------------|------------------------|-------------|-------------|------------|--------------|-----------------------|--------------------|--------------------------|-------------|--------------|------------------|-------------------------|--------------|
|                |        | THM         | HYDRO      | GAS        | Total       |                        |             |             |            |              |                       |                    |                          |             |              |                  |                         |              |
|                |        | MW          | MW         | MW         | MW          | MW                     | MW          | MW          | MW         | MW           | MW                    | MW                 | MW                       | MW          | MW           | MW               | MW                      | Hzs          |
| 21/10/2019     | 9 Hrs  | 3958        | 725        | 441        | 5124        | 4941                   | 836         | 4103        | 118        | -1171        | 13951                 | 0                  | 13951                    | 684         | 190          | 15996            | 15996                   | 50.03        |
| 22/10/2019     | 10 Hrs | 4587        | 965        | 425        | 5977        | 6368                   | 222         | 4083        | 419        | -1762        | 15307                 | 0                  | 15307                    | 867         | 190          | 18126            | 18126                   | 50.01        |
| 23/10/2019     | 10 Hrs | 4519        | 416        | 429        | 5364        | 6356                   | 81          | 4356        | 424        | -1468        | 15113                 | 0                  | 15113                    | 1139        | 247          | 17967            | 17967                   | 50.03        |
| 24/10/2019     | 12 Hrs | 3868        | 271        | 418        | 4557        | 6840                   | 876         | 4081        | 408        | -1796        | 14966                 | 0                  | 14966                    | 1101        | 226          | 18089            | 18089                   | 50.00        |
| 25/10/2019     | 10 Hrs | 3151        | 361        | 9          | 3521        | 5817                   | 1118        | 4825        | 348        | -1404        | 14225                 | 0                  | 14225                    | 1130        | 251          | 17010            | 17010                   | 50.01        |
| 26/10/2019     | 10 Hrs | 3412        | 543        | 386        | 4341        | 5232                   | 1302        | 3902        | 315        | -1467        | 13625                 | 0                  | 13625                    | 739         | 191          | 16022            | 16022                   | 50.00        |
| 27/10/2019     | 9 Hrs  | 2749        | 258        | 392        | 3398        | 4804                   | 548         | 4289        | 317        | -1119        | 12238                 | 0                  | 12238                    | 683         | 192          | 14232            | 14232                   | 50.07        |
| <b>Maximum</b> |        | <b>4587</b> | <b>965</b> | <b>441</b> | <b>5977</b> | <b>6840</b>            | <b>1302</b> | <b>4825</b> | <b>424</b> | <b>-1119</b> | <b>15307</b>          | <b>0</b>           | <b>15307</b>             | <b>1139</b> | <b>251</b>   | <b>18126</b>     | <b>18126</b>            | <b>50.07</b> |
| <b>Minimum</b> |        | <b>2749</b> | <b>258</b> | <b>9</b>   | <b>3398</b> | <b>4804</b>            | <b>81</b>   | <b>3902</b> | <b>118</b> | <b>-1796</b> | <b>12238</b>          | <b>0</b>           | <b>12238</b>             | <b>683</b>  | <b>190</b>   | <b>14232</b>     | <b>14232</b>            | <b>50.00</b> |
| <b>Average</b> |        | <b>3749</b> | <b>506</b> | <b>357</b> | <b>4612</b> | <b>5765</b>            | <b>712</b>  | <b>4234</b> | <b>336</b> | <b>-1455</b> | <b>14203</b>          | <b>0</b>           | <b>14203</b>             | <b>906</b>  | <b>212</b>   | <b>16777</b>     | <b>16777</b>            | <b>50.02</b> |

**Supply Position During Day Peak (MW)**

| Date           | Time   | MSGENCO     |             |            |             | Central Sector Receipt | Wind        | CPP         | SOLAR      | TPCL Exch.   | MSEDCL Catered Demand | Load Shedding( LS) | MSEDCL Demand (Incl. LS) | TPCL Gen.   | R-INFRA Gen. | State Demand Met | State Demand (Incl. LS) | Freq.        |
|----------------|--------|-------------|-------------|------------|-------------|------------------------|-------------|-------------|------------|--------------|-----------------------|--------------------|--------------------------|-------------|--------------|------------------|-------------------------|--------------|
|                |        | THM         | HYDRO       | GAS        | Total       |                        |             |             |            |              |                       |                    |                          |             |              |                  |                         |              |
|                |        | MW          | MW          | MW         | MW          | MW                     | MW          | MW          | MW         | MW           | MW                    | MW                 | MW                       | MW          | MW           | MW               | MW                      | Hzs          |
| 21/10/2019     | 18 Hrs | 3939        | 1060        | 424        | 5423        | 4784                   | 185         | 3909        | 31         | -1422        | 12910                 | 0                  | 12910                    | 859         | 190          | 15381            | 15381                   | 49.96        |
| 22/10/2019     | 18 Hrs | 4829        | 299         | 422        | 5550        | 6091                   | 257         | 4188        | 21         | -1603        | 14504                 | 0                  | 14504                    | 1147        | 192          | 17446            | 17446                   | 50.03        |
| 23/10/2019     | 18 Hrs | 4224        | 886         | 422        | 5532        | 5880                   | 83          | 4365        | 9          | -1471        | 14398                 | 0                  | 14398                    | 1172        | 222          | 17263            | 17263                   | 50.00        |
| 24/10/2019     | 13 Hrs | 3590        | 183         | 416        | 4189        | 6768                   | 922         | 3940        | 401        | -1937        | 14283                 | 0                  | 14283                    | 924         | 193          | 17337            | 17337                   | 50.02        |
| 25/10/2019     | 18 Hrs | 3063        | 222         | 341        | 3626        | 5693                   | 1030        | 4395        | 32         | -1541        | 13235                 | 0                  | 13235                    | 1077        | 191          | 16044            | 16044                   | 50.05        |
| 26/10/2019     | 13 Hrs | 3404        | 123         | 401        | 3928        | 4942                   | 1145        | 3627        | 411        | -1570        | 12483                 | 0                  | 12483                    | 875         | 190          | 15118            | 15118                   | 50.04        |
| 27/10/2019     | 18 Hrs | 2562        | 138         | 532        | 3232        | 4696                   | 162         | 3600        | 39         | -1040        | 10688                 | 0                  | 10688                    | 849         | 190          | 12768            | 12768                   | 49.97        |
| <b>Maximum</b> |        | <b>4829</b> | <b>1060</b> | <b>532</b> | <b>5550</b> | <b>6768</b>            | <b>1145</b> | <b>4395</b> | <b>411</b> | <b>-1040</b> | <b>14504</b>          | <b>0</b>           | <b>14504</b>             | <b>1172</b> | <b>222</b>   | <b>17446</b>     | <b>17446</b>            | <b>50.05</b> |
| <b>Minimum</b> |        | <b>2562</b> | <b>123</b>  | <b>341</b> | <b>3232</b> | <b>4696</b>            | <b>83</b>   | <b>3600</b> | <b>9</b>   | <b>-1937</b> | <b>10688</b>          | <b>0</b>           | <b>10688</b>             | <b>849</b>  | <b>190</b>   | <b>12768</b>     | <b>12768</b>            | <b>49.96</b> |
| <b>Average</b> |        | <b>3659</b> | <b>416</b>  | <b>423</b> | <b>4497</b> | <b>5551</b>            | <b>541</b>  | <b>4003</b> | <b>135</b> | <b>-1512</b> | <b>13214</b>          | <b>0</b>           | <b>13214</b>             | <b>986</b>  | <b>195</b>   | <b>15908</b>     | <b>15908</b>            | <b>50.01</b> |

## Supply Position During Evening Peak (MW)

| Date           | Time   | MSGENCO     |             |            |             | Central Sector Receipt | Wind        | CPP         | SOLAR    | TPCL Exch.   | MSEDCL Cateder Demand | Load Shedding( LS) | MSEDCL Demand (Incl. LS) | TPCL Gen.   | R-INFRA Gen. | State Demand Met | State Demand (Incl. LS) | Freq.        |
|----------------|--------|-------------|-------------|------------|-------------|------------------------|-------------|-------------|----------|--------------|-----------------------|--------------------|--------------------------|-------------|--------------|------------------|-------------------------|--------------|
|                |        | THM         | HYDRO       | GAS        | Total       |                        |             |             |          |              |                       |                    |                          |             |              |                  |                         |              |
|                |        | MW          | MW          | MW         | MW          | MW                     | MW          | MW          | MW       | MW           | MW                    | MW                 | MW                       | MW          | MW           | MW               | MW                      | Hzs          |
| 21/10/2019     | 19 Hrs | 4004        | 1585        | 425        | 6014        | 5671                   | 190         | 4101        | 0        | -1535        | 14441                 | 0                  | 14441                    | 891         | 190          | 17057            | 17057                   | 50.02        |
| 22/10/2019     | 19 Hrs | 5123        | 691         | 422        | 6236        | 6077                   | 344         | 4432        | 0        | -1491        | 15598                 | 0                  | 15598                    | 1246        | 236          | 18571            | 18571                   | 50.02        |
| 23/10/2019     | 19 Hrs | 4147        | 1821        | 423        | 6391        | 5803                   | 106         | 4447        | 0        | -1400        | 15347                 | 0                  | 15347                    | 1276        | 246          | 18269            | 18269                   | 50.01        |
| 24/10/2019     | 19 Hrs | 3802        | 780         | 422        | 5004        | 5601                   | 700         | 4645        | 1        | -1395        | 14556                 | 0                  | 14556                    | 1294        | 248          | 17493            | 17493                   | 49.98        |
| 25/10/2019     | 19 Hrs | 3539        | 406         | 391        | 4336        | 5462                   | 1177        | 5103        | 9        | -1560        | 14527                 | 0                  | 14527                    | 1121        | 191          | 17399            | 17399                   | 50.06        |
| 26/10/2019     | 20 Hrs | 3452        | 499         | 410        | 4361        | 5611                   | 428         | 4670        | 0        | -1395        | 13675                 | 0                  | 13675                    | 922         | 191          | 16183            | 16183                   | 50.02        |
| 27/10/2019     | 19 Hrs | 2589        | 342         | 519        | 3450        | 5739                   | 173         | 3880        | 0        | -1300        | 11942                 | 0                  | 11942                    | 859         | 190          | 14290            | 14290                   | 50.05        |
| <b>Maximum</b> |        | <b>5123</b> | <b>1821</b> | <b>519</b> | <b>6391</b> | <b>6077</b>            | <b>1177</b> | <b>5103</b> | <b>9</b> | <b>-1300</b> | <b>15598</b>          | <b>0</b>           | <b>15598</b>             | <b>1294</b> | <b>248</b>   | <b>18571</b>     | <b>18571</b>            | <b>50.06</b> |
| <b>Minimum</b> |        | <b>2589</b> | <b>342</b>  | <b>391</b> | <b>3450</b> | <b>5462</b>            | <b>106</b>  | <b>3880</b> | <b>0</b> | <b>-1560</b> | <b>11942</b>          | <b>0</b>           | <b>11942</b>             | <b>859</b>  | <b>190</b>   | <b>14290</b>     | <b>14290</b>            | <b>49.98</b> |
| <b>Average</b> |        | <b>3808</b> | <b>875</b>  | <b>430</b> | <b>5113</b> | <b>5709</b>            | <b>445</b>  | <b>4468</b> | <b>1</b> | <b>-1439</b> | <b>14298</b>          | <b>0</b>           | <b>14298</b>             | <b>1087</b> | <b>213</b>   | <b>17037</b>     | <b>17037</b>            | <b>50.02</b> |

## Supply Position During Night Off Peak (MW)

| Date           | Time   | MSGENCO     |            |            |             | Central Sector Receipt | Wind        | CPP         | SOLAR    | TPCL Exch.   | MSEDCL Cateder Demand | Load Shedding( LS) | MSEDCL Demand (Incl. LS) | TPCL Gen.  | R-INFRA Gen. | State Demand Met | State Demand (Incl. LS) | Freq.        |
|----------------|--------|-------------|------------|------------|-------------|------------------------|-------------|-------------|----------|--------------|-----------------------|--------------------|--------------------------|------------|--------------|------------------|-------------------------|--------------|
|                |        | THM         | HYDRO      | GAS        | Total       |                        |             |             |          |              |                       |                    |                          |            |              |                  |                         |              |
|                |        | MW          | MW         | MW         | MW          | MW                     | MW          | MW          | MW       | MW           | MW                    | MW                 | MW                       | MW         | MW           | MW               | MW                      | Hzs          |
| 21/10/2019     | 3 Hrs  | 3970        | 495        | 441        | 4906        | 3336                   | 503         | 3734        | 0        | -863         | 11616                 | 0                  | 11616                    | 652        | 190          | 13321            | 13321                   | 49.99        |
| 22/10/2019     | 3 Hrs  | 3965        | 592        | 441        | 4998        | 3385                   | 298         | 3439        | 0        | -931         | 11189                 | 0                  | 11189                    | 652        | 190          | 12962            | 12962                   | 49.99        |
| 23/10/2019     | 4 Hrs  | 4021        | 250        | 430        | 4701        | 4627                   | 145         | 3468        | 0        | -916         | 12025                 | 0                  | 12025                    | 693        | 191          | 13825            | 13825                   | 49.99        |
| 24/10/2019     | 4 Hrs  | 3574        | 192        | 437        | 4203        | 4870                   | 284         | 3723        | 0        | -936         | 12144                 | 0                  | 12144                    | 625        | 190          | 13895            | 13895                   | 50.01        |
| 25/10/2019     | 4 Hrs  | 2727        | 151        | 430        | 3308        | 4241                   | 871         | 3790        | 0        | -876         | 11334                 | 0                  | 11334                    | 689        | 191          | 13090            | 13090                   | 50.01        |
| 26/10/2019     | 4 Hrs  | 3245        | 154        | 397        | 3796        | 2938                   | 1530        | 3653        | 0        | -932         | 10985                 | 0                  | 10985                    | 633        | 190          | 12740            | 12740                   | 50.02        |
| 27/10/2019     | 24 Hrs | 2640        | 105        | 506        | 3251        | 4354                   | 250         | 3554        | 0        | -1213        | 10196                 | 0                  | 10196                    | 795        | 190          | 12394            | 12394                   | 50.03        |
| <b>Maximum</b> |        | <b>4021</b> | <b>592</b> | <b>506</b> | <b>4998</b> | <b>4870</b>            | <b>1530</b> | <b>3790</b> | <b>0</b> | <b>-863</b>  | <b>12144</b>          | <b>0</b>           | <b>12144</b>             | <b>795</b> | <b>191</b>   | <b>13895</b>     | <b>13895</b>            | <b>50.03</b> |
| <b>Minimum</b> |        | <b>2640</b> | <b>105</b> | <b>397</b> | <b>3251</b> | <b>2938</b>            | <b>145</b>  | <b>3439</b> | <b>0</b> | <b>-1213</b> | <b>10196</b>          | <b>0</b>           | <b>10196</b>             | <b>625</b> | <b>190</b>   | <b>12394</b>     | <b>12394</b>            | <b>49.99</b> |
| <b>Average</b> |        | <b>3449</b> | <b>277</b> | <b>440</b> | <b>4166</b> | <b>3964</b>            | <b>554</b>  | <b>3623</b> | <b>0</b> | <b>-952</b>  | <b>11356</b>          | <b>0</b>           | <b>11356</b>             | <b>677</b> | <b>190</b>   | <b>13175</b>     | <b>13175</b>            | <b>50.01</b> |

## Details of Supply Position (MUs)

| Date           | MSGENCO        |               |               |                | Pench (MS)   | Central Sector Receipt | Central Sector Share | WIND           | CPP            | SOLAR        | TPCL Gen.     | R-INFRA Gen. | TPCL Exch.     | Energy Requirement |               |                |
|----------------|----------------|---------------|---------------|----------------|--------------|------------------------|----------------------|----------------|----------------|--------------|---------------|--------------|----------------|--------------------|---------------|----------------|
|                | THM            | HYDRO         | GAS           | Total          |              |                        |                      |                |                |              |               |              |                | MSEDCL             | MUMBAI        | STATE          |
|                | Mus            | Mus           | Mus           | Mus            | Mus          | Mus                    | Mus                  | Mus            | Mus            | Mus          | Mus           | Mus          | Mus            | Mus                | Mus           | Mus            |
| 21/10/2019     | 94.951         | 15.429        | 10.406        | 120.786        | 0.568        | 108.121                | 109.330              | 10.905         | 92.956         | 3.261        | 18.559        | 4.569        | -29.758        | 306.271            | 52.886        | 359.157        |
| 22/10/2019     | 103.966        | 14.914        | 10.252        | 129.132        | 0.678        | 131.682                | 131.842              | 5.895          | 89.212         | 3.935        | 21.942        | 4.674        | -33.861        | 325.995            | 60.477        | 386.472        |
| 23/10/2019     | 101.201        | 12.496        | 10.379        | 124.076        | 0.469        | 134.102                | 133.870              | 3.557          | 97.477         | 3.225        | 23.089        | 5.143        | -31.868        | 330.569            | 60.099        | 390.668        |
| 24/10/2019     | 88.070         | 8.283         | 10.193        | 106.546        | 0.734        | 139.147                | 139.738              | 13.708         | 96.713         | 2.655        | 22.916        | 5.182        | -32.110        | 326.659            | 60.208        | 386.867        |
| 25/10/2019     | 72.162         | 6.548         | 6.337         | 85.047         | 0.906        | 122.492                | 123.700              | 26.192         | 103.155        | 2.856        | 21.471        | 4.819        | -33.067        | 306.675            | 59.358        | 366.033        |
| 26/10/2019     | 78.091         | 7.248         | 9.452         | 94.791         | 0.474        | 112.464                | 111.487              | 24.560         | 92.582         | 2.974        | 18.385        | 4.579        | -30.871        | 296.500            | 53.835        | 350.335        |
| 27/10/2019     | 63.893         | 5.698         | 10.781        | 80.372         | 0.175        | 110.468                | 109.523              | 9.975          | 89.238         | 4.420        | 17.933        | 4.640        | -26.669        | 267.804            | 49.242        | 317.046        |
| <b>Maximum</b> | <b>103.966</b> | <b>15.429</b> | <b>10.781</b> | <b>129.132</b> | <b>0.906</b> | <b>139.147</b>         | <b>139.738</b>       | <b>103.966</b> | <b>103.155</b> | <b>4.420</b> | <b>23.089</b> | <b>5.182</b> | <b>-26.669</b> | <b>330.569</b>     | <b>60.477</b> | <b>390.668</b> |
| <b>Minimum</b> | <b>63.893</b>  | <b>5.698</b>  | <b>6.337</b>  | <b>80.372</b>  | <b>0.175</b> | <b>108.121</b>         | <b>109.330</b>       | <b>63.893</b>  | <b>89.212</b>  | <b>2.655</b> | <b>17.933</b> | <b>4.569</b> | <b>-33.861</b> | <b>267.804</b>     | <b>49.242</b> | <b>317.046</b> |
| <b>Average</b> | <b>86.048</b>  | <b>10.088</b> | <b>9.686</b>  | <b>105.821</b> | <b>0.572</b> | <b>122.639</b>         | <b>122.784</b>       | <b>86.048</b>  | <b>94.476</b>  | <b>3.332</b> | <b>20.614</b> | <b>4.801</b> | <b>-31.172</b> | <b>308.639</b>     | <b>56.586</b> | <b>365.225</b> |

## Details of Koyna Water Consumption (in TMC)

---

| Date       | For the Day | For the Month | Balance |
|------------|-------------|---------------|---------|
| 21/10/2019 | 0.001       | 1.887         | 58.229  |
| 22/10/2019 | 0.057       | 1.944         | 58.172  |
| 23/10/2019 | 0.191       | 2.135         | 57.981  |
| 24/10/2019 | 0.173       | 2.308         | 57.808  |
| 25/10/2019 | 0.088       | 2.396         | 57.720  |
| 26/10/2019 | 0.090       | 2.486         | 57.630  |
| 27/10/2019 | 0.080       | 2.566         | 57.550  |

**State Load Despatch Center, Airoli (MSETCL)**  
**Central Sector Share/Drawal from 21/Oct/2019 to 27/Oct/2019**

| Date         | DAY      | Central Sector Share |         | Total Interstate Bilateral Purchase |         | Total Share    |         | Total Drawal   |         | Overdrawal(+) / UnderDrawal(-) |         |
|--------------|----------|----------------------|---------|-------------------------------------|---------|----------------|---------|----------------|---------|--------------------------------|---------|
|              |          | MUs                  | Avg. MW | MUs                                 | Avg. MW | MUs            | Avg. MW | MUs            | Avg. MW | MUs                            | Avg. MW |
|              |          | 1                    |         | 2                                   |         | 1+2=3          |         | 4              |         | 3-4=5                          |         |
| 21/10/2019   | MONDAY   | 80.119               | 4526    | 29.211                              | 1217    | 109.330        | 4555    | 108.121        | 4505    | -1.209                         | -50     |
| 22/10/2019   | TUESDAY  | 102.659              | 5464    | 29.183                              | 1216    | 131.842        | 5493    | 131.682        | 5487    | -0.160                         | -7      |
| 23/10/2019   | WEDNESDA | 100.545              | 5545    | 33.325                              | 1389    | 133.870        | 5578    | 134.102        | 5588    | 0.232                          | 10      |
| 24/10/2019   | THURSDAY | 105.320              | 5788    | 34.418                              | 1434    | 139.738        | 5822    | 139.147        | 5798    | -0.591                         | -25     |
| 25/10/2019   | FRIDAY   | 90.698               | 5121    | 33.002                              | 1375    | 123.700        | 5154    | 122.492        | 5104    | -1.208                         | -50     |
| 26/10/2019   | SATURDAY | 80.657               | 4614    | 30.830                              | 1285    | 111.487        | 4645    | 112.464        | 4686    | 0.977                          | 41      |
| 27/10/2019   | SUNDAY   | 82.021               | 4536    | 27.502                              | 1146    | 109.523        | 4563    | 110.468        | 4603    | 0.945                          | 39      |
| <b>Total</b> |          | <b>642.020</b>       |         | <b>217.470</b>                      |         | <b>859.490</b> |         | <b>858.476</b> |         | <b>-1.014</b>                  |         |

| Generating Unit Outages for the week 21 October- 2019 to 27 October -2019 |             |                    |           |           |           |            |                                                                                             |
|---------------------------------------------------------------------------|-------------|--------------------|-----------|-----------|-----------|------------|---------------------------------------------------------------------------------------------|
| Sr No                                                                     | Outage Type | Name               | Trip Date | Trip Time | Sync Date | Sync Time  | Reason                                                                                      |
| 1                                                                         | PLANNED     | SWPGL U-3          | 01-Nov-18 | 0.28      |           | Continued. | Annual Overhaul                                                                             |
| 2                                                                         | PLANNED     | Chandrapur Unit 7  | 27-Jul-19 | 0         |           | Continued. | Annual Overhaul                                                                             |
| 3                                                                         | FORCED      | SWPGL U-1          | 16-Feb-16 | 17.09     |           | Continued. | No PPA.                                                                                     |
| 4                                                                         | FORCED      | Parli Unit 4       | 01-Apr-16 | 0         |           | Continued. | Economic shutdown                                                                           |
| 5                                                                         | FORCED      | Parli Unit 5       | 01-Apr-16 | 0         |           | Continued. | Economic shutdown                                                                           |
| 6                                                                         | FORCED      | PGPL U1            | 07-Feb-17 | 17.3      |           | Continued. | No Schedule                                                                                 |
| 7                                                                         | FORCED      | PGPL U2            | 07-Feb-17 | 17.3      |           | Continued. | No Schedule                                                                                 |
| 8                                                                         | FORCED      | IEPL Unit 1        | 28-Aug-18 | 21.26     |           | Continued. | No PPA                                                                                      |
| 9                                                                         | FORCED      | SWPGL U-2          | 27-Nov-18 | 0         |           | Continued. | No Schedule.                                                                                |
| 10                                                                        | FORCED      | SWPGL U-4          | 15-Dec-18 | 0         |           | Continued. | No Schedule                                                                                 |
| 11                                                                        | FORCED      | VIPL U-1           | 29-Dec-18 | 0.3       |           | Continued. | Coal Shortage                                                                               |
| 12                                                                        | FORCED      | VIPL U-2           | 17-Jan-19 | 0.15      |           | Continued. | Coal Shortage                                                                               |
| 13                                                                        | FORCED      | Koyna Unit 10      | 05-Aug-19 | 20.05     | 26-Oct-19 | 10.1       | Stator Earth Fault                                                                          |
| 14                                                                        | FORCED      | Paras Unit 4       | 25-Aug-19 | 0.45      |           | Continued. | Annual Overhaul Converted Zero Schedule From 28.10.2019 18.00                               |
| 15                                                                        | FORCED      | Koradi Unit 7      | 27-Aug-19 | 9.52      |           | Continued. | Coal Flow Problem Due To Wet Coal.(Converted To Zero Schedule From 12.09.2019 At 20.00 hrs) |
| 16                                                                        | FORCED      | RPL(AMT) U-1       | 01-Sep-19 | 9.11      |           | Continued. | Generator Protection operated                                                               |
| 17                                                                        | FORCED      | Bhusawal Unit 3    | 01-Sep-19 | 17.56     |           | Continued. | Zero Schedule from 18:00hrs of 28/09/2019                                                   |
| 18                                                                        | FORCED      | Koradi Unit 6      | 06-Sep-19 | 15.41     |           | Continued. | Zero Schedule                                                                               |
| 19                                                                        | FORCED      | Adani U-1          | 19-Sep-19 | 1.43      | 24-Oct-19 | 17.42      | Due to Low Coal Stock.                                                                      |
| 20                                                                        | FORCED      | AEML Unit 2        | 07-Oct-19 | 21.18     | 01-Nov-19 | 10.15      | Coal Shortage                                                                               |
| 21                                                                        | FORCED      | Nasik Unit 3       | 09-Oct-19 | 23.57     |           | Continued. | Zero schedule.                                                                              |
| 22                                                                        | FORCED      | Nasik Unit 4       | 09-Oct-19 | 23.59     | 02-Nov-19 | 23.48      | Zero schedule.                                                                              |
| 23                                                                        | FORCED      | Khaparkheda Unit 1 | 12-Oct-19 | 0.11      |           | Continued. | Zero Schedule                                                                               |
| 24                                                                        | FORCED      | Khaparkheda Unit 2 | 12-Oct-19 | 0.17      |           | Continued. | Zero Schedule                                                                               |
| 25                                                                        | FORCED      | Khaparkheda Unit 3 | 13-Oct-19 | 19.57     |           | Continued. | Zero Schedule                                                                               |
| 26                                                                        | FORCED      | Parli Unit 8       | 16-Oct-19 | 1.36      |           | Continued. | Flame Failure (Converted To Zero Schedule DT.23.10.2019 18.00.hrs)                          |
| 27                                                                        | FORCED      | Parli Unit 6       | 17-Oct-19 | 23.25     | 22-Oct-19 | 17.05      | Poor Coal Receipt.                                                                          |
| 28                                                                        | FORCED      | Uran Unit 8        | 18-Oct-19 | 4.18      | 23-Oct-19 | 10.38      | Generator Vibration High.                                                                   |
| 29                                                                        | FORCED      | Bhusawal Unit 4    | 19-Oct-19 | 22.35     | 22-Oct-19 | 5.23       | Boiler Tube Leakage                                                                         |
| 30                                                                        | FORCED      | Adani U-2          | 21-Oct-19 | 22.58     | 25-Oct-19 | 16.05      | APH Hot PA Bellow Leakage                                                                   |
| 31                                                                        | FORCED      | Koradi Unit 9      | 21-Oct-19 | 1.18      | 24-Oct-19 | 18.3       | Boiler Tube Leakage                                                                         |
| 32                                                                        | FORCED      | Khaparkheda Unit 4 | 22-Oct-19 | 23.52     |           | Continued. | Zero Schedule By MSEDCL.                                                                    |
| 33                                                                        | FORCED      | Parli Unit 6       | 23-Oct-19 | 3.3       |           | Continued. | Zero Schedule By MSEDCL.                                                                    |
| 34                                                                        | FORCED      | Parli Unit 7       | 23-Oct-19 | 17        |           | Continued. | Zero Schedule.                                                                              |
| 35                                                                        | FORCED      | Paras Unit 3       | 23-Oct-19 | 0         |           | Continued. | Zero Schedule By MSEDCL.                                                                    |
| 36                                                                        | FORCED      | Uran Unit 8        | 23-Oct-19 | 12.46     | 25-Oct-19 | 4.14       | Compress Bearing vibration high.                                                            |
| 37                                                                        | FORCED      | Koradi Unit-8      | 24-Oct-19 | 5.27      | 29-Oct-19 | 21.36      | Rotary Air Preheater Trip.                                                                  |
| 38                                                                        | FORCED      | Adani U-4          | 24-Oct-19 | 4.39      | 24-Oct-19 | 8.33       | governing valve 1 &3 sudden Closing.                                                        |
| 39                                                                        | FORCED      | Chandrapur Unit 6  | 25-Oct-19 | 1.03      | 25-Oct-19 | 23         | Bus-1 LBB Operation.                                                                        |
| 40                                                                        | FORCED      | RPL(AMT) U-3       | 25-Oct-19 | 2         |           | Continued. | Zero Schedule.                                                                              |
| 41                                                                        | FORCED      | Uran Unit B0       | 25-Oct-19 | 5.3       | 25-Oct-19 | 14.38      | Gas Skid Failure.                                                                           |
| 42                                                                        | FORCED      | RPL(AMT) U-2       | 25-Oct-19 | 22        |           | Continued. | Zero Schedule.                                                                              |
| 43                                                                        | FORCED      | Chandrapur Unit 6  | 25-Oct-19 | 23.11     | 26-Oct-19 | 1.15       | Turbine Tripped                                                                             |
| 44                                                                        | FORCED      | Uran Unit 8        | 25-Oct-19 | 5.3       | 25-Oct-19 | 15.43      | Gas Skid Failure                                                                            |
| 45                                                                        | FORCED      | Chandrapur Unit 5  | 25-Oct-19 | 1.03      | 04-Nov-19 | 6.24       | Bus-1 LBB Operation (Converted into zero schedule 26.10.2019 at 00.23Hrs).                  |
| 46                                                                        | FORCED      | Chandrapur Unit 3  | 25-Oct-19 | 1.03      | 04-Nov-19 | 11.39      | Bus-1 LBB Operation (Converted into zero schedule 26.10.2019 at 00.23Hrs).                  |
| 47                                                                        | FORCED      | Uran Unit A0       | 25-Oct-19 | 5.3       | 25-Oct-19 | 12.15      | Gas Skid Failure.                                                                           |
| 48                                                                        | FORCED      | Uran Unit 7        | 25-Oct-19 | 5.3       | 25-Oct-19 | 11.34      | Gas Skid Failure.                                                                           |
| 49                                                                        | FORCED      | Uran Unit 6        | 25-Oct-19 | 5.3       | 25-Oct-19 | 9.53       | Gas Skid Failure                                                                            |
| 50                                                                        | FORCED      | Uran Unit 5        | 25-Oct-19 | 5.3       | 27-Oct-19 | 9.33       | Gas Skid Failure                                                                            |
| 51                                                                        | FORCED      | RPL(AMT) U-5       | 26-Oct-19 | 0.3       | 04-Nov-19 | 18.11      | Zero Schedule                                                                               |
| 52                                                                        | FORCED      | RPL(AMT) U-4       | 26-Oct-19 | 8         | 06-Nov-19 | 17.24      | Zero Schedule                                                                               |
| 53                                                                        | FORCED      | Chandrapur Unit 6  | 26-Oct-19 | 21.52     | 04-Nov-19 | 2.05       | Zero Schedule                                                                               |

**List of Transmission line Trippings/Outages for the week 21 October- 2019 to 27 October -2019**

| Sr. No. | Voltage Level | Outage Type | Name                                     | Trip Date | Trip Time | Sync Date | Sync Time  | Reason                                                                          |
|---------|---------------|-------------|------------------------------------------|-----------|-----------|-----------|------------|---------------------------------------------------------------------------------|
| 1       | 220 KV        | HT          | BOISAR BORIVALI                          | 24-Jul-18 | 13.18     |           | Continued. | To Control Line Loading(H/T from Boisar end)                                    |
| 2       | 220 KV        | PO          | Mudshingi Chikodi                        | 24-Sep-19 | 17.12     |           | Continued. | No Schedule.                                                                    |
| 3       | 220 KV        | PO          | Talandage - Chikodi                      | 01-Oct-19 | 17.1      |           | Continued. | No Schedule.                                                                    |
| 4       | 220 KV        | PO          | Badnera-Akola I                          | 16-Oct-19 | 8.07      | 23-Oct-19 | 12.55      | Erection Of inline 220Kv Towers.                                                |
| 5       | 220 KV        | PO          | Badnera-Akola li                         | 16-Oct-19 | 8.07      | 23-Oct-19 | 12.56      | Erection Of inline 220Kv Towers.                                                |
| 6       | 220 KV        | Tripped     | Nanded - Parli Ext. Ckt II               | 21-Oct-19 | 7.5       | 21-Oct-19 | 13.48      | Distance Protection                                                             |
| 7       | 220 KV        | PO          | Trombay - Kalwa                          | 21-Oct-19 | 20.04     | 22-Oct-19 | 7.36       | Construction work                                                               |
| 8       | 220 KV        | PO          | Khaparkheda-Butibori 3                   | 22-Oct-19 | 8.4       | 22-Oct-19 | 15.41      | SSN To DSN Conversion.                                                          |
| 9       | 220 KV        | PO          | Kalmeshwar-Pandhurna                     | 22-Oct-19 | 10        | 22-Oct-19 | 14.07      | Work At Pandhurna End.                                                          |
| 10      | 220 KV        | PO          | Wardha Butibori-III                      | 22-Oct-19 | 10.39     | 22-Oct-19 | 14.59      | Repairing of Earthwire At LOC No.9 & 10.                                        |
| 11      | 220 KV        | PO          | Arey - TPC Borivali                      | 22-Oct-19 | 11.02     | 22-Oct-19 | 21.2       | Replacement of CT.                                                              |
| 12      | 220 KV        | Tripped     | 220kv Halkarni- Tillary                  | 22-Oct-19 | 11.5      | 22-Oct-19 | 17.55      | Earthwire Stringing Distance Protection Y-Ph 18.13Km LOC No.281 Y-Ph Insulator. |
| 13      | 220 KV        | PO          | Halkarni-Mahalaxmi line                  |           | 11.58     | 22-Oct-19 | 17.45      | Earthwire Stringing.                                                            |
| 14      | 220 KV        | Tripped     | 220kv Halkarni- Tillary                  | 22-Oct-19 | 17.55     | 22-Oct-19 | 21.57      | Y-Ph Insulator Flash Over At LOC No.281.                                        |
| 15      | 220 KV        | PO          | Trombay - Kalwa                          | 22-Oct-19 | 20.17     | 23-Oct-19 | 7.29       | Tower Piling Work At LOC No.22A.                                                |
| 16      | 220 KV        | Tripped     | Khadka-Chaligaon-2                       | 22-Oct-19 | 1.02      | 23-Oct-19 | 10.13      | Distance Protection                                                             |
| 17      | 220 KV        | PO          | Trombay Dharavi 9                        | 23-Oct-19 | 8.5       | 01-Nov-19 | 14.42      | Erection Of Tower LoC.I No.23                                                   |
| 18      | 220 KV        | PO          | 220/22 Kv 50 Mva Bhel Ptr 1 @Mahad       | 23-Oct-19 | 8.52      | 23-Oct-19 | 19.3       | Cold Welding FR Oil Leakage.                                                    |
| 19      | 220 KV        | PO          | 220kv Halkarni- Tillary                  | 23-Oct-19 | 9.03      | 23-Oct-19 | 17.47      | Earth Wire Replacement.                                                         |
| 20      | 220 KV        | PO          | Halkarni-Mahalaxmi line                  | 23-Oct-19 | 9.05      | 23-Oct-19 | 17.43      | Earth Wire Replacement.                                                         |
| 21      | 220 KV        | PO          | Talandge-Mudshingi Ckt-I                 | 23-Oct-19 | 10.05     | 23-Oct-19 | 12.15      | Line Maintenance work                                                           |
| 22      | 220 KV        | PO          | Butibori - VIPL Ckt I                    | 23-Oct-19 | 10.06     | 23-Oct-19 | 16.21      | For CT Capacitance & Tan Delta & CB CRM & Timing.                               |
| 23      | 220 KV        | PO          | Tembhurni - Jeur                         | 23-Oct-19 | 10.54     | 23-Oct-19 | 13.37      | Routine Maintenance Work                                                        |
| 24      | 220 KV        | PO          | khaparkheda-Khaparkheda(new)-I           | 23-Oct-19 | 11.4      | 23-Oct-19 | 18.23      | Routine Maintenance Work                                                        |
| 25      | 220 KV        | HT          | Dasturi-Kandalgaon Line                  | 23-Oct-19 | 13.15     | 23-Oct-19 | 17.42      | Relay work.                                                                     |
| 26      | 220 KV        | PO          | Padghe - Jindal                          | 23-Oct-19 | 14.3      | 23-Oct-19 | 21.28      | Cheking CT Secondary Wiring Of Bus Bar Core.                                    |
| 27      | 220 KV        | HT          | Trombay MSETCL Tie 1                     | 23-Oct-19 | 14.37     | 23-Oct-19 | 19.14      | For Availing Bus Outage.                                                        |
| 28      | 220 KV        | HT          | Trombay - Mulund                         | 23-Oct-19 | 14.41     | 23-Oct-19 | 19.17      | For Availing Bus Outage.                                                        |
| 29      | 220 KV        | HT          | Loteparshuram- Dasturi Line              | 23-Oct-19 | 17.55     | 23-Oct-19 | 20.31      | Relay work.                                                                     |
| 30      | 220 KV        | PO          | Trombay - Kalwa                          | 23-Oct-19 | 20.02     | 24-Oct-19 | 7.08       | Tower Piling Work At Loc.No.22A.                                                |
| 31      | 220 KV        | Tripped     | Bhambori Amalner                         | 23-Oct-19 | 23.02     | 24-Oct-19 | 7.39       | Distance Protection                                                             |
| 32      | 220 KV        | Tripped     | 220/132 KV 200 MVA ICT - 2 @ CHINCHWAD 2 | 23-Oct-19 | 6.33      | 24-Oct-19 | 22.44      | Differential protection                                                         |
| 33      | 220 KV        | PO          | Raymond - TKES                           | 24-Oct-19 | 8.2       | 24-Oct-19 | 17.4       | Routine Maintenance Work Outages From Consumer End.                             |
| 34      | 220 KV        | PO          | Pophali - Pedambe II                     | 24-Oct-19 | 9.25      | 24-Oct-19 | 9.38       | SF6 Gas Filling Work.                                                           |
| 35      | 220 KV        | PO          | 220/100 kV 200 MVA ICT-II @Kalwa         | 24-Oct-19 | 10.18     | 24-Oct-19 | 13.1       | DC Leakage Attending Work.                                                      |
| 36      | 220 KV        | PO          | Halkarni-Olam(Agro)                      | 24-Oct-19 | 12.2      | 24-Oct-19 | 14.28      | LA Replacement.                                                                 |
| 37      | 220 KV        | PO          | Virur - Virurlytss1                      | 24-Oct-19 | 13.05     | 24-Oct-19 | 15         | ABT Meter Replacement Work.                                                     |
| 38      | 220 KV        | EO          | Khadka-Chaligaon-2                       | 24-Oct-19 | 13.06     | 24-Oct-19 | 14.35      | Attending Hot Spot On Line ISO R PH.                                            |
| 39      | 220 KV        | PO          | Virur - Virur Rly Tss 2                  | 24-Oct-19 | 15.2      | 24-Oct-19 | 16.15      | ABT Meter.                                                                      |
| 40      | 220 KV        | Tripped     | Chandrapur GCR - Sicom II                | 24-Oct-19 | 1.03      | 25-Oct-19 | 1.44       | Due To LTS Operation.                                                           |
| 41      | 220 KV        | Tripped     | Chandrapur GCR - Sicom I                 | 25-Oct-19 | 1.03      | 25-Oct-19 | 1.33       | Due To LTS Operation.                                                           |
| 42      | 220 KV        | Tripped     | Borivali - Tarapur                       | 25-Oct-19 | 4.19      | 25-Oct-19 | 13.46      | Distance Protection                                                             |
| 43      | 220 KV        | PO          | Bus section @ Kalwa                      | 25-Oct-19 | 6.44      | 25-Oct-19 | 10.08      | Due To Outage On ICT.                                                           |
| 44      | 220 KV        | PO          | 220/100 kV 200 MVA ICT II @Padghe        | 25-Oct-19 | 8.26      | 25-Oct-19 | 17.33      | U Bolt Replacement Work.                                                        |
| 45      | 220 KV        | Tripped     | Mahalakshmi Amona                        | 25-Oct-19 | 9.01      | 25-Oct-19 | 9.27       | Tripped At Amona End Only.                                                      |
| 46      | 220 KV        | Tripped     | Tillari Amona                            | 25-Oct-19 | 9.01      | 25-Oct-19 | 9.28       | Tripped At Amona End Only.                                                      |

**List of Transmission line Trippings/Outages for the week 21 October- 2019 to 27 October -2019**

| Sr. No. | Voltage Level | Outage Type | Name                                        | Trip Date | Trip Time | Sync Date | Sync Time  | Reason                                                                       |
|---------|---------------|-------------|---------------------------------------------|-----------|-----------|-----------|------------|------------------------------------------------------------------------------|
| 47      | 220 KV        | PO          | Butibori - Purti                            | 25-Oct-19 | 9.2       | 25-Oct-19 | 14.54      | STN To DTN Conversion At Loc 198 & SSN To DSN Conversion at 200              |
| 48      | 220 KV        | Tripped     | Dahanu Versova                              | 25-Oct-19 | 9.33      | 25-Oct-19 | 16.2       | Distance Protection                                                          |
| 49      | 220 KV        | PO          | Trombay - Mulund                            | 25-Oct-19 | 10.04     | 25-Oct-19 | 18.55      | Line Isolator Alignment Work.                                                |
| 50      | 220 KV        | EO          | 220/22 Kv 50 Mva Areva Ptr 2 @Anandnagar    | 25-Oct-19 | 10.45     | 25-Oct-19 | 11.5       | Hot Spot LV CT.                                                              |
| 51      | 220 KV        | PO          | 220/100 Kv 200 MVA ICT I @Pal-Dombivali     | 25-Oct-19 | 11.24     | 25-Oct-19 | 18.25      | Relay Testing Work.                                                          |
| 52      | 220 KV        | PO          | Butibori - VIPL Ckt I                       | 25-Oct-19 | 12.01     | 25-Oct-19 | 18.09      | Testing Work                                                                 |
| 53      | 220 KV        | PO          | Bableshtar Ahamadnagar-Ii                   | 25-Oct-19 | 14.12     | 25-Oct-19 | 18.4       | Flash Over Disc Replacement.                                                 |
| 54      | 220 KV        | PO          | Trombay - Kalwa                             | 25-Oct-19 | 20.18     | 27-Oct-19 | 8.3        | Piling work at Loc.No.22A                                                    |
| 55      | 220 KV        | Tripped     | Parli(U-VIII) GCR CKT                       | 25-Oct-19 | 2.25      | 26-Oct-19 | 15.45      | Distance Protection                                                          |
| 56      | 220 KV        | Tripped     | Satana-Gangapur                             | 26-Oct-19 | 6.55      | 27-Oct-19 | 15.47      | Distance Protection                                                          |
| 57      | 220 KV        | Tripped     | Nanded - Parli Ext. Ckt II                  | 26-Oct-19 | 7.02      | 26-Oct-19 | 7.2        | Distance Protection                                                          |
| 58      | 220 KV        | HT          | EKLAHARE (OCR) Nasik - Navsari I            | 26-Oct-19 | 17.53     | 01-Nov-19 | 9.54       | Over Voltage                                                                 |
| 59      | 220 KV        | PO          | Ranjangaon-Lonikand                         | 27-Oct-19 | 15.29     |           | Continued. | Tower jumps opened.                                                          |
| 60      | 220 KV        | PO          | Trombay - Kalwa                             | 31-Oct-19 | 21.01     |           | Continued. | Pilling Work At LOC.NO.19                                                    |
| 61      | 400 KV        | PO          | Karad Solapur (PG)                          | 08-Nov-19 | 11:49     |           | Continued. | Line Converted As 220 Kv Solapur (PG)- Jeur From LOC 403                     |
| 62      | 400 KV        | Tripped     | 400/220/33 Kv 315 Mva ICT 1 @Padghe         | 03-May-17 | 10.07     |           | Continued. | Differential Protection Declared Faulty.                                     |
| 63      | 400 KV        | HT          | 400/220/33 Kv 500 Mva Ict 1 @ CHANDRAPUR 2  | 15-Nov-18 | 17.1      |           | Continued. | Due To CVT Porcelain Collars Of The ICT-1 are Damaged.                       |
| 64      | 400 KV        | PO          | Lonikand I - Koyana stage-IV                | 12-Apr-19 | 8.2       | 23-Oct-19 | 15.52      | Relay Retrofitting while charging at 22.10hrs tripped on Distance Protection |
| 65      | 400 KV        | HT          | Khadka-Aurangabad (Waluj)                   | 19-Oct-19 | 19.15     | 26-Oct-19 | 10.02      | Over Voltage                                                                 |
| 66      | 400 KV        | Tripped     | Kolhapur Solapur(PG) I                      | 19-Oct-19 | 21.28     | 21-Oct-19 | 7.16       | Over Voltage                                                                 |
| 67      | 400 KV        | Tripped     | Alkud-Kolhapur(Talandage)                   | 20-Oct-19 | 2.06      | 21-Oct-19 | 6.59       | Over Voltage                                                                 |
| 68      | 400 KV        | Tripped     | Kolhapur Solapur (PG) II                    | 21-Oct-19 | 21.5      | 22-Oct-19 | 9.27       | Over Voltage                                                                 |
| 69      | 400 KV        | HT          | Dhule Khandwa I                             | 21-Oct-19 | 22.06     | 02-Nov-19 | 9.4        | Over Voltage                                                                 |
| 70      | 400 KV        | Tripped     | KolhapurIII-Alkud                           | 21-Oct-19 | 2.55      | 22-Oct-19 | 8.11       | Over Voltage                                                                 |
| 71      | 400 KV        | Tripped     | Kolhapur Solapur(PG) I                      | 22-Oct-19 | 0.27      | 24-Oct-19 | 11.43      | Over Voltage                                                                 |
| 72      | 400 KV        | Tripped     | 400/220kv 315 Mva ICT I @Karad              | 23-Oct-19 | 3.22      | 24-Oct-19 | 10..35     | Differential protection                                                      |
| 73      | 400 KV        | PO          | Chandrapur - Khaperkheda                    | 23-Oct-19 | 9.13      | 23-Oct-19 | 17.03      | Auto Recloser Out.                                                           |
| 74      | 400 KV        | PO          | Akola II - Akola I Ckt-I                    | 23-Oct-19 | 10.18     | 23-Oct-19 | 18.48      | Routine Maintenance Work                                                     |
| 75      | 400 KV        | PO          | 400/220kv 500MVA ICT-1 @ TAPTITANDA         | 23-Oct-19 | 13.06     | 23-Oct-19 | 14.37      | HOT Line 71 Deg Celcius.                                                     |
| 76      | 400 KV        | PO          | Padgha - Boisar (PG)                        | 23-Oct-19 | 14.25     | 24-Oct-19 | 15.27      | Line Reactor Work.                                                           |
| 77      | 400 KV        | HT          | Lonikand I - Koyana stage-IV                | 24-Oct-19 | 23.34     | 25-Oct-19 | 12.16      | Over Voltage                                                                 |
| 78      | 400 KV        | Tripped     | Kolhapur Solapur (PG) II                    | 24-Oct-19 | 23.54     | 26-Oct-19 | 13.02      | Over Voltage                                                                 |
| 79      | 400 KV        | Tripped     | Chandrapur Bhadravati II                    | 24-Oct-19 | 1.03      | 25-Oct-19 | 8.36       | Bus-1 LBB Operated.                                                          |
| 80      | 400 KV        | Tripped     | Main Bus I @ Chandrapur Sw                  | 25-Oct-19 | 1.03      | 25-Oct-19 | 2.55       | LBB Operated.                                                                |
| 81      | 400 KV        | Tripped     | Chandrapur II - Chandrapur ckt 2            | 25-Oct-19 | 1.03      | 25-Oct-19 | 7.24       | Tripped With Bus -1 LBB Operated.                                            |
| 82      | 400 KV        | Tripped     | Chandrapur - Khaperkheda                    | 25-Oct-19 | 1.03      | 25-Oct-19 | 7.13       | Bus-1 LBB Operated.                                                          |
| 83      | 400 KV        | Tripped     | Chandrapur Bhadravati III                   | 25-Oct-19 | 1.03      | 25-Oct-19 | 8.43       | Bus-1 LBB Operated.                                                          |
| 84      | 400 KV        | Tripped     | Bus Coupler @ Chandrapur                    | 25-Oct-19 | 1.03      | 25-Oct-19 | 2.55       | Bus-1 LBB Operated.                                                          |
| 85      | 400 KV        | Tripped     | 400/220/33 kv 315 MVA ICT-I @Chandrapur GCR | 25-Oct-19 | 1.03      | 25-Oct-19 | 3.05       | Bus-1 LBB Operated.                                                          |
| 86      | 400 KV        | Tripped     | 400/11.5 kv 90MVA STN T/F-IV @ Chandrapur   | 25-Oct-19 | 1.03      | 25-Oct-19 | 9.48       | Tripped With Bus-1 LBB Operated Taken In Service.                            |

**List of Transmission line Trippings/Outages for the week 21 October- 2019 to 27 October -2019**

| Sr. No. | Voltage Level | Outage Type | Name                                      | Trip Date | Trip Time | Sync Date | Sync Time  | Reason                                                                  |
|---------|---------------|-------------|-------------------------------------------|-----------|-----------|-----------|------------|-------------------------------------------------------------------------|
| 87      | 400 KV        | Tripped     | Chandrapur-II - Nanded ckt II             | 25-Oct-19 | 3.15      | 04-Nov-19 | 7.04       | Over Voltage                                                            |
| 88      | 400 KV        | PO          | 400/220 Kv 600 MVA ICT-II @Kalwa          | 25-Oct-19 | 6.44      | 25-Oct-19 | 9.52       | Investigation Of Buchholz tripping/maloperation.                        |
| 89      | 400 KV        | PO          | 400/11.5 kV 90MVA STN T/F-IV @ Chandrapur | 25-Oct-19 | 10.04     | 25-Oct-19 | 18.55      | Generation End Breaker Tripped Due To Relay Problem.Charged Trough TBC. |
| 90      | 400 KV        | EO          | TBC @ Babhaleshwar                        | 25-Oct-19 | 12.4      | 25-Oct-19 | 13.47      | Attending Hot Spot On Line Work By Hot Line.                            |
| 91      | 400 KV        | HT          | Lonikand I - Koyna stage-IV               | 25-Oct-19 | 23.04     | 26-Oct-19 | 9.39       | Over Voltage                                                            |
| 92      | 400 KV        | Tripped     | Chandrapur - Parli                        | 25-Oct-19 | 5.58      | 04-Nov-19 | 6.43       | Distance Protection (RFC from 26.10.2019 23:14Hrs).                     |
| 93      | 400 KV        | PO          | 400/220 kV 500 MVA ICT III @ Jejuri       | 26-Oct-19 | 9.53      | 26-Oct-19 | 14.31      | Annual Maintenance Work                                                 |
| 94      | 400 KV        | EO          | Khadka- Deepnagar Ckt 2                   | 26-Oct-19 | 10.1      | 26-Oct-19 | 14.38      | Testing of Y Phase CVT                                                  |
| 95      | 400 KV        | HT          | Khadka-Aurangabad (Waluj)                 | 26-Oct-19 | 14.55     | 02-Nov-19 | 11.28      | Over Voltage                                                            |
| 96      | 400 KV        | HT          | karad -kolhapur-II                        | 26-Oct-19 | 22.52     | 02-Nov-19 | 11.05      | Over Voltage                                                            |
| 97      | 400 KV        | HT          | Lonikand I - Koyna stage-IV               | 26-Oct-19 | 23.01     | 30-Oct-19 | 9.35       | Over Voltage                                                            |
| 98      | 400 KV        | HT          | Chandrapur Bhadravati I                   | 26-Oct-19 | 14.03     | 31-Oct-19 | 18.43      | Over Voltage                                                            |
| 99      | 400 KV        | HT          | Dhule- Bableshwar - I                     | 27-Oct-19 | 14.05     | 30-Oct-19 | 9.31       | Over Voltage                                                            |
| 100     | 400 KV        | HT          | Akola II - RPL(Rattanindia) Ckt I         | 27-Oct-19 | 14.07     |           | Continued. | Over Voltage                                                            |
| 101     | 400 KV        | HT          | 400/220KV 500MVA ICT-I @Nanded            | 27-Oct-19 | 15.28     | 27-Oct-19 | 17.33      | Smoke observed from R phase of earth pit                                |
| 102     | 400 KV        | HT          | Karad-Jaigad - I                          | 27-Oct-19 | 21.58     |           | Continued. | Over Voltage                                                            |
| 103     | 400 KV        | HT          | Dhule Sar'Sarovar II                      | 06-Nov-19 | 19.22     |           | Continued. | Over Voltage                                                            |
| 104     | 400 KV        | HT          | Bhusawal-Aurangabad                       | 07-Nov-19 | 19.58     |           | Continued. | Over Voltage                                                            |
| 105     | 400 KV        | HT          | Lonikand I - Koyna stage-IV               | 08-Nov-19 | 0.04      |           | Continued. | Over Voltage                                                            |
| 106     | 500 KV        | Tripped     | Chandrapur - Padghe Hvdc Pole 2           | 11-Nov-19 | 1.03      | 25-Oct-19 | 4.12       | Bus-1 LBB Operated Taken In Service.                                    |