

State Load Despatch Center,Airoli (MSETCL)
Power System Position from 20/Nov/2017 to 26/Nov/2017

Supply Position During Morning Peak (MW)

Date	Time	MSGENCO				Central Sector Receipt	Wind	CPP	SOLAR	TPCL Exch.	MSEDCL Catered Demand	Load Shedding(LS)	MSEDCL Demand (Incl. LS)	TPCL Gen.	R-INFRA Gen.	State Demand Met	State Demand (Incl. LS)	Freq.
		THM	HYDRO	GAS	Total													
		MW	MW	MW	MW	MW	MW	MW	MW	MW	MW	MW	MW	MW	MW	MW	MW	Hzs
20/11/2017	12 Hrs	5270	437	444	6151	7430	226	4807	378	-1262	17730	0	17730	1096	502	20590	20590	49.96
21/11/2017	12 Hrs	5184	585	431	6200	8190	192	4559	389	-1437	18093	0	18093	1109	502	21141	21141	49.95
22/11/2017	12 Hrs	5094	902	418	6414	8158	79	4558	344	-1477	18076	0	18076	1105	502	21160	21160	49.96
23/11/2017	12 Hrs	5276	195	420	5891	8192	92	4505	460	-1324	17816	0	17816	1132	503	20775	20775	50.01
24/11/2017	12 Hrs	5241	269	415	5925	7790	87	4315	497	-1264	17350	0	17350	1131	503	20248	20248	49.97
25/11/2017	12 Hrs	5164	427	423	6014	7572	189	4473	474	-1175	17546	0	17546	988	488	20197	20197	49.94
26/11/2017	12 Hrs	5123	226	418	5767	7836	253	4581	505	-1191	17751	0	17751	740	222	19904	19904	49.95
Maximum		5276	902	444	6414	8192	253	4807	505	-1175	18093	0	18093	1132	503	21160	21160	50.01
Minimum		5094	195	415	5767	7430	79	4315	344	-1477	17350	0	17350	740	222	19904	19904	49.94
Average		5193	434	424	6052	7881	160	4543	435	-1304	17766	0	17766	1043	460	20574	20574	49.96

Supply Position During Day Peak (MW)

Date	Time	MSGENCO				Central Sector Receipt	Wind	CPP	SOLAR	TPCL Exch.	MSEDCL Catered Demand	Load Shedding(LS)	MSEDCL Demand (Incl. LS)	TPCL Gen.	R-INFRA Gen.	State Demand Met	State Demand (Incl. LS)	Freq.
		THM	HYDRO	GAS	Total													
		MW	MW	MW	MW	MW	MW	MW	MW	MW	MW	MW	MW	MW	MW	MW	MW	Hzs
20/11/2017	15 Hrs	5283	557	420	6260	7651	110	4847	210	-1175	17903	0	17903	1114	504	20696	20696	49.92
21/11/2017	16 Hrs	5189	773	414	6376	7856	160	4836	135	-1297	18066	0	18066	1128	502	20994	20994	49.89
22/11/2017	15 Hrs	5090	338	412	5840	8752	88	4467	311	-1365	18093	0	18093	1095	502	21055	21055	49.97
23/11/2017	15 Hrs	5181	213	409	5803	8268	149	4273	345	-1205	17633	0	17633	1131	504	20473	20473	49.91
24/11/2017	13 Hrs	5192	125	434	5751	8096	137	4249	496	-1219	17510	0	17510	1129	503	20361	20361	50.00
25/11/2017	13 Hrs	5254	109	415	5778	7839	108	4433	478	-1033	17603	0	17603	1110	502	20248	20248	49.94
26/11/2017	13 Hrs	5090	270	417	5777	7801	185	4611	505	-1256	17623	0	17623	619	251	19749	19749	50.01
Maximum		5283	773	434	6376	8752	185	4847	505	-1033	18093	0	18093	1131	504	21055	21055	50.01
Minimum		5090	109	409	5751	7651	88	4249	135	-1365	17510	0	17510	619	251	19749	19749	49.89
Average		5183	341	417	5941	8038	134	4531	354	-1221	17776	0	17776	1047	467	20511	20511	49.95

Supply Position During Evening Peak (MW)

Date	Time	MSGENCO				Central Sector Receipt	Wind	CPP	SOLAR	TPCL Exch.	MSEDCL Cateder Demand	Load Shedding(LS)	MSEDCL Demand (Incl. LS)	TPCL Gen.	R-INFRA Gen.	State Demand Met	State Demand (Incl. LS)	Freq.
		THM	HYDRO	GAS	Total													
		MW	MW	MW	MW	MW	MW	MW	MW	MW	MW	MW	MW	MW	MW	MW	MW	Hzs
20/11/2017	19 Hrs	5270	836	437	6543	5861	275	4850	0	-1231	16298	0	16298	1119	501	19149	19149	49.98
21/11/2017	19 Hrs	5167	916	425	6508	6013	48	4895	0	-1287	16177	0	16177	1102	504	19070	19070	49.99
22/11/2017	19 Hrs	5111	338	421	5870	6530	176	4628	0	-1262	15942	0	15942	1106	502	18812	18812	49.99
23/11/2017	19 Hrs	5218	690	425	6333	6428	94	4489	0	-1183	16161	0	16161	1129	502	18975	18975	50.00
24/11/2017	19 Hrs	5006	353	428	5787	5940	312	4477	0	-1140	15376	0	15376	1118	504	18138	18138	50.01
25/11/2017	19 Hrs	4960	680	448	6088	6172	148	4708	0	-1153	15963	0	15963	951	502	18569	18569	50.02
26/11/2017	19 Hrs	5081	236	437	5754	6395	247	3937	0	-1141	15192	0	15192	804	277	17414	17414	50.02
Maximum		5270	916	448	6543	6530	312	4895	0	-1140	16298	0	16298	1129	504	19149	19149	50.02
Minimum		4960	236	421	5754	5861	48	3937	0	-1287	15192	0	15192	804	277	17414	17414	49.98
Average		5116	578	432	6126	6191	186	4569	0	-1200	15873	0	15873	1047	470	18590	18590	50.00

Supply Position During Night Off Peak (MW)

Date	Time	MSGENCO				Central Sector Receipt	Wind	CPP	SOLAR	TPCL Exch.	MSEDCL Cateder Demand	Load Shedding(LS)	MSEDCL Demand (Incl. LS)	TPCL Gen.	R-INFRA Gen.	State Demand Met	State Demand (Incl. LS)	Freq.
		THM	HYDRO	GAS	Total													
		MW	MW	MW	MW	MW	MW	MW	MW	MW	MW	MW	MW	MW	MW	MW	MW	Hzs
20/11/2017	1 Hrs	4543	82	442	5067	5335	77	3303	0	-970	12812	0	12812	497	376	14655	14655	49.99
21/11/2017	1 Hrs	4627	121	433	5181	4826	183	3755	0	-1131	12814	0	12814	497	375	14817	14817	50.00
22/11/2017	24 Hrs	4502	126	425	5053	5322	208	3755	0	-1309	13029	0	13029	500	376	15214	15214	49.99
23/11/2017	24 Hrs	4395	118	445	4958	5274	167	3737	0	-1203	12933	0	12933	488	376	15000	15000	49.97
24/11/2017	24 Hrs	4462	122	447	5031	4765	382	3592	0	-1203	12567	0	12567	493	375	14638	14638	50.01
25/11/2017	1 Hrs	4483	92	437	5012	4585	362	3573	0	-1041	12491	0	12491	485	376	14393	14393	50.01
26/11/2017	24 Hrs	4270	108	449	4827	4584	258	3611	0	-1152	12128	0	12128	501	376	14157	14157	50.05
Maximum		4627	126	449	5181	5335	382	3755	0	-970	13029	0	13029	501	376	15214	15214	50.05
Minimum		4270	82	425	4827	4584	77	3303	0	-1309	12128	0	12128	485	375	14157	14157	49.97
Average		4469	110	440	5018	4956	234	3618	0	-1144	12682	0	12682	494	376	14696	14696	50.00

Details of Supply Position (MUs)

Date	MSGENCO				Pench (MS)	Central Sector Receipt	Central Sector Share	WIND	CPP	SOLAR	TPCL Gen.	R-INFRA Gen.	TPCL Exch.	Energy Requirement		
	THM	HYDRO	GAS	Total										MSEDCL	MUMBAI	STATE
	Mus	Mus	Mus	Mus	Mus	Mus	Mus	Mus	Mus	Mus	Mus	Mus	Mus	Mus	Mus	Mus
20/11/2017	122.960	7.292	10.466	140.718	0.019	149.453	146.608	4.409	102.856	2.131	19.470	10.553	-26.650	372.917	56.673	429.590
21/11/2017	121.126	8.900	10.343	140.369	0.016	154.736	152.225	3.608	106.716	2.461	19.442	10.597	-28.856	379.034	58.895	437.929
22/11/2017	119.346	7.608	10.292	137.246	0.025	159.244	158.340	3.021	104.678	2.670	19.564	10.861	-28.774	378.085	59.199	437.284
23/11/2017	120.811	4.854	10.370	136.035	0.030	158.925	157.243	3.085	100.531	3.017	19.750	10.800	-26.661	374.902	57.211	432.113
24/11/2017	117.805	4.331	10.479	132.615	0.027	151.917	151.779	5.746	98.879	3.330	19.262	10.815	-25.787	366.700	55.862	422.562
25/11/2017	117.176	5.050	10.458	132.684	0.059	147.539	147.119	5.627	101.742	3.233	17.835	10.425	-24.545	366.280	52.805	419.085
26/11/2017	113.526	4.164	10.404	128.094	0.039	153.248	151.700	6.823	96.680	3.359	13.738	7.178	-26.071	362.133	46.987	409.120
Maximum	122.960	8.900	10.479	140.718	0.059	159.244	158.340	122.960	106.716	3.359	19.750	10.861	-24.545	379.034	59.199	437.929
Minimum	113.526	4.164	10.292	128.094	0.016	147.539	146.608	113.526	96.680	2.131	13.738	7.178	-28.856	362.133	46.987	409.120
Average	118.964	6.028	10.402	135.394	0.031	153.580	152.145	118.964	101.726	2.886	18.437	10.176	-26.763	371.436	55.376	426.812

Details of Koyna Water Consumption (in TMC)

Date	For the Day	For the Month	Balance
20/11/2017	0.118	3.051	44.603
21/11/2017	0.137	3.188	44.466
22/11/2017	0.102	3.290	44.364
23/11/2017	0.043	3.333	44.321
24/11/2017	0.041	3.374	44.280
25/11/2017	0.066	3.440	44.214
26/11/2017	0.042	3.482	44.172

State Load Despatch Center, Airoli (MSETCL)
Central Sector Share/Drawal from 20/Nov/2017 to 26/Nov/2017

Date	DAY	Central Sector Share		Total Interstate Bilateral Purchase		Total Share		Total Drawal		Overdrawal(+) / UnderDrawal(-)	
		MUs	Avg. MW	MUs	Avg. MW	MUs	Avg. MW	MUs	Avg. MW	MUs	Avg. MW
		1		2		1+2=3		4		3-4=5	
20/11/2017	MONDAY	106.008	6068	40.600	1692	146.608	6109	149.453	6227	2.845	119
21/11/2017	TUESDAY	106.402	6297	45.823	1909	152.225	6343	154.736	6447	2.511	105
22/11/2017	WEDNESDA	109.626	6549	48.714	2030	158.340	6598	159.244	6635	0.904	38
23/11/2017	THURSDAY	107.536	6502	49.707	2071	157.243	6552	158.925	6622	1.682	70
24/11/2017	FRIDAY	102.461	6275	49.318	2055	151.779	6324	151.917	6330	0.138	6
25/11/2017	SATURDAY	100.224	6083	46.895	1954	147.119	6130	147.539	6147	0.420	18
26/11/2017	SUNDAY	106.452	6276	45.248	1885	151.700	6321	153.248	6385	1.548	65
Total		738.709		326.305		1065.014		1075.062		10.048	

GENERATING UNITS OUTAGES FOR THE WEEK FROM 20/11/2017 TO 26/11/2017							
Generator	Generating Unit	Capacity	Tripped Date	Tripped Time	Synch. Date	Synch Time	Reason
PLANNED OUTAGES							
IPP	Tata Trombay 6	500MW	15/Jul/2015	17.08		Continued.	Economic shutdown(Converted to AOH for 30 Days from 00.00Hrs 06-03-2016)
CS	Tarapur 1	160MW	04/Jun/2017	19.09		Continued.	3 months outage for refuelling.
MSPGCL	Chandrapur Unit 5	500MW	01/Nov/2017	09.20		Continued.	Annual Overhaul
IPP	Trombay 8	250MW	18/Nov/2017	19.40		Continued.	Annual Overhaul
FORCED OUTAGES							
RGPL	Dabhol Dabhol 1B	230MW	28/May/2013	22:02		Continued.	Gas Shortage.
RGPL	Dabhol Dabhol 1X	230MW	27/Jun/2013	21.46		Continued.	Gas Shortage
RGPL	Dabhol Dabhol 1A	230MW	27/Jun/2013	21.47		Continued.	Gas Shortage
MSPGCL	Koradi Unit 6	210MW	20/Mar/2015	01.02		Continued.	EE R&M LE Work
IPP	SWPGL U-1	135MW	16/Feb/2016	17.09		Continued.	Change Over , No Schedule
IPP	SWPGL U-2	135MW	29/Feb/2016	21.46		Continued.	Change over against Unit III
MSPGCL	Parli Unit 4	210MW	01/Apr/2016	00.00		Continued.	Economic shutdown
MSPGCL	Parli Unit 5	210MW	01/Apr/2016	00.00		Continued.	Economic shutdown
MSPGCL	Bhusawal Unit 2	210MW	14/Jun/2016	19.35		Continued.	Boiler Tube Leakage(Converted to Zero Shedule By MSEDC. from 00.00Hrs dt.19-6-16)
MSPGCL	Uran Unit 8	108MW	14/Aug/2016	07.56		Continued.	Maintenance work
RGPL	Dabhol 2A	230MW	24/Aug/2016	13.31		Continued.	Change Over.
MSPGCL	Koradi Unit 5	200MW	05/Sep/2016	00.21		Continued.	ID Fan problem, Converted to Zero Schedule By MSEDC. from 00.00hrs/22-9-16. Shutdown taken on 18.10.2016 at 00:00Hrs for Turbine inspection and maintenance work
IPP	PGPL U1	262MW	07/Feb/2017	17.30		Continued.	No Schedule
IPP	PGPL U2	126MW	07/Feb/2017	17.30		Continued.	No Schedule
MSPGCL	Ghatghar Unit-2	125MW	28/Jul/2017	00.00		Continued.	due to common pressure shaft with unit 1.
IPP	SWPGL U-3	135MW	26/Aug/2017	17.40	20/Nov/2017	01.52	Boiler Tube Leakage
MSPGCL	Khaparkheda Unit 3	210MW	12/Sep/2017	00.00		Continued.	Coal Shortage
IPP	RPL(AMT) U-5	270MW	17/Sep/2017	02.01		Continued.	Coal Shortage
IPP	RPL(AMT) U-3	270MW	17/Sep/2017	00.02		Continued.	Coal Shortage
MSPGCL	Chandrapur Unit 3	210MW	25/Oct/2017	00.45	26/Nov/2017	23.54	Boiler tube leakage. Continued due to shortage of water from dt.01/11/17 0:00 hrs
IPP	Dhariwal	300MW	27/Oct/2017	17.31		Continued.	Drum level Not Maintained
MSPGCL	Chandrapur Unit 4	210MW	29/Oct/2017	04.45	26/Nov/2017	19.20	Auxiliary supply failure. Continued due to water shortage from dt. 01/11/17 0:00 hrs.
MSPGCL	Bhusawal Unit 3	210MW	31/Oct/2017	22.37		Continued.	Coal Shortage
MSPGCL	Koradi Unit 7	210MW	01/Nov/2017	00.05	26/Nov/2017	16.36	Poor Coal Receipt.
IPP	SWPGL U-4	135MW	01/Nov/2017	00.02	22/Nov/2017	00.17	Boiler Tube Leakage
MSPGCL	Koradi Unit-8	660MW	07/Nov/2017	00.06		Continued.	poor coal receipt.
IPP	RPL(AMT) U-2	270MW	10/Nov/2017	00.00		Continued.	Coal Shortage
IPP	Adani U-1	660MW	10/Nov/2017	02.29	20/Nov/2017	06.08	Coal Shortage
MSPGCL	Ghatghar Unit-1	125MW	13/Nov/2017	19.45	21/Nov/2017	21.00	COMPRESSER PROBLEM.
MSPGCL	Nasik Unit 5	210MW	16/Nov/2017	04.45		Continued.	Flame Failure, withdrawn due to coal shortage since 20.11.2017 at 11:00Hrs
IPP	Adani U-3	660MW	17/Nov/2017	20.59		Continued.	Tripped on APS Bellow Leakage
MSPGCL	Khaparkheda Unit 1	210MW	18/Nov/2017	19.19		Continued.	Coal Shortage
MSPGCL	Chandrapur Unit 7	500MW	18/Nov/2017	00.43	20/Nov/2017	03.07	pressure parts leakage.
IPP	Adani U-5	660MW	19/Nov/2017	20.40		Continued.	Due to heavy leakage in seal air duct.
MSPGCL	Parli Unit 7	250MW	20/Nov/2017	21.00	25/Nov/2017	07.32	Coal Shortage
IPP	SWPGL U-3	135MW	20/Nov/2017	07.35	20/Nov/2017	08.36	Coal mill problem
MSPGCL	Khaparkheda Unit 2	210MW	20/Nov/2017	12.14		Continued.	Coal Shortage
IPP	IEPL Unit 1	270MW	21/Nov/2017	09.26	21/Nov/2017	13.09	ID Fan Problem
IPP	IEPL Unit 1	270MW	22/Nov/2017	23.50		Continued.	Electrical fault
IPP	JSW (J) U3	300MW	22/Nov/2017	08.58	22/Nov/2017	16.09	electrical fault
MSPGCL	Khaparkheda Unit 4	210MW	23/Nov/2017	19.56	24/Nov/2017	00.16	Furnace Pressure High
IPP	SWPGL U-3	135MW	23/Nov/2017	00.00	24/Nov/2017	11.19	Zero schedule
MSPGCL	Parli Unit 8	250MW	24/Nov/2017	12.50	27/Nov/2017	12.45	Boiler Tube Leakage
MSPGCL	Ghatghar Unit-1	125MW	24/Nov/2017	10.00	26/Nov/2017	11.55	Governor Compressor Repairing work
MSPGCL	Khaparkheda Unit 4	210MW	25/Nov/2017	19.19		Continued.	CHP coal feeding problem
MSPGCL	Chandrapur Unit 7	500MW	25/Nov/2017	14.00		Continued.	Air heater problem
IPP	REL Unit 2	250MW	25/Nov/2017	06:53	26/Nov/2017	18.27	Oil Leakage Attend Work Of GT

LINE OUTAGES AND RIPPING FOR THE WEEK FROM 20/11/2017 TO 26/11/2017

Voltage	Name of Line	Tripping Date	Tripping Time	Synch Date	Synch Time	Reason
400 KV	Karad -Solapur (PG)	03/May/2017	11:49		Continued.	Line converted as 220 kV Solapur (PG)- Jeur from LOC 403
400 KV	Ektuni-Bableshtar ckt I	17/Nov/2017	21.55	20/Nov/2017	15.49	Over Voltage
400 KV	Karad - Jaigad - II	18/Nov/2017	17.44	21/Nov/2017	09.00	Over Voltage
400 KV	karad -kolhapur-I	18/Nov/2017	20.07	21/Nov/2017	08.50	Over Voltage
400 KV	Dhule Sar'Sarovar I	19/Nov/2017	18.03	20/Nov/2017	06.30	Over Voltage
400 KV	Khadka-Aurangabad (Waluj)	19/Nov/2017	18.03	20/Nov/2017	06.22	Over Voltage
400 KV	Lonikand I - Koyna stage-IV	20/Nov/2017	00.04	20/Nov/2017	06.08	Over Voltage
400 KV	Alkud-Kolhapur(Talandage)	20/Nov/2017	11.54	21/Nov/2017	08.42	Quarterly Maintenance Work
400 KV	Ektuni-Bableshtar ckt II	20/Nov/2017	16.02	22/Nov/2017	11.32	Attending Hot Spot
400 KV	Khadka-Aurangabad (Waluj)	20/Nov/2017	18.47	21/Nov/2017	06.12	Over Voltage
400 KV	Dhule Sar'Sarovar I	20/Nov/2017	19.07	21/Nov/2017	06.29	Over Voltage
400 KV	Lonikand I - Koyna stage-IV	20/Nov/2017	23.59	21/Nov/2017	06.08	Over Voltage
400 KV	Kolhapur Solapur(PG) I	21/Nov/2017	09.11	21/Nov/2017	18.11	Quarterly Maintenance Work
400 KV	Wardha (Pg) Warora I	21/Nov/2017	09.28	21/Nov/2017	18.34	Routine Maintenance Work
400 KV	Wardha (PG)-Warora II	21/Nov/2017	09.29	21/Nov/2017	18.55	Routine Maintenance Work
400 KV	Ektuni-Bableshtar ckt II	21/Nov/2017	11.15	22/Nov/2017	11.32	Routine Maintenance Work
400 KV	Karad-Jaigad - I	21/Nov/2017	18.06	22/Nov/2017	10.44	Over Voltage
400 KV	karad -kolhapur-II	21/Nov/2017	18.15	22/Nov/2017	10.27	Over Voltage
400 KV	Khadka-Aurangabad (Waluj)	21/Nov/2017	18.19	22/Nov/2017	08.34	Over Voltage
400 KV	Dhule Sar'Sarovar II	21/Nov/2017	19.05	22/Nov/2017	10.26	Over Voltage
400 KV	Pune(GIS)-A'bad(Waluj) Ckt 2	22/Nov/2017	09.32	22/Nov/2017	10.39	hand Tripped for load relief
400 KV	Chandrapur II- Warora ckt II	22/Nov/2017	10.57	22/Nov/2017	14.33	Diagnostic testing work
400 KV	Nagthane - Dabhol-II	22/Nov/2017	12.57	22/Nov/2017	19.51	Tree cutting work
400 KV	Dhule Sar'Sarovar II	22/Nov/2017	18.05	23/Nov/2017	10.35	Over Voltage
400 KV	Karad - Jaigad - II	22/Nov/2017	18.14	23/Nov/2017	10.47	Over Voltage
400 KV	Bhusawal-Aurangabad	22/Nov/2017	18.19	23/Nov/2017	07.22	Over Voltage
400 KV	karad -kolhapur-I	22/Nov/2017	18.20	23/Nov/2017	10.55	Over Voltage
400 KV	Lonikand I - Koyna stage-IV	23/Nov/2017	00.19	23/Nov/2017	07.19	Over Voltage
400 KV	Lonikand I - Talegaon(Pgcl)	23/Nov/2017	17.26	23/Nov/2017	19.51	EMERGENCY OUTAGE BY WRDLC
400 KV	karad -kolhapur-II	23/Nov/2017	18.02	27/Nov/2017	10.39	Over Voltage
400 KV	Karad-Jaigad - I	23/Nov/2017	18.03		Continued.	Over Voltage
400 KV	Dhule Sar'Sarovar II	23/Nov/2017	18.09	24/Nov/2017	11.00	Over Voltage
400 KV	Khadka-Aurangabad (Waluj)	23/Nov/2017	18.13	24/Nov/2017	10.51	Over Voltage
400 KV	Bhusawal-Aurangabad	24/Nov/2017	18.24	26/Nov/2017	11.24	Over Voltage
400 KV	Dhule Sar'Sarovar I	25/Nov/2017	09.19	27/Nov/2017	06.26	LOC no.95 Y PH string repl work.
400 KV	Ektuni-Bableshtar ckt I	26/Nov/2017	00.26	26/Nov/2017	06.28	Over Voltage
400 KV	Padghe - Kalwa-II	26/Nov/2017	12.58	26/Nov/2017	17.32	Distance Protection
400 KV	Khadka-Aurangabad (Waluj)	26/Nov/2017	17.38	27/Nov/2017	06.20	Over Voltage
400 KV	Lonikand I - Koyna stage-IV	26/Nov/2017	20.28	27/Nov/2017	06.11	Over Voltage
400 KV	karad -kolhapur-II	27/Nov/2017	17.52		Continued.	Over Voltage
400 KV	Dhule Sar'Sarovar I	28/Nov/2017	17.38		Continued.	Over Voltage
220 KV	Chandrapur GCR - Warora - I	05/Apr/2015	09.13		Continued.	Bunching of conductor Loc no 86 Disconnecting of jumper at Loc no 86 & 107 and de-energising the line bet.86 to 107.
220 KV	Chandrapur GCR - Wani	05/Apr/2015	09.15		Continued.	Bunching of conductor Loc no 86 Disconnecting of jumper at Loc no 86 & 107 and de-energising the line bet.86 to 107.
220 KV	Talandage - Chikodi	01/Jun/2017	00.01		Continued.	NO SCHEDULE.
220 KV	Mudshingi - Chikodi	01/Jun/2017	00.06		Continued.	NO SCHEDULE.
220 KV	Kharghar-Borivali ckt II	07/Jun/2017	12.23		Continued.	Distance Protection RY phase fault.
220 KV	Pedambe-Nerle	23/Sep/2017	00.50		Continued.	B Phase CT Burst at Pedambe End
220 KV	Mumewadi -Halkarni II	17/Nov/2017	10.00		Continued.	Tower erection work (temporarily line would be Mumewadi-Tillari)
220 KV	Halkarni - Tillari II	17/Nov/2017	12.25		Continued.	Tower erection work. (temporarily line would be Mumewadi-Tillari)
220 KV	Osmanabad - Solapur (Bale)	19/Nov/2017	14.35	26/Nov/2017	20.26	for partly ict o/l.
220 KV	Purti-Bhugaon	20/Nov/2017	02.05	20/Nov/2017	03.17	Distance Protection
220 KV	Mahalakshmi Amona	20/Nov/2017	05.30	20/Nov/2017	07.16	Over Voltage
220 KV	Tillari Amona	20/Nov/2017	05.30	20/Nov/2017	06.56	Over Voltage
220 KV	Nigade- Peth Line	20/Nov/2017	10.00	20/Nov/2017	17.00	Testing Work
220 KV	Bhugaon- Wardha	20/Nov/2017	10.01	20/Nov/2017	11.49	Measurment of stackwise ir values of la.
220 KV	Butibori - VIPL Ckt I	20/Nov/2017	10.04	20/Nov/2017	17.36	Attending Hot Spot
220 KV	Niwali - Pawas Line	20/Nov/2017	10.14	20/Nov/2017	16.45	Routine Maintenance Work
220 KV	New Koyna - Loteparshuram	20/Nov/2017	10.45	20/Nov/2017	16.00	Attending Hot Spot
220 KV	Gadchandur - Virur-I	20/Nov/2017	12.40	20/Nov/2017	16.46	relay Replacement work.
220 KV	Kandalgaon - Koyna	20/Nov/2017	16.28	20/Nov/2017	20.20	Distance Protection
220 KV	Pophali - New Koyna	20/Nov/2017	16.28	20/Nov/2017	19.57	Distance Protection
220 KV	Karad - Kadegaon	21/Nov/2017	09.54	21/Nov/2017	17.55	Testing Work
220 KV	Talandge-Hamidwada	21/Nov/2017	09.54	21/Nov/2017	17.38	insulator cleaning work.
220 KV	Bhugaon- Wardha	21/Nov/2017	14.56	21/Nov/2017	15.38	Attending Hot Spot
220 KV	Parli 3 (Oldgr)-Harangul Ckt I	21/Nov/2017	18.07	21/Nov/2017	18.20	Attending Hot Spot
220 KV	Bhugaon-WardhaPG (Deoli)	22/Nov/2017	07.49	22/Nov/2017	17.14	Taken on TBC
220 KV	Uran - Kharghar 2	22/Nov/2017	08.38	24/Nov/2017	17.34	Line Maintenance work
220 KV	Talandge-Hamidwada	22/Nov/2017	09.00	22/Nov/2017	17.23	Insulator cleaning Work
220 KV	Solapur(PG)- Jeur	22/Nov/2017	09.46	22/Nov/2017	18.40	Insulator Replacement Work
220 KV	Mahad - Pedambe	22/Nov/2017	13.55	22/Nov/2017	15.21	Attending Oil Leakage
220 KV	Dhamangaon New - Badnera	23/Nov/2017	09.02	23/Nov/2017	18.57	REPL. OF R Y B PH CTS
220 KV	Mudshingi-Belewadi	23/Nov/2017	09.05	23/Nov/2017	17.24	Insulator Cleaning.
220 KV	Theur-Phursungi	23/Nov/2017	09.44	23/Nov/2017	15.50	Half yearly maintenance work
220 KV	Centuri Enka- Bhosari	23/Nov/2017	10.01	23/Nov/2017	18.23	CT LEAKAGE ATTENDING.
220 KV	Talandage(400kv) - Five Star Midc	23/Nov/2017	10.08	23/Nov/2017	17.47	INSULATOR CLEANING
220 KV	Chinchwad-Hinjewadi I	23/Nov/2017	10.11	23/Nov/2017	16.42	HT FOR LOAD MANAGEMENT.
220 KV	Lonand-Baramati	23/Nov/2017	11.05	23/Nov/2017	14.38	REPLACEMENT OF FLASHOVER STRING.
220 KV	Urse - Talegaon (Ambi) Ckt 1	23/Nov/2017	11.20	23/Nov/2017	16.30	DIAGNOSTIC TESTING.

Voltage	Name of Line	Tripping Date	Tripping Time	Synch Date	Synch Time	Reason
220 KV	Bhugaon- Wardha	23/Nov/2017	15.00	23/Nov/2017	16.08	Y PH CT HOT SPOT ATTENDING WORK
220 KV	Padegaon-Sawangi	23/Nov/2017	18.22	23/Nov/2017	18.37	DISTANCE PROTECTION OPERATED ZONE 1
220 KV	Mudshingi-Belewadi	24/Nov/2017	08.54	24/Nov/2017	17.24	Insulator Cleaning
220 KV	Pedhambe - Oni	24/Nov/2017	12.56	24/Nov/2017	13.18	Distance Protection
220 KV	chandrapur-Tadali	24/Nov/2017	14.53	24/Nov/2017	18.14	Tan Delta Measurment of CTs
220 KV	Mahalakshmi Amona	25/Nov/2017	04.03	25/Nov/2017	09.20	Trip on on high voltage.
220 KV	Kalwa - Colourchem	25/Nov/2017	09.15	25/Nov/2017	20.03	Isolator maintenance work.
220 KV	Talandage(kolh'r)- Sawantwadi II	25/Nov/2017	09.24	27/Nov/2017	13.38	RMW,while charging line at 17.49 HRS , it tripped on D P.
220 KV	Ghodbunder - Gorai	25/Nov/2017	09.45	25/Nov/2017	14.14	Replacement of bugs and connector of insulator.
220 KV	Washala - Ghatghar	25/Nov/2017	10.30	25/Nov/2017	16.25	Routine Maintenance Work
220 KV	Hinjawadi I- Chinchwad	25/Nov/2017	11.06	25/Nov/2017	17.11	For load control at user end.
220 KV	Boisar Versova Line	25/Nov/2017	12.27	25/Nov/2017	12.51	Routine Maintenance Work
220 KV	Urse - Talegaon (Ambi) Ckt 1	25/Nov/2017	14.01	25/Nov/2017	16.38	For isolator problem attending.
220 KV	Trombay - Mulund	26/Nov/2017	08.05	26/Nov/2017	17.24	Routine Maintenance Work & Isolator maintenance work.
220 KV	Uran - Kharghar I	26/Nov/2017	08.55		Continued.	Line maintenance work.
220 KV	Deepnagar Amalner	27/Nov/2017	17.27		Continued.	Distance Protection Operated Zone 1 R PH 50.75KM 7.2KA.
132 KV	Dhule(220kv)-Dondaicha(132 Kv)	20/Nov/2017	14.16	20/Nov/2017	15.42	e/w removing work.
132 KV	Yawal - Chopda	21/Nov/2017	21.00	21/Nov/2017	21.12	Distance Protection
132 KV	Amalner(220kv)-Chopda	24/Nov/2017	02.41	24/Nov/2017	03.10	Distance Protection
132 KV	Bhoom - Kharda	24/Nov/2017	12.35	24/Nov/2017	12.42	Over Current Protection
132 KV	Bhoom - Kharda	24/Nov/2017	13.11	24/Nov/2017	13.18	Over Current Protection
132 KV	Padegaon - Sillod	24/Nov/2017	19.57	24/Nov/2017	20.16	Distance Protection
132 KV	Main Bus I @ Parbhani	26/Nov/2017	16.52	26/Nov/2017	17.11	lbb relay opted of 132kv bus b-ph ct burst of 132kv parbhani ckt 2 at 132kv parbhani s/s.
132 KV	Parbhani - Parbhani I	26/Nov/2017	16.52	26/Nov/2017	18.55	LBB OPTD of parbhani CKT 1& hence busbar OPTD.
132 KV	Parbhani-Gangakhed	26/Nov/2017	16.52	26/Nov/2017	17.15	Distance Protection
132 KV	Parbhani-Purna	26/Nov/2017	16.52	26/Nov/2017	17.16	LBB OPTD of parbhani CKT 1& hence busbar OPTD.
132 KV	Bageshwari-Parbhani	26/Nov/2017	16.52	26/Nov/2017	17.16	LBB OPTD of parbhani CKT 1& hence busbar OPTD.