

State Load Despatch Center,Airoli (MSETCL)
Power System Position from 21/Dec/2015 to 27/Dec/2015

Supply Position During Morning Peak (MW)

Date	Time	MSGENCO				Central Sector Receipt	Wind	CPP	SOLAR	TPCL Exch.	MSEDCL Catered Demand	Load Shedding(LS)	MSEDCL Demand (Incl. LS)	TPCL Gen.	R-INFRA Gen.	State Demand Met	State Demand (Incl. LS)	Freq.
		THM	HYDRO	GAS	Total													
		MW	MW	MW	MW	MW	MW	MW	MW	MW	MW	MW	MW	MW	MW	MW	MW	Hzs
21/12/2015	12 Hrs	6203	579	424	7206	4465	106	5412	169	-1023	16335	15	16350	1255	405	19018	19033	49.87
22/12/2015	11 Hrs	6063	200	448	6711	4783	115	5375	155	-1026	16113	15	16128	1089	405	18633	18648	49.92
23/12/2015	11 Hrs	5586	440	305	6331	4636	73	5610	145	-914	15881	15	15896	1126	406	18327	18342	49.91
24/12/2015	11 Hrs	5331	846	322	6499	4891	286	4800	142	-734	15884	11	15895	1157	406	18181	18192	49.91
25/12/2015	10 Hrs	5537	572	310	6419	3861	790	4054	122	-768	14478	14	14492	731	405	16382	16396	49.95
26/12/2015	12 Hrs	5509	567	438	6514	4536	343	4292	176	-705	15156	16	15172	1040	404	17305	17321	49.99
27/12/2015	12 Hrs	5548	684	280	6512	4391	508	4253	163	-666	15161	15	15176	756	405	16988	17003	49.93
Maximum		6203	846	448	7206	4891	790	5610	176	-666	16335	16	16350	1255	406	19018	19033	49.99
Minimum		5331	200	280	6331	3861	73	4054	122	-1026	14478	11	14492	731	404	16382	16396	49.87
Average		5682	555	361	6599	4509	317	4828	153	-834	15572	14	15587	1022	405	17833	17848	49.93

Supply Position During Day Peak (MW)

Date	Time	MSGENCO				Central Sector Receipt	Wind	CPP	SOLAR	TPCL Exch.	MSEDCL Catered Demand	Load Shedding(LS)	MSEDCL Demand (Incl. LS)	TPCL Gen.	R-INFRA Gen.	State Demand Met	State Demand (Incl. LS)	Freq.
		THM	HYDRO	GAS	Total													
		MW	MW	MW	MW	MW	MW	MW	MW	MW	MW	MW	MW	MW	MW	MW	MW	Hzs
21/12/2015	13 Hrs	6152	495	434	7081	3928	139	5380	169	-1015	15682	15	15697	1224	405	18326	18341	49.91
22/12/2015		5615	199	335	6149	4706	167	5305	184	-1199	15312	29	15341	936	405	17852	17881	49.89
23/12/2015		5593	134	298	6025	4281	39	5561	175	-993	15088	15	15103	1035	406	17522	17537	49.91
24/12/2015		5296	610	292	6198	4528	137	4798	164	-781	15044	11	15055	1094	406	17325	17336	49.89
25/12/2015		5687	160	296	6143	4021	376	4224	199	-859	14104	14	14118	788	408	16159	16173	49.92
26/12/2015		5503	564	428	6495	4187	245	4249	178	-822	14532	16	14548	916	403	16673	16689	50.01
27/12/2015		5539	446	278	6263	4031	415	4234	194	-700	14437	15	14452	699	406	16242	16257	49.92
Maximum		6152	610	434	7081	4706	415	5561	199	-700	15682	29	15697	1224	408	18326	18341	50.01
Minimum		5296	134	278	6025	3928	39	4224	164	-1199	14104	11	14118	699	403	16159	16173	49.89
Average		5626	373	337	6336	4240	217	4821	180	-910	14885	16	14902	956	406	17157	17173	49.92

Supply Position During Evening Peak (MW)

Date	Time	MSGENCO				Central Sector Receipt	Wind	CPP	SOLAR	TPCL Exch.	MSEDCL Catered Demand	Load Shedding(LS)	MSEDCL Demand (Incl. LS)	TPCL Gen.	R-INFRA Gen.	State Demand Met	State Demand (Incl. LS)	Freq.
		THM	HYDRO	GAS	Total													
		MW	MW	MW	MW	MW	MW	MW	MW	MW	MW	MW	MW	MW	MW	MW	MW	Hzs
21/12/2015	19 Hrs	5668	177	432	6277	3887	623	4684	0	-1244	14227	12	14239	894	404	16769	16781	49.89
22/12/2015	20 Hrs	5243	184	310	5737	4552	171	4932	0	-1110	14282	10	14292	895	408	16695	16705	49.93
23/12/2015	19 Hrs	5300	654	302	6256	4264	92	4876	0	-1193	14295	9	14304	834	405	16727	16736	49.93
24/12/2015	19 Hrs	5455	798	308	6561	2961	348	4826	1	-1092	13605	12	13617	809	405	15911	15923	49.97
25/12/2015	19 Hrs	5674	177	453	6304	3247	219	4265	0	-961	13074	13	13087	742	404	15181	15194	49.99
26/12/2015	19 Hrs	5554	427	441	6422	3918	332	4255	0	-1036	13891	12	13903	761	404	16092	16104	50.00
27/12/2015	19 Hrs	5307	296	284	5887	3220	526	4276	0	-739	13170	12	13182	740	404	15053	15065	49.95
Maximum		5674	798	453	6561	4552	623	4932	1	-739	14295	13	14304	895	408	16769	16781	50.00
Minimum		5243	177	284	5737	2961	92	4255	0	-1244	13074	9	13087	740	404	15053	15065	49.89
Average		5457	388	361	6206	3721	330	4588	0	-1054	13792	11	13803	811	405	16061	16072	49.95

Supply Position During Night Off Peak (MW)

Date	Time	MSGENCO				Central Sector Receipt	Wind	CPP	SOLAR	TPCL Exch.	MSEDCL Catered Demand	Load Shedding(LS)	MSEDCL Demand (Incl. LS)	TPCL Gen.	R-INFRA Gen.	State Demand Met	State Demand (Incl. LS)	Freq.
		THM	HYDRO	GAS	Total													
		MW	MW	MW	MW	MW	MW	MW	MW	MW	MW	MW	MW	MW	MW	MW	MW	Hzs
21/12/2015	3 Hrs	5426	119	455	6000	2152	203	4440	0	-477	12318	11	12329	620	404	13819	13830	49.99
22/12/2015	4 Hrs	4914	255	465	5634	2314	271	4378	0	-387	12210	11	12221	626	407	13630	13641	49.76
23/12/2015	4 Hrs	5274	105	319	5698	1744	193	4755	0	-279	12111	11	12122	610	407	13407	13418	49.95
24/12/2015	24 Hrs	5167	99	312	5578	1258	803	4297	0	-514	11422	12	11434	701	405	13042	13054	49.98
25/12/2015	24 Hrs	5608	122	455	6185	39	714	4234	0	-583	10589	13	10602	652	402	12226	12239	50.05
26/12/2015	5 Hrs	5524	111	475	6110	-454	802	4235	0	-163	10530	12	10542	652	407	11752	11764	49.99
27/12/2015	3 Hrs	5548	92	307	5947	-243	970	4274	0	-214	10734	11	10745	651	403	12002	12013	49.98
Maximum		5608	255	475	6185	2314	970	4755	0	-163	12318	13	12329	701	407	13819	13830	50.05
Minimum		4914	92	307	5578	-454	193	4234	0	-583	10530	11	10542	610	402	11752	11764	49.76
Average		5352	129	398	5879	973	565	4373	0	-374	11416	12	11428	645	405	12840	12851	49.96

Details of Supply Position (MUs)

Date	MSGENCO				Pench (MS)	Central Sector Receipt	Central Sector Share	WIND	CPP	SOLAR	TPCL Gen.	R-INFRA Gen.	TPCL Exch.	Energy Requirement		
	THM	HYDRO	GAS	Total										MSEDCL	MUMBAI	STATE
	Mus	Mus	Mus	Mus	Mus	Mus	Mus	Mus	Mus	Mus	Mus	Mus	Mus	Mus	Mus	Mus
21/12/2015	137.263	6.942	10.651	154.856	0.343	83.311	86.049	7.367	115.378	1.117	20.543	9.746	-20.844	341.189	51.132	392.321
22/12/2015	128.000	6.680	9.137	143.817	0.332	90.488	92.061	4.939	116.425	1.208	19.570	9.747	-19.804	337.073	49.123	386.196
23/12/2015	128.707	5.884	7.501	142.092	0.241	86.786	88.858	3.097	120.804	1.149	18.926	9.743	-19.067	334.861	47.736	382.597
24/12/2015	127.016	9.383	7.416	143.815	0.080	76.820	82.329	7.519	113.173	1.177	19.631	9.728	-15.510	326.994	44.869	371.863
25/12/2015	131.976	5.650	8.549	146.175	0.299	56.363	65.038	13.578	101.565	1.203	16.928	9.715	-15.533	303.351	42.176	345.527
26/12/2015	133.419	7.063	10.469	150.951	0.294	55.987	68.235	13.334	102.232	1.212	17.957	9.705	-15.046	308.670	42.708	351.378
27/12/2015	119.809	6.970	6.960	133.739	0.164	52.198	58.805	19.005	101.778	1.243	16.477	9.681	-12.507	295.456	38.664	334.120
Maximum	137.263	9.383	10.651	154.856	0.343	90.488	92.061	137.263	120.804	1.243	20.543	9.747	-12.507	341.189	51.132	392.321
Minimum	119.809	5.650	6.960	133.739	0.080	52.198	58.805	119.809	101.565	1.117	16.477	9.681	-20.844	295.456	38.664	334.120
Average	129.456	6.939	8.669	145.064	0.250	71.708	77.339	129.456	110.194	1.187	18.576	9.724	-16.902	321.085	45.201	366.286

Details of Koyna Water Consumption (in TMC)

Date	For the Day	For the Month	Balance
21/12/2015	0.105	1.891	39.195
22/12/2015	0.079	1.970	39.116
23/12/2015	0.065	2.035	39.051
24/12/2015	0.102	2.137	38.949
25/12/2015	0.065	2.202	38.884
26/12/2015	0.071	2.273	38.813
27/12/2015	0.079	2.352	38.734

State Load Despatch Center, Airoli (MSETCL)
Central Sector Share/Drawal from 21/Dec/2015 to 27/Dec/2015

Date	DAY	Central Sector Share		Total Interstate Bilateral Purchase		Total Share		Total Drawal		Overdrawal(+) / UnderDrawal(-)	
		MUs	Avg. MW	MUs	Avg. MW	MUs	Avg. MW	MUs	Avg. MW	MUs	Avg. MW
		1		2		1+2=3		4		3-4=5	
21/12/2015	MONDAY	79.621	3579	6.428	268	86.049	3585	83.311	3471	-2.738	-114
22/12/2015	TUESDAY	79.896	3824	12.165	507	92.061	3836	90.488	3770	-1.573	-66
23/12/2015	WEDNESDA	80.526	3694	8.332	347	88.858	3702	86.786	3616	-2.072	-86
24/12/2015	THURSDAY	75.495	3424	6.834	285	82.329	3430	76.820	3201	-5.509	-230
25/12/2015	FRIDAY	64.622	2710	0.416	17	65.038	2710	56.363	2348	-8.675	-361
26/12/2015	SATURDAY	69.738	2845	-1.503	-63	68.235	2843	55.987	2333	-12.248	-510
27/12/2015	SUNDAY	61.144	2453	-2.339	-97	58.805	2450	52.198	2175	-6.607	-275
Total		511.042		30.333		541.375		501.953		-39.422	

GENERATING UNITS OUTAGES FOR THE WEEK FROM 21/12/2015 TO 27/12/2015							
Generator	Generating Unit	Capacity	Tripped Date	Tripped Time	Synch. Date	Synch Time	Reason
PLANNED OUTAGES							
Cent_Sect	Tarapur 2	160MW	10/Sep/2015	12.55		Continued.	Refuelling work
MSPGCL	Koyana Unit 7	80MW	18/Dec/2015	08:25	24/Dec/2015	19.45	for attending lower guide bearing cooler leakage work
FORCED OUTAGES							
RGPPL	Dabhol Dabhol 1B	230MW	28/May/2013	22:02		Continued.	Gas Shortage.
RGPPL	Dabhol Dabhol 2A	230MW	06/Jun/2013	09.10		Continued.	Gas Shortage
RGPPL	Dabhol Dabhol 3A	230MW	06/Jun/2013	08.28		Continued.	Gas Shortage
RGPPL	Dabhol Dabhol 1A	230MW	27/Jun/2013	21.47		Continued.	Gas Shortage
RGPPL	Dabhol Dabhol 1X	230MW	27/Jun/2013	21.46		Continued.	Gas Shortage
RGPPL	Dabhol Dabhol 2X	230MW	15/Jul/2013	15.09		Continued.	Gas Shortage
RGPPL	Dabhol Dabhol 2B	230MW	08/Aug/2013	15.03		Continued.	Gas Shortage
IPP	Dhariwal	300MW	28/May/2014	02.27		Continued.	No schedule
MSPGCL	Chandrapur Unit 1	210MW	28/Aug/2014	07:15		Continued.	Economic Shutdown.
MSPGCL	Koradi Unit 6	210MW	20/Mar/2015	01.02		Continued.	Economic shutdown
MSPGCL	Uran Unit 7	108MW	17/Apr/2015	00.07		Continued.	Gas turbine problem
MSPGCL	Parli Unit 3	210MW	14/Jun/2015	12.58		Continued.	Water Shortage
IPP	WPCL U-2	135MW	16/Jun/2015	00.00		Continued.	No Schdule
MSPGCL	Parli Unit 6	250MW	25/Jun/2015	15.03		Continued.	Water Shortage
MSPGCL	Parli Unit 4	210MW	05/Jul/2015	18.45		Continued.	Water Shortage
MSPGCL	Parli Unit 5	210MW	06/Jul/2015	14.55		Continued.	Water Shortage.
MSPGCL	Parli Unit 7	250MW	08/Jul/2015	12.08		Continued.	Water Shortage
IPP	Tata Trombay 6	500MW	15/Jul/2015	17.08		Continued.	Economic shutdown
IPP	WPCL U-1	135MW	23/Oct/2015	17.31		Continued.	ESP filter problem
MSPGCL	Chandrapur Unit-8	500MW	10/Nov/2015	12.10		Continued.	Drum level low
IPP	Adani U-4	660MW	14/Dec/2015	06.55		Continued.	Hot air line leakage
MSPGCL	Khaparkheda Unit 3	210MW	19/Dec/2015	19.08	21/Dec/2015	08.49	Boiler Tube Leakage
MSPGCL	Bhusawal Unit 2	210MW	20/Dec/2015	21.49	21/Dec/2015	00.31	Drum level High
IPP	RPL(AMT) U-5	270MW	20/Dec/2015	09.17	22/Dec/2015	17.45	P.A.Fan Problem
IPP	RPL(AMT) U-4	270MW	20/Dec/2015	20.55	22/Dec/2015	15.05	ID Fan Problem
MSPGCL	Chandrapur Unit-5	500MW	21/Dec/2015	23.47	22/Dec/2015	05.15	condenser pressure high
MSPGCL	Uran Unit 8	108MW	22/Dec/2015	12.58	25/Dec/2015	12.26	Gas shortage
MSPGCL	Chandrapur Unit-6	500MW	22/Dec/2015	00.45	22/Dec/2015	05.41	CCW Pump Failed
MSPGCL	Uran Unit B0	120MW	22/Dec/2015	12.54	25/Dec/2015	16.50	Gas shortage
MSPGCL	Khaparkheda Unit 5	500MW	22/Dec/2015	12.14	25/Dec/2015	04.05	Boiler Tube Leakage
IPP	JSW (J) U3	300MW	23/Dec/2015	13.18		Continued.	Economic shutdown
IPP	Adani U-5	660MW	24/Dec/2015	17.40	28/Dec/2015	06.34	Leakage in HRH Line
IPP	RPL(AMT) U-5	270MW	25/Dec/2015	08.39	25/Dec/2015	09.58	Flame Failure
MSPGCL	Khaparkheda Unit 2	210MW	26/Dec/2015	10.36	26/Dec/2015	17.57	Air heater problem
MSPGCL	Uran Unit 6	108MW	26/Dec/2015	22.16		Continued.	Gas shortage
MSPGCL	Chandrapur Unit-5	500MW	27/Dec/2015	18.50		Continued.	Capital Overhaul.

LINE OUTAGES FOR THE WEEK FROM 21/12/2015 TO 27/12/2015

Voltage	Name of Line	Tripping Date	Tripping Time	Synch Date	Synch Time	Reason
400 KV	Akola II - Taptitanda ckt-II	06/Oct/2015	09.44	22/Dec/2015	12.13	For Controlling Line Loading.
400 KV	Kolhapur Solapur(PG) I	17/Dec/2015	07.43	22/Dec/2015	08.57	Line Rectification Work.
400 KV	Kolhapur Solapur (PG) II	17/Dec/2015	08.15	22/Dec/2015	09.28	Line Rectification Work.
400 KV	Babhaleshwar-Taptitanda ckt-I	19/Dec/2015	07.28		Continued.	Over Voltage (RFC 17.58 Hrs)
400 KV	Karad-Jaigad - I	20/Dec/2015	16.13	21/Dec/2015	08.55	Over Voltage
400 KV	Bhusawal-Aurangabad	20/Dec/2015	16.51	21/Dec/2015	08.53	Over Voltage
400 KV	Lonikand I - Koyna stage-IV	20/Dec/2015	17.13	21/Dec/2015	08.41	Over Voltage
400 KV	Dhule Sar'Sarovar I	20/Dec/2015	17.38	21/Dec/2015	06.41	Over Voltage
400 KV	Kalwa - Kharghar	21/Dec/2015	06.05	21/Dec/2015	12.59	Anticorrosiv painting work
400 KV	Karad Solapur (PG)	21/Dec/2015	16.16	22/Dec/2015	07.33	Attending Hot Spot
400 KV	Bhusawal-Aurangabad	21/Dec/2015	17.07	22/Dec/2015	09.04	Over Voltage
400 KV	Lonikand I - Koyna stage-IV	21/Dec/2015	17.09	22/Dec/2015	07.44	Over Voltage
400 KV	Dhule Sar'Sarovar I	21/Dec/2015	18.04	22/Dec/2015	07.02	Over Voltage
400 KV	Kalwa - Kharghar	22/Dec/2015	06.03	22/Dec/2015	09.56	paint of tower work
400 KV	karad -kolhapur-II	22/Dec/2015	06.45	22/Dec/2015	08.54	Over Voltage
400 KV	N.Koyna-Karad -Ckt I	22/Dec/2015	09.40	23/Dec/2015	09.23	R M Work (RFC 19.44)
400 KV	Babhaleshwar-Taptitanda ckt-I	22/Dec/2015	12.14	22/Dec/2015	17.20	line rectification work
400 KV	Akola II - Taptitanda ckt-I	22/Dec/2015	12.15		Continued.	change over & availed outage(RFC 17.20Hrs)
400 KV	karad -kolhapur-II	22/Dec/2015	16.36	23/Dec/2015	09.02	Over Voltage
400 KV	Karad - Jaigad - II	22/Dec/2015	16.59	23/Dec/2015	09.31	Over Voltage
400 KV	Bhusawal-Aurangabad	22/Dec/2015	17.02	23/Dec/2015	06.45	Over Voltage
400 KV	Dhule Sar'Sarovar I	22/Dec/2015	17.24	23/Dec/2015	06.49	Over Voltage
400 KV	Lonikand I - Koyna stage-IV	22/Dec/2015	20.41	23/Dec/2015	08.50	Over Voltage
400 KV	Kolhapur Solapur (PG) II	22/Dec/2015	21.27	23/Dec/2015	06.44	Over Voltage
400 KV	Kalwa - Kharghar	23/Dec/2015	06.16	23/Dec/2015	09.42	Cross Arm Painting work
400 KV	Padghe - Nagothane - II	23/Dec/2015	09.46	24/Dec/2015	07.44	Insulator repl.work(RFC 19.45Hrs)
400 KV	Chandrapur2-Parali 2 ckt1	23/Dec/2015	12.21	23/Dec/2015	12.54	To out Reactor
400 KV	karad -kolhapur-I	23/Dec/2015	16.11	24/Dec/2015	08.55	Over Voltage
400 KV	Karad-Jaigad - I	23/Dec/2015	16.21	24/Dec/2015	09.03	Over Voltage
400 KV	Bhusawal-Aurangabad	23/Dec/2015	17.04	24/Dec/2015	08.00	Over Voltage
400 KV	Dhule Sar'Sarovar I	23/Dec/2015	18.05	24/Dec/2015	07.59	Over Voltage
400 KV	Lonikand I - Koyna stage-IV	23/Dec/2015	21.27	24/Dec/2015	08.44	Over Voltage
400 KV	Kolhapur Solapur(PG) I	23/Dec/2015	21.55	24/Dec/2015	07.34	Over Voltage
400 KV	Koradi Bhilai	24/Dec/2015	03.20	24/Dec/2015	04.29	Distance Protection
400 KV	Dabhol Nagothane II	24/Dec/2015	03.30	24/Dec/2015	09.57	Over Voltage
400 KV	Karad Solapur (PG)	24/Dec/2015	06.13	24/Dec/2015	09.49	Distance Protection
400 KV	Padghe - Nagothane - I	24/Dec/2015	08.55	25/Dec/2015	09.42	Insulator repl.work(RFC 18.30Hrs)
400 KV	Main Bus-I @ Koradi-II	24/Dec/2015	13.20	24/Dec/2015	20.43	Dropper connection work
400 KV	karad -kolhapur-II	24/Dec/2015	15.57		Continued.	Over Voltage
400 KV	Karad - Jaigad - II	24/Dec/2015	16.04		Continued.	Over Voltage
400 KV	Lonikand I - Koyna stage-IV	24/Dec/2015	16.28	26/Dec/2015	10.17	Distance Protection (RFC 19.19Hrs Dt.25-12-2015)
400 KV	Dhule Sar'Sarovar I	24/Dec/2015	16.47	26/Dec/2015	07.37	Over Voltage
400 KV	Bhusawal-Aurangabad	24/Dec/2015	17.14	25/Dec/2015	08.40	Over Voltage
400 KV	Kolhapur Solapur (PG) II	24/Dec/2015	20.36	25/Dec/2015	09.02	Over Voltage
400 KV	Dhule- Bableshwar - I	25/Dec/2015	00.47	25/Dec/2015	07.32	Over Voltage
400 KV	Dabhol Nagothane II	25/Dec/2015	02.30		Continued.	Over Voltage
400 KV	Babhaleshwar - Padghe-II	25/Dec/2015	08.28	26/Dec/2015	08.00	Insulator repl.work(RFC 20.25Hrs)
400 KV	Kolhapur Solapur(PG) I	25/Dec/2015	16.46	26/Dec/2015	07.10	Over Voltage
400 KV	Bhusawal-Aurangabad	25/Dec/2015	17.03	26/Dec/2015	09.28	Over Voltage
400 KV	Kolhapur Solapur (PG) II	25/Dec/2015	21.45	26/Dec/2015	07.30	Over Voltage
400 KV	Dabhol Nagothane II	26/Dec/2015	13.15	26/Dec/2015	17.50	To attend Hot Spot, Opp.Outage RFC.
400 KV	Kolhapur Solapur (PG) II	26/Dec/2015	17.06	27/Dec/2015	09.41	Over Voltage
400 KV	Lonikand I - Koyna stage-IV	26/Dec/2015	17.08	27/Dec/2015	08.59	Over Voltage
400 KV	Bhusawal-Aurangabad	26/Dec/2015	17.09	27/Dec/2015	08.37	Over Voltage
400 KV	Dhule Sar'Sarovar I	26/Dec/2015	17.09	27/Dec/2015	08.30	Over Voltage
400 KV	Padghe - Nagothane - I	27/Dec/2015	01.58	28/Dec/2015	09.01	Over Voltage
400 KV	Lonikand I - Koyna stage-IV	27/Dec/2015	09.06	28/Dec/2015	10.06	Distance Protection
400 KV	Kolhapur Solapur (PG) II	27/Dec/2015	16.10	28/Dec/2015	09.21	Over Voltage
400 KV	Dhule Sar'Sarovar I	27/Dec/2015	17.02	28/Dec/2015	08.09	Over Voltage
400 KV	Bhusawal-Aurangabad	27/Dec/2015	17.10	28/Dec/2015	07.10	Over Voltage
400 KV	Kolhapur Solapur (PG) II	28/Dec/2015	17.11		Continued.	Over Voltage
400 KV	Dhule Sar'Sarovar I	28/Dec/2015	17.18		Continued.	Over Voltage

Voltage	Name of Line	Tripping Date	Tripping Time	Synch Date	Synch Time	Reason
400 KV	Bhusawal-Aurangabad	28/Dec/2015	17.32		Continued.	Over Voltage
400 KV	Lonikand I - Koyna stage-IV	28/Dec/2015	19.48		Continued.	Over Voltage
220 KV	Chandrapur GCR - Warora - I	05/Apr/2015	09.13		Continued.	pc no 86 Disconnecting of jumer at Loc no 86 & 107 and de-energisi
220 KV	Chandrapur GCR - Wani	05/Apr/2015	09.15		Continued.	pc no 86 Disconnecting of jumer at Loc no 86 & 107 and de-energisi
220 KV	Wadkhal - Ndil3	14/Nov/2015	10.58		Continued.	Strengthening work
220 KV	Boisar(M) - Ghodbunder	16/Dec/2015	08.29		Continued.	Tower Erection and Stringing work
220 KV	Borivali - Tarapur	16/Dec/2015	09.34		Continued.	Tower Erection and Stringing work
220 KV	Wadkhal - Ipci 2	19/Dec/2015	11.00		Continued.	Conductor Replacement Work With High Amacity Conductor.
220 KV	Kharghar - Kalwa	20/Dec/2015	07.21	22/Dec/2015	23.41	Tapping TIFL line on kalwa- khargher
220 KV	Arey - TPC Borivali	20/Dec/2015	08.53	21/Dec/2015	10.20	Replacement of Hydraulic cylinder in Gis
220 KV	Mumewadi -Halkarni II	21/Dec/2015	08.20	21/Dec/2015	18.20	Replacement of Line side Isolator
220 KV	Parvati - Hybrid Pass	21/Dec/2015	08.51	21/Dec/2015	16.40	control urse line load
220 KV	Hinjawadi I- Chinchwad	21/Dec/2015	09.32	21/Dec/2015	16.08	control urse line load
220 KV	Nasik - Raymond	21/Dec/2015	09.37	21/Dec/2015	17.53	Line Maintenance work
220 KV	Nasik Navsari I	21/Dec/2015	12.21	21/Dec/2015	20.56	Line Maintenance work at navsari end
220 KV	Ranjangaon-Lonikand	21/Dec/2015	13.00	21/Dec/2015	23.38	Distance Protection
220 KV	Pophali - Pedambe II	22/Dec/2015	07:30	22/Dec/2015	19:05	Annual Maintenance work of Bus section II at Pophali
220 KV	Bus Section II @ Pophali	22/Dec/2015	07:51	22/Dec/2015	18:50	Annual Maintenance work of Bus Section II
220 KV	Pophali - New Koyna	22/Dec/2015	07:51	22/Dec/2015	18:50	Annual maintenance work of Bus section II at Pophali
220 KV	Pophali - Nerale	22/Dec/2015	07:51	22/Dec/2015	19:50	Annual Maintenance of Bus section II at pophali
220 KV	Nasik Navsari I	22/Dec/2015	08.40	22/Dec/2015	18.36	Testing Work
220 KV	Bhaveghar - Kolshet	22/Dec/2015	11.36	22/Dec/2015	14.08	Commissioning of scada
220 KV	Mahad - Posco	22/Dec/2015	12.55	22/Dec/2015	19.45	Lilo arrangement at kandalgaon
220 KV	Kharghar Trombay	22/Dec/2015	16.43	22/Dec/2015	18.35	Distance Protection
220 KV	Ambazari-Amravati	23/Dec/2015	10.40	23/Dec/2015	18.17	Conversion of SSN to DSN
220 KV	Wadkhal - Ndil 2	23/Dec/2015	10.55		Continued.	Strengthening work
220 KV	Wadkhal - Ipci 1	23/Dec/2015	11.00	23/Dec/2015	11.25	Bus Bar prot.operated at Wadkhal
220 KV	Osmanabad - Solapur (Bale)	23/Dec/2015	12.07	23/Dec/2015	17.00	To attend Hot Spot
220 KV	Parli 3 (Old Gcr)-Osmanabad	23/Dec/2015	12.26	23/Dec/2015	13.09	Distance Protection
220 KV	IPCL - SPCL	23/Dec/2015	13.48	23/Dec/2015	19.38	Attending Oil Leakage
220 KV	Pedambe-Nerle	24/Dec/2015	08.20	24/Dec/2015	16.55	Line Maintenance work
220 KV	Nasik Navsari I	24/Dec/2015	08.51	24/Dec/2015	18.30	Line Maintenance work
220 KV	REL Borivali Aarey Line	24/Dec/2015	14.02	24/Dec/2015	14.30	Distance Protection
220 KV	Waluj- Padegaon li	25/Dec/2015	05.05	25/Dec/2015	05.49	Distance Protection
220 KV	Pedambe-Pophali	25/Dec/2015	08.20	25/Dec/2015	19.05	Repl.of B Phase Breaker Pole
220 KV	Nasik Navsari I	25/Dec/2015	08.27	25/Dec/2015	18.03	Insulator replacement
220 KV	Mudshingi-Wathar	25/Dec/2015	15.44	25/Dec/2015	22.29	Insulator Decapping
220 KV	Trombay Carnac 6	25/Dec/2015	19.19		Continued.	Over Voltage
220 KV	Trombay Carnac 5	25/Dec/2015	19.25	26/Dec/2015	14.35	Over Voltage
220 KV	Nasik Navsari I	26/Dec/2015	08.37	26/Dec/2015	18.49	work at Navsari End.
220 KV	Eklahara(Gcr)(Nasik)- Bableshtar 2	26/Dec/2015	09.37	26/Dec/2015	17.58	To attend Hot Spot
220 KV	Dahanu Ghodbunder Line 1	26/Dec/2015	11.00	26/Dec/2015	17.52	For Repl of CT,CVT & Junction Boxes.
220 KV	Dahanu-Viraj	27/Dec/2015	08.54	27/Dec/2015	12.41	For Replacement of Y Ph string at CT Gantry
132 KV	Amravati-Akola	24/Dec/2015	12.57	24/Dec/2015	13.11	Distance Protection
132 KV	Padegaon Paithan	25/Dec/2015	05.05	25/Dec/2015	05.53	Distance Protection
132 KV	Telgaon - Majalgaon	26/Dec/2015	03.42	26/Dec/2015	04.03	Distance Protection
132 KV	Telgaon - Majalgaon	27/Dec/2015	03:42	27/Dec/2015	04:03	Distance Protection