

State Load Despatch Center,Airoli (MSETCL)
Power System Position from 26/Dec/2016 to 01/Jan/2017

Supply Position During Morning Peak (MW)

Date	Time	MSGENCO				Central Sector Receipt	Wind	CPP	SOLAR	TPCL Exch.	MSEDCL Catered Demand	Load Shedding(LS)	MSEDCL Demand (Incl. LS)	TPCL Gen.	R-INFRA Gen.	State Demand Met	State Demand (Incl. LS)	Freq.
		THM	HYDRO	GAS	Total													
		MW	MW	MW	MW	MW	MW	MW	MW	MW	MW	MW	MW	MW	MW	MW	MW	Hzs
26/12/2016	12 Hrs	5750	1913	434	8097	6522	167	3499	180	-860	17605	0	17605	1285	502	20252	20252	49.91
27/12/2016	11 Hrs	5436	1966	456	7858	6470	262	3576	158	-846	17648	0	17648	1223	507	20224	20224	50.00
28/12/2016	12 Hrs	5932	1667	441	8040	6155	279	3549	180	-915	17521	0	17521	1195	505	20136	20136	49.98
29/12/2016	12 Hrs	5591	2053	430	8074	5838	231	3691	173	-840	17167	412	17579	1241	507	19755	20167	49.98
30/12/2016	12 Hrs	6176	1290	449	7915	6196	105	3501	176	-951	16942	0	16942	1199	509	19601	19601	49.98
31/12/2016	12 Hrs	6394	1544	284	8222	6005	52	3665	173	-880	17468	0	17468	1125	503	19976	19976	49.92
01/01/2017	10 Hrs	6395	843	306	7544	6397	38	3447	98	-362	17162	0	17162	916	510	18950	18950	49.95
Maximum		6395	2053	456	8222	6522	279	3691	180	-362	17648	412	17648	1285	510	20252	20252	50.00
Minimum		5436	843	284	7544	5838	38	3447	98	-951	16942	0	16942	916	502	18950	18950	49.91
Average		5953	1611	400	7964	6226	162	3561	163	-808	17359	59	17418	1169	506	19842	19901	49.96

Supply Position During Day Peak (MW)

Date	Time	MSGENCO				Central Sector Receipt	Wind	CPP	SOLAR	TPCL Exch.	MSEDCL Catered Demand	Load Shedding(LS)	MSEDCL Demand (Incl. LS)	TPCL Gen.	R-INFRA Gen.	State Demand Met	State Demand (Incl. LS)	Freq.
		THM	HYDRO	GAS	Total													
		MW	MW	MW	MW	MW	MW	MW	MW	MW	MW	MW	MW	MW	MW	MW	MW	Hzs
26/12/2016	13 Hrs	5720	1724	435	7879	6570	76	3652	185	-852	17510	0	17510	1213	508	20083	20083	49.95
27/12/2016	14 Hrs	5470	1776	316	7562	6374	106	3618	181	-802	17271	0	17271	1186	510	19769	19769	49.99
28/12/2016	13 Hrs	5863	1289	440	7592	5990	176	3558	187	-848	16887	0	16887	1227	508	19470	19470	49.96
29/12/2016	13 Hrs	5514	1790	425	7729	5634	235	3700	185	-870	16613	477	17090	1167	510	19160	19637	49.96
30/12/2016	13 Hrs	6287	1163	424	7874	5926	93	3511	179	-952	16631	0	16631	1173	510	19266	19266	49.92
31/12/2016	14 Hrs	6332	1206	292	7830	6014	38	3634	173	-741	17181	0	17181	1076	509	19507	19507	49.95
01/01/2017	13 Hrs	6340	874	285	7499	6264	40	3445	182	-482	16948	0	16948	907	509	18846	18846	49.97
Maximum		6340	1790	440	7879	6570	235	3700	187	-482	17510	477	17510	1227	510	20083	20083	49.99
Minimum		5470	874	285	7499	5634	38	3445	173	-952	16613	0	16631	907	508	18846	18846	49.92
Average		5932	1403	374	7709	6110	109	3588	182	-792	17006	68	17074	1136	509	19443	19511	49.96

Supply Position During Evening Peak (MW)

Date	Time	MSGENCO				Central Sector Receipt	Wind	CPP	SOLAR	TPCL Exch.	MSEDCL Cateder Demand	Load Shedding(LS)	MSEDCL Demand (Incl. LS)	TPCL Gen.	R-INFRA Gen.	State Demand Met	State Demand (Incl. LS)	Freq.
		THM	HYDRO	GAS	Total													
		MW	MW	MW	MW	MW	MW	MW	MW	MW	MW	MW	MW	MW	MW	MW	MW	Hzs
26/12/2016	19 Hrs	4643	810	449	5902	5883	211	3568	0	-933	14631	0	14631	1180	386	17130	17130	49.94
27/12/2016	19 Hrs	5053	713	413	6179	5392	306	3574	0	-1021	14614	0	14614	1121	384	17140	17140	49.96
28/12/2016	19 Hrs	5716	273	444	6433	5394	147	3534	0	-1078	14616	0	14616	1069	385	17148	17148	49.97
29/12/2016	19 Hrs	4414	803	436	5653	6039	165	3544	0	-1121	14280	0	14280	984	386	16771	16771	49.98
30/12/2016	19 Hrs	5233	503	434	6170	5229	132	3485	0	-1140	13876	0	13876	1016	386	16418	16418	49.95
31/12/2016	19 Hrs	5241	398	286	5925	5396	109	3557	0	-1011	14159	0	14159	1016	386	16572	16572	49.99
01/01/2017	20 Hrs	5329	565	300	6194	4708	193	3105	0	-941	13259	0	13259	723	385	15308	15308	49.99
Maximum		5716	810	449	6433	6039	306	3574	0	-933	14631	0	14631	1180	386	17148	17148	49.99
Minimum		4414	273	286	5653	4708	109	3105	0	-1140	13259	0	13259	723	384	15308	15308	49.94
Average		5090	581	395	6065	5434	180	3481	0	-1035	14205	0	14205	1016	385	16641	16641	49.97

Supply Position During Night Off Peak (MW)

Date	Time	MSGENCO				Central Sector Receipt	Wind	CPP	SOLAR	TPCL Exch.	MSEDCL Cateder Demand	Load Shedding(LS)	MSEDCL Demand (Incl. LS)	TPCL Gen.	R-INFRA Gen.	State Demand Met	State Demand (Incl. LS)	Freq.
		THM	HYDRO	GAS	Total													
		MW	MW	MW	MW	MW	MW	MW	MW	MW	MW	MW	MW	MW	MW	MW	MW	Hzs
26/12/2016	4 Hrs	4717	115	476	5308	4171	220	2675	0	-333	12041	0	12041	668	388	13430	13430	50.05
27/12/2016	2 Hrs	4839	112	466	5417	3595	529	3167	0	-513	12195	0	12195	629	387	13724	13724	49.99
28/12/2016	24 Hrs	5178	227	471	5876	3214	301	3157	0	-808	11740	0	11740	629	385	13562	13562	49.99
29/12/2016	3 Hrs	5356	115	465	5936	3184	424	3183	0	-414	12313	0	12313	628	386	13741	13741	49.96
30/12/2016	24 Hrs	5245	271	457	5973	3452	67	3113	0	-809	11796	0	11796	674	386	13665	13665	50.02
31/12/2016	23 Hrs	5249	75	304	5628	3440	129	3088	0	-809	11476	0	11476	741	386	13412	13412	49.95
01/01/2017	23 Hrs	5346	80	306	5732	3401	125	3061	0	-821	11498	0	11498	696	386	13401	13401	50.02
Maximum		5356	271	476	5973	4171	529	3183	0	-333	12313	0	12313	741	388	13741	13741	50.05
Minimum		4717	75	304	5308	3184	67	2675	0	-821	11476	0	11476	628	385	13401	13401	49.95
Average		5133	142	421	5696	3494	256	3063	0	-644	11866	0	11866	666	386	13562	13562	50.00

Details of Supply Position (MUs)

Date	MSGENCO				Pench (MS)	Central Sector Receipt	Central Sector Share	WIND	CPP	SOLAR	TPCL Gen.	R-INFRA Gen.	TPCL Exch.	Energy Requirement		
	THM	HYDRO	GAS	Total										MSEDCL	MUMBAI	STATE
	Mus	Mus	Mus	Mus	Mus	Mus	Mus	Mus	Mus	Mus	Mus	Mus	Mus	Mus	Mus	Mus
26/12/2016	123.706	20.348	10.889	154.943	0.321	130.737	130.845	5.339	77.557	1.265	23.013	10.484	-16.836	353.005	50.333	403.338
27/12/2016	125.736	20.989	10.601	157.326	0.106	122.083	122.291	8.287	82.452	1.239	22.251	10.502	-17.787	352.564	50.540	403.104
28/12/2016	131.849	15.438	10.939	158.226	0.278	117.904	119.935	9.003	81.829	1.237	21.860	10.502	-17.716	353.517	50.076	403.593
29/12/2016	122.531	22.827	10.880	156.238	0.478	122.264	126.622	6.318	82.903	1.223	21.593	10.438	-17.731	351.215	49.762	400.977
30/12/2016	131.497	11.383	10.786	153.666	0.720	124.816	128.455	2.815	81.767	1.217	22.170	10.463	-17.994	346.287	50.627	396.914
31/12/2016	137.821	14.242	8.170	160.233	0.679	116.948	119.172	1.979	82.342	1.182	21.472	10.457	-16.598	349.107	48.527	397.634
01/01/2017	137.150	8.991	7.180	153.321	0.343	117.836	117.980	2.228	78.121	1.118	18.761	10.351	-12.965	339.659	42.077	381.736
Maximum	137.821	22.827	10.939	160.233	0.720	130.737	130.845	137.821	82.903	1.265	23.013	10.502	-12.965	353.517	50.627	403.593
Minimum	122.531	8.991	7.180	153.321	0.106	116.948	117.980	122.531	77.557	1.118	18.761	10.351	-17.994	339.659	42.077	381.736
Average	130.041	16.317	9.921	156.279	0.418	121.798	123.614	130.041	80.996	1.212	21.589	10.457	-16.804	349.336	48.849	398.185

Details of Koyna Water Consumption (in TMC)

Date	For the Day	For the Month	Balance
26/12/2016	0.371	9.163	32.505
27/12/2016	0.411	9.574	32.094
28/12/2016	0.283	9.857	31.811
29/12/2016	0.437	10.294	31.374
30/12/2016	0.173	10.467	31.201
31/12/2016	0.251	10.718	30.950
01/01/2017	0.132	0.132	30.818

State Load Despatch Center, Airoli (MSETCL)
Central Sector Share/Drawal from 26/Dec/2016 to 01/Jan/2017

Date	DAY	Central Sector Share		Total Interstate Bilateral Purchase		Total Share		Total Drawal		Overdrawal(+) / UnderDrawal(-)	
		MUs	Avg. MW	MUs	Avg. MW	MUs	Avg. MW	MUs	Avg. MW	MUs	Avg. MW
		1		2		1+2=3		4		3-4=5	
26/12/2016	MONDAY	103.556	5425	27.289	1137	130.845	5452	130.737	5447	-0.108	-4
27/12/2016	TUESDAY	95.500	5069	26.791	1116	122.291	5095	122.083	5087	-0.208	-9
28/12/2016	WEDNESDA	96.647	4974	23.288	970	119.935	4997	117.904	4913	-2.031	-85
29/12/2016	THURSDAY	103.720	5253	22.902	954	126.622	5276	122.264	5094	-4.358	-182
30/12/2016	FRIDAY	103.024	5327	25.431	1060	128.455	5352	124.816	5201	-3.639	-152
31/12/2016	SATURDAY	98.666	4945	20.506	854	119.172	4966	116.948	4873	-2.224	-93
01/01/2017	SUNDAY	98.153	4896	19.827	826	117.980	4916	117.836	4910	-0.144	-6
Total		699.266		166.034		865.300		852.588		-12.712	

GENERATING UNITS OUTAGES FOR THE WEEK FROM 26/12/2016 TO 01/01/2017							
Generator	Generating Unit	Capacity	Tripped Date	Tripped Time	Synch. Date	Synch Time	Reason
PLANNED OUTAGES							
IPP	Tata Trombay 6	500MW	15/Jul/2015	17.08		Continued.	Economic shutdown(Converted to AOH for 30 Days from 00.00Hrs 06-03-2016)
MSPGCL	Paras Unit 3	250MW	25/Oct/2016	08.54		Continued.	Stator Fault, continued under AOH.26/10/2016 00.00hrs
MSPGCL	Koradi Unit-8	660MW	12/Dec/2016	23.59		Continued.	Annual Overhaul
FORCED OUTAGES							
RGPPL	Dabhol Dabhol 1B	230MW	28/May/2013	22.02		Continued.	Gas Shortage.
RGPPL	Dabhol Dabhol 1X	230MW	27/Jun/2013	21.46		Continued.	Gas Shortage
RGPPL	Dabhol Dabhol 1A	230MW	27/Jun/2013	21.47		Continued.	Gas Shortage
IPP	Dhariwal	300MW	28/May/2014	02.27		Continued.	No schedule
MSPGCL	Koradi Unit 6	210MW	20/Mar/2015	01.02		Continued.	EE R&M LE Work
MSPGCL	Parli Unit 4	210MW	05/Jul/2015	18.45		Continued.	Economic shutdown
MSPGCL	Parli Unit 5	210MW	06/Jul/2015	14.55		Continued.	Economic shutdown
IPP	WPCL U-1	135MW	16/Feb/2016	17.09		Continued.	Change Over , No Schedule
IPP	WPCL U-2	135MW	29/Feb/2016	21.46		Continued.	Change over against Unit III
MSPGCL	Bhusawal Unit 2	210MW	14/Jun/2016	19.35		Continued.	Boiler Tube Leakage(Converted to Zero Shedule By MSEDCL. from 00.00Hrs dt.19-6-16)
IPP	RPL(AMT) U-3	270MW	29/Jun/2016	03.01		Continued.	Zero Shedule By MSEDCL.
MSPGCL	Uran Unit 8	108MW	14/Aug/2016	07.56		Continued.	Maintenance work
RGPPL	Dabhol 2A	230MW	24/Aug/2016	13.31		Continued.	Change Over.
MSPGCL	Koradi Unit 5	200MW	05/Sep/2016	00.21		Continued.	ID Fan problem, Converted to Zero Schedule By MSEDCL from 00.00hrs/22-9-16. Shutdown taken on 18.10.2016 at 00:00Hrs for Turbine inspection and maintenance work
MSPGCL	Bhusawal Unit 3	210MW	16/Sep/2016	00.02		Continued.	Zero Schedule by MSEDCL
IPP	Adani U-1	660MW	06/Nov/2016	11.10		Continued.	Coal Shortage
IPP	RPL(AMT) U-5	270MW	15/Nov/2016	20.00		Continued.	Zero schedule
IPP	RPL(AMT) U-2	270MW	16/Nov/2016	22.36		Continued.	Zero Schedule By MSEDCL.
IPP	RPL(AMT) U-4	270MW	16/Nov/2016	21.03		Continued.	Zero Schedule By MSEDCL.
IPP	JSW (J) U1		16/Nov/2016	14.38		Continued.	Due To CW Duct Leakage.
IPP	RPL(AMT) U-1	270MW	17/Nov/2016	17.23		Continued.	Zero Schedule.
MSPGCL	Parli Unit 8	250MW	18/Nov/2016	16.23		Continued.	w/dn for balance work.
IPP	JSW (J) U2	300MW	01/Dec/2016	00.00		Continued.	No Schedule.
MSPGCL	Nasik Unit 3	210MW	11/Dec/2016	16.50		Continued.	Boiler Tube Leakage
MSPGCL	Koradi Unit 7	660MW	19/Dec/2016	21.52		Continued.	Zero Schedule BY MSEDCL
IPP	PGPL U1	262MW	20/Dec/2016	18.30	27/Dec/2016	04.00	No Schedule
IPP	PGPL U2	126MW	20/Dec/2016	18.32	27/Dec/2016	06.07	No Schedule
IPP	Adani U-2	660MW	21/Dec/2016	11.02	26/Dec/2016	10.17	Air preheater problem
MSPGCL	Koradi Unit 10	660MW	22/Dec/2016	13.10	26/Dec/2016	21.42	Main steam line leakage.
MSPGCL	Chandrapur Unit 5	500MW	25/Dec/2016	07.44	26/Dec/2016	22.49	Economizer Tube Leakage.
MSPGCL	Ghatghar Unit-1	125MW	25/Dec/2016	21.00	28/Dec/2016	23.10	Generator Air Cooler Leakage
MSPGCL	Chandrapur Unit-8	500MW	26/Dec/2016	18.31	28/Dec/2016	23.21	Boiler Tube Leakage
IPP	PGPL U1	262MW	27/Dec/2016	19.14	28/Dec/2016	04.00	no schedule.
MSPGCL	Koradi Unit 10	660MW	27/Dec/2016	16.36	27/Dec/2016	20.43	Turbine sealing line leakage.
MSPGCL	Khaparkheda Unit 5	500MW	27/Dec/2016	09.54	27/Dec/2016	14.07	Drum level low
IPP	PGPL U2	126MW	27/Dec/2016	19.15	28/Dec/2016	05.00	no schedule.
MSPGCL	Chandrapur Unit 4	210MW	27/Dec/2016	09.39	30/Dec/2016	06.00	Boiler Tube Leakage
IPP	PGPL U2	126MW	28/Dec/2016	19.18	31/Dec/2016	04.55	No Schedule
IPP	PGPL U1	262MW	28/Dec/2016	19.15	31/Dec/2016	03.59	No Schedule
MSPGCL	Khaparkheda Unit 4	210MW	28/Dec/2016	12.22	29/Dec/2016	21.10	Boiler Tube Leakage
MSPGCL	Chandrapur Unit-8	500MW	29/Dec/2016	04.22	30/Dec/2016	02.51	Electrical fault.
MSPGCL	Koradi Unit 10	660MW	29/Dec/2016	04.54		Continued.	Boiler Tube Leakage
MSPGCL	Chandrapur Unit-8	500MW	30/Dec/2016	02.52	30/Dec/2016	05.30	Tripped in Reverse power
MSPGCL	Uran Unit 6	108MW	31/Dec/2016	06.33	03/Jan/2017	18.44	Gas shortage
IPP	PGPL U1	262MW	31/Dec/2016	19.15	02/Jan/2017	04.00	No Schedule
IPP	PGPL U2	126MW	31/Dec/2016	19.15	02/Jan/2017	04.56	No Schedule

LINE OUTAGES FOR THE WEEK FROM 26/12/2016 TO 01/01/2017

Voltage	Name of Line	Tripping Date	Tripping Time	Synch Date	Synch Time	Reason
400 KV	karad -kolhapur-II	25/Dec/2016	16.32	26/Dec/2016	10.14	Over Voltage
400 KV	Karad-Jaigad - I	25/Dec/2016	16.36	26/Dec/2016	10.17	Over Voltage
400 KV	Bhusawal-Aurangabad	25/Dec/2016	17.16	26/Dec/2016	07.26	Over Voltage
400 KV	Dhule Sar'Sarovar II	25/Dec/2016	17.23	26/Dec/2016	06.29	Over Voltage
400 KV	Lonikand I - Koyna stage-IV	25/Dec/2016	20.47	26/Dec/2016	09.20	Over Voltage
400 KV	Kolhapur Solapur (PG) II	25/Dec/2016	21.42	26/Dec/2016	22.00	Over Voltage
400 KV	Padghe - Kalwa - I	26/Dec/2016	07.37	27/Dec/2016	09.38	PMU installation work.
400 KV	karad -kolhapur-II	26/Dec/2016	16.32	27/Dec/2016	11.32	Over Voltage
400 KV	Karad-Jaigad - I	26/Dec/2016	16.37	27/Dec/2016	11.24	Over Voltage
400 KV	Dhule Sar'Sarovar I	26/Dec/2016	16.56	27/Dec/2016	06.53	Over Voltage
400 KV	Bhusawal-Aurangabad	26/Dec/2016	17.42	27/Dec/2016	06.51	Over Voltage
400 KV	Lonikand I - Koyna stage-IV	26/Dec/2016	21.21	27/Dec/2016	09.00	Over Voltage
400 KV	Kolhapur Solapur (PG) II	26/Dec/2016	22.00	27/Dec/2016	06.55	Over Voltage
400 KV	karad -kolhapur-I	27/Dec/2016	16.06	28/Dec/2016	09.40	Over Voltage
400 KV	Karad - Jaigad - II	27/Dec/2016	16.08	28/Dec/2016	09.41	Over Voltage
400 KV	Bhusawal-Aurangabad	27/Dec/2016	17.08	28/Dec/2016	06.47	Over Voltage
400 KV	Lonikand I - Koyna stage-IV	27/Dec/2016	17.09	28/Dec/2016	07.39	Over Voltage
400 KV	Dhule Sar'Sarovar I	27/Dec/2016	19.10	28/Dec/2016	06.48	Over Voltage
400 KV	Padghe - Kalwa-II	28/Dec/2016	07.01	28/Dec/2016	08.36	PMU connection work.
400 KV	Kalwa - Talegaon(PG)	28/Dec/2016	15.32	28/Dec/2016	16.39	CODE:2612 PMU comissioning work.
400 KV	karad -kolhapur-II	28/Dec/2016	16.39	29/Dec/2016	09.30	Over Voltage
400 KV	Karad-Jaigad - I	28/Dec/2016	16.42	29/Dec/2016	09.34	Over Voltage
400 KV	Bhusawal-Aurangabad	28/Dec/2016	17.09	29/Dec/2016	07.15	Over Voltage
400 KV	Dhule Sar'Sarovar II	28/Dec/2016	17.32	29/Dec/2016	07.19	Over Voltage
400 KV	Lonikand I - Koyna stage-IV	28/Dec/2016	20.57	29/Dec/2016	09.34	Over Voltage
400 KV	Kalwa - Kharghar	29/Dec/2016	07.46	29/Dec/2016	09.40	PMU comissioning work
400 KV	Akola-Nandgaonpeth (RPL)	29/Dec/2016	10.17	29/Dec/2016	17.33	Line signature test
400 KV	Dhule - Bableshtar - II	29/Dec/2016	12.32	29/Dec/2016	17.02	Fixing of repaire sleeves at damaged portion of conductor
400 KV	karad -kolhapur-I	29/Dec/2016	16.34	30/Dec/2016	10.01	Over Voltage
400 KV	Karad - Jaigad - II	29/Dec/2016	16.35	30/Dec/2016	10.03	Over Voltage
400 KV	Bhusawal-Aurangabad	29/Dec/2016	17.39	30/Dec/2016	07.03	Over Voltage
400 KV	Dhule Sar'Sarovar II	29/Dec/2016	18.10	30/Dec/2016	07.57	Over Voltage
400 KV	Lonikand I - Koyna stage-IV	29/Dec/2016	22.05	30/Dec/2016	07.38	Over Voltage
400 KV	Dhule - Bableshtar - I	30/Dec/2016	11.50	30/Dec/2016	17.14	Conductor Repair Sleeves.
400 KV	Akola Wardha I	30/Dec/2016	15.04	31/Dec/2016	10.50	Distance Protection
400 KV	Karad-Jaigad - I	30/Dec/2016	16.08	31/Dec/2016	09.29	Over Voltage
400 KV	karad -kolhapur-II	30/Dec/2016	16.09	31/Dec/2016	06.41	Over Voltage
400 KV	Bhusawal-Aurangabad	30/Dec/2016	17.23	31/Dec/2016	07.20	Over Voltage
400 KV	Dhule Sar'Sarovar II	30/Dec/2016	18.10	31/Dec/2016	07.27	Over Voltage
400 KV	Lonikand I - Koyna stage-IV	30/Dec/2016	22.07	31/Dec/2016	07.31	Over Voltage
400 KV	Kolhapur Solapur(PG) I	31/Dec/2016	09.00	02/Jan/2017	13.57	For Lilo At Alkud S/Stn.
400 KV	Bhusawal-Aurangabad	31/Dec/2016	16.51	01/Jan/2017	08.57	Over Voltage
400 KV	Dhule Sar'Sarovar II	31/Dec/2016	17.16	01/Jan/2017	09.00	Over Voltage
400 KV	karad -kolhapur-I	31/Dec/2016	19.35	01/Jan/2017	09.12	Over Voltage
400 KV	Karad - Jaigad - II	31/Dec/2016	19.40	01/Jan/2017	09.17	Over Voltage
400 KV	Lonikand I - Koyna stage-IV	31/Dec/2016	21.18	01/Jan/2017	08.56	Over Voltage
400 KV	karad -kolhapur-I	01/Jan/2017	16.41	02/Jan/2017	07.39	Over Voltage
400 KV	Karad - Jaigad - II	01/Jan/2017	16.44	02/Jan/2017	10.48	Over Voltage
400 KV	Bhusawal-Aurangabad	01/Jan/2017	17.19	02/Jan/2017	06.17	Over Voltage
400 KV	Dhule Sar'Sarovar II	01/Jan/2017	17.24	02/Jan/2017	06.25	Over Voltage
400 KV	Lonikand I - Koyna stage-IV	01/Jan/2017	17.26	02/Jan/2017	06.41	Over Voltage
400 KV	Dhule Sar'Sarovar I	06/Jan/2017	16.46		Continued.	Over Voltage
400 KV	Jaigad-Karad Ckt-II	06/Jan/2017	17.06		Continued.	Over Voltage
400 KV	Bhusawal-Aurangabad	06/Jan/2017	19.43		Continued.	Over Voltage
400 KV	Lonikand I - Koyna stage-IV	06/Jan/2017	21.57		Continued.	Over Voltage
400 KV	karad -kolhapur-I	07/Jan/2017	02.06		Continued.	Over Voltage
220 KV	220/100 Kv 200 MVA ICT III @Borivali	21/Sep/2014	09.16		Continued.	Failed on internal Fault(Now repaired and ready for commissioning)
220 KV	Chandrapur GCR - Warora - I	05/Apr/2015	09.13		Continued.	Bunching of conductor Loc no 86 Disconnecting of jumer at Loc no 86 & 107 and de-energising the line bet.86 to 107.
220 KV	Chandrapur GCR - Wani	05/Apr/2015	09.15		Continued.	Bunching of conductor Loc no 86 Disconnecting of jumer at Loc no 86 & 107 and de-energising the line bet.86 to 107.
220 KV	Kalwa - Borivali	27/Oct/2016	08.32	31/Dec/2016	20.15	Outage availed on28.10.2016 at 08:09 hrs for construction activity of Mumbai strenghtning work
220 KV	Mulund - GIS Bhandup	27/Oct/2016	08.53	01/Jan/2017	16.51	outage availed on 28.10.2016 at 09:30hrs for construction activity of mumbai strenghtning work.
220 KV	karad - Dasgaon	20/Dec/2016	09.37	28/Dec/2016	16.00	Construction Work.
220 KV	Badnera - Deoli (PG)	26/Dec/2016	07.49	26/Dec/2016	08.24	LINE OPEN BY WRLDC DUE TO HIGH O/DI.
220 KV	Kalwa 52B Interconnector CB	26/Dec/2016	10.50	26/Dec/2016	14.00	Attending Hot Spot
220 KV	Badnera - Deoli (PG)	26/Dec/2016	11.17	26/Dec/2016	18.41	Replacement work
220 KV	Pophali - Nerale	26/Dec/2016	12.15	26/Dec/2016	18.30	TRIPPED ON DP.
220 KV	Trombay Salsette 1 Backbay	26/Dec/2016	17.38	27/Dec/2016	18.11	Distance Protection
220 KV	Goregaon Versova Line 2	27/Dec/2016	09.28	27/Dec/2016	12.22	Routine Maintenance Work
220 KV	Badnera - Deoli (PG)	27/Dec/2016	12.00	27/Dec/2016	16.53	Attending Oil Leakage
220 KV	Boisar-Viraj	27/Dec/2016	12.27	27/Dec/2016	17.09	Construction work.
220 KV	Butibori-Khaperkheda	27/Dec/2016	12.45	27/Dec/2016	15.50	Attending Oil Leakage
220 KV	Mahad - Pedambe	27/Dec/2016	13.30	27/Dec/2016	18.00	Attending Hot Spot
220 KV	220KV/132KV ICT I @ Bhusawal II	27/Dec/2016	13.37	27/Dec/2016	18.04	Oil top up work.
220 KV	Lonikand (400 Kv)-Theur I	27/Dec/2016	17.47	27/Dec/2016	21.29	Attending Hot Spot

Voltage	Name of Line	Tripping Date	Tripping Time	Synch Date	Synch Time	Reason
220 KV	Vita - Mhaishal	28/Dec/2016	09.30	28/Dec/2016	13.07	To attend Hot Spot
220 KV	Bapgaon - Kalwa	28/Dec/2016	10.18	28/Dec/2016	19.49	Testing Work
220 KV	Chalisgaon - Babhaleshwar	28/Dec/2016	11.18	28/Dec/2016	15.36	Line Maintenance work
220 KV	Oni Kharepatan Line	28/Dec/2016	11.59	28/Dec/2016	12.21	Distance Protection
220 KV	Kalmeshwar-Kalmeshwar Rly Tss 1	28/Dec/2016	19.46	28/Dec/2016	22.55	Problem in Y-PH CT.
220 KV	Lonikand-II- Kathapur	29/Dec/2016	11.26	29/Dec/2016	17.24	Testing Work
220 KV	Loteparshuram- Dasturi Line	29/Dec/2016	13.33	30/Dec/2016	00.35	Distance Protection
220 KV	Bableshwar -Ahamadnagar-I	29/Dec/2016	17.59	29/Dec/2016	21.53	String replacement work
220 KV	Padgha-Temghar-II	30/Dec/2016	08.44	01/Jan/2017	18.46	On trolling ICT At Padgha.
220 KV	Padgha - Temghar I	30/Dec/2016	08.44	01/Jan/2017	18.47	On trolling ICT At Padgha.
220 KV	Babhaleshwar-Nagar-I	30/Dec/2016	09.13	30/Dec/2016	14.11	Distance Protection
220 KV	Jambhul - Pal	30/Dec/2016	10.14	30/Dec/2016	18.10	Annual Maintenance Work
220 KV	Kamba - Kolshet	30/Dec/2016	11.52	30/Dec/2016	17.30	Testing And Maintenance Work.
220 KV	Pegasus - Infosys	31/Dec/2016	10.37	31/Dec/2016	17.11	Testing Work
220 KV	Kharghar - Nerul	31/Dec/2016	11.30	03/Jan/2017	19.06	High AMP Conductor Repalcement.
220 KV	Kalmeshwar-Pandhurna	31/Dec/2016	12.21	31/Dec/2016	16.21	Attending Oil Leakage
220 KV	Kolhapur-Birdi	31/Dec/2016	15.09	31/Dec/2016	16.58	Line Maintenance work
220 KV	220/22 Kv 50 Mva Telk Ptr 2 @Mahad	04/Jan/2017	10.26		Continued.	T/F Replacement Work.
220 KV	Pusad - Hingoli	05/Jan/2017	18.34		Continued.	For Wardha-Yeotmal L/L.
220 KV	Nanded-Ghatodi	05/Jan/2017	18.42		Continued.	For Kumbhargaoon-Nanded L/L.
132 KV	Waghala (Nanded2) - Narsi	27/Dec/2016	13.18	27/Dec/2016	13.25	Distance Protection
132 KV	Paranda - Kallamb	28/Dec/2016	16.55	28/Dec/2016	17.15	Attending Oil Leakage
132 KV	Kanhan-Pench	31/Dec/2016	11.37	31/Dec/2016	14.46	Damaged Control Cable Replacement.
132 KV	Beed(220kv) -Telgaon	31/Dec/2016	12.32	31/Dec/2016	12.55	Distance Protection