

**State Load Despatch Center,Airoli (MSETCL)**  
**Power System Position from 21/Dec/2020 to 27/Dec/2020**

**Supply Position During Morning Peak (MW)**

| Date           | Time   | MSGENCO     |             |            |             | Central Sector Receipt | Wind       | CPP         | SOLAR       | TPCL Exch.  | MSEDCL Catered Demand | Load Sheddin g(LS) | MSEDCL Demand (Incl. LS) | TPCL Gen.   | R-INFRA Gen. | State Demand Met | State Demand (Incl. LS) | Freq.        |
|----------------|--------|-------------|-------------|------------|-------------|------------------------|------------|-------------|-------------|-------------|-----------------------|--------------------|--------------------------|-------------|--------------|------------------|-------------------------|--------------|
|                |        | THM         | HYDRO       | GAS        | Total       |                        |            |             |             |             |                       |                    |                          |             |              |                  |                         |              |
|                |        | MW          | MW          | MW         | MW          | MW                     | MW         | MW          | MW          | MW          | MW                    | MW                 | MW                       | MW          | MW           | MW               | MW                      | Hzs          |
| 21-12-2020     | 12 Hrs | 6286        | 607         | 280        | 7173        | 7612                   | 746        | 4103        | 1107        | -805        | 19936                 | 0                  | 19936                    | 1093        | 498          | 22332            | 22332                   | 50.02        |
| 22-12-2020     | 12 Hrs | 5469        | 1622        | 280        | 7371        | 8435                   | 205        | 4077        | 1047        | -762        | 20373                 | 0                  | 20373                    | 1098        | 496          | 22729            | 22729                   | 50.02        |
| 23-12-2020     | 12 Hrs | 5871        | 1090        | 280        | 7240        | 8064                   | 87         | 4564        | 1032        | -759        | 20229                 | 0                  | 20229                    | 1109        | 498          | 22595            | 22595                   | 49.99        |
| 24-12-2020     | 11 Hrs | 5967        | 1774        | 272        | 8014        | 8021                   | 239        | 3928        | 926         | -657        | 20470                 | 0                  | 20470                    | 1171        | 499          | 22798            | 22798                   | 50.05        |
| 25-12-2020     | 12 Hrs | 5332        | 1830        | 82         | 7244        | 8682                   | 245        | 3902        | 945         | -665        | 20352                 | 0                  | 20352                    | 1051        | 501          | 22570            | 22570                   | 49.89        |
| 26-12-2020     | 12 Hrs | 5924        | 1392        | 149        | 7466        | 8921                   | 200        | 3967        | 997         | -838        | 20712                 | 0                  | 20712                    | 980         | 500          | 23030            | 23030                   | 50.02        |
| 27-12-2020     | 11 Hrs | 6276        | 462         | 280        | 7018        | 9197                   | 57         | 3961        | 872         | -643        | 20462                 | 0                  | 20462                    | 865         | 500          | 22470            | 22470                   | 50.01        |
| <b>Maximum</b> |        | <b>6286</b> | <b>1830</b> | <b>280</b> | <b>8014</b> | <b>9197</b>            | <b>746</b> | <b>4564</b> | <b>1107</b> | <b>-643</b> | <b>20712</b>          | <b>0</b>           | <b>20712</b>             | <b>1171</b> | <b>501</b>   | <b>23030</b>     | <b>23030</b>            | <b>50.05</b> |
| <b>Minimum</b> |        | <b>5332</b> | <b>462</b>  | <b>82</b>  | <b>7018</b> | <b>7612</b>            | <b>57</b>  | <b>3902</b> | <b>872</b>  | <b>-838</b> | <b>19936</b>          | <b>0</b>           | <b>19936</b>             | <b>865</b>  | <b>496</b>   | <b>22332</b>     | <b>22332</b>            | <b>49.89</b> |
| <b>Average</b> |        | <b>5875</b> | <b>1254</b> | <b>232</b> | <b>7361</b> | <b>8419</b>            | <b>254</b> | <b>4072</b> | <b>989</b>  | <b>-733</b> | <b>20362</b>          | <b>0</b>           | <b>20362</b>             | <b>1052</b> | <b>499</b>   | <b>22646</b>     | <b>22646</b>            | <b>50.00</b> |

**Supply Position During Day Peak (MW)**

| Date           | Time   | MSGENCO     |             |            |             | Central Sector Receipt | Wind       | CPP         | SOLAR       | TPCL Exch.  | MSEDCL Catered Demand | Load Sheddin g(LS) | MSEDCL Demand (Incl. LS) | TPCL Gen.   | R-INFRA Gen. | State Demand Met | State Demand (Incl. LS) | Freq.        |
|----------------|--------|-------------|-------------|------------|-------------|------------------------|------------|-------------|-------------|-------------|-----------------------|--------------------|--------------------------|-------------|--------------|------------------|-------------------------|--------------|
|                |        | THM         | HYDRO       | GAS        | Total       |                        |            |             |             |             |                       |                    |                          |             |              |                  |                         |              |
|                |        | MW          | MW          | MW         | MW          | MW                     | MW         | MW          | MW          | MW          | MW                    | MW                 | MW                       | MW          | MW           | MW               | MW                      | Hzs          |
| 21-12-2020     | 13 Hrs | 6261        | 360         | 279        | 6900        | 7543                   | 617        | 3949        | 1090        | -770        | 19329                 | 0                  | 19329                    | 1093        | 497          | 21689            | 21689                   | 50.02        |
| 22-12-2020     | 13 Hrs | 5478        | 1161        | 279        | 6918        | 7995                   | 151        | 3999        | 1083        | -801        | 19345                 | 0                  | 19345                    | 1019        | 497          | 21662            | 21662                   | 50.03        |
| 23-12-2020     | 13 Hrs | 5678        | 826         | 270        | 6774        | 7746                   | 71         | 4503        | 1059        | -738        | 19414                 | 0                  | 19414                    | 1111        | 497          | 21760            | 21760                   | 50.00        |
| 24-12-2020     | 13 Hrs | 5631        | 1344        | 248        | 7224        | 8188                   | 94         | 3772        | 1020        | -756        | 19542                 | 0                  | 19542                    | 1084        | 500          | 21882            | 21882                   | 49.98        |
| 25-12-2020     | 13 Hrs | 5317        | 1700        | 79         | 7096        | 8357                   | 236        | 3912        | 998         | -668        | 19930                 | 0                  | 19930                    | 1031        | 498          | 22128            | 22128                   | 50.00        |
| 26-12-2020     | 13 Hrs | 5918        | 792         | 138        | 6848        | 9106                   | 146        | 3889        | 1020        | -814        | 20194                 | 0                  | 20194                    | 981         | 501          | 22490            | 22490                   | 50.01        |
| 27-12-2020     | 13 Hrs | 6187        | 240         | 268        | 6694        | 8986                   | 70         | 3751        | 1006        | -689        | 19818                 | 0                  | 19818                    | 833         | 500          | 21840            | 21840                   | 49.99        |
| <b>Maximum</b> |        | <b>6261</b> | <b>1700</b> | <b>279</b> | <b>7224</b> | <b>9106</b>            | <b>617</b> | <b>4503</b> | <b>1090</b> | <b>-668</b> | <b>20194</b>          | <b>0</b>           | <b>20194</b>             | <b>1111</b> | <b>501</b>   | <b>22490</b>     | <b>22490</b>            | <b>50.03</b> |
| <b>Minimum</b> |        | <b>5317</b> | <b>240</b>  | <b>79</b>  | <b>6694</b> | <b>7543</b>            | <b>70</b>  | <b>3751</b> | <b>998</b>  | <b>-814</b> | <b>19329</b>          | <b>0</b>           | <b>19329</b>             | <b>833</b>  | <b>497</b>   | <b>21662</b>     | <b>21662</b>            | <b>49.98</b> |
| <b>Average</b> |        | <b>5781</b> | <b>917</b>  | <b>223</b> | <b>6922</b> | <b>8274</b>            | <b>198</b> | <b>3968</b> | <b>1039</b> | <b>-748</b> | <b>19653</b>          | <b>0</b>           | <b>19653</b>             | <b>1022</b> | <b>499</b>   | <b>21922</b>     | <b>21922</b>            | <b>50.00</b> |

**Supply Position During Evening Peak (MW)**

| Date           | Time   | MSGENCO     |             |            |             | Central Sector Receipt | Wind       | CPP         | SOLAR    | TPCL Exch.  | MSEDCL Catered Demand | Load Sheddin g(LS) | MSEDCL Demand (Incl. LS) | TPCL Gen.   | R-INFRA Gen. | State Demand Met | State Demand (Incl. LS) | Freq.        |
|----------------|--------|-------------|-------------|------------|-------------|------------------------|------------|-------------|----------|-------------|-----------------------|--------------------|--------------------------|-------------|--------------|------------------|-------------------------|--------------|
|                |        | THM         | HYDRO       | GAS        | Total       |                        |            |             |          |             |                       |                    |                          |             |              |                  |                         |              |
|                |        | MW          | MW          | MW         | MW          | MW                     | MW         | MW          | MW       | MW          | MW                    | MW                 | MW                       | MW          | MW           | MW               | MW                      | Hzs          |
| 21-12-2020     | 19 Hrs | 6229        | 256         | 272        | 6757        | 6074                   | 642        | 4132        | 0        | -765        | 16840                 | 0                  | 16840                    | 1048        | 497          | 19150            | 19150                   | 50.02        |
| 22-12-2020     | 19 Hrs | 5760        | 1046        | 282        | 7088        | 5967                   | 375        | 4195        | 0        | -684        | 16941                 | 0                  | 16941                    | 1109        | 498          | 19232            | 19232                   | 50.00        |
| 23-12-2020     | 19 Hrs | 5873        | 614         | 282        | 6768        | 6201                   | 289        | 4669        | 0        | -695        | 17232                 | 0                  | 17232                    | 1103        | 501          | 19532            | 19532                   | 50.03        |
| 24-12-2020     | 19 Hrs | 5548        | 1108        | 231        | 6886        | 6374                   | 337        | 3925        | 0        | -724        | 16798                 | 0                  | 16798                    | 1082        | 500          | 19104            | 19104                   | 50.03        |
| 25-12-2020     | 19 Hrs | 5261        | 876         | 136        | 6272        | 6600                   | 576        | 3976        | 7        | -703        | 16728                 | 0                  | 16728                    | 1027        | 501          | 18960            | 18960                   | 50.01        |
| 26-12-2020     | 20 Hrs | 5812        | 590         | 291        | 6694        | 6786                   | 202        | 3801        | 0        | -730        | 16752                 | 0                  | 16752                    | 1062        | 500          | 19044            | 19044                   | 50.00        |
| 27-12-2020     | 19 Hrs | 5791        | 642         | 280        | 6712        | 6637                   | 343        | 3296        | 0        | -940        | 16048                 | 0                  | 16048                    | 749         | 289          | 18026            | 18026                   | 50.01        |
| <b>Maximum</b> |        | <b>6229</b> | <b>1108</b> | <b>291</b> | <b>7088</b> | <b>6786</b>            | <b>642</b> | <b>4669</b> | <b>7</b> | <b>-684</b> | <b>17232</b>          | <b>0</b>           | <b>17232</b>             | <b>1109</b> | <b>501</b>   | <b>19532</b>     | <b>19532</b>            | <b>50.03</b> |
| <b>Minimum</b> |        | <b>5261</b> | <b>256</b>  | <b>136</b> | <b>6272</b> | <b>5967</b>            | <b>202</b> | <b>3296</b> | <b>0</b> | <b>-940</b> | <b>16048</b>          | <b>0</b>           | <b>16048</b>             | <b>749</b>  | <b>289</b>   | <b>18026</b>     | <b>18026</b>            | <b>50.00</b> |
| <b>Average</b> |        | <b>5753</b> | <b>733</b>  | <b>253</b> | <b>6740</b> | <b>6377</b>            | <b>395</b> | <b>3999</b> | <b>1</b> | <b>-749</b> | <b>16763</b>          | <b>0</b>           | <b>16763</b>             | <b>1026</b> | <b>469</b>   | <b>19007</b>     | <b>19007</b>            | <b>50.01</b> |

## Supply Position During Night Off Peak (MW)

| Date           | Time   | MSGENCO     |            |            |             | Central Sector Receipt | Wind        | CPP         | SOLAR    | TPCL Exch.  | MSEDCL Catered Demand | Load Sheddin g(LS) | MSEDCL Demand (Incl. LS) | TPCL Gen.  | R-INFRA Gen. | State Demand Met | State Demand (Incl. LS) | Freq.        |
|----------------|--------|-------------|------------|------------|-------------|------------------------|-------------|-------------|----------|-------------|-----------------------|--------------------|--------------------------|------------|--------------|------------------|-------------------------|--------------|
|                |        | THM         | HYDRO      | GAS        | Total       |                        |             |             |          |             |                       |                    |                          |            |              |                  |                         |              |
|                |        | MW          | MW         | MW         | MW          | MW                     | MW          | MW          | MW       | MW          | MW                    | MW                 | MW                       | MW         | MW           | MW               | MW                      | Hzs          |
| 21-12-2020     | 3 Hrs  | 4248        | 99         | 284        | 4631        | 5097                   | 1126        | 3264        | 0        | -607        | 13511                 | 0                  | 13511                    | 574        | 282          | 14974            | 14974                   | 50.01        |
| 22-12-2020     | 4 Hrs  | 4730        | 189        | 295        | 5214        | 5070                   | 744         | 3496        | 0        | -510        | 14014                 | 0                  | 14014                    | 602        | 282          | 15408            | 15408                   | 49.99        |
| 23-12-2020     | 4 Hrs  | 4602        | 112        | 296        | 5010        | 5592                   | 383         | 3645        | 0        | -453        | 14178                 | 0                  | 14178                    | 600        | 282          | 15512            | 15512                   | 49.97        |
| 24-12-2020     | 2 Hrs  | 5196        | 146        | 295        | 5636        | 5353                   | 453         | 3110        | 0        | -569        | 13984                 | 0                  | 13984                    | 606        | 283          | 15442            | 15442                   | 49.99        |
| 25-12-2020     | 2 Hrs  | 5101        | 98         | 144        | 5342        | 5556                   | 635         | 3153        | 0        | -660        | 14026                 | 0                  | 14026                    | 534        | 284          | 15504            | 15504                   | 49.98        |
| 26-12-2020     | 4 Hrs  | 4516        | 92         | 144        | 4752        | 6220                   | 721         | 3140        | 0        | -541        | 14292                 | 0                  | 14292                    | 599        | 283          | 15716            | 15716                   | 50.02        |
| 27-12-2020     | 24 Hrs | 5236        | 88         | 293        | 5618        | 5940                   | 299         | 3185        | 0        | -911        | 14130                 | 0                  | 14130                    | 531        | 284          | 15856            | 15856                   | 50.00        |
| <b>Maximum</b> |        | <b>5236</b> | <b>189</b> | <b>296</b> | <b>5636</b> | <b>6220</b>            | <b>1126</b> | <b>3645</b> | <b>0</b> | <b>-453</b> | <b>14292</b>          | <b>0</b>           | <b>14292</b>             | <b>606</b> | <b>284</b>   | <b>15856</b>     | <b>15856</b>            | <b>50.02</b> |
| <b>Minimum</b> |        | <b>4248</b> | <b>88</b>  | <b>144</b> | <b>4631</b> | <b>5070</b>            | <b>299</b>  | <b>3110</b> | <b>0</b> | <b>-911</b> | <b>13511</b>          | <b>0</b>           | <b>13511</b>             | <b>531</b> | <b>282</b>   | <b>14974</b>     | <b>14974</b>            | <b>49.97</b> |
| <b>Average</b> |        | <b>4804</b> | <b>118</b> | <b>250</b> | <b>5172</b> | <b>5547</b>            | <b>623</b>  | <b>3285</b> | <b>0</b> | <b>-607</b> | <b>14019</b>          | <b>0</b>           | <b>14019</b>             | <b>578</b> | <b>283</b>   | <b>15488</b>     | <b>15488</b>            | <b>49.99</b> |

## Details of Supply Position (MUs)

| Date           | MSGENCO        |               |              |                | Pench (MS)   | Central Sector Receipt | Central Sector Share | WIND           | CPP           | SOLAR        | TPCL Gen.     | R-INFRA Gen.  | TPCL Exch.     | Energy Requirement |               |                |
|----------------|----------------|---------------|--------------|----------------|--------------|------------------------|----------------------|----------------|---------------|--------------|---------------|---------------|----------------|--------------------|---------------|----------------|
|                | THM            | HYDRO         | GAS          | Total          |              |                        |                      |                |               |              |               |               |                | MSEDCL             | MUMBAI        | STATE          |
|                | Mus            | Mus           | Mus          | Mus            | Mus          | Mus                    | Mus                  | Mus            | Mus           | Mus          | Mus           | Mus           | Mus            | Mus                | Mus           | Mus            |
| 21-12-2020     | 134.894        | 8.259         | 6.804        | 149.957        | 0.510        | 149.189                | 150.603              | 19.968         | 88.210        | 7.630        | 19.967        | 9.460         | -17.568        | 397.386            | 46.995        | 444.381        |
| 22-12-2020     | 129.326        | 18.703        | 6.810        | 154.839        | 0.269        | 154.864                | 154.282              | 9.442          | 92.444        | 7.288        | 22.045        | 9.904         | -14.480        | 404.397            | 46.429        | 450.826        |
| 23-12-2020     | 133.225        | 13.125        | 6.842        | 153.192        | 0.465        | 154.033                | 155.308              | 7.517          | 98.529        | 7.292        | 21.458        | 9.696         | -14.946        | 405.617            | 46.101        | 451.718        |
| 24-12-2020     | 135.541        | 17.359        | 6.335        | 159.235        | 0.509        | 162.686                | 162.211              | 7.097          | 85.781        | 6.955        | 21.130        | 9.775         | -15.462        | 406.292            | 46.367        | 452.659        |
| 25-12-2020     | 126.403        | 16.197        | 2.911        | 145.511        | 0.518        | 170.089                | 170.695              | 12.006         | 86.182        | 6.797        | 19.144        | 9.894         | -15.808        | 404.777            | 44.846        | 449.623        |
| 26-12-2020     | 135.282        | 12.317        | 4.343        | 151.942        | 0.510        | 176.400                | 177.900              | 8.369          | 85.473        | 6.915        | 19.895        | 10.280        | -16.339        | 412.760            | 46.513        | 459.273        |
| 27-12-2020     | 140.468        | 6.239         | 6.880        | 153.587        | 0.499        | 178.414                | 179.132              | 4.099          | 82.682        | 6.819        | 16.033        | 8.630         | -18.693        | 406.908            | 43.356        | 450.264        |
| <b>Maximum</b> | <b>140.468</b> | <b>18.703</b> | <b>6.880</b> | <b>159.235</b> | <b>0.518</b> | <b>178.414</b>         | <b>179.132</b>       | <b>140.468</b> | <b>98.529</b> | <b>7.630</b> | <b>22.045</b> | <b>10.280</b> | <b>-14.480</b> | <b>412.760</b>     | <b>46.995</b> | <b>459.273</b> |
| <b>Minimum</b> | <b>126.403</b> | <b>6.239</b>  | <b>2.911</b> | <b>145.511</b> | <b>0.269</b> | <b>149.189</b>         | <b>150.603</b>       | <b>126.403</b> | <b>82.682</b> | <b>6.797</b> | <b>16.033</b> | <b>8.630</b>  | <b>-18.693</b> | <b>397.386</b>     | <b>43.356</b> | <b>444.381</b> |
| <b>Average</b> | <b>133.591</b> | <b>13.171</b> | <b>5.846</b> | <b>152.609</b> | <b>0.469</b> | <b>163.668</b>         | <b>164.304</b>       | <b>133.591</b> | <b>88.472</b> | <b>7.099</b> | <b>19.953</b> | <b>9.663</b>  | <b>-16.185</b> | <b>405.448</b>     | <b>45.801</b> | <b>451.249</b> |

### Details of Koyna Water

| Date       | For the Day | For the Month | Balance |
|------------|-------------|---------------|---------|
| 21-12-2020 | 0.104       | 2.768         | 42.123  |
| 22-12-2020 | 0.339       | 3.108         | 41.783  |
| 23-12-2020 | 0.224       | 3.332         | 41.559  |
| 24-12-2020 | 0.315       | 3.646         | 41.245  |
| 25-12-2020 | 0.311       | 3.957         | 40.934  |
| 26-12-2020 | 0.219       | 4.175         | 40.716  |
| 27-12-2020 | 0.104       | 4.279         | 40.612  |

### State Load Despatch Center,Airoli (MSETCL) Central Sector Share/Drawal from 21/Dec/2020 to 27/Dec/2020

| Date         | DAY       | Central Sector Share |         | Total Interstate |         | Total Share     |         | Total Drawal    |         | Overdrawal(+) / |         |
|--------------|-----------|----------------------|---------|------------------|---------|-----------------|---------|-----------------|---------|-----------------|---------|
|              |           | MUs                  | Avg. MW | MUs              | Avg. MW | MUs             | Avg. MW | MUs             | Avg. MW | MUs             | Avg. MW |
|              |           | <b>1</b>             |         | <b>2</b>         |         | <b>1+2=3</b>    |         | <b>4</b>        |         | <b>3-4=5</b>    |         |
| 21-12-2020   | MONDAY    | 121.542              | 6246    | 29.061           | 1211    | 150.603         | 6275    | 149.189         | 6216    | -1.414          | -59     |
| 22-12-2020   | TUESDAY   | 122.426              | 6397    | 31.856           | 1327    | 154.282         | 6428    | 154.864         | 6453    | 0.582           | 24      |
| 23-12-2020   | WEDNESDAY | 124.557              | 6440    | 30.751           | 1281    | 155.308         | 6471    | 154.033         | 6418    | -1.275          | -53     |
| 24-12-2020   | THURSDAY  | 130.264              | 6727    | 31.947           | 1331    | 162.211         | 6759    | 162.686         | 6779    | 0.475           | 20      |
| 25-12-2020   | FRIDAY    | 132.797              | 7074    | 37.898           | 1579    | 170.695         | 7112    | 170.089         | 7087    | -0.606          | -25     |
| 26-12-2020   | SATURDAY  | 135.612              | 7370    | 42.288           | 1762    | 177.900         | 7412    | 176.400         | 7350    | -1.500          | -62     |
| 27-12-2020   | SUNDAY    | 134.557              | 7419    | 44.575           | 1857    | 179.132         | 7464    | 178.414         | 7434    | -0.718          | -30     |
| <b>Total</b> |           | <b>901.754</b>       |         | <b>248.377</b>   |         | <b>1150.131</b> |         | <b>1145.675</b> |         | <b>-4.456</b>   |         |

Generating Unit Outages for 21.12.2020 to 27.12.2020

| Outage Type | Name                | Trip Date | Trip Time | Sync. Date | Sync. Time | Reason                                                               |
|-------------|---------------------|-----------|-----------|------------|------------|----------------------------------------------------------------------|
| PLANNED     | Koradi Unit 10      | 09-Nov-20 | 1.28      | 22-Dec-20  | 16.3       | Air heater problem(Converted in to Annual Overhaul.From 09.11.2020)  |
| PLANNED     | Khaparkheda Unit 3  | 19-Nov-20 | 23.55     | 21-Dec-20  | 18.56      | ANNUAL OVERHAUL                                                      |
| PLANNED     | Koyna STG-IV Unit-2 | 23-Nov-20 | 8         |            | Continued. | Capital Overhaul                                                     |
| PLANNED     | Chandrapur Unit-8   | 20-Dec-20 | 0         |            | Continued. | Annual Overhaul                                                      |
| FORCED      | SWPGL U-1           | 16-Feb-16 | 17.09     |            | Continued. | No PPA.                                                              |
| FORCED      | PGPL U1             | 07-Feb-17 | 17.3      |            | Continued. | No Schedule                                                          |
| FORCED      | PGPL U2             | 07-Feb-17 | 17.3      |            | Continued. | No Schedule                                                          |
| FORCED      | IEPL Unit 1         | 28-Aug-18 | 21.26     |            | Continued. | No PPA                                                               |
|             |                     |           |           |            |            |                                                                      |
| FORCED      | VIPL U-1            | 29-Dec-18 | 0.3       |            | Continued. | Coal Shortage                                                        |
| FORCED      | VIPL U-2            | 17-Jan-19 | 0.15      |            | Continued. | Coal Shortage                                                        |
| FORCED      | Bhusawal Unit 3     | 01-Sep-19 | 17.56     | 02-Jan-21  | 6.35       | Zero Schedule from 18:00hrs of 28/09/2019                            |
| FORCED      | RPL(AMT) U-4        | 12-Nov-19 | 0         | 23-Dec-20  | 2.48       | Zero Schedule By MSEDCL.                                             |
| FORCED      | Nasik Unit 5        | 12-Dec-19 | 10.25     |            | Continued. | PA Fan Problem (Under Case 4 Bidding From 11.00Hrs DT. 13-12-2019)   |
| FORCED      | RPL(AMT) U-5        | 11-Feb-20 | 19.3      | 23-Dec-20  | 1.25       | Zero Schedule By MSEDCL.                                             |
| FORCED      | RPL(AMT) U-3        | 11-Feb-20 | 18        | 21-Dec-20  | 2          | Zero Schedule By MSEDCL.                                             |
| FORCED      | Uran Unit 8         | 01-Mar-20 | 20.57     |            | Continued. | Gas shortage                                                         |
| FORCED      | Uran Unit 7         | 25-May-20 | 12.51     |            | Continued. | Turbine Blade Failure                                                |
| FORCED      | Uran Unit B0        | 25-May-20 | 12.51     |            | Continued. | Turbine Blade Failure                                                |
| FORCED      | JSW (J) U2          | 01-Nov-20 | 4.44      |            | Continued. | No Schedule                                                          |
| FORCED      | Nasik Unit 3        | 03-Dec-20 | 6.45      |            | Continued. | Economizer Tube Leakage. (Zero Schedule from 18:45hrs of 05.12.2020) |
| FORCED      | Adani U-4           | 15-Dec-20 | 23.48     |            | Continued. | Zero schedule.                                                       |
| FORCED      | Adani U-5           | 16-Dec-20 | 3.5       | 02-Jan-21  | 7.15       | Zero schedule.                                                       |
| FORCED      | Adani U-1           | 16-Dec-20 | 10.58     |            | Continued. | Withdrawal For RSD.                                                  |
| FORCED      | Koradi Unit 7       | 20-Dec-20 | 11.27     | 21-Dec-20  | 10.27      | Furnace Draft                                                        |
| FORCED      | Parli Unit 8        | 20-Dec-20 | 17.24     | 22-Dec-20  | 17.42      | Boiler Tube Leakage                                                  |
| FORCED      | Bhusawal Unit 4     | 21-Dec-20 | 20.41     | 24-Dec-20  | 0.19       | Boiler Tube Leakage                                                  |
| FORCED      | Paras Unit 4        | 22-Dec-20 | 8.1       | 22-Dec-20  | 23.35      | Electrical protection.                                               |
| FORCED      | Koradi Unit 9       | 22-Dec-20 | 22.38     | 25-Dec-20  | 21.08      | Boiler Tube Leakage                                                  |
| FORCED      | Khaparkheda Unit 3  | 22-Dec-20 | 8.27      | 23-Dec-20  | 11.09      | Reheat protection                                                    |
| FORCED      | Adani U-3           | 23-Dec-20 | 23.59     | 12-Jan-21  | 19.52      | Turbine Bearing Vibration.                                           |
| FORCED      | Koradi Unit 10      | 23-Dec-20 | 12.15     | 23-Dec-20  | 15.23      | Turbine Tripped.                                                     |
| FORCED      | Bhusawal Unit 5     | 24-Dec-20 | 21.15     | 09-Jan-21  | 13.23      | Due to clinker formed inside the bottom ash hopper.                  |
| FORCED      | Chandrapur Unit 7   | 24-Dec-20 | 6.25      | 26-Dec-20  | 19.55      | Boiler Tube Leakage                                                  |
| FORCED      | Uran Unit 6         | 25-Dec-20 | 0.16      | 26-Dec-20  | 16.24      | Filter replacement.                                                  |
| FORCED      | Koradi Unit 10      | 25-Dec-20 | 10.56     | 03-Jan-21  | 22.4       | Boiler Tube Leakage                                                  |
| FORCED      | Uran Unit A0        | 25-Dec-20 | 10.53     | 25-Dec-20  | 17.58      | AMR Installation work                                                |

**Weekly Line Outage/Trippings for 21.12.2020 to 27.12.2020**

| Outage Type | Name                                      | Trip Date | Trip Time | Sync. Date | Sync. Time | Voltage Level | Reason                                                                                      |
|-------------|-------------------------------------------|-----------|-----------|------------|------------|---------------|---------------------------------------------------------------------------------------------|
| PO          | Mudshingi Chikodi                         | 24-Sep-19 | 17.12     |            | Continued  | 220 KV        | No Schedule(Charge from Mudshingi end only)                                                 |
| PO          | Talandage - Chikodi                       | 01-Oct-19 | 17.1      |            | Continued  | 220 KV        | No Schedule(Close at Chikodi end only)                                                      |
| PO          | Parli 3 (Old Gcr)-Girwali Ckt-3           | 20-Aug-20 | 13.05     |            | Continued  | 220 KV        | Erection of Tower Due to Railway Crossing                                                   |
| PO          | Parli 3(Old Gcr)- Girwali Ckt 4           | 20-Aug-20 | 13.06     |            | Continued  | 220 KV        | Erection of Tower Due to Railway Crossing                                                   |
| PO          | Trombay - Kalwa                           | 16-Dec-20 | 6.43      |            | Continued  | 220 KV        | HTLS work.                                                                                  |
| EO          | Boisar(MS) - Boisar (PG) - I              | 20-Dec-20 | 21.55     | 21-Dec-20  | 0.13       | 220 KV        | Attending Hot Spot                                                                          |
| PO          | Vita Alkud                                | 21-Dec-20 | 5.44      | 21-Dec-20  | 10.52      | 220 KV        | Fixing of PA Rod                                                                            |
| PO          | Vita - Mhaishal                           | 21-Dec-20 | 6.09      | 21-Dec-20  | 10.52      | 220 KV        | Fixing of PA Rod                                                                            |
| PO          | Adlabs - Pedambe                          | 21-Dec-20 | 6.5       | 22-Dec-20  | 14.26      | 220 KV        | Erection of New Tower                                                                       |
| PO          | Mahad - Pedambe                           | 21-Dec-20 | 7.36      | 22-Dec-20  | 14.25      | 220 KV        | Erection of New Tower                                                                       |
| PO          | Sawantwadi-Bidri                          | 21-Dec-20 | 9.1       | 21-Dec-20  | 16.58      | 220 KV        | Insulator Cleaning work                                                                     |
| PO          | 220/132 kv 100MVA ICT @ Bhandara.         | 21-Dec-20 | 9.16      | 21-Dec-20  | 18.1       | 220 KV        | OLTC Problem.                                                                               |
| PO          | Yeotmal- Pusad                            | 21-Dec-20 | 10.19     | 21-Dec-20  | 14.05      | 220 KV        | Heavy Leakage with rising nature observed from Y Phase.                                     |
| PO          | 220/132/11 Kv 200 Mva Cgl lct 2 @Amravati | 21-Dec-20 | 10.27     | 21-Dec-20  | 17.55      | 220 KV        | Testing Work                                                                                |
| PO          | Borivali - Tarapur                        | 21-Dec-20 | 11.03     | 21-Dec-20  | 15.59      | 220 KV        | Line Maintenance work                                                                       |
| PO          | Chinchwad- Parvati                        | 21-Dec-20 | 12.06     | 25-Dec-20  | 20.25      | 220 KV        | CB Overhauling work                                                                         |
| PO          | Balapur-Malegaon                          | 21-Dec-20 | 12.1      | 21-Dec-20  | 18.04      | 220 KV        | Replacement and Tightening of Nut Bolt                                                      |
| PO          | Shivajinagar-Gangapur                     | 21-Dec-20 | 14.57     | 21-Dec-20  | 19.46      | 220 KV        | Line Maintenance work                                                                       |
| PO          | Mumewadi -Halkarni ckt-II                 | 22-Dec-20 | 7.27      | 22-Dec-20  | 18.08      | 220 KV        | Testing & Commissioning of new control & relay panels.                                      |
| PO          | Malharpeth - Karad(400kv)                 | 22-Dec-20 | 9.36      | 22-Dec-20  | 14.19      | 220 KV        | CRM vales of 220kv.                                                                         |
| PO          | 220/132kv 100 Mva lct 2 @Peth             | 22-Dec-20 | 10.02     | 22-Dec-20  | 15.07      | 220 KV        | Replacement of 198Kv LA for 220/132Kv 100MVA ICT-2 (HV side)                                |
| PO          | 220/132 KV 100MVA ICT-II @ Bhokar         | 22-Dec-20 | 12.05     | 22-Dec-20  | 18.15      | 220 KV        | Testing & maintenance work.                                                                 |
| PO          | ALKUD - MENDHEGIRI CKT - 1                | 22-Dec-20 | 13.35     | 22-Dec-20  | 17.57      | 220 KV        | Jumpering for metering bay.                                                                 |
| Tripped     | Dhule - Dondaicha Ckt                     | 22-Dec-20 | 13.56     | 22-Dec-20  | 15.03      | 220 KV        | Bus bar protection operated at bus-1.                                                       |
| Tripped     | Dhule-Amalner( 220kv)                     | 22-Dec-20 | 13.56     | 22-Dec-20  | 15.13      | 220 KV        | Bus bar protection operated at bus-1.                                                       |
| Tripped     | 220/132 Kv 150 MVA ICT @Boisar-II         | 22-Dec-20 | 14.44     | 22-Dec-20  | 22.35      | 220 KV        | Internal fault Master trip.                                                                 |
| PO          | New Koyna - Niwali                        | 23-Dec-20 | 9.4       | 23-Dec-20  | 18.11      | 220 KV        | Foe Cold & Chemical Washing Washing Of Insulator< Tree Cutting.                             |
| PO          | Vita - Ghatnandre                         | 23-Dec-20 | 10        | 23-Dec-20  | 17.34      | 220 KV        | Cold Washing Insulator.                                                                     |
| PO          | Nadgaonpeth-Amravati                      | 23-Dec-20 | 10.33     | 23-Dec-20  | 17.31      | 220 KV        | For Diagnostic Testing Work.                                                                |
| PO          | 220/100 Kv 200 Mva Aval lct 2 @Taloja     | 23-Dec-20 | 11.21     | 23-Dec-20  | 18.27      | 220 KV        | Routine Maintenance Work                                                                    |
| PO          | Gadchandur - Virur-I                      | 23-Dec-20 | 11.24     | 23-Dec-20  | 17.2       | 220 KV        | Testing Work                                                                                |
| PO          | Osmanabad - Barshi                        | 23-Dec-20 | 11.39     | 23-Dec-20  | 16.42      | 220 KV        | Work At Barshi.                                                                             |
| PO          | Shivajinagar-Gangapur                     | 23-Dec-20 | 14.3      | 23-Dec-20  | 19.3       | 220 KV        | Replacement Of Jumper With Jump Cone At Location No. 323 324 328 329.                       |
| PO          | New Koyna - Niwali                        | 24-Dec-20 | 8.3       | 24-Dec-20  | 18.23      | 220 KV        | Cold & Chemical washing Washing of insulators tree cutting work at loc nos. 1-13 6-195 1-53 |

| Outage Type | Name                                             | Trip Date | Trip Time | Sync. Date | Sync. Time | Voltage Level | Reason                                                                               |
|-------------|--------------------------------------------------|-----------|-----------|------------|------------|---------------|--------------------------------------------------------------------------------------|
| PO          | Vita - Ghatnandre                                | 24-Dec-20 | 10        | 24-Dec-20  | 18.1       | 220 KV        | Cold washing of insulators                                                           |
| PO          | Roma-Bhavegar                                    | 24-Dec-20 | 10.07     | 24-Dec-20  | 18.03      | 220 KV        | Diagnostic testing work.                                                             |
| PO          | Taloja II - OCIL-I                               | 24-Dec-20 | 10.11     | 24-Dec-20  | 13.38      | 220 KV        | R ph LA replacement work at Taloja ss. & R ph CT hot spot attending work at ocil end |
| HT          | Chinchwad-Hinjewadi I                            | 24-Dec-20 | 11.14     | 24-Dec-20  | 18.37      | 220 KV        | Load management.                                                                     |
| HT          | Sahara-Urse                                      | 24-Dec-20 | 11.36     | 24-Dec-20  | 17.42      | 220 KV        | For load management.                                                                 |
| PO          | TALEGAON - TALEGAON ambi (PG)-I                  | 24-Dec-20 | 12.22     | 24-Dec-20  | 17.3       | 220 KV        | Half yearly maintenance Diagnostic testing work.                                     |
| Tripped     | Adlabs - Pedambe                                 | 24-Dec-20 | 13.48     | 24-Dec-20  | 15.05      | 220 KV        | R-Ph 9.56KM 4.27K AMP Line tripped from pedambe end only.                            |
| PO          | Ranjangaon-Lonikand                              | 24-Dec-20 | 16.27     | 24-Dec-20  | 20.1       | 220 KV        | Replacement R ph LA having 1000 micro Amp leakage current.                           |
| PO          | New Koyna - Niwali                               | 25-Dec-20 | 8.56      | 25-Dec-20  | 18.2       | 220 KV        | Cold & Chemical Washing Tree Cutting Work At Loc No. 1-3 6-195 1-53.                 |
| PO          | 220/132 Kv 100 Mva T&R Ict-1 @Bambhori           | 25-Dec-20 | 9.45      | 25-Dec-20  | 13         | 220 KV        | Quarterly Maintenance Work                                                           |
| PO          | 220/22 Kv 50 Mva Bhel Ptr 1 @Kamba               | 25-Dec-20 | 9.45      | 25-Dec-20  | 13.58      | 220 KV        | Replacement Of Buchhloz relay And Bay Maintenance Work.                              |
| PO          | 220/100 Kv 200 Mva Vijai Ict 3 @Padghe           | 25-Dec-20 | 10.07     | 25-Dec-20  | 17.25      | 220 KV        | Replacement Of Rusted "U" Bolts At 100KV Side Of Main Bus.                           |
| PO          | 220/132 Kv 200 Mva ICT-I @Girwali                | 25-Dec-20 | 10.35     | 25-Dec-20  | 12.23      | 220 KV        | Testing Work                                                                         |
| PO          | ALKUD - MENDHEGIRI CKT - 1                       | 25-Dec-20 | 11.06     | 25-Dec-20  | 22.03      | 220 KV        | For Connecting Metering CT PT LA CC Drops At 400/220KV Alkud S/s.                    |
| PO          | Chinchwad- Parvati                               | 25-Dec-20 | 12.06     | 25-Dec-20  | 20.35      | 220 KV        | For CB Overhauling Work.                                                             |
| PO          | 220/100 Kv 200 MVA ICT IV @Apta                  | 25-Dec-20 | 13.27     | 25-Dec-20  | 18.14      | 220 KV        | Cabling Work Of CTR Fire Protection System Of ICT 4 Bay Agency.                      |
| Tripped     | Ghatghar - Bapgaon                               | 25-Dec-20 | 13.4      | 25-Dec-20  | 16.02      | 220 KV        | Black Start activity.                                                                |
| PO          | 220/132 Kv 100 Mva T&R Ict-2 @Bambhori           | 25-Dec-20 | 14        | 25-Dec-20  | 16.3       | 220 KV        | Tan delta measurement.                                                               |
| PO          | 220/22 Kv 50 Mva Areva Ptr 2 @Anandnagar         | 25-Dec-20 | 14.08     | 25-Dec-20  | 15.3       | 220 KV        | For Inspection Oil Leakage From OLTC Conservator Tank.                               |
| PO          | Shivajinagar-Gangapur                            | 25-Dec-20 | 15.04     | 25-Dec-20  | 18.41      | 220 KV        | Line Maintenance work                                                                |
| Tripped     | Kamba - Kolshet                                  | 25-Dec-20 | 17.34     | 25-Dec-20  | 18.11      | 220 KV        | B-PH To Earth.                                                                       |
| Tripped     | Kolshet-Roma                                     | 25-Dec-20 | 17.34     | 26-Dec-20  | 9.01       | 220 KV        | Insulator string Broken at kolshet end.                                              |
| PO          | 220/33kV 125 MVA Transformer 3 @Chembur R/S      | 26-Dec-20 | 7.28      | 27-Dec-20  | 15.26      | 220 KV        | Replacement work                                                                     |
| PO          | New Koyna - Niwali                               | 26-Dec-20 | 8.49      | 26-Dec-20  | 18.01      | 220 KV        | For cold & chemical washing of Insulators tree cutting                               |
| PO          | EKLAHRE (GCR)Nashik-Airoli Knowledge Park        | 26-Dec-20 | 9.22      | 26-Dec-20  | 16.04      | 220 KV        | Replacement of Jumper                                                                |
| PO          | 220/33kV 125 MVA Transformer 1 @Chembur R/S      | 26-Dec-20 | 9.4       | 27-Dec-20  | 13.32      | 220 KV        | CT Replacement work                                                                  |
| PO          | Uran - Apta IV                                   | 26-Dec-20 | 10        | 26-Dec-20  | 15         | 220 KV        | For Black Start activity                                                             |
| Tripped     | Chikhli-Jalna-II                                 | 26-Dec-20 | 10.24     | 26-Dec-20  | 19.41      | 220 KV        | LTS operated due to ICT Tripping at Akola                                            |
| Tripped     | Chikhli-Jalna-I                                  | 26-Dec-20 | 10.24     | 26-Dec-20  | 19.41      | 220 KV        | LTS operated due to ICT Tripping at Akola                                            |
| EO          | 220/132 Kv 200 Mva Emco Ict 2 @Raymond (Nasik 2) | 26-Dec-20 | 11.09     | 26-Dec-20  | 17.15      | 220 KV        | Attending Oil Leakage                                                                |

| Outage Type | Name                                              | Trip Date | Trip Time | Sync. Date | Sync. Time | Voltage Level | Reason                                                                                                                  |
|-------------|---------------------------------------------------|-----------|-----------|------------|------------|---------------|-------------------------------------------------------------------------------------------------------------------------|
| PO          | Urse - Talegaon (Ambi) Ckt 1                      | 26-Dec-20 | 12.19     | 26-Dec-20  | 16.43      | 220 KV        | Testing Work                                                                                                            |
| EO          | 220/100 Kv 100 Mva Cgl Ict 1 @Taloja              | 26-Dec-20 | 13.5      | 26-Dec-20  | 17.3       | 220 KV        | Attending Oil Leakage                                                                                                   |
| PO          | 220/132 Kv 200 Mva Vijai Ict 1 @Ranjangaon        | 26-Dec-20 | 16.27     | 26-Dec-20  | 19.31      | 220 KV        | LA Replacement                                                                                                          |
| PO          | 220/100 Kv 100 Mva Cgl Ict 2 @Tambati             | 27-Dec-20 | 11.11     | 31-Dec-20  | 15.12      | 220 KV        | HV circuit Breaker overhauling                                                                                          |
| PO          | Trombay-Chembur Line 1                            | 27-Dec-20 | 13.33     | 27-Dec-20  | 13.37      | 220 KV        | Replacement work                                                                                                        |
| EO          | Karad - Kadegaon                                  | 27-Dec-20 | 17.01     | 27-Dec-20  | 20.5       | 220 KV        | Replacement work                                                                                                        |
| PO          | Karad Solapur (PG)                                | 03-May-17 | 11:49     |            | Continued  | 400 KV        | Line Converted As 220 Kv Solapur (PG)- Jeur From LOC 403                                                                |
| Tripped     | 400/220/33 Kv 315 Mva ICT 1 @Padghe               | 15-Nov-18 | 10.07     |            | Continued  | 400 KV        | Differential Protection Declared Faulty.                                                                                |
| PO          | 400/220kv 315 MVA ICT I @ KOLHAPUR-III (TALANDGE) | 10-Aug-20 | 9.58      |            | Continued  | 400 KV        | Replacement of existing 315 MVA ICT by 3*167 MVA ICT.                                                                   |
| PO          | 400/220/33 Kv 315 Mva Ict 2 @Dhule                | 23-Sep-20 | 9.12      |            | Continued  | 400 KV        | Augmentation work of 400/220 315MVA ICT-II to 501MVA                                                                    |
| HT          | Dhule Sar'Sarovar II                              | 19-Dec-20 | 20.02     | 23-Dec-20  | 11.06      | 400 KV        | Over Voltage                                                                                                            |
| HT          | Padghe - Nagothane - I                            | 20-Dec-20 | 23.42     | 21-Dec-20  | 8.55       | 400 KV        | Over Voltage                                                                                                            |
| Tripped     | 400/220/33 Kv 315 MVA ICT II @Babhleshwar         | 21-Dec-20 | 5.31      | 21-Dec-20  | 19.34      | 400 KV        | Bucholz Protection Optd                                                                                                 |
| Tripped     | Akola Aurangabad(PG) I                            | 21-Dec-20 | 6.5       | 21-Dec-20  | 11.06      | 400 KV        | Distance Protection                                                                                                     |
| Tripped     | Koradi Bhilai                                     | 21-Dec-20 | 9.11      | 21-Dec-20  | 9.44       | 400 KV        | Tripped                                                                                                                 |
| EO          | Koradi-Bhusawal                                   | 21-Dec-20 | 16.52     | 21-Dec-20  | 20.21      | 400 KV        | Replacement of B phase Flashover String                                                                                 |
| HT          | Padghe - Nagothane - I                            | 22-Dec-20 | 2.04      | 23-Dec-20  | 10.59      | 400 KV        | Over Voltage                                                                                                            |
| HT          | Akola Aurangabad(PG) I                            | 22-Dec-20 | 12.2      | 22-Dec-20  | 12.43      | 400 KV        | To take L/R in service at akola end.                                                                                    |
| PO          | Dhule Sar'Sarovar II                              | 22-Dec-20 | 12.45     | 23-Dec-20  | 11.06      | 400 KV        | Replacement of damaged earthwire disc insulator & O.M.work.                                                             |
| Tripped     | Dhule(MS)- Dhule(BDTCL) -1                        | 22-Dec-20 | 13.56     | 22-Dec-20  | 15.26      | 400 KV        | Bus bar protection operated at bus-1.                                                                                   |
| Tripped     | Dhule- Bableshwar - I                             | 22-Dec-20 | 13.56     | 22-Dec-20  | 15.44      | 400 KV        | Bus bar protection operated at bus-1.                                                                                   |
| Tripped     | Dhule Sar'Sarovar I                               | 22-Dec-20 | 13.56     | 22-Dec-20  | 16.01      | 400 KV        | Bus bar protection operated at bus-1.                                                                                   |
| Tripped     | Dhule Khandwa II                                  | 22-Dec-20 | 13.56     | 22-Dec-20  | 15.45      | 400 KV        | Bus bar protection operated at bus-1.                                                                                   |
| Tripped     | 400/220/33 Kv 315 Mva Ict 1 @Dhule                | 22-Dec-20 | 13.56     | 22-Dec-20  | 14.48      | 400 KV        | Bus bar protection operated at bus-1.                                                                                   |
| PO          | 400/15.75 KV 250MVA GT II @ Chandrapur            | 22-Dec-20 | 17.48     | 22-Dec-20  | 19.02      | 400 KV        | AMR meter installation.                                                                                                 |
| HT          | Dhule- Bableshwar - I                             | 22-Dec-20 | 19.43     | 23-Dec-20  | 7.01       | 400 KV        | Over Voltage                                                                                                            |
| HT          | Bhusawal-Aurangabad                               | 22-Dec-20 | 19.47     | 23-Dec-20  | 6.37       | 400 KV        | Over Voltage                                                                                                            |
| PO          | Chandrapur - Khaperkheda                          | 23-Dec-20 | 6.53      | 23-Dec-20  | 21.25      | 400 KV        | Shifting of line on ERS towers for erection of proposed tower below the existing line for railways height raising work. |
| PO          | Chandrapur-II - Nanded ckt II                     | 23-Dec-20 | 9.48      | 23-Dec-20  | 17.51      | 400 KV        | Diagnostic Testing work.                                                                                                |
| PO          | Dhule Sar'Sarovar I                               | 23-Dec-20 | 13.49     | 24-Dec-20  | 6.32       | 400 KV        | Replacement Of Damaged Earth wire Replacement PID Suspicious Disc Insulator And Other Maintenance Work.(RFC 18.35)      |
| HT          | Bhusawal-Aurangabad                               | 23-Dec-20 | 20.04     | 24-Dec-20  | 7.24       | 400 KV        | Over Voltage                                                                                                            |
| EO          | Akola II - RPL(Rattanindia) Ckt-II                | 23-Dec-20 | 21.17     | 24-Dec-20  | 4.56       | 400 KV        | Attending Hot Spot                                                                                                      |
| EO          | Chakan Talegaon(Pg)                               | 23-Dec-20 | 22.24     | 24-Dec-20  | 5.06       | 400 KV        | Attending Hot Spot                                                                                                      |
| HT          | Padghe - Nagothane - I                            | 23-Dec-20 | 22.48     | 24-Dec-20  | 8.35       | 400 KV        | Over Voltage                                                                                                            |
| PO          | Lonikand 1 - Talegaon(Pgcil)                      | 24-Dec-20 | 10.11     | 24-Dec-20  | 15.05      | 400 KV        | AMP work.                                                                                                               |

| Outage Type | Name                                             | Trip Date | Trip Time | Sync. Date | Sync. Time | Voltage Level | Reason                                                      |
|-------------|--------------------------------------------------|-----------|-----------|------------|------------|---------------|-------------------------------------------------------------|
| EO          | 400/220 KV 500 MVA ICT I @ Kudus                 | 24-Dec-20 | 12.32     | 24-Dec-20  | 18.28      | 400 KV        | Safety purpose for erection ICT-2.                          |
| HT          | Khadka-Aurangabad (Waluj)                        | 24-Dec-20 | 18.08     | 25-Dec-20  | 6.47       | 400 KV        | Over Voltage                                                |
| HT          | Dhule Sar'Sarovar II                             | 24-Dec-20 | 19.01     | 25-Dec-20  | 7.37       | 400 KV        | Over Voltage                                                |
| PO          | 400/220kV 315MVA ICT-III @ Kharghar              | 25-Dec-20 | 0.06      | 27-Dec-20  | 22.38      | 400 KV        | Oil Filtration work.                                        |
| PO          | Padghe - Nagothane - II                          | 25-Dec-20 | 11.31     | 26-Dec-20  | 6.4        | 400 KV        | For String Replacement Work At Loc No. 307.                 |
| PO          | Girwali- Lonikand 2                              | 25-Dec-20 | 11.54     | 25-Dec-20  | 15.55      | 400 KV        | Hardware Tightening & Fitting Work.                         |
| HT          | Khadka-Aurangabad (Waluj)                        | 25-Dec-20 | 17.55     | 26-Dec-20  | 6.49       | 400 KV        | Over Voltage                                                |
| HT          | Dhule Sar'Sarovar II                             | 25-Dec-20 | 18.07     | 26-Dec-20  | 6.26       | 400 KV        | Over Voltage                                                |
| EO          | Padghe - Kalwa- I                                | 26-Dec-20 | 5.36      | 26-Dec-20  | 8.18       | 400 KV        | To Attend Frequent Tripping Of Metering MCB Of R-Phase CVT. |
| EO          | Akola-Nandgaonpeth (RPL)                         | 26-Dec-20 | 6.16      | 26-Dec-20  | 20.26      | 400 KV        | Attending Hot Spot                                          |
| PO          | Babhaleshwar - Padghe-II                         | 26-Dec-20 | 9.17      | 26-Dec-20  | 18.26      | 400 KV        | Tan Delta Measurment of CTs                                 |
| PO          | Wardha (Pg) Warora I                             | 26-Dec-20 | 9.52      | 26-Dec-20  | 17.02      | 400 KV        | CVT Testing                                                 |
| Tripped     | 400/220/33 Kv 315 Mva ICT I @ Akola (M)          | 26-Dec-20 | 10.24     | 26-Dec-20  | 19.15      | 400 KV        | Bucholz Protection Optd                                     |
| HT          | Dhule Sar'Sarovar I                              | 26-Dec-20 | 17.35     | 27-Dec-20  | 9.13       | 400 KV        | Over Voltage                                                |
| HT          | Khadka-Aurangabad (Waluj)                        | 26-Dec-20 | 22.53     | 27-Dec-20  | 8.01       | 400 KV        | Over Voltage                                                |
| PO          | Khadka - Bableshtar                              | 27-Dec-20 | 9.09      | 27-Dec-20  | 18.47      | 400 KV        | Cold Washing of Insulator string                            |
| PO          | Dhule Sar'Sarovar II                             | 27-Dec-20 | 9.37      | 28-Dec-20  | 7.5        | 400 KV        | Maintenance Work(RFC at 17.25 Hrs)                          |
| Tripped     | 400/220kv 315 Mva ICT II @Karad                  | 27-Dec-20 | 13.54     | 27-Dec-20  | 15.34      | 400 KV        | Differential protection                                     |
| HT          | Khadka-Aurangabad (Waluj)                        | 27-Dec-20 | 19.1      | 28-Dec-20  | 7.16       | 400 KV        | Over Voltage                                                |
| PO          | 765/400 KV 1500 MVA ICT II @ Aurangabad (Ektuni) | 20-Dec-20 | 9.57      | 21-Dec-20  | 5.35       | 765 KV        | Routine Maintenance Work                                    |
| PO          | Koradi III - Akola II- ckt-II                    | 21-Dec-20 | 11.45     | 21-Dec-20  | 16.39      | 765 KV        | Line Equipment Maintenance activities.                      |
| Tripped     | 765/400 KV 1500 MVA ICT II @ Aurangabad (Ektuni) | 21-Dec-20 | 20.51     | 21-Dec-20  | 23.12      | 765 KV        | Bucholz Protection Optd.                                    |