

State Load Despatch Center,Airoli (MSETCL)
Power System Position from 27/Mar/2017 to 02/Apr/2017

Supply Position During Morning Peak (MW)

Date	Time	MSGENCO				Central Sector Receipt	Wind	CPP	SOLAR	TPCL Exch.	MSEDCL Cateder Demand	Load Shedding(LS)	MSEDCL Demand (Incl. LS)	TPCL Gen.	R-INFRA Gen.	State Demand Met	State Demand (Incl. LS)	Freq.
		THM	HYDRO	GAS	Total													
		MW	MW	MW	MW	MW	MW	MW	MW	MW	MW	MW	MW	MW	MW	MW	MW	Hzs
27/03/2017	12 Hrs	6634	1901	402	8937	6443	393	4426	184	-1367	19016	394	19410	1372	489	22244	22638	49.99
28/03/2017	12 Hrs	6633	1509	433	8575	6663	98	4930	182	-1118	19330	0	19330	1249	499	22196	22196	49.97
29/03/2017	12 Hrs	6195	2056	418	8669	6571	66	5127	166	-1473	19126	431	19557	1371	492	22462	22893	49.94
30/03/2017	12 Hrs	6557	1747	430	8734	6326	45	5495	172	-1514	19258	424	19682	1333	485	22590	23014	49.99
31/03/2017	12 Hrs	6492	543	414	7449	6655	67	6120	169	-1539	18921	0	18921	1251	497	22208	22208	49.96
01/04/2017	12 Hrs	6535	433	293	7261	6723	135	5987	144	-1379	18871	0	18871	1166	434	21850	21850	49.98
02/04/2017	12 Hrs	6202	1169	294	7665	5641	404	5570	198	-1003	18475	0	18475	804	499	20781	20781	49.95
Maximum		6634	2056	433	8937	6723	404	6120	198	-1003	19330	431	19682	1372	499	22590	23014	49.99
Minimum		6195	433	293	7261	5641	45	4426	144	-1539	18475	0	18475	804	434	20781	20781	49.94
Average		6464	1337	383	8184	6432	173	5379	174	-1342	19000	178	19178	1221	485	22047	22226	49.97

Supply Position During Day Peak (MW)

Date	Time	MSGENCO				Central Sector Receipt	Wind	CPP	SOLAR	TPCL Exch.	MSEDCL Cateder Demand	Load Shedding(LS)	MSEDCL Demand (Incl. LS)	TPCL Gen.	R-INFRA Gen.	State Demand Met	State Demand (Incl. LS)	Freq.
		THM	HYDRO	GAS	Total													
		MW	MW	MW	MW	MW	MW	MW	MW	MW	MW	MW	MW	MW	MW	MW	MW	Hzs
27/03/2017	13 Hrs	6616	1813	400	8829	6465	280	4491	193	-1363	18895	650	19545	1377	499	22134	22784	49.97
28/03/2017	13 Hrs	6704	1541	419	8664	6143	130	5051	188	-1237	18939	0	18939	1180	503	21859	21859	49.95
29/03/2017	13 Hrs	5673	1944	431	8048	6674	88	5133	188	-1470	18661	667	19328	1372	499	22002	22669	49.90
30/03/2017	13 Hrs	6592	1719	426	8737	6165	63	5490	182	-1430	19207	538	19745	1380	500	22517	23055	50.00
31/03/2017	16 Hrs	6519	914	430	7863	6335	169	6155	107	-1444	19185	0	19185	1268	500	22397	22397	49.97
01/04/2017	16 Hrs	6517	450	305	7272	6338	702	5936	117	-1251	19114	0	19114	1179	503	22047	22047	49.99
02/04/2017	13 Hrs	6192	1182	300	7674	5570	426	5605	192	-977	18490	0	18490	909	504	20880	20880	49.96
Maximum		6704	1944	431	8829	6674	702	6155	193	-977	19207	667	19745	1380	504	22517	23055	50.00
Minimum		5673	450	300	7272	5570	63	4491	107	-1470	18490	0	18490	909	499	20880	20880	49.90
Average		6402	1366	387	8155	6241	265	5409	167	-1310	18928	265	19193	1238	501	21977	22242	49.96

Supply Position During Evening Peak (MW)

Date	Time	MSGENCO				Central Sector Receipt	Wind	CPP	SOLAR	TPCL Exch.	MSEDCL Cateder Demand	Load Shedding(LS)	MSEDCL Demand (Incl. LS)	TPCL Gen.	R-INFRA Gen.	State Demand Met	State Demand (Incl. LS)	Freq.
		THM	HYDRO	GAS	Total													
		MW	MW	MW	MW	MW	MW	MW	MW	MW	MW	MW	MW	MW	MW	MW	MW	Hzs
27/03/2017	20 Hrs	6572	1214	415	8201	5892	80	4342	0	-1156	17359	0	17359	1309	506	20330	20330	49.97
28/03/2017	22 Hrs	6501	286	440	7227	5627	278	5177	0	-1529	16780	0	16780	791	388	19488	19488	49.90
29/03/2017	20 Hrs	6388	863	442	7693	5944	425	5315	0	-1442	17935	0	17935	1139	503	21019	21019	49.94
30/03/2017	20 Hrs	6436	251	436	7123	5476	628	5979	0	-1492	17714	0	17714	1084	388	20678	20678	49.91
31/03/2017	20 Hrs	5873	227	422	6522	6048	428	5723	0	-1571	17150	0	17150	961	388	20070	20070	49.92
01/04/2017	20 Hrs	5823	338	297	6458	5744	777	5334	0	-1449	16864	0	16864	933	387	19633	19633	49.99
02/04/2017	20 Hrs	5620	545	297	6462	5522	653	5371	0	-1263	16745	0	16745	754	387	19149	19149	49.96
Maximum		6572	1214	442	8201	6048	777	5979	0	-1156	17935	0	17935	1309	506	21019	21019	49.99
Minimum		5620	227	297	6458	5476	80	4342	0	-1571	16745	0	16745	754	387	19149	19149	49.90
Average		6173	532	393	7098	5750	467	5320	0	-1415	17221	0	17221	996	421	20052	20052	49.94

Supply Position During Night Off Peak (MW)

Date	Time	MSGENCO				Central Sector Receipt	Wind	CPP	SOLAR	TPCL Exch.	MSEDCL Cateder Demand	Load Shedding(LS)	MSEDCL Demand (Incl. LS)	TPCL Gen.	R-INFRA Gen.	State Demand Met	State Demand (Incl. LS)	Freq.
		THM	HYDRO	GAS	Total													
		MW	MW	MW	MW	MW	MW	MW	MW	MW	MW	MW	MW	MW	MW	MW	MW	Hzs
27/03/2017	4 Hrs	6579	204	447	7230	5457	455	4250	0	-551	16841	0	16841	825	509	18726	18726	49.98
28/03/2017	4 Hrs	6412	264	444	7120	5766	123	4664	0	-650	17023	0	17023	866	509	19048	19048	49.91
29/03/2017	4 Hrs	6355	262	445	7062	5496	286	5022	0	-834	17032	0	17032	699	509	19074	19074	49.92
30/03/2017	4 Hrs	6209	132	442	6783	5391	596	5234	0	-860	17144	0	17144	697	508	19209	19209	49.97
31/03/2017	5 Hrs	6121	200	433	6754	5136	398	6102	0	-891	17499	0	17499	703	388	19481	19481	50.01
01/04/2017	23 Hrs	5739	370	300	6409	5589	457	5687	0	-1410	16732	0	16732	769	388	19299	19299	49.97
02/04/2017	4 Hrs	5506	118	301	5925	5185	509	5563	0	-924	16258	0	16258	698	388	18268	18268	49.99
Maximum		6579	370	447	7230	5766	596	6102	0	-551	17499	0	17499	866	509	19481	19481	50.01
Minimum		5506	118	300	5925	5136	123	4250	0	-1410	16258	0	16258	697	388	18268	18268	49.91
Average		6132	221	402	6755	5431	403	5218	0	-874	16933	0	16933	751	457	19015	19015	49.96

Details of Supply Position (MUs)

Date	MSGENCO				Pench (MS)	Central Sector Receipt	Central Sector Share	WIND	CPP	SOLAR	TPCL Gen.	R-INFRA Gen.	TPCL Exch.	Energy Requirement		
	THM	HYDRO	GAS	Total										MSEDCL	MUMBAI	STATE
	Mus	Mus	Mus	Mus	Mus	Mus	Mus	Mus	Mus	Mus	Mus	Mus	Mus	Mus	Mus	Mus
27/03/2017	157.912	22.912	10.231	191.055	0.456	145.213	144.908	6.260	105.692	1.370	26.533	12.080	-25.140	424.450	63.752	488.202
28/03/2017	156.613	15.342	10.462	182.417	0.434	144.574	145.644	4.207	118.265	1.314	24.320	11.613	-25.343	425.434	61.276	486.710
29/03/2017	150.194	21.734	10.513	182.441	0.043	142.581	140.426	6.775	123.244	1.307	25.909	12.091	-28.604	427.744	66.604	494.348
30/03/2017	152.388	17.027	10.498	179.913	0.000	141.989	143.749	9.660	133.002	1.256	24.040	11.504	-30.706	435.114	66.250	501.364
31/03/2017	148.676	7.866	10.445	166.987	0.045	141.840	146.809	7.860	143.071	1.201	22.898	10.520	-31.741	429.218	65.159	494.377
01/04/2017	145.657	7.355	7.310	160.322	0.080	143.718	142.535	11.282	139.170	1.200	21.070	9.978	-30.204	425.488	61.252	486.740
02/04/2017	143.256	9.531	7.174	159.961	0.065	131.792	132.177	13.944	132.331	1.362	18.323	10.095	-24.792	414.598	53.210	467.808
Maximum	157.912	22.912	10.513	191.055	0.456	145.213	146.809	157.912	143.071	1.370	26.533	12.091	-24.792	435.114	66.604	501.364
Minimum	143.256	7.355	7.174	159.961	0.000	131.792	132.177	143.256	105.692	1.200	18.323	9.978	-31.741	414.598	53.210	467.808
Average	150.671	14.538	9.519	174.728	0.160	141.672	142.321	150.671	127.825	1.287	23.299	11.126	-28.076	426.007	62.500	488.507

Details of Koyna Water Consumption (in TMC)

Date	For the Day	For the Month	Balance
27/03/2017	0.428	5.455	12.323
28/03/2017	0.274	5.729	12.049
29/03/2017	0.385	6.114	11.664
30/03/2017	0.295	6.409	11.369
31/03/2017	0.100	6.509	11.269
01/04/2017	0.080	0.080	11.189
02/04/2017	0.150	0.230	11.039

State Load Despatch Center, Airoli (MSETCL)
Central Sector Share/Drawal from 27/Mar/2017 to 02/Apr/2017

Date	DAY	Central Sector Share		Total Interstate Bilateral Purchase		Total Share		Total Drawal		Overdrawal(+) / UnderDrawal(-)	
		MUs	Avg. MW	MUs	Avg. MW	MUs	Avg. MW	MUs	Avg. MW	MUs	Avg. MW
		1		2		1+2=3		4		3-4=5	
27/03/2017	MONDAY	124.375	6017	20.533	856	144.908	6038	145.213	6051	0.305	13
28/03/2017	TUESDAY	122.691	6046	22.953	956	145.644	6068	144.574	6024	-1.070	-45
29/03/2017	WEDNESDA	119.095	5830	21.331	889	140.426	5851	142.581	5941	2.155	90
30/03/2017	THURSDAY	120.468	5966	23.281	970	143.749	5990	141.989	5916	-1.760	-73
31/03/2017	FRIDAY	125.046	6095	21.763	907	146.809	6117	141.840	5910	-4.969	-207
01/04/2017	SATURDAY	118.326	5915	24.209	1009	142.535	5939	143.718	5988	1.183	49
02/04/2017	SUNDAY	115.850	5491	16.327	680	132.177	5507	131.792	5491	-0.385	-16
Total		845.852		150.396		996.248		991.707		-4.541	

GENERATING UNITS OUTAGES FOR THE WEEK FROM 27/03/2017 TO 02/04/2017							
Generator	Generating Unit	Capacity	Tripped Date	Tripped Time	Synch. Date	Synch Time	Reason
PLANNED OUTAGES							
IPP	Tata Trombay 6	500MW	15/Jul/2015	17.08		Continued.	Economic shutdown(Converted to AOH for 30 Days from 00.00Hrs 06-03-2016)
MSPGCL	Chandrapur Unit 7	500MW	25/Jan/2017	19.32		Continued.	Capital Overhaul
FORCED OUTAGES							
RGPL	Dabhol Dabhol 1B	230MW	28/May/2013	22.02		Continued.	Gas Shortage.
RGPL	Dabhol Dabhol 1X	230MW	27/Jun/2013	21.46		Continued.	Gas Shortage
RGPL	Dabhol Dabhol 1A	230MW	27/Jun/2013	21.47		Continued.	Gas Shortage
IPP	Dhariwal	300MW	28/May/2014	02.27		Continued.	No schedule
MSPGCL	Koradi Unit 6	210MW	20/Mar/2015	01.02		Continued.	EE R&M LE Work
IPP	SWPGL U-1	135MW	16/Feb/2016	17.09		Continued.	Change Over , No Schedule
IPP	SWPGL U-2	135MW	29/Feb/2016	21.46		Continued.	Change over against Unit III
MSPGCL	Parli Unit 4	210MW	01/Apr/2016	00.00		Continued.	Economic shutdown
MSPGCL	Parli Unit 5	210MW	01/Apr/2016	00.00		Continued.	Economic shutdown
MSPGCL	Bhusawal Unit 2	210MW	14/Jun/2016	19.35		Continued.	Boiler Tube Leakage(Converted to Zero Shedule By MSEDCL. from 00.00Hrs dt.19-6-16)
IPP	RPL(AMT) U-3	270MW	29/Jun/2016	03.01	29/Mar/2017	08.59	Zero Shedule By MSEDCL.
MSPGCL	Uran Unit 8	108MW	14/Aug/2016	07.56		Continued.	Maintenance work
RGPL	Dabhol 2A	230MW	24/Aug/2016	13.31		Continued.	Change Over.
MSPGCL	Koradi Unit 5	200MW	05/Sep/2016	00.21		Continued.	ID Fan problem, Converted to Zero Schedule By MSEDCL from 00.00hrs/22-9-16. Shutdown taken on 18.10.2016 at 00.00Hrs for Turbine inspection and maintenance work
IPP	RPL(AMT) U-5	270MW	15/Nov/2016	20.00	27/Mar/2017	16.18	Zero schedule
IPP	RPL(AMT) U-4	270MW	16/Nov/2016	21.03	30/Mar/2017	06.04	Zero Schedule By MSEDCL.
IPP	RPL(AMT) U-2	270MW	16/Nov/2016	22.36	28/Mar/2017	07.14	Zero Schedule By MSEDCL.
IPP	RPL(AMT) U-1	270MW	17/Nov/2016	17.23	27/Mar/2017	07.19	Zero Schedule.
IPP	JSW (J) U2	300MW	01/Dec/2016	00.00		Continued.	No Schedule.
MSPGCL	Koradi Unit 10	660MW	07/Feb/2017	00.10		Continued.	Work Of PG Test.
IPP	PGPL U1	262MW	07/Feb/2017	17.30		Continued.	No Schedule
IPP	PGPL U2	126MW	07/Feb/2017	17.30		Continued.	No Schedule
MSPGCL	Koyana STG- IV Unit - 1	250MW	17/Mar/2017	10.45		Continued.	Turbine bearing Vibration high
IPP	SWPGL U-4	135MW	22/Mar/2017	00.01	01/Apr/2017	00.39	SSC Chain Broken.
IPP	Adani U-4	660MW	24/Mar/2017	22.00	30/Mar/2017	14.10	Main Steam Stop Valve Block.
MSPGCL	Nasik Unit 4	210MW	25/Mar/2017	05.45		Continued.	BTL continued under zero schedule by MSEDCL w.e.f. 26.03.2017 at 00:00 hrs
IPP	RPL(AMT) U-5	270MW	27/Mar/2017	16.26	27/Mar/2017	17.58	Breaker feedback problem
IPP	RPL(AMT) U-1	270MW	27/Mar/2017	17.56	27/Mar/2017	21.12	PA Fan Vibration Problem
MSPGCL	Bhusawal Unit 4	500MW	27/Mar/2017	02.29	28/Mar/2017	04.14	Poor Coal bunkering.
MSPGCL	Bhusawal Unit 4	500MW	28/Mar/2017	04.54	28/Mar/2017	06.22	Class A Protection Fail.
MSPGCL	Parli Unit 8	250MW	28/Mar/2017	09.14	28/Mar/2017	12.44	Drum level low
MSPGCL	Paras Unit 4	250MW	28/Mar/2017	18.26	01/Apr/2017	17.00	Boiler Tube Leakage
MSPGCL	Chandrapur Unit 9	500MW	28/Mar/2017	14.33	02/Apr/2017	11.13	Boiler Tube Leakage
MSPGCL	Bhusawal Unit 5	500MW	29/Mar/2017	12.16	29/Mar/2017	14.14	Flame Failure
MSPGCL	Parli Unit 8	250MW	29/Mar/2017	10.33	29/Mar/2017	14.12	dc earth fault indication
IPP	RPL(AMT) U-5	270MW	30/Mar/2017	17.17	30/Mar/2017	19.24	tripped on id fan.
MSPGCL	Koyana Unit 3	75MW	31/Mar/2017	12.05	31/Mar/2017	21.15	RMW.
MSPGCL	Parli Unit 8	250MW	31/Mar/2017	12.55		Continued.	Low furnace pressure
MSPGCL	Uran Unit 5	108MW	01/Apr/2017	01.21	03/Apr/2017	05.06	filter replacement work.
MSPGCL	Koyana Unit 1	75MW	02/Apr/2017	00.45	02/Apr/2017	04.25	Mechanical Protection operated
MSPGCL	Chandrapur Unit 5	500MW	02/Apr/2017	03.35		Continued.	Boiler Tube Leakage
MSPGCL	Chandrapur Unit 9	500MW	02/Apr/2017	15.29	02/Apr/2017	20.28	Drum level low

LINE OUTAGES AND RIPPING FOR THE WEEK FROM 27/03/2017 TO 02/04/2017

Voltage	Name of Line	Tripping Date	Tripping Time	Synch Date	Synch Time	Reason
400 KV	Jaigad-Karad Ckt-I	26/Mar/2017	09.51	27/Mar/2017	09.01	Insulator repl. work for attending decapping at loc no.24.
400 KV	Dhule Sar'Sarovar II	26/Mar/2017	14.40	27/Mar/2017	06.04	Distance Protection
400 KV	Dhule Sar'Sarovar II	27/Mar/2017	12.55	28/Mar/2017	06.40	Distance Protection
400 KV	Karad - Lonikand 1	27/Mar/2017	13.44	27/Mar/2017	16.00	Distance Protection
400 KV	Lonikand 1 - Chakan	28/Mar/2017	04.18	28/Mar/2017	06.32	Distance Protection
400 KV	Nagothane - Dabhol I	28/Mar/2017	04.57	28/Mar/2017	12.16	Distance Protection
400 KV	Karad - Lonikand 1	28/Mar/2017	12.29	28/Mar/2017	18.50	Distance Protection
400 KV	Dhule Sar'Sarovar II	28/Mar/2017	13.49	28/Mar/2017	17.52	Distance Protection
400 KV	Jejuri- Koyanastage-IV	28/Mar/2017	22.19	28/Mar/2017	23.20	Distance Protection
400 KV	Karad - Jaigad - II	29/Mar/2017	03.00	29/Mar/2017	08.52	Distance Protection
400 KV	New Koyna -Koyna Stage IV-I	29/Mar/2017	08.33	29/Mar/2017	14.18	Routine Maintenance Work
400 KV	Karad - Lonikand 1	29/Mar/2017	15.00	29/Mar/2017	16.38	Distance Protection
400 KV	Dhule Sar'Sarovar II	29/Mar/2017	20.31	30/Mar/2017	07.48	Over Voltage
400 KV	Karad - Jaigad - II	29/Mar/2017	22.22	29/Mar/2017	22.38	tripped only from jaigad end.
400 KV	Karad - Jaigad - II	29/Mar/2017	23.18	30/Mar/2017	12.17	Distance Protection
400 KV	Dhule Sar'Sarovar II	30/Mar/2017	20.29	31/Mar/2017	07.45	Over Voltage
400 KV	New Koyna - Koyna Stage IV-II	31/Mar/2017	08.27	31/Mar/2017	15.45	Routine Maintenance Work
400 KV	Koradi-Khaperkheda I	31/Mar/2017	16.00	31/Mar/2017	18.04	Distance Protection
400 KV	Kolhapur Solapur(PG) I	31/Mar/2017	17.05	01/Apr/2017	01.49	To make lilo at alkud ss
400 KV	Lonikand I - Koyna stage-IV	31/Mar/2017	18.14	31/Mar/2017	18.57	Distance Protection
400 KV	Dhule Sar'Sarovar II	31/Mar/2017	20.53	01/Apr/2017	05.57	Over Voltage
400 KV	Main Bus 1@Nagothane	01/Apr/2017	12.17	01/Apr/2017	19.30	Repairing of 29A PG Isolator of Dabhol-I
400 KV	Kalwa - Talegaon(PG)	01/Apr/2017	17.06	01/Apr/2017	20.30	To attend Hot Spot
400 KV	karad -kolhapur-I	01/Apr/2017	17.20	02/Apr/2017	08.13	Over Voltage
400 KV	Dhule Sar'Sarovar I	01/Apr/2017	18.10	02/Apr/2017	08.51	Over Voltage
400 KV	Karad - Jaigad - II	02/Apr/2017	09.27	02/Apr/2017	14.41	For Attending Decapping in Pilot String.
400 KV	Dhule Sar'Sarovar II	02/Apr/2017	16.17	03/Apr/2017	06.37	Over Voltage
400 KV	Karad - Jaigad - II	02/Apr/2017	18.05	03/Apr/2017	08.24	Over Voltage
400 KV	Dhule Sar'Sarovar I	03/Apr/2017	21.22		Continued.	Over Voltage
220 KV	Chandrapur GCR - Warora - I	05/Apr/2015	09.13		Continued.	Bunching of conductor Loc no 86 Disconnecting of jumer at Loc no 86 & 107
220 KV	Chandrapur GCR - Wani	05/Apr/2015	09.15		Continued.	Bunching of conductor Loc no 86 Disconnecting of jumer at Loc no 86 & 107
220 KV	Oni Kharepatan Line	27/Mar/2017	06.17	27/Mar/2017	17.26	Earth Fault.
220 KV	Kharepatan -Pawas Line	27/Mar/2017	06.56	27/Mar/2017	07.24	Distance Protection
220 KV	Niwali - Pawas Line	27/Mar/2017	06.56	27/Mar/2017	07.06	Distance Protection
220 KV	Talandage - Sawantwadi I	27/Mar/2017	09.48	27/Mar/2017	17.00	Insulator Washing.
220 KV	Chinchwad-Hinjewadi I	27/Mar/2017	12.49	27/Mar/2017	18.52	Testing Work
220 KV	Trombay Salsette 1 Backbay	27/Mar/2017	13.04	27/Mar/2017	14.50	Distance Protection
220 KV	Nanded-Ghatodi	27/Mar/2017	13.26	27/Mar/2017	14.51	Line Signature analysis
220 KV	Centuri Enka- Bhosari	27/Mar/2017	13.31	27/Mar/2017	16.51	Attending Oil Leakage
220 KV	Nasik Navsari II	28/Mar/2017	05.17	28/Mar/2017	09.55	Distance Protection
220 KV	Nasik Navsari I	28/Mar/2017	05.17	28/Mar/2017	09.54	Tripped From Navsari End.
220 KV	Adlabs - Pedambe	28/Mar/2017	06.15	28/Mar/2017	11.10	Distance Protection
220 KV	Mahad - Pedambe	28/Mar/2017	06.17	28/Mar/2017	09.10	Distance Protection
220 KV	Mulund - GIS Bhandup	28/Mar/2017	10.51	28/Mar/2017	13.46	Attending Hot Spot
220 KV	Nashik-Airoli Knowledge Park	28/Mar/2017	14.05	28/Mar/2017	16.57	Distance Protection
220 KV	Niwali - Pawas Line	28/Mar/2017	18.50	28/Mar/2017	21.32	Replacement Of Broken String At LOC .26
220 KV	Nasik Navsari II	29/Mar/2017	09.14	29/Mar/2017	17.49	Routine Maintenance Work
220 KV	Raymond - Washala	29/Mar/2017	09.50	29/Mar/2017	17.29	REPLACEMENT OF CTS.
220 KV	Uran - Kharghar 2	29/Mar/2017	10.10	29/Mar/2017	18.31	DISC. ISULATOR REPLACEMENT
220 KV	Butibori - VIPL Ckt I	29/Mar/2017	11.18	29/Mar/2017	16.41	ABT METER INSTALLATION WORK AR VIPLEND
220 KV	Niwali - Pawas Line	29/Mar/2017	14.30	29/Mar/2017	16.02	Routine Maintenance Work
220 KV	Miraj - Mhaishal	29/Mar/2017	14.50	29/Mar/2017	15.21	construction work
220 KV	Lamboti-Vita	29/Mar/2017	16.26	29/Mar/2017	16.31	Bus Bar Protection testing work.
220 KV	Lamboti - Solapur li(Bale) Ckt- I	29/Mar/2017	16.26	29/Mar/2017	16.28	Bus Bar Protection testing work.
220 KV	Lamboti - Pandharpur li	29/Mar/2017	16.26	29/Mar/2017	16.28	Bus Bar Protection testing work.
220 KV	Lamboti -Solapur li(Bale) Ckt- li	29/Mar/2017	16.26	29/Mar/2017	16.31	Bus Bar Protection testing work.
220 KV	Uran - Apta IV	29/Mar/2017	16.37	29/Mar/2017	16.85	gas relay bypass.
220 KV	Butibori - VIPL Ckt II	29/Mar/2017	16.44	29/Mar/2017	18.06	ABT METER INSTALLATION WORK AR VIPLEND
220 KV	Tilawani-Talandge-I	29/Mar/2017	16.54	29/Mar/2017	19.16	y phase red hot spot attend.
220 KV	Padghe - Nalasopara	29/Mar/2017	17.00	29/Mar/2017	17.10	Distance Protection
220 KV	Sawantwadi-Bidri	30/Mar/2017	00.22	30/Mar/2017	16.13	Distance Protection
220 KV	Lonikand-VSNL	30/Mar/2017	09.06	30/Mar/2017	13.27	Routine Maintenance Work
220 KV	Taloja li - OCIL-II	30/Mar/2017	09.16	30/Mar/2017	17.49	ct replacement work.
220 KV	Vilebagad-Kandalgaon	30/Mar/2017	09.50	30/Mar/2017	17.58	Routine Maintenance Work
220 KV	Baramati- Kalyani	30/Mar/2017	11.05	30/Mar/2017	13.10	Routine Maintenance Work
220 KV	Patoda-Manjarsumba	30/Mar/2017	12.10	30/Mar/2017	14.45	Relay Testing Work.

Voltage	Name of Line	Tripping Date	Tripping Time	Synch Date	Synch Time	Reason
220 KV	Butibori-VIPL-IV GIS Bay	30/Mar/2017	14.23	30/Mar/2017	15.46	installation of abt meters.
220 KV	Nanded-Parbhani	30/Mar/2017	15.15	30/Mar/2017	18.10	Attending Hot Spot
220 KV	Flagship-Chinchwad	30/Mar/2017	16.18	30/Mar/2017	17.58	diagnostic testing.
220 KV	Lonand-Baramati	30/Mar/2017	16.35	30/Mar/2017	18.10	Attending Hot Spot
220 KV	Tillari Amona	31/Mar/2017	04.37	31/Mar/2017	05.03	high voltage.
220 KV	Mahalakshmi Amona	31/Mar/2017	04.37	31/Mar/2017	05.04	high voltage.
220 KV	Versova Gorai Line	31/Mar/2017	06.08	31/Mar/2017	09.37	Routine Maintenance Work
220 KV	Temghar - Kalwa	31/Mar/2017	08.21	31/Mar/2017	10.07	Earth wire removing work.
220 KV	Chalisgaon-Pimparkhed	31/Mar/2017	09.25	31/Mar/2017	11.42	Testing Work
220 KV	Chalisgaon-Pimparkhed	31/Mar/2017	10.00	31/Mar/2017	11.42	Quarterly Maintainance Work
220 KV	Kharepatan -Pawas Line	31/Mar/2017	11.32	31/Mar/2017	17.02	Routine Maintenance Work
220 KV	Karad - Sadawagpur I	31/Mar/2017	12.06	31/Mar/2017	18.33	Routine Maintenance Work
220 KV	Koradi-Ambazari-Ii	31/Mar/2017	16.00	31/Mar/2017	16.26	Backup Protection
220 KV	Khaparkheda-Ambazari-I	31/Mar/2017	16.00	31/Mar/2017	16.41	Distance Protection
220 KV	Vita - Ghatnandre	31/Mar/2017	17.35	31/Mar/2017	18.10	Distance Protection
220 KV	Sawantwadi-Bidri	01/Apr/2017	04.55	01/Apr/2017	07.20	Distance Protection
220 KV	Gorai MSETCL Borivali Line-2	01/Apr/2017	09.04	01/Apr/2017	19.18	Testing Work
220 KV	Sawantwadi-Bidri	01/Apr/2017	10.10	01/Apr/2017	17.18	Insulator cleaning work
220 KV	New Koyna - Loteparshuram	01/Apr/2017	10.54	01/Apr/2017	13.15	Line Signature Analysis Test
220 KV	Loteparshuram- Dasturi Line	01/Apr/2017	13.50	01/Apr/2017	15.35	Routine Maintenance Work
220 KV	Infosys - Hinjawadi 1	01/Apr/2017	13.58	01/Apr/2017	16.46	Distance Relay Testing Work
220 KV	Parli 3 (Old Gcr)-Osmanabad	01/Apr/2017	17.45	01/Apr/2017	20.28	Annual Maintenance Work
220 KV	Trombay - Kalwa	01/Apr/2017	19.07	01/Apr/2017	19.08	Kalwa-Saishet-VI converted to Kalwa-Trombay
220 KV	Trombay - Kalwa	01/Apr/2017	19.09	02/Apr/2017	17.14	Distance Protection
220 KV	Vita - Miraj	01/Apr/2017	19.52	01/Apr/2017	20.26	Distance Protection
220 KV	Miraj - Mhaishal	01/Apr/2017	20.08	01/Apr/2017	20.35	Distance Protection
220 KV	Kalwa Salsette III	02/Apr/2017	07.35	02/Apr/2017	21.06	To Facilitate Work on 220KV Trombay-Salsette II Line.
220 KV	Boisar Versova Line	02/Apr/2017	09.15	02/Apr/2017	10.05	Isolator Work.
220 KV	Trombay Salsette 1 Backbay	02/Apr/2017	10.00	02/Apr/2017	22.48	To Facilitate Work on 220KV Trombay-Salsette-II Line.
220 KV	Boisar-Viraj	02/Apr/2017	10.08	02/Apr/2017	10.53	Isolator Work.
220 KV	Phulambri-Bhokardan	02/Apr/2017	10.30	02/Apr/2017	12.35	Attending Hot Spot
132 KV	Uppalwadi-Pardi	29/Mar/2017	09.05	29/Mar/2017	13.52	Quarterly Maintainance Work
132 KV	Yavatmal-Pandharkawada	29/Mar/2017	10.47	29/Mar/2017	13.28	Attending Hot Spot
132 KV	Brahmapuri - Aa Energy	29/Mar/2017	11.05	29/Mar/2017	14.35	Measurment of Tan Delta of ICT
132 KV	Parli 2(Girwali) -Gangakhed	29/Mar/2017	11.08	30/Mar/2017	20.45	FOR LILO WORK.
132 KV	Parli 1 - Parli 2(Girwali) Ckt - I	29/Mar/2017	11.08	29/Mar/2017	22.09	FOR LILO WORK.
132 KV	Padegaon Paithan	29/Mar/2017	12.46	29/Mar/2017	17.30	Relay Testing Work.
132 KV	Gangakhed - Kandhar	29/Mar/2017	13.15	29/Mar/2017	14.40	TO REMOVE HANGING CLOTH AT LOC.
132 KV	Parli- Gangakhed	30/Mar/2017	11.08	30/Mar/2017	20.45	making lilo at 132kv parly.
132 KV	Waluj - Bajaj-I	30/Mar/2017	15.00	30/Mar/2017	18.15	Relay Testing Work
132 KV	Warwat Bakal-Khamgaon	30/Mar/2017	15.35	30/Mar/2017	18.45	making tripping arrangement on 132kv khamgaon -warwatbakal ckt between
132 KV	Hingoli-I - Hingoli-I Ckt 1	02/Apr/2017	17.36	02/Apr/2017	18.13	Distance Protection
132 KV	Cosmofilms-Badnapur	02/Apr/2017	19.10	02/Apr/2017	19.22	Master Trip Relay Operated.