

MAHARASHTRA STATE ELECTRICITY TRANSMISSION COMPANY LTD.
Maharashtra State Load Despatch Centre, Kalwa

To,
DSS CONTROL ROOM,
Head Office Mumbai.

No. 871/02.06.14

Sub: Report of the Power System position for the period 26-May-14 To 1-Jun-14

Date	Monday 26-May-14	Tuesday 27-May-14	Wednesday 28-May-14	Thursday 29-May-14	Friday 30-May-14	Saturday 31-May-14	Sunday 1-Jun-14
On Line Capacity (MW)							
MSPGCL THM	4820	5371	5238	5130	4781	5391	4948
MSPGCL HY	1303	1366	1378	1378	1368	1309	1309
MSPGCL GAS	460	600	620	520	445	600	600
MSPGCL TOTAL	6583	7337	7236	7028	6594	7300	6857
Cent. Sect.(incl. RGPPL)	5810	5808	5903	6195	6111	6187	5587
MSPGCL + CS	12393	13145	13139	13223	12705	13487	12444
TPCL	1627	1627	1627	1627	1627	1627	1627
REL	500	500	500	500	500	500	500
TPCL + REL	2127	2127	2127	2127	2127	2127	2127
CPP	3943	3939	3849	3883	3070	3070	2600
STATE OLC	18463	19211	19115	19233	17902	18684	17171
Morning Peak Demand (MW)	12 Hrs	11 Hrs	13 Hrs	13 Hrs	12 Hrs	12 Hrs	13 Hrs
MSPGCL THM	5173	4922	5811	5464	5365	5243	5375
MSPGCL HY	1334	1239	602	221	249	882	826
MSPGCL GAS	571	531	576	576	426	572	573
MSPGCL TOTAL	7078	6692	6989	6261	6040	6697	6774
Cent. Sect.(incl. RGPPL)	5973	6033	5634	5827	5856	6234	5707
Wind	224	184	96	674	597	573	573
CPP	3950	4140	4061	3767	3329	3257	2258
TPCL Asst	-1350	-1413	-1314	-1375	-1396	-1319	-945
MSEDCL Catered	16046	15784	15619	15309	14564	15569	14510
Load Shedding (LS)	759	496	708	710	558	790	1038
MSEDCL Demand(Incl LS)	16805	16280	16327	16019	15122	16359	15548
TPCL + REL Dem.	3184	3189	3221	3239	3226	2964	2264
State Demand (Incl LS)	19989	19469	19548	19258	18348	19323	17812
Sys. Freq. (Hz)	49.9	49.9	49.97	49.97	49.99	49.94	49.96
Evening Peak Demand (MW)	16 Hrs	14 Hrs	14 Hrs	14 Hrs	15 Hrs	14 Hrs	14 Hrs
MSPGCL THM	5180	5268	5836	5488	5666	5592	5442
MSPGCL HY	1294	251	296	124	119	632	931
MSPGCL GAS	435	550	576	574	424	572	571
MSPGCL TOTAL	6909	6069	6708	6186	6209	6796	6944
Cent. Sect.(incl. RGPPL)	5778	5318	5878	6021	5820	6014	5298
Wind	370	529	157	657	782	621	625
CPP	3701	3960	4027	3910	3286	3297	2291
TPCL Asst	-1397	-1314	-1287	-1303	-1396	-1293	-925
MSEDCL Catered	15444	14702	15643	15629	14832	15562	14367
Load Shedding (LS)	766	594	619	396	319	786	989
MSEDCL Demand(Incl LS)	16210	15296	16262	16025	15151	16348	15356
TPCL + REL Dem.	3193	3210	3168	3181	3216	2925	2249
State Demand (Incl LS)	19403	18506	19430	19206	18367	19273	17605
Sys. Freq. (Hz)	49.93	49.99	49.94	49.89	49.93	49.91	49.95

Chief Engineer
MSLDC, Kalwa

SLDC,KALWA
MSPGCL WEEKLY FORCED & PLANNED UNIT OUTAGES

WEEK	26-May-14	TO	1-Jun-14
------	-----------	----	----------

A) (UNITWISE PLANNED/FORCED OUTAGE POSITION @ 05:30 HRS. OF THE DAY OF (MSPGCL THERMAL UNITS ONLY)

Sr.No	Date	26-May-2014		27-May-2014		28-May-2014		29-May-2014		30-May-2014		31-May-2014		1-Jun-2014	
	Day	MONDAY		TUESDAY		WEDNESDAY		THURSDAY		FRIDAY		SATURDAY		SUNDAY	
	Outage Type	PLANNED	FORCED	PLANNED	FORCED	PLANNED	FORCED	PLANNED	FORCED	PLANNED	FORCED	PLANNED	FORCED	PLANNED	FORCED
1	NASIK	*	5	*	5	*	3	*	3,5	*	*	*	*	*	*
2	KORADI	5	7	5	7	5	*	5	*	5	*	5	*	5	*
3	KHAPERKHEDA	*	2	*	2	*	2	*	2	*	2	*	2	*	4
4	PARALI	3	*	3	5	3	5	3	5	3	5	3	4,5	3	4,5
5	CHANDRAPUR	*	*	*	*	*	*	*	*	*	*	*	*	*	2
6	BHUSAVAL	*	5	*	*	*	*	*	*	*	*	*	*	*	*
7	PARAS	*	*	*	*	*	*	*	*	*	*	*	*	*	*

REMARKS:-
 1)THIS INFORMATION TO BE VERIFIED FROM CGM.(GEN.WORKS) MSPGCL,H.O. MUMBAI REPORT BEFORE SUBMITTING TO THE CABINET COMMITTEE
 2) URAN GTPS UNITS ARE KEPT SHUT OR ON STAND BY MODE DUE TO GAS SHORTAGE.
 3) Koradi U-1 to 4, Paras U-2, Parli U-1,2, Bhusawal U-1 and Nasik 1,2 are withdrawn being a vintage units.

B) WEEKLY CENTRAL SECTOR SHARE/DRAWL(IN MUs)

DATE	DAY	CENT.SECT. SHARE		TOTAL INTER STATE BILATERAL PURCHASE		TOTAL SHARE		TOTAL DRAWL		OVERDRAWL(+) UNDREDRAWL(-)	
		MUs	AVG. MW	MUs	AVG. MW	MUs	AVG. MW	MUs	AVG. MW	MUs	AVG. MW
		1		2		1+2=3		4		3-4=5	
26-May-2014	MONDAY	101.246	4219	20.052	836	121.298	5054	124.615	5192	3.317	138
27-May-2014	TUESDAY	78.872	3286	42.675	1778	121.547	5064	124.107	5171	2.560	107
28-May-2014	WEDNESDAY	98.491	4104	23.351	973	121.842	5077	123.817	5159	1.975	82
29-May-2014	THURSDAY	106.207	4425	21.571	899	127.778	5324	124.381	5183	-3.397	-142
30-May-2014	FRIDAY	108.766	4532	20.608	859	129.374	5391	128.141	5339	-1.233	-51
31-May-2014	SATURDAY	112.372	4682	14.900	621	127.272	5303	131.170	5465	3.898	162
1-Jun-2014	SUNDAY	108.152	4506	15.824	659	123.976	5166	131.266	5469	7.290	304
	TOTAL	714.106		158.981		873.087		887.497		14.410	

Details of Koyna Water Consumption (In TMC)

DATE	For the Day	For the Month	Balance
26-May-14	0.189	6.269	-14.550
27-May-14	0.111	6.380	-14.661
28-May-14	0.072	6.452	-14.733
29-May-14	0.086	6.538	-14.819
30-May-14	0.066	6.604	-14.885
31-May-14	0.159	6.763	-15.044
1-Jun-14	0.187	0.187	67.313

Supply Position During Evening Peak (MW)

Date	Time	MSEDCL Generation				NO. 401 / 18.03.2014	WIND	CPP	TPCL Exch	MSEDCL Catered Demand	Load Shedding (LS).	MSEDCL Demand (Incl LS)	TPCL Gen.	REL Gen.	State demand met	State Demand (Incl LS)	Freq.
		Thermal	Hydro	Gas	Total												
		MW	MW	MW	MW												
26-May-14	16	5180	1294	435	6909	5778	370	3701	-1397	15444	766	16210	1279	517	18637	19403	49.93
27-May-14	14	5268	251	550	6069	5318	529	3960	-1314	14702	594	15296	1374	522	17912	18506	49.99
28-May-14	14	5836	296	576	6708	5878	157	4027	-1287	15643	619	16262	1360	521	18811	19430	49.94
29-May-14	14	5488	124	574	6186	6021	657	3910	-1303	15629	396	16025	1357	521	18810	19206	49.89
30-May-14	15	5666	119	424	6209	5820	782	3286	-1396	14832	319	15151	1301	519	18048	18367	49.93
31-May-14	14	5592	632	572	6796	6014	621	3297	-1293	15562	786	16348	1110	522	18487	19273	49.91
1-Jun-14	14	5442	931	571	6944	5298	625	2291	-925	14367	989	15356	804	520	16616	17605	49.95
Maximum		5836	1294	576	6944	6021	782	4027	-925	15643	989	16348	1374	522	18811	19430	49.99
Minimum		5180	119	424	6069	5298	157	2291	-1397	14367	319	15151	804	517	16616	17605	49.89
Average		5496	521	529	6546	5732	534	3496	-1274	15168	638	15807	1226	520	18189	18827	49.93

Supply Position During Morning Peak (MW)

Date	Time	MSEDCL Generation				Central Sector Receipt	WIND	CPP	TPCL Exch	MSEDCL Catered Demand	Load Shedding (LS).	MSEDCL Demand (Incl LS)	TPCL Gen.	REL Gen.	State demand met	State Demand (Incl LS)	Freq.
		Thermal	Hydro	Gas	Total												
		MW	MW	MW	MW												
26-May-14	12	5173	1334	571	7078	5973	224	3950	-1350	16046	759	16805	1313	521	19230	19989	49.90
27-May-14	11	4922	1239	531	6692	6033	184	4140	-1413	15784	496	16280	1263	513	18973	19469	49.90
28-May-14	13	5811	602	576	6989	5634	96	4061	-1314	15619	708	16327	1388	519	18840	19548	49.97
29-May-14	13	5464	221	576	6261	5827	674	3767	-1375	15309	710	16019	1349	515	18548	19258	49.97
30-May-14	12	5365	249	426	6040	5856	597	3329	-1396	14564	558	15122	1313	517	17790	18348	49.99
31-May-14	12	5243	882	572	6697	6234	573	3257	-1319	15569	790	16359	1124	521	18533	19323	49.94
1-Jun-14	13	5375	826	573	6774	5707	573	2258	-945	14510	1038	15548	800	519	16774	17812	49.96
Maximum		5811	1334	576	7078	6234	674	4140	-945	16046	1038	16805	1388	521	19230	19989	49.99
Minimum		4922	221	426	6040	5634	96	2258	-1413	14510	496	15122	800	513	16774	17812	49.90
Average		5336	765	546	6647	5895	417	3537	-1302	15343	723	16066	1221	518	18384	19107	49.95

Details of Supply Position (MUs)

Date	MSEDCL Generation					Central Sector Receipt	Central Sector Share	WIND	CPP	TPCL Gen	R-Infra Gen	TPCL Exch	Energy Requirement		
	Thermal	Hydro	Gas	Pench(MS)	Total								MSEDCL	MUMBAI	State
26-May-14	119.716	12.670	12.670	0.250	145.306	124.615	121.298	14.464	94.530	24.921	12.295	-26.505	353.511	63.721	417.232
27-May-14	120.593	8.741	12.013	0.104	141.451	124.107	121.547	14.270	93.979	25.484	12.341	-27.491	347.381	65.316	412.697
28-May-14	123.010	8.087	13.779	0.271	145.147	123.817	121.842	13.138	91.979	24.329	12.134	-28.874	346.339	65.334	411.673
29-May-14	117.525	7.465	13.419	0.322	138.731	124.381	127.778	20.232	91.857	24.936	12.234	-28.328	348.039	65.497	413.536
30-May-14	120.043	5.832	10.462	0.253	136.590	128.141	129.374	22.523	78.261	24.872	12.495	-27.853	338.673	65.220	403.893
31-May-14	121.854	11.418	13.600	0.088	146.960	131.170	127.272	19.797	76.846	23.899	12.490	-25.374	350.413	61.763	412.176
1-Jun-14	117.607	9.952	13.752	0.200	141.511	131.266	123.976	19.693	59.097	20.018	12.473	-21.142	331.434	53.632	385.066
Maximum	123.010	12.670	13.779	0.322	146.960	131.266	129.374	22.523	94.530	25.484	12.495	-21.142	353.511	65.497	417.232
Minimum	117.525	5.832	10.462	0.088	136.590	123.817	121.298	13.138	59.097	20.018	12.134	-28.874	331.434	53.632	385.066
Average	120.050	9.166	12.814	0.213	142.242	126.785	124.727	17.731	83.793	24.066	12.352	-26.510	345.113	62.926	408.039

MAHARASHTRA STATE ELECTRICITY TRANSMISSION COMPANY LTD.

Maharashtra State Load Despatch Centre, Kalwa

Information for Weekly Cabinet Meeting

For the Week

26-May-14

to

1-Jun-14

Demand Supply Summary

	Morning Peak (MW)	Evening Peak (MW)
Average Peak Demand	16066	15807
Average Peak Supply	15343	15168
Average Load Relief (LS)	723	638

Average Supply Summary

	Morning Peak (MW)	Evening Peak (MW)	Mus
Thermal	5336	5496	120.05
Gas	546	529	12.81
Hydro	765	521	9.17
CS Drawal (Total)	5895	5732	126.79
TPCL	-1302	-1274	-26.51

Koyna Water position

	Water in TMC Feet
Average Water Used Per Day	0.124
Balance Left	67.313
Balance Left Last Year Same Week	-1.323

MSPGCL Unit Outage Position

Date	MSPGCL (in MW)		
	Planned	Forced	Total
26-May-14	410	1130	1540
27-May-14	410	840	1250
28-May-14	410	630	1040
29-May-14	410	840	1250
30-May-14	410	420	830
31-May-14	410	630	1040
1-Jun-14	410	840	1250

Distressed Load Shedding

Maxm. No. of Hours in a day	0
Number of Days	0

GENERATING UNIT OUTAGES FOR THE WEEK

FROM 26-May-14 TO 1-Jun-14

UNIT UNDER PLANNED OUTAGE

name	unit_no	derat_cap	date_trip	time_trip	date_sync	time_sync	reasondes
Parli	Unit 3	210	13-Feb-13	23.50		Continued.	Water Shortage
Koradi	Unit 5	200	10-Apr-14	19.21		Continued.	Coal conservation

UNIT UNDER FORCED OUTAGE

name	unit_no	derat_cap	date_trip	time_trip	date_sync	time_sync	reason
Dabhol	1B	230	28-May-13	22.02		Continued.	Gas shortage.
Dabhol	2A	230	6-Jun-13	09.10		Continued.	Gas Shortage
Dabhol	3A	230	6-Jun-13	08.28		Continued.	Gas Shortage
Dabhol	1A	230	27-Jun-13	21.47		Continued.	Gas Shortage
Dabhol	1X	290	27-Jun-13	21.46		Continued.	Gas Shortage
Dabhol	2X	290	15-Jul-13	15.09		Continued.	Gas Shortage
Dabhol	2B	230	8-Aug-13	15.03		Continued.	Gas Shortage
Dabhol	3X	290	29-Dec-13	05.47		Continued.	Gas Shortage
Dabhol	3B	230	29-Dec-13	06.14		Continued.	Gas Shortage
Tata	Trombay 8	250	9-Jan-14	22.54		Continued.	Emergency H/T, Fire at turbine track.
CPP	WPCL U-1	135	30-Jan-14	12.45		Continued.	turbine vibration
CPP	WPCL U-2	135	18-Feb-14	00.02		Continued.	Ash Conveying problem
CPP	WPCL U-4	135	3-Apr-14	00.01		Continued.	No Schedule
CPP	IPL U-2	270	29-Apr-14	09:34	27-May-14	20:07	PA Fan problem
CPP	Adani U-2	660	22-May-14	10.48	27-May-14	11.30	Boiler Tube Leakage
Bhusawal	Unit 5	500	23-May-14	09.02	26-May-14	06.30	Boiler Tube Leakage
Nasik	Unit 5	210	24-May-14	7.40	27-May-14	08.10	BTL
Koradi	Unit 7	210	25-May-14	5.37	28-May-14	02.59	BTL
Khaparkheda	Unit 2	210	25-May-14	6.11	1-Jun-14	4.09	flame falure
Parli	Unit 7	250	25-May-14	21.18	26-May-14	03.56	Air Heater Problem.
Parli	Unit 5	210	26-May-14	22.34		Continued.	Coal Shortage.
CPP	Adani U-2	660	27-May-14	17.19	30-May-14	15.52	BLR T/L.
Nasik	Unit 3	210	27-May-14	20.35	29-May-14	21.30	BLR Validity Extn.
Bhusawal	Unit 5	500	27-May-14	09.38	27-May-14	13.58	Gen Prot Optd.
CPP	Dhariwal	300	28-May-14	02.27		Continued.	PA Fan Vibration Problem. (U-1).
Bhusawal	Unit 3	210	28-May-14	16.02	28-May-14	17.15	Furnace Pressure Low.
Nasik	Unit 5	210	28-May-14	20.00	30-May-14	06.55	PA Fan Problem.
Uran	Unit 6	108	29-May-14	21.53	31-May-14	01.30	Fire At By Pass Jumper Damper.
CPP	Adani U-3	660	29-May-14	21.05		Continued.	B.T.L
Nasik	Unit 3	210	29-May-14	21.50	30-May-14	23.45	Trip.
CPP	Adani U-2	660	30-May-14	18.22		Continued.	Boiler Tube Leakage
CPP	IPL U-1	270	30-May-14	02:42	1-Jun-14	18.40	Coal shortage
Parli	Unit 4	210	30-May-14	17.45	1-Jun-14	19.12	Coal Shortage
Chandrapur	Unit 2	210	31-May-14	13.01		Continued.	furnace presuure high due to btl
CPP	JSW (J) U4	300	31-May-14	23.51		Continued.	CWL Problem.
CPP	VIPL U-2	300	1-Jun-14	1.50		Continued.	BTL
CPP	JSW (J) U3	300	1-Jun-14	2.47		Continued.	Heater prv.broken
Khaparkheda	Unit 4	210	1-Jun-14	2.03		Continued.	BTL
Paras	Unit 3	250	1-Jun-14	07.39		Continued.	Flame Failure.
Khaparkheda	Unit 1	210	1-Jun-14	19.15	2-Jun-14	00.07	Furnace Pressure High.
CPP	IPL U-2	270	1-Jun-14	10.42		Continued.	BLR T/L.
Chandrapur	Unit 7	500	2-Jun-14	03.37		Continued.	BFP Problem.

LINE OUTAGES FOR THE WEEK

FROM 26-May-14 TO 1-Jun-14

Voltage	Name	date_trip	time_trip	date_sync	time_sync	Reason
500KV	HVDC Pole II Padgha	28-May-14	00.50	28-May-14	07.40	Premansoon Maint.Work.
500KV	HVDC Pole I Padgha	29-May-14	22.27	30-May-14	06.22	PM Work.
500KV	765KV Akola II - Tiroda - I	31-May-14	17.31	31-May-14	23.36	over voltage
400KV	Deepnagar-Tapitatanda	24-May-14	21.58	26-May-14	08.52	distance protection
400KV	Karad - Kolhapur - II	25-May-14	16.15	26-May-14	06.48	Over Voltage.
400KV	Karad-Jaigad I	25-May-14	16.37	26-May-14	06.52	Over Voltage.
400KV	Kolhapur - Mapusa - II	25-May-14	16.39	26-May-14	09.10	Over Voltage.
400KV	Bhusawal- Aurangabad	25-May-14	17.12	26-May-14	07.20	Over Voltage.
400KV	Karad - Newkoyna - I	26-May-14	11.54	26-May-14	16.00	For Armoring in Span No.185-186 B Ph.
400KV	Kolhapur - Mapusa - I	26-May-14	16.48	27-May-14	08.37	Over Voltage.
400KV	Kolhapur-Karad -I	26-May-14	17.06	27-May-14	07.00	Over Voltage.
400KV	Bhusawal- Aurangabad	26-May-14	20.14	27-May-14	08.29	Over Voltage.
400KV	Karad - Kolhapur - II	27-May-14	14.52	28-May-14	07.27	Over Voltage.
400KV	Karad-Jaigad I	27-May-14	17.31	28-May-14	07.29	Over Voltage.
400KV	Bhusawal- Aurangabad	27-May-14	17.46	28-May-14	07.10	Over Voltage.
400KV	Kolhapur-Solapur (PG) II	27-May-14	15.03	27-May-14	15.37	Dist.Prot.
400KV	Kolhapur - Mapusa - I	27-May-14	16.42	28-May-14	08.55	Over Voltage.
400KV	Kalwa - Talegaon (PGCIL)	27-May-14	16.58	28-May-14	02.30	Dist.Prot.
400KV	400/220KV,315 MVA ICT-I At Lonikand.	27-May-14	13.18	27-May-14	14.11	NDR.
400KV	Padgha - Nagothane - I	27-May-14	16.56	28-May-14	08.31	Dist.Prot.
400KV	Padgha - Talegaon (PG)	27-May-14	22.43	28-May-14	00.29	To remove broken OPGW wire of 400KV Kalwa-Talegaon line.
400KV	400/220KV 500MVA ICT- I at Khaperkheda	28-May-14	07.03	28-May-14	16.29	P.M.Work
400KV	Karad - Kolhapur - II	28-May-14	16.12	29-May-14	07.22	Over Voltage.
400KV	Padgha - Talegaon (PG)	28-May-14	04.41	28-May-14	09.21	R-Ph Wave trap suspension string found broken.
400KV	Kolhapur-Solapur (PG) II	28-May-14	16.29	28-May-14	19.11	E/W Repair.
400KV	Bhusawal- Aurangabad	28-May-14	17.53	29-May-14	07.29	Over Voltage.
400KV	Karad - Kolhapur - I	29-May-14	16.31	30-May-14	08.00	Over Voltage.
400KV	Dhule-Sar'Sarovar - I	29-May-14	01.56	29-May-14	08.10	Over Voltage.
400KV	Bhusawal- Aurangabad	29-May-14	18.01	30-May-14	09.00	Over Voltage.
400KV	Wardha (PG) - Warora - I	29-May-14	15.40	29-May-14	17.35	Distance Prot.
400KV	Kolhapur - Mapusa - I	29-May-14	17.36	30-May-14	08.36	Over Voltage.
400KV	Main Bus - II @ Koradi	29-May-14	10.25	29-May-14	15.45	RMW Along With Tan Delta for 400kv CTS & CVTs.
400KV	Parli-Lonikand -I	29-May-14	09.38	29-May-14	13.12	Taken On TBC at Parley end To Attend Hot Spot.
400KV	400/220KV,315 MVA ICT-I at BBLSR	29-May-14	17.53	29-May-14	20.50	PM Work.
400KV	Bhusawal- Aurangabad	30-May-14	17.56	31-May-14	7.42	Over Voltage
400KV	Kolhapur-Mapusa-II	30-May-14	17.30	31-May-14	9.17	Over Voltage
400KV	400/220KV 315MVA ICT-II @ Kharghar	30-May-14	08.37	30-May-14	20.47	Maint.work
400KV	400/220KV 315 MVA ICT-I @ Padgha	30-May-14	09.42	30-May-14	14.50	Repl.of Bucholz relay of R phase Unit
400KV	400/220 KV 315 MVA ICT- II @ Dhule	30-May-14	09.30	30-May-14	20.58	Repl.of B Phase Relay
400KV	Kharkheda - Chandrapur	30-May-14	10.00	30-May-14	18.46	Relocation
400KV	Koradi - Bhusawal	30-May-14	12.58	30-May-14	13.20	Removal of Line Reactor
400KV	400/220KV 315 MVA ICT- II @ Padgha	30-May-14	15.00	30-May-14	17.12	P.M.Work
400KV	Karad - Kolhapur - II	30-May-14	17.18	31-May-14	7.18	over voltage
400KV	New Koyna - Koyna Stage IV - II	31-May-14	8.30	31-May-14	17.35	attending ct oil leakage
400KV	Kalwa-Kharghar	31-May-14	9.10	31-May-14	17.37	demonstration of multifunctional testing kit
400KV	400/220 KV 500 MVA ICT-III @ Dhule	31-May-14	9.28	31-May-14	12.44	pre mansoon maint.work
400KV	Padghe-BBLSR-I	31-May-14	15.35	31-May-14	19.04	replacemnt of insulator string
400KV	Karad - Kolhapur - I	31-May-14	17.10	1-Jun-14	08.49	over voltage
400KV	Bhusawal- Aurangabad	31-May-14	17.18	1-Jun-14	09.25	over voltage
400KV	Kolhapur - Mapusa - I	31-May-14	16.26	1-Jun-14	09.55	over voltage
400KV	Dhule-Sar'Sarovar - I	31-May-14	21.48	1-Jun-14	07.47	over voltage
400KV	Chakan-Talegaon(PG)	1-Jun-14	00.19	1-Jun-14	5.21	Hot spot
400KV	Karad-Kolhapur-II	1-Jun-14	13.58		Continued.	Over Voltage.
400KV	Bhusawal- Aurangabad	1-Jun-14	17.13		Continued.	Over Voltage.
400KV	Lonikand- Koyna Stage IV	1-Jun-14	17.44	2-Jun-14	06.29	Over Voltage.
400KV	Karad-Jaigad I	1-Jun-14	16.09		Continued.	Over Voltage.
400KV	Kolhapur - Mapusa - II	1-Jun-14	16.16		Continued.	Over Voltage.
400KV	Dabhol-Nagothane - II	1-Jun-14	16.00		Continued.	Over Voltage.
400KV	400/220 KV315 MVA ICT-I @ BBLR	1-Jun-14	21.33		Continued.	Taken on TBC,For Iso.alignment.
400KV	Dhule-Sar'Sarovar - II	1-Jun-14	17.00		Continued.	Over Voltage.
220KV	BBLSR-Chaligaon	26-May-14	18.30	27-May-14	04.00	Conductor Broken.
220KV	Mudsinghi - Mumewadi - I	27-May-14	10.25	27-May-14	13.02	Testing work.
220KV	Karad-Kadegaon	27-May-14	10.02	27-May-14	12.16	Hot Spot of Wave Trap.
220KV	Miraj - Kadegaon	27-May-14	12.27	27-May-14	13.15	Hot Spot of R-Ph CT.
220KV	Nasik - Navasari - II	27-May-14	13.22	27-May-14	17.05	Dist.Prot.
220KV	Karad-Vita-II	27-May-14	14.00	27-May-14	15.04	Dist.Prot.
220KV	Vita - Lamboti	27-May-14	14.29	27-May-14	20.03	Dist.Prot.
220KV	Babaleshwar - Ranjangaon	27-May-14	15.07	27-May-14	19.40	Dist.Prot.
220KV	Parli-I - Harangul - II	27-May-14	17.51	28-May-14	00.28	Repl of bolted type jumpers to LA,CT & wave trap.

220KV	Borivali - Bhandup	28-May-14	05.55	28-May-14	07.09	Removing bird nest from B-Ph W/T.
220KV	Borivali-Ghodbandar	28-May-14	07.17	28-May-14	07.50	Removing bird nest from B-Ph W/T.
220KV	Apta-Uran-IV	28-May-14	10.34	28-May-14	19.12	Repl.of cutpoint & suspension insu.by polymer strings.
220KV	Lamboti-Bale-I	28-May-14	10.05	28-May-14	12.40	Q.M.Work
220KV	Karad-Vita-II	28-May-14	15.46	28-May-14	18.31	To attend hot spot.
220KV	Nasik - Navasari - II	28-May-14	14.29	28-May-14	15.41	Dist.Prot.
220KV	Nasik - Ghatghar	28-May-14	15.15	28-May-14	19.32	Dist.Prot.
220KV	Girwali - Parly - II	28-May-14	09.37	28-May-14	18.22	Repl.of bolted jumpers of LA,CT,WT.
220KV	Beed-Patoda II	28-May-14	09.30	28-May-14	13.52	Q.M.Work
220KV	220/132 KV 200 MVA ICT - II @ Girawali	28-May-14	10.37	28-May-14	13.14	Oil top up in conservator tank.
220KV	Parli-I - Harangul - II	28-May-14	18.23	28-May-14	22.41	Testing work.
220KV	Usmanabad-Barshi	28-May-14	12.40	28-May-14	16.12	For checking noise in CT at Barshi end.
220KV	Badnera - Deoli (PGCIL)	29-May-14	15.40	29-May-14	16.52	Distance Prot.
220KV	Apta-Uran-IV	29-May-14	08.22	29-May-14	19.50	Replacement Of Cut point and Suspension Disc Insulator.
220KV	Kalyani-Baramati Agro	29-May-14	08.00	29-May-14	09.05	Out Insulator Three Jumpers Connectionunder Jica-2.
220KV	220/100 KV 125MVA ICT-II @ Borivali	29-May-14	09.40	29-May-14	15.22	Annual Maintenance Work.
220KV	Babaleshwar - Alephata	29-May-14	09.30	29-May-14	20.54	Fixing Of Vibration Damper.
220KV	Baramati-Kalyani	29-May-14	09.10	29-May-14	19.25	Replacement Of Line Insulator Under Jica-2.
220KV	Jejuri-Jejuri I	29-May-14	09.41	29-May-14	15.53	A.M.Work.
220KV	220/132 KV, 200 MVA ICT - 6 at Nasik	29-May-14	09.46	29-May-14	20.09	Emergency Outage Jump Reconnect Work.
220KV	Pirangut - Hinjewadi - II	29-May-14	11.52	29-May-14	14.40	Hot Spot Attending Work.
220KV	220KV PT bay at Hinjewadi-I	29-May-14	15.05	29-May-14	15.45	Emergency tage To Attend R Ph PT Leakage.
220KV	Dhule - Malegaon	30-May-14	06.21	30-May-14	20.04	Bus outage At Malegaon.
220KV	Chalisgaon - Malegaon	30-May-14	06.20		Continued.	Bus outage at Malegaon.
220KV	220kv Main Bus @ Malegaon	30-May-14	06.27	30-May-14	10.34	Replacement Of Main Bus Conductor due to Broken Stands.
220KV	Bhoiser - Tarapur - I	30-May-14	08.05	30-May-14	20.05	Maint.work
220KV	Nasik-Navsari-I	30-May-14	10.09	31-May-14	19.41	Maint.work
220KV	Dhule - Malegaon	30-May-14	06.27	30-May-14	20.04	Bus Outage at Malegaon
220KV	Apta-Uran-IV	30-May-14	08.32	30-May-14	18.40	Repl.of Cut point and Suspension Disc Insulator
220KV	Bale-Usmanabad	30-May-14	10.22	30-May-14	13.26	Armoring work at Loc.No.135
220KV	Parly - Harangool - II	30-May-14	17.55		Continued.	Hot Spot
220KV	Parli Extn. - Parli -1 @ Parli	30-May-14	08.09		Continued.	Repl.of Bolted type Jumper CT& WT
220KV	Pedambe-Pophali I	31-May-14	9.10	31-May-14	10.45	ct oil top up
220KV	220/100 KV 100 MVA ICT - I @ Vasai	31-May-14	17.46	31-May-14	18.36	R phase bushing leakage
220KV	Tarapur - Boiser	31-May-14	8.55	31-May-14	22.03	maint.work
220KV	220 KV Interconnector @ Kalwa	1-Jun-14	07.39	1-Jun-14	11.33	CT Tan Delta & CB Timing.
220KV	220/100KV 200MVA ICT-III at Trombay	1-Jun-14	10.04	1-Jun-14	18.15	Hot Spot & R.M.Work
220KV	Hinganghat-Warora	1-Jun-14	20.36	1-Jun-14	21.26	Dist.Prot.
220KV	Vasai - Bhoisor (PGCIL)	1-Jun-14	21.11	1-Jun-14	03.37	Hot Spot.
132KV	Beed - Talegaon	26-May-14	19.02	26-May-14	19.37	Distance Protection,R & B Z-III.
132KV	Akola - Gorakshan	26-May-14	19.18	26-May-14	19.40	Distance Protection,R Ph Z-I.
132KV	Pangari - Telgaon	26-May-14	19.02	27-May-14	05.58	Distance Protection,R & B Ph, Tripped due to CB Wiring Burnt.
132KV	BBLSR - Sangamner	27-May-14	15.09	27-May-14	15.15	Tripped on FTR.
132KV	BBLSR - Rahuri	27-May-14	15.09	27-May-14	15.14	Tripped on FTR.
132KV	Babaleshwar - Kopargaon	27-May-14	15.09	27-May-14	15.16	Tripped on FTR.
132KV	BBLSR - Newasa	27-May-14	15.09	27-May-14	15.16	Tripped on FTR.
132KV	Bhusawal - Nimbhora	28-May-14	14.17	28-May-14	14.37	Dist.Prot.
132KV	Yawat - Theur	29-May-14	11.34	29-May-14	15.43	Maintenance Work.
132KV	Phursungi-Phursungi II	29-May-14	10.37	29-May-14	12.57	Half Yearly Maintenance Work.
132KV	Nanded - Narsi	1-Jun-14	12.39	1-Jun-14	12.55	Dist.Prot.
132KV	Parbhani-Parthur	1-Jun-14	14.47	1-Jun-14	14.51	Dist.Prot.
100KV	Kalwa - Washi	29-May-14	06.30	29-May-14	08.41	Hot Spot Attending Work.