

State Load Despatch Center,Airoli (MSETCL)
Power System Position from 27/May/2024 to 02/Jun/2024

Supply Position During Morning Peak (MW)

Date	Time	MSGENCO				Central Sector Receipt	Wind	CPP	SOLAR	TPCL Exch.	MSEDCL Catered Demand	Load Sheddin g(LS)	MSEDCL Demand (Incl. LS)	TPCL Gen.	R-INFRA Gen.	State Demand Met	State Demand (Incl. LS)	Freq.
		THM	HYDRO	GAS	Total													
		MW	MW	MW	MW	MW	MW	MW	MW	MW	MW	MW	MW	MW	MW	MW	MW	Hzs
27-05-2024	12 Hrs	6171	641	284	7096	8525	1915	4954	1748	-2458	21221	0	21221	944	504	25686	25686	49.99
28-05-2024	12 Hrs	5345	431	281	6057	8064	2231	4543	2333	-2477	20200	0	20200	891	504	24623	24623	50.00
29-05-2024	12 Hrs	5504	1072	281	6857	8863	1900	4803	2505	-2443	21956	0	21956	897	501	26326	26326	49.96
30-05-2024	12 Hrs	6693	462	281	7436	9265	867	5068	2451	-2350	22199	0	22199	1020	503	26610	26610	50.01
31-05-2024	12 Hrs	6116	1707	277	8100	9085	788	5125	2390	-2609	22326	0	22326	817	489	26794	26794	50.00
01-06-2024	12 Hrs	6578	175	279	7032	9751	500	5282	2330	-2117	22284	0	22284	1050	504	26449	26449	49.95
02-06-2024	12 Hrs	6411	128	279	6818	9651	526	5261	2211	-1840	22173	0	22173	688	444	25599	25599	49.93
Maximum		6693	1707	284	8100	9751	2231	5282	2505	-1840	22326	0	22326	1050	504	26794	26794	50.01
Minimum		5345	128	277	6057	8064	500	4543	1748	-2609	20200	0	20200	688	444	24623	24623	49.93
Average		6117	659	280	7057	9029	1247	5005	2281	-2328	21765	0	21765	901	493	26012	26012	49.98

Supply Position During Day Peak (MW)

Date	Time	MSGENCO				Central Sector Receipt	Wind	CPP	SOLAR	TPCL Exch.	MSEDCL Catered Demand	Load Sheddin g(LS)	MSEDCL Demand (Incl. LS)	TPCL Gen.	R-INFRA Gen.	State Demand Met	State Demand (Incl. LS)	Freq.
		THM	HYDRO	GAS	Total													
		MW	MW	MW	MW	MW	MW	MW	MW	MW	MW	MW	MW	MW	MW	MW	MW	Hzs
27-05-2024	16 Hrs	6710	685	258	7653	8669	2383	5154	1096	-2422	21989	0	21989	1051	501	26507	26507	49.94
28-05-2024	17 Hrs	7129	256	278	7663	8740	2102	5708	1042	-2359	22334	0	22334	1069	467	26791	26791	50.03
29-05-2024	16 Hrs	6514	918	280	7712	9201	1965	5062	1743	-2405	22763	0	22763	1070	502	27255	27255	50.02
30-05-2024	16 Hrs	7092	726	280	8098	9069	1324	6183	1757	-2470	23431	0	23431	1089	504	28024	28024	50.06
31-05-2024	16 Hrs	7064	1655	278	8997	9045	962	5710	1644	-2554	23261	0	23261	1088	504	27950	27950	49.99
01-06-2024	16 Hrs	7165	607	279	8051	9956	608	6549	1333	-2149	23855	0	23855	1238	503	28238	28238	50.07
02-06-2024	16 Hrs	6744	777	278	7799	9402	417	6494	1231	-2042	22820	0	22820	770	456	26569	26569	50.03
Maximum		7165	1655	280	8997	9956	2383	6549	1757	-2042	23855	0	23855	1238	504	28238	28238	50.07
Minimum		6514	256	258	7653	8669	417	5062	1042	-2554	21989	0	21989	770	456	26507	26507	49.94
Average		6917	803	276	7996	9155	1394	5837	1407	-2343	22922	0	22922	1054	491	27333	27333	50.02

Supply Position During Evening Peak (MW)

Date	Time	MSGENCO				Central Sector Receipt	Wind	CPP	SOLAR	TPCL Exch.	MSEDCL Catered Demand	Load Sheddin g(LS)	MSEDCL Demand (Incl. LS)	TPCL Gen.	R-INFRA Gen.	State Demand Met	State Demand (Incl. LS)	Freq.
		THM	HYDRO	GAS	Total													
		MW	MW	MW	MW	MW	MW	MW	MW	MW	MW	MW	MW	MW	MW	MW	MW	Hzs
27-05-2024	20 Hrs	7190	1154	274	8618	6933	2545	6248	0	-2017	21768	0	21768	1041	410	25795	25795	50.04
28-05-2024	21 Hrs	7449	1856	286	9591	6686	2040	6447	0	-1663	22585	0	22585	1228	482	26474	26474	50.03
29-05-2024	21 Hrs	6825	1961	362	9148	6645	2523	6420	0	-1613	22597	0	22597	1289	502	26527	26527	49.96
30-05-2024	20 Hrs	7259	1450	287	8996	7223	2477	6392	0	-1918	22615	0	22615	1149	455	26692	26692	50.03
31-05-2024	21 Hrs	7484	1894	372	9750	6754	1734	6693	0	-1782	22615	0	22615	1264	464	26659	26659	49.99
01-06-2024	20 Hrs	7138	1008	283	8429	8969	1482	6612	0	-1918	23084	0	23084	1014	438	26945	26945	49.99
02-06-2024	21 Hrs	6738	675	285	7698	8341	1139	6632	0	-1747	21577	0	21577	906	492	25208	25208	49.99
Maximum		7484	1961	372	9750	8969	2545	6693	0	-1613	23084	0	23084	1289	502	26945	26945	50.04
Minimum		6738	675	274	7698	6645	1139	6248	0	-2017	21577	0	21577	906	410	25208	25208	49.96
Average		7155	1428	307	8890	7364	1991	6492	0	-1808	22406	0	22406	1127	463	26329	26329	50.00

Supply Position During Night Off Peak (MW)

Date	Time	MSGENCO				Central Sector Receipt	Wind	CPP	SOLAR	TPCL Exch.	MSEDCL Catered Demand	Load Sheddin g(LS)	MSEDCL Demand (Incl. LS)	TPCL Gen.	R-INFRA Gen.	State Demand Met	State Demand (Incl. LS)	Freq.
		THM	HYDRO	GAS	Total													
		MW	MW	MW	MW	MW	MW	MW	MW	MW	MW	MW	MW	MW	MW	MW	MW	Hzs
27-05-2024	4 Hrs	6530	1763	286	8579	6687	2278	5073	0	-1956	20265	0	20265	599	294	23510	23510	49.95
28-05-2024	8 Hrs	6405	435	287	7127	7526	2794	5010	623	-1915	20650	0	20650	589	315	23984	23984	50.08
29-05-2024	8 Hrs	5807	1098	287	7192	7715	2632	5198	676	-1863	21086	0	21086	597	302	24312	24312	50.03
30-05-2024	8 Hrs	6912	505	287	7704	8073	959	6200	666	-1737	21364	0	21364	670	430	24702	24702	50.03
31-05-2024	8 Hrs	6821	1924	286	9031	7849	1224	5119	663	-1763	21623	0	21623	718	370	24974	24974	50.10
01-06-2024	8 Hrs	6690	184	286	7160	8537	963	6067	595	-1677	21194	0	21194	697	374	24393	24393	49.98
02-06-2024	8 Hrs	6602	286	284	7172	8663	736	6281	515	-1577	21352	0	21352	642	390	24399	24399	49.97
Maximum		6912	1924	287	9031	8663	2794	6281	676	-1577	21623	0	21623	718	430	24974	24974	50.10
Minimum		5807	184	284	7127	6687	736	5010	0	-1956	20265	0	20265	589	294	23510	23510	49.95
Average		6538	885	286	7709	7864	1655	5564	534	-1784	21076	0	21076	645	354	24325	24325	50.02

Details of Supply Position (MUs)

Date	MSGENCO				Pench (MS)	Central Sector Receipt	Central Sector Share	WIND	CPP	SOLAR	TPCL Gen.	R-INFRA Gen.	TPCL Exch.	Energy Requirement		
	THM	HYDRO	GAS	Total										MSEDCL	MUMBAI	STATE
	Mus	Mus	Mus	Mus	Mus	Mus	Mus	Mus	Mus	Mus	Mus	Mus	Mus	Mus	Mus	Mus
27-05-2024	156.883	27.627	6.725	191.235	0.000	178.344	185.224	57.015	129.733	13.871	19.741	9.768	-52.179	505.908	81.688	599.707
28-05-2024	156.775	21.279	6.951	185.005	0.000	179.956	185.959	58.018	130.617	18.022	21.206	10.139	-49.645	509.878	80.990	602.963
29-05-2024	151.707	30.798	7.342	189.847	0.000	186.563	191.001	57.015	135.764	19.370	21.614	10.446	-48.762	528.234	80.822	620.619
30-05-2024	167.835	27.234	7.315	202.384	0.000	190.198	194.987	38.203	144.696	19.203	22.880	11.355	-48.014	534.713	82.249	628.919
31-05-2024	166.245	40.048	7.305	213.598	0.000	190.532	195.817	33.152	142.793	18.631	22.646	11.087	-49.604	537.012	83.337	632.439
01-06-2024	168.141	15.911	7.088	191.140	0.000	211.320	216.465	26.733	150.079	17.109	24.274	11.470	-44.464	540.732	80.208	632.125
02-06-2024	159.367	16.798	6.981	183.146	0.000	211.166	218.506	20.953	150.890	16.383	18.905	10.874	-43.134	528.630	72.913	612.317
Maximum	168.141	40.048	7.342	213.598	0.000	211.320	218.506	168.141	150.890	19.370	24.274	11.470	-43.134	540.732	83.337	632.439
Minimum	151.707	15.911	6.725	183.146	0.000	178.344	185.224	151.707	129.733	13.871	18.905	9.768	-52.179	505.908	72.913	599.707
Average	160.993	25.671	7.101	193.765	0.000	192.583	198.280	160.993	140.653	17.513	21.609	10.734	-47.972	526.444	80.315	618.441

Details of Koyna Water Consumption (in TMC)

Date	For the Day	For the Month	Balance
27-05-2024	0.558	10.135	11.778
28-05-2024	0.411	10.546	11.368
29-05-2024	0.624	11.170	10.743
30-05-2024	0.561	11.731	10.182
31-05-2024	0.852	12.583	9.330
01-06-2024	0.313	0.313	67.187
02-06-2024	0.334	0.647	66.853

State Load Despatch Center,Airoli (MSETCL) Central Sector Share/Drawal from 27/May/2024 to 02/Jun/2024

Date	DAY	Central Sector Share		Total Interstate		Total Share		Total Drawal		Overdrawal(+) /	
		MUs	Avg. MW	MUs	Avg. MW	MUs	Avg. MW	MUs	Avg. MW	MUs	Avg. MW
		1		2		1+2=3		4		3-4=5	
27-05-2024	MONDAY	91.887	7624	93.337	3889	185.224	7718	178.344	7431	-6.880	-287
28-05-2024	TUESDAY	53.932	7616	132.027	5501	185.959	7748	179.956	7498	-6.003	-250
29-05-2024	WEDNESDAY	71.309	7839	119.692	4987	191.001	7958	186.563	7773	-4.438	-185
30-05-2024	THURSDAY	91.971	8021	103.016	4292	194.987	8124	190.198	7925	-4.789	-200
31-05-2024	FRIDAY	91.947	8055	103.870	4328	195.817	8159	190.532	7939	-5.285	-220
01-06-2024	SATURDAY	101.400	8904	115.065	4794	216.465	9019	211.320	8805	-5.145	-214
02-06-2024	SUNDAY	108.413	8994	110.093	4587	218.506	9104	211.166	8799	-7.340	-306
Total		610.860		777.099		1387.959		1348.079		-39.880	

Generator Unit Outages/Trippings from 27.05.2024 to 02.06.2024						
Name of Unit	Date Trip	Time Trip	Date Sync	Time Sync	Reason	Outage Type
PGPL U2	07-02-2017	17.3		Continued.	No Schedule.(NO PPA)	NOPPA
PGPL U1	07-02-2017	17.3		Continued.	No Schedule (NO PPA)	NOPPA
VIPL U-1	29-12-2018	0.3		Continued.	Coal Shortage. (NO PPA From 20.05.2019)	NOPPA
VIPL U-2	17-01-2019	0.15		Continued.	Coal shortage.(NO PPA From 20.05.2019)	NOPPA
Tarapur 1	08-01-2020	10:37		Continued.	Refueling. While refueling preparation, some repair works identified which are being executed before refueling.	FORCED
Tarapur 2	13-07-2020	04:38		Continued.	For cleaning of clogged basket strainer of cooling water system due to heavy ingress of debris from sea. The outage extended for repair and re-fueling.	FORCED
Koradi Unit 7	27-04-2021	20.03		Continued.	Retired (04/08/2021 At 00.00)	FORCED
Uran Unit A0	07-09-2022	16:30		Continued.	TURBINE TRIPPED ON HIGH VIBRATIONS	FORCED
Uran Unit 5	19-05-2024	02:00		Continued.	As per MSEDCL zero schedule.	ZEROSCH/R SD
Chandrapur Unit 9	24-05-2024	01:59	27-05-2024	23:48	Boiler Tube Leakage	FORCED
Uran Unit 6	24-05-2024	02:00	28-05-2024	22:22	Due to Zero schedule by MSEDCL.	ZEROSCH/R SD
Bhusawal Unit 3	24-05-2024	15:37	28-05-2024	03:23	Boiler Tube Leakage	FORCED
RPL(AMT) U-2	25-05-2024	13:52	28-05-2024	12:46	ID Fan Tripped at high Vibration.	FORCED
Ghatghar Unit-2	26-05-2024	13:17		Continued.	Stator Earth Fault	FORCED
SWPGPL U-1	27-05-2024	15:35	30-05-2024	04:19	ID Fan Problem	FORCED
Koradi Unit 8	28-05-2024	01:14	30-05-2024	05:46	Boiler Tube Leakage	FORCED
SWPGPL U-3	28-05-2024	10:14	31-05-2024	04:06	Boiler Tube Leakage	FORCED
RPL(AMT) U-2	28-05-2024	13:35	28-05-2024	15:29	Turbine Condenser Vacuum Low.	FORCED
RPL(AMT) U-4	28-05-2024	18:57		Continued.	Due to ID Fan tripped on high vibration..	FORCED
Koradi Unit 9	28-05-2024	22:12	02-06-2024	14:25	Boiler Tube Leakage	FORCED
Uran Unit 6	29-05-2024	02:00	29-05-2024	19:54	As per MSEDCL zero schedule.	ZEROSCH/R SD
Bhusawal Unit 3	29-05-2024	02:31	02-06-2024	06:24	Boiler Tube Leakage	FORCED
Uran Unit 6	30-05-2024	02:00	30-05-2024	19:53	As per MSEDCL zero schedule	ZEROSCH/R SD
Khaparkheda Unit 3	30-05-2024	22:20	31-05-2024	04:02	Due to furnace draft high.	FORCED
Uran Unit 6	31-05-2024	01:02	31-05-2024	19:00	Due to Zero Schedule given by MSEDCL.	ZEROSCH/R SD
Bhusawal Unit 4	31-05-2024	09:09	31-05-2024	11:05	Flame Failure	FORCED
Uran Unit 6	01-06-2024	02:00	01-06-2024	22:42	Due to Zero Schedule given by MSEDCL.	ZEROSCH/R SD
Nasik Unit 3	01-06-2024	02:15	01-06-2024	05:30	Low furnace pressure	FORCED
Paras Unit 4	01-06-2024	02:27		Continued.	Drum level low	FORCED
Koradi Unit 6	01-06-2024	11:00	01-06-2024	13:20	Generator master trip relay malfunction	FORCED
SWPGPL U-3	01-06-2024	11:51	01-06-2024	13:20	Turbine feedwater Pump failure.	FORCED
Uran Unit 6	02-06-2024	02:00		Continued.	Due to Zero Schedule given by MSEDCL.	ZEROSCH/R SD
Khaparkheda Unit 3	02-06-2024	03:05		Continued.	Boiler Tube Leakage	FORCED
Paras Unit 3	02-06-2024	06:16	03-06-2024	02:23	Valve malfunction operate.	FORCED
Bhusawal Unit 3	02-06-2024	06:37	02-06-2024	06:56	Low Vacuum	FORCED
Chandrapur Unit 9	02-06-2024	22:52		Continued.	Condenser Vacuum low	FORCED

Transmission Line Outages/Trippings from 27.05.2024 to 02.06.2024							
Name of Line	Date Trip	Time Trip	Date Sync	Time Sync	Reason	Outage Type	Voltage
PARLI - KUMBHARGAON (NANDED) CKT - 1	26-05-2024	23:21	27-05-2024	02:24	Y-ph CVT jumper connection work.	PO	400 KV
PARLI - KUMBHARGAON (NANDED) CKT - 1	26-05-2024	23:21	27-05-2024	02:24	Y-ph CVT jumper connection work.	PO	400 KV
400/220/33 KV 315MVA ICT - 1 @ BABHALESHWAR	27-05-2024	11:27	27-05-2024	21:02	DFRA SFRA testing, premonsoon maintenance and quarterly bay maintenace work.	PO	400 KV
400/220/33 KV 500 MVA ICT - 1 @	27-05-2024	11:20	27-05-2024	16:39	Pre-monsoon Maintenance work.	PO	400 KV
PADGHE - KALWA CKT - 2	28-05-2024	03:28	28-05-2024	04:05	Tripped from Kalwa end only on PDR.	T	400 KV
400/220 KV 105 MVA SPARE ICT	28-05-2024	10:41	28-05-2024	16:47	1) Bushing & winding testing of ICT Unit.2) Bay Maintenance work.	PO	400 KV
400/220/33 KV 500 MVA ICT - 3 @ DHULE	28-05-2024	10:39	29-05-2024	00:18	Outage required for 501 MVA ICT-3 RRS scheme live trial	PO	400 KV
400/220KV 167 MVA SPARE ICT @ DHULE	28-05-2024	10:41	29-05-2024	00:15	Outage required for 501 MVA ICT-3 RRS scheme live trial	PO	400 KV
CHAKAN - TALEGAON(PG)	28-05-2024	21:59	29-05-2024	03:16	Emergency outage by powergrid	HT	400 KV
400/220/33 KV 167 MVA SPARE ICT @ KHAPARKHEDA	29-05-2024	11:38	30-05-2024	17:48	Wiring & Relay Protection required for RRS Scheme of ICTs	PO	400 KV
400/220/33 KV 500 MVA ICT - 2 @ NANDED	29-05-2024	08:32	29-05-2024	13:50	Pre-monsoon maintenance work.	PO	400 KV
400/220/33 KV 500 MVA ICT - 2 @ NANDED	29-05-2024	08:32	29-05-2024	13:50	Pre-Monsoon maintenance work	PO	400 KV
400/220/33 KV 500MVA ICT - 1 @ KHAPARKHEDA	29-05-2024	11:38	29-05-2024	20:44	Wiring & Relay Protection required for RRS Scheme of ICTs	PO	400 KV
400/220/33 KV 500MVA ICT - 1 @ KHAPARKHEDA	29-05-2024	11:38	29-05-2024	20:44	Wiring and relay protection required for PRS scheme of ICTs	PO	400 KV
400220kv 167MVA SPARE ICT @ DEEPNAGAR	29-05-2024	17:04	29-05-2024	18:12	For replacement of nitrogen gas cylinder due to low N2 Pressure alarm appears on CTR NIFPS Panel.	PO	400 KV
KORADI - SATPUR	29-05-2024	10:17	29-05-2024	18:16	for the work of interconnection of PMUs	PO	400 KV
LONIKAND I - TALEGAON (PGCIL)	30-05-2024	22:55	31-05-2024	05:47	Cold line washing.	PO	400 KV
400/220/33 KV 315MVA ICT - 2 @ CHAKAN	30-05-2024	15:38	30-05-2024	21:45	Routine Maintenance and DT.	PO	400 KV
400/220/33 KV 500MVA ICT - 2 @ KHAPARKHEDA	30-05-2024	10:36	30-05-2024	17:32	Wiring & Relay Protection required for RRS Scheme of ICTs	PO	400 KV
400/220/33KV 315MVA ICT - 3 @ LONIKAND	30-05-2024	06:44	30-05-2024	13:07	DT Work & Bay Maintenance	PO	400 KV
400/220kv SPARE ICT @ JEJURI	30-05-2024	10:48	30-05-2024	15:52	For Pre Monsoon Maintenance & Testing work	PO	400 KV
400KV 125 MVAR BUS REACTOR @ AKOLA	30-05-2024	11:00	30-05-2024	15:43	Attend the misaligned clamp of 41689b b-phase isolator.	T	400 KV
MAIN BUS - 1 @ KUMBHARGAON (NANDED)	30-05-2024	10:36	30-05-2024	17:56	CVT Tan-d testing work	PO	400 KV
220 KV KHADKA (400 KV)- CHALISGAON CKT -1	31-05-2024	08:09	31-05-2024	16:45	FOR WORK OF RESTRINGING OF CONDUCTOR BETWEEN LOC NO. 299 TO 313	PO	400 KV

Transmission Line Outages/Trippings from 27.05.2024 to 02.06.2024							
Name of Line	Date Trip	Time Trip	Date Sync	Time Sync	Reason	Outage Type	Voltage
AKOLA - WARDHA(PG) CKT - 1	31-05-2024	16:40	31-05-2024	20:45	FOR RECTIFICATION OF MELTED JUMPER PAD		400 KV
400/220/33 KV 315 MVA ICT - 1 @ PARLI	31-05-2024	15:05	31-05-2024	15:57	220 kV Busbar operated	T	400 KV
400/220/33 KV 315 MVA ICT - 2 @ PARLI	31-05-2024	15:05	31-05-2024	15:43	220 kV Busbar operated	T	400 KV
400/220/33 KV 500 MVA ICT - 3 @ PARLI	31-05-2024	15:05	31-05-2024	15:51	220 kV Busbar operated	T	400 KV
400/220kv 500MVA ICT-2 @ TAPTITANDA	31-05-2024	08:29	31-05-2024	14:40	Pre monsoon work, and testing work.	PO	400 KV
400KV 125 MVAR BUS REACTOR @ AKOLA	31-05-2024	08:28	31-05-2024	14:07	routine maintenance & testing work	PO	400 KV
STATION TRANSFORMER - 8A @ CHANDRAPUR SWITCHING SS	31-05-2024	10:52	31-05-2024	15:08	MAIN AND TIE BAY TRIPPED ON BUCHOLZ PROT OF STN TF 8A	T	400 KV
220 KV KHADKA (400 KV)- CHALISGAON CKT -1	01-06-2024	08:13	01-06-2024	16:50	Work of restringing of conductor between Loc no.299 to 313	PO	400 KV
400/220/33 KV 315 MVA ICT - 1 @ LONIKAND	01-06-2024	18:02	01-06-2024	20:20	Premansoon activity and bay maintenance work	PO	400 KV
400/220/33 KV 501MVA ICT - 4 @ BABHALESHWAR	01-06-2024	11:15	01-06-2024	20:55	For obtaining sufficient clearance so as to carry out connection of jumper of 501 MVA ICT V to 400 KV Main Bus II by Hot Line method	PO	400 KV
400/220/33KV 315MVA ICT - 2 @ LONIKAND	01-06-2024	20:38	01-06-2024	22:30	Premansoon activity and bay maintenance work	PO	400 KV
400/220KV 500 MVA ICT - 1 @ VIKHROLI GIS	01-06-2024	00:26	01-06-2024	06:25	HT for Load Management	HT	400 KV
AURANGABAD(MS) - AURANGABAD(PG) CKT -2	01-06-2024	18:17	01-06-2024	22:08	Attending Hotspot by PGCIL		400 KV
BABLESHWAR- AURANGABAD (WALUJ)	01-06-2024	11:49	01-06-2024	13:40	Line tripped on distance protection.	T	400 KV
400/220 KV 3X200 MVA ICT - 2 @ KALWA	02-06-2024	07:15	02-06-2024	10:20	Pre-monsoon maintenance activity	PO	400 KV
EKLAHARE (OCR) - NAVASARI CKT - 2	25-05-2024	13:25	01-06-2024	22:40	For load management	HT	220 KV
220 KV PARLI (OLD GCR)- GIRWALI (400 KV) CKT 3	26-05-2024	15:40	27-05-2024	02:55	Tripped due earth wire strangling of 132kv Parli-Girwali ckt.	T	220 KV
220 KV PARLI (OLD GCR)- GIRWALI (400 KV) CKT 4	26-05-2024	15:40	27-05-2024	03:05	Tripped due earth wire strangling of 132kv Parli-Girwali ckt.	T	220 KV
MULUND - GIS BHANDUP	26-05-2024	22:05	27-05-2024	02:08	For the installation of saver assembly sets at TL no. 20 & 21 (Total 6 sets out of 6 sets are to be installed)	PO	220 KV
220 / 11 KV 200 MVA GT @ BHIRA (T)	26-05-2024	23:40	27-05-2024	06:35	REPLACEMENT OF OIL COOLER	PO	220 KV

Transmission Line Outages/Trippings from 27.05.2024 to 02.06.2024							
Name of Line	Date Trip	Time Trip	Date Sync	Time Sync	Reason	Outage Type	Voltage
KHARGHAR - BORIVALI CKT - 2	26-05-2024	22:03	27-05-2024	02:34	For the installation of saver assembly sets at TL no. 20 & 21 (Total 6 sets out of 66 sets are to be installed)	PO	220 KV
PADGHE - NALASOPARA - VASAI (T)	26-05-2024	01:27	27-05-2024	18:55	B) As on dt: 25.05.2024 at 21:00Hrs to 27.05.2024 at 06:00Hrs. outage on 220kV Padghe- Nalasopara for the work of erection of in-line Monopole , cut point formation and conductor de-stringing & stringing work. 1) Jumper at loc.52 of 220kV Padghe-Nalasopra line will be opened to avoid the backfeeding from 220kV Vasai-Nalasopara link line. 2) After opening the jumper at loc.no. 52, 220kV Nalasopara-Vasai link line will be charged at 23:00Hrs. on dt:-25.05.2024 for 02 days. 3) In-line monopole erection work will be carry out at loc.no.48,49 & 49A. 4) Cut point formation over newly erected Monopole work will be carrying out at loc.no. 48,49,&49A of 220kV Padghe-Nalasopara line and also related tower's conductor de-stringing and stringing work will be carry out of above said ckt. 5) After erection of Monopole tower, cut point formation and conductor stringing work, 220kV Padghe-Nalasopara-Vasai tap line will be charged at 06:00 Hrs. on dt: 27.05.2024.	PO	220 KV
DAHANU - VIRAJ	27-05-2024	10:23	27-05-2024	18:14	MVAR Management.	HT	220 KV
HINJAWADI I- CHINCHWAD	27-05-2024	10:34	27-05-2024	20:03	Due to overloading of 220kV Urse-chinchwad ckt.	HT	220 KV
KHAREPATAN -PAWAS LINE	27-05-2024	08:39	27-05-2024	10:49	For Premonsoon activity.	PO	220 KV
OSMANABAD - BARSHI	27-05-2024	09:21	27-05-2024	13:41	Work at Barshi end.	PO	220 KV
OSMANABAD - BARSHI	27-05-2024	09:21	27-05-2024	13:41	Replacement of LA's under LE scheme along with quarterly bay maintenance work.	PO	220 KV
PEDHAMBE ONI LINE	27-05-2024	14:08	27-05-2024	17:17	For replacement of flashover strings at loc no 125 top ph Oni side and broken insulator string at loc no 125 bottom ph Oni side.	PO	220 KV
TALANDAGE - FIVE STAR MIDC 1	27-05-2024	10:40	27-05-2024	20:41	Retrofitting of O/C E/F Relay	PO	220 KV
THEUR-PHURSUNGI CKT I	27-05-2024	09:12	27-05-2024	21:42	Dist. relay retrofitting, commissioning and testing work by agency GE	PO	220 KV

Transmission Line Outages/Trippings from 27.05.2024 to 02.06.2024							
Name of Line	Date Trip	Time Trip	Date Sync	Time Sync	Reason	Outage Type	Voltage
WARDHA-D-GAON NEW	27-05-2024	07:42	27-05-2024	09:53	For replacement of faulty middle stack of 220kv BPH LA the stack is having low IR value(4.6MOHM) top to earth IR value is(8.54 GOHM).	PO	220 KV
132 KV PADEGAON (220 KV) - SAWANGI (220 KV) CKT	27-05-2024	12:35	27-05-2024	16:49	Tree cutting in urban, forest , military area.		220 KV
220 KV KEKATNIBHORA - KHADKA (400 KV) CKT	27-05-2024	08:25	27-05-2024	20:51	For Work of restringing of conductor From loc no 299 to 313.	PO	220 KV
220/110 KV 100 MVA PTR 1 @ BIDRI	27-05-2024	08:35	27-05-2024	14:10	Diagnostic testing work. Quarterly maintenance work.	PO	220 KV
220/132 KV 100 MVA ICT 3 @ RANJANGAON	27-05-2024	10:28	27-05-2024	15:57	For Premansoon Bay maintenance work.	PO	220 KV
220/132 KV 200 MVA ICT 2	27-05-2024	08:00	27-05-2024	09:48	Pre-monsoon Work.	PO	220 KV
220/132 KV, 100MVA ICT 1 @ ANJANGAON(VIHIGAON)	27-05-2024	09:25	27-05-2024	18:45	Pre-monsoon work.	PO	220 KV
220/132KV 200MVA ICT 5 @ EKLAHARE (OCR)	27-05-2024	10:07	27-05-2024	13:30	Pre monsoon maintenance work	PO	220 KV
220/33 kv 50 MVA CGL PTR 1 @ MUDSHINGI	27-05-2024	09:16	27-05-2024	17:26	"Transformer painting work. "	PO	220 KV
220/33KV 100MVA PTR 2 @ 5 STAR MIDC, KAGAL	27-05-2024	10:23			for premansoon maintenance work	PO	220 KV
220/33KV 50MVA PTR 1 @ 5 STAR MIDC, KAGAL	27-05-2024	10:23	27-05-2024	12:38	for premansoon maintenance work	PO	220 KV
220/33KV 50MVA PTR 3 @ WATHAR	27-05-2024	09:09	27-05-2024	16:16	Quarterly Maintenance works.	PO	220 KV
BUS COUPLER @ PHURSUNGI	27-05-2024	10:59	27-05-2024	20:07	ICT overloaded at Lonikand.	HT	220 KV
KARAD - KADEGAON	27-05-2024	15:04	27-05-2024	20:35	Replacement of faulty disc insulator strings at various locations	PO	220 KV
NEW KOYNA - NIWALI	27-05-2024	11:27	27-05-2024	13:39	For replacement of flashover insulator string at loc no 125 middle ph Niwali side	PO	220 KV
PADGHE - NALASOPARA - VASAI (T)	27-05-2024	17:10	27-05-2024	18:55	As on dt:27.05.2024 at 04:00Hrs. to 06:00 Hrs. outage on 220kV Nalasopara-Vasai link line for the work of re-conect the jumper atloc.no.52 of 220kV Padghe-Nalasopara line. 1) To re-connecting the jumper at loc.no.52 of 220kV Padghe-Nalasopara-Vasai tap line. 2) After re-connecting the jumper at loc.no.52, 220kV Padghe-Nalasopara-Vasai tap line will be charged at 06:00 Hrs. on Dt: -27.05. 2024.	PO	220 KV
SATANA - GANGAPUR	27-05-2024	13:05	28-05-2024	18:30	Unbalanced current R phase Jump open	T	220 KV
SATANA - GANGAPUR	27-05-2024	13:05	28-05-2024	18:30	Unbalanced current R-PH jump open at 314 loc.	HT	220 KV
DAHANU - VIRAJ	28-05-2024	10:20	28-05-2024	17:40	Control MVAR export form DTPS to Boisar.	HT	220 KV
GHODBUNDER - GORAI	28-05-2024	17:59	28-05-2024	20:23	Bus Fault	T	220 KV

Transmission Line Outages/Trippings from 27.05.2024 to 02.06.2024							
Name of Line	Date Trip	Time Trip	Date Sync	Time Sync	Reason	Outage Type	Voltage
KHAPARKHEDA-AMBAZARI-I	28-05-2024	14:48	28-05-2024	18:33	Distance protection	T	220 KV
POPHLI PEDHMBE LINE- 1	28-05-2024	06:56	28-05-2024	10:25	R phase CT oil level top up work.	PO	220 KV
THEUR-PHURSUNGI CKT II	28-05-2024	09:01	28-05-2024	19:05	Dist. relay retrofitting commissioning and testing work by agency GE	PO	220 KV
VERSOVA - GORAI	28-05-2024	17:59	28-05-2024	20:30	Bus Fault	T	220 KV
WPCL-WARORA 2	28-05-2024	10:28	28-05-2024	16:58	Replacement of Y Phase LA	PO	220 KV
100 MVA 220/132 KV ICT - III @ HINGOLI	28-05-2024	10:10	28-05-2024	12:08	Maintenance work	PO	220 KV
220 KV KHADKA(400 KV) - KEKATNIBHORA CKR	28-05-2024	08:14	28-05-2024	17:36	Restranging work of conductor	PO	220 KV
220/132 KV 100 MVA ICT 1	28-05-2024	17:47	28-05-2024	19:16	Maintenance work	PO	220 KV
220/132KV 100MVA ICT 1@ PETH	28-05-2024	10:01	28-05-2024	16:30	Premonsoon Maintenance Work	PO	220 KV
220/33 KV 50 MVA PTR - 1 @ PHALTAN MIDC	28-05-2024	09:05	28-05-2024	11:35	Quarterly Maintenance Work	PO	220 KV
220/33KV 50MVA PTR 1 @ MIRAJ	28-05-2024	09:38	28-05-2024	17:58	Premonsoon Maintenance Work	PO	220 KV
220/33kv 125 MVA TF 1 @ GORAI	28-05-2024	17:59	28-05-2024	20:28	Bus Fault	T	220 KV
220/33kv 125 MVA TF 2 @ GORAI	28-05-2024	17:59			Bus Fault	T	220 KV
GORAI -MSETCL BORIVALI CKT -1	28-05-2024	17:59			Bus fault	T	220 KV
GORAI -MSETCL BORIVALI CKT -2	28-05-2024	17:59	02-06-2024	20:00	Bus fault	T	220 KV
JINDAL - JINDAL EHV CONSUMER BAY	28-05-2024	07:24	28-05-2024	15:50	transformer oil leakage arresting and general maintenance	PO	220 KV
MAIN BUS - 1 @ GORAI	28-05-2024	17:59			Bus Fault	T	220 KV
MAIN BUS - 2 @ GORAI	28-05-2024	17:59	28-05-2024	20:23	Bus Fault	T	220 KV
220 KV KHAPARKHEDA 2 (NEW) - KANHAN CKT	29-05-2024	15:24	29-05-2024	19:58	Distance Protection	T	220 KV
BOISAR II - BOISAR (PG) CKT - 1	29-05-2024	05:33	29-05-2024	09:12	work for replacement of existing 0.4 ACSR Zebra Conductor and all its Hardware by equivalent CCC HTLS Conductor and suitable Hardware for 220kV Boisar - PGCIL (Dead Line). Outage required of 220kV PGCIL - Boisar Line No. 1 for safety purpose only.	PO	220 KV
BOMBAY DYEING - SAHARA	29-05-2024	15:52	29-05-2024	19:12	Replacement of string insulators at Loc No. 127 & 128.	PO	220 KV
DAHANU - VIRAJ	29-05-2024	10:15	29-05-2024	10:24	To control MVAR export form DTPS to Boisar	HT	220 KV
HINJAWADI I- CHINCHWAD	29-05-2024	19:41	29-05-2024	19:44	Load Management	HT	220 KV
KHAPARKHEDA-AMBAZARI-I	29-05-2024	10:09	29-05-2024	11:57	Distance Protection	T	220 KV
KHAPARKHEDA-KALMESHWAR	29-05-2024	18:07	29-05-2024	20:33	Outage on Kanhan-Khaperkheda line	HT	220 KV
TALANDGE - ICHALKARANJI 2	29-05-2024	17:49	30-05-2024	00:06	Retrofitting of O/C E/F Back up relay	PO	220 KV
URAN - ONGC URAN	29-05-2024	11:07	29-05-2024	18:54	For A/R schemes testing in new distance relay at 220kV ONGC (Uran) S/S.	PO	220 KV

Transmission Line Outages/Trippings from 27.05.2024 to 02.06.2024							
Name of Line	Date Trip	Time Trip	Date Sync	Time Sync	Reason	Outage Type	Voltage
WARDHA - WARDHA RLY TSS 2	29-05-2024	08:45	29-05-2024	11:38	Stackwise IR measurement of LA	PO	220 KV
100 MVA 220/132 KV ICT - II @ JALKOT	29-05-2024	12:20	29-05-2024	14:27	Maintenance work	PO	220 KV
220 KV DONDAICHA - DHULE (400 KV) CKT	29-05-2024	10:41	29-05-2024	13:03	To attend Red Hot	PO	220 KV
220 KV GIRWALI (400 KV) -PARLI U-8 CKT	29-05-2024	12:53	29-05-2024	17:03	OPGW tightening work	PO	220 KV
220 KV KALMESHVAR WARUD CKT II	29-05-2024	04:01	29-05-2024	04:30	Distance Protection	T	220 KV
220 KV KAULEWADA-KORADI 2 CKT - II	29-05-2024	07:33	29-05-2024	13:09	Tan Delta measurement	PO	220 KV
220 KV KEKATNIBHORA - KHADKA (400 KV) CKT	29-05-2024	08:22	30-05-2024	19:12	Work of restringing of conductor from loc no. 299 to 313.	HT	220 KV
220/132 KV 100 MVA ICT 1 @ PARANDA	29-05-2024	12:10	29-05-2024	15:20	Pre Mansoon maintenance work	PO	220 KV
220/132 KV 100 MVA ICT 2	29-05-2024	14:00	29-05-2024	15:37	Pre-Monsoon maintenance work	PO	220 KV
220/33 KV 25 MVA T/F 1 @ JATH	29-05-2024	12:56	29-05-2024	16:40	33kV LV circuit breaker Overhauling Work	PO	220 KV
220/33 KV 25 MVA T/F 2 @ JATH	29-05-2024	18:20	29-05-2024	21:56	33kV LV Circuit breaker Overhauling Work	PO	220 KV
MALHARPETH SATARA MIDC	29-05-2024	07:03	29-05-2024	09:02	Stringing of Earth Wire from Loc No.48 to 52	PO	220 KV
NEW KOYNA - NIWALI	29-05-2024	14:49	29-05-2024	19:39	Diagnostic testing & Relay testing work , Routine maint. Work	PO	220 KV
NIGADE- PETH LINE	30-05-2024	10:52	30-05-2024	13:29	Replacement Work of bend/titled tower at Loc No.74	PO	220 KV
TALANDGE - ICHALKARANJI 1	30-05-2024	18:37	30-05-2024	23:33	Retrofitting of O/C E/F Back up relay.	PO	220 KV
220 KV CHALISGAON - KHADKA CKT - 2	30-05-2024	08:21	30-05-2024	17:40	Work of restringing of conductor between loc no. 299 to 313.	HT	220 KV
220 KV CHANDRAPUR GCR (400 KV) - WANI CKT	30-05-2024	12:25	30-05-2024	18:13	Backup relay replacement work by testing division yavatmal.	HT	220 KV
220/100 KV 100 MVA ICT 1 @ VASAI-II	30-05-2024	02:05	30-05-2024	06:34	For Premonsoon maintenance work.	PO	220 KV
220/100 KV 200 MVA ICT 4 @ KALWA	30-05-2024	09:43	30-05-2024	17:08	For Daignostic testing and R & M work .	PO	220 KV
220/132 KV 100 MVA ICT 1 @ LONIKAND 2	30-05-2024	10:27	30-05-2024	14:04	PREMANSOON MAINTENANCE	PO	220 KV
220/132 KV 100 MVA ICT 2	30-05-2024	11:00	30-05-2024	15:43	Pre-monsoon work activity.	HT	220 KV
220/132 KV 100 MVA ICT 2 @ LONIKAND 2	30-05-2024	15:13	30-05-2024	19:24	PREMANSOON MAINTENANCE	PO	220 KV
220/132 KV 100MVA PTR NO 6 @CHINCHWAD	30-05-2024	11:55	30-05-2024	18:01	Dignostic Testing & HYM		220 KV
220/132 KV 200 MVA ICT 2 @ AMALNER	30-05-2024	17:50	30-05-2024	21:45	Testing work.	HT	220 KV
220/132KV 100MVA ICT 2 @ CHAKAN PHASE II	30-05-2024	11:05	30-05-2024	15:50	Half yearly maintenance and Diagnostic testing work and Premonsoon maintenance work .	PO	220 KV

Transmission Line Outages/Trippings from 27.05.2024 to 02.06.2024							
Name of Line	Date Trip	Time Trip	Date Sync	Time Sync	Reason	Outage Type	Voltage
220/132kV 100MVA ICT - 2 @ KALWAN	30-05-2024	14:54	30-05-2024	16:33	1.old 220kV Y Ph PT commissioning work due to ratio error & B Ph. PT commissioning work with new 0.2 metering class PT 2.220kV Bus PT -2 Bus isolator alignment work	PO	220 KV
220/33 KV 50MVA PTR - 2 @ KALWAN	30-05-2024	14:53	30-05-2024	16:35	1.old 220kV Y Ph PT commissioning work due to ratio error & B Ph. PT commissioning work with new 0.2 metering class PT 2.220kV Bus PT -2 Bus isolator alignment work	PO	220 KV
220/33KV 50MVA PTR -2 @ KURKUMBH	30-05-2024	13:35	30-05-2024	13:15	Pre monsoon maintenance of bay equipments	PO	220 KV
220/33KV 50MVA PTR 1 @ KURKUMBH	30-05-2024	09:50	30-05-2024	16:05	Pre monsoon maintenance of bay equipments	PO	220 KV
BUS SECTION @ KALWAN (BHENDI)	30-05-2024	14:54	30-05-2024	16:37	old 220kV Y Ph PT commissioning work due to ratio error & B Ph. PT commissioning work with new 0.2 metering class PT 220kV Bus PT -2 Bus isolator alingment work	PO	220 KV
BUS SECTION-6 @ TROMBAY	30-05-2024	00:50	30-05-2024	08:50	1)220KV Main Bus-5 Bus bar protection panel testing. 2)220KV MB-5 Bus CVT Testing 3)220KV BS-5 Main bus-5 side GOD maintenance. 4)220KV GT-6.2 29A GOD dismantling in view of upcoming reactor project. 5)220KV TC-6 29A GOD maintenance 6)220KV TC-7/TV-1(KVTL) 29A GOD Maintenance 7)220kv TD-6 29A GOD Maintenance	PO	220 KV
KARAD -MUDSHINGI CKT 2-TAK	30-05-2024	10:07	31-05-2024	1774	Opening of Jump at Loc No.64 & 76 for replacement of bend/titled tower at Loc No.74	PO	220 KV
MALEGAON - KALWAN CKT-2	30-05-2024	14:57	30-05-2024	16:31	1.old 220kV Y Ph PT commissioning work due to ratio error & B Ph. PT commissioning work with new 0.2 metering class PT 2.220kV Bus PT -2 Bus isolator alignment work	PO	220 KV
MALHARPETH SATARA MIDC	30-05-2024	08:49	30-05-2024	15:23	Cold Line Washing of Insulator Strings from Loc No. 48 to 53	PO	220 KV
NEW KOYNA - PEDAMBE	30-05-2024	12:58	30-05-2024	17:44	Y Phase Breaker to line side isolator conductor strand broken. Y Phase Line side isolator to transfer bus isolator conductor strand broken.	PO	220 KV

Transmission Line Outages/Trippings from 27.05.2024 to 02.06.2024							
Name of Line	Date Trip	Time Trip	Date Sync	Time Sync	Reason	Outage Type	Voltage
PALGHAR - NALASOPARA	30-05-2024	05:10	30-05-2024	08:56	Replacement of Insulator String Identified in PID.	PO	220 KV
TBC @ FLAGSHIP	30-05-2024	09:30	30-05-2024	15:45	Half Yearly Maintenance.	PO	220 KV
WARORA-BHUGAON CKT - 1	30-05-2024	07:18	30-05-2024	09:49	Binding/repair work of opened strands of y- phase jumper conductor just near to wavetrap.	HT	220 KV
220 KV PARLI (OLD GCR)- GIRWALI (400 KV) CKT 3	31-05-2024	15:05	31-05-2024	15:31	220 KV BUS SECTIONALISER R PH CT BURST 220KV BUS BAR PROT OPTD.	T	220 KV
220 KV PARLI (OLD GCR)- GIRWALI (400 KV) CKT 4	31-05-2024	15:05	31-05-2024	15:31	220 KV BUS SECTIONALISER R PH CT BURST 220KV BUS BAR PROT OPTD.	T	220 KV
BOMBAY DYEING - SAHARA	31-05-2024	12:48	31-05-2024	16:00	Replacement of flashover string insulators at Loc No. 124.	PO	220 KV
BUTIBORI-INOX	31-05-2024	09:13	31-05-2024	00:04	SF6 BREAKER MAINTENANCE & N2 SYSTEM INSTALLATION AT M/S. INOX (220KV INOX S/S.)	PO	220 KV
GADCHANDUR - VIRUR-II	31-05-2024	05:41	31-05-2024	17:33	FOR HEIGTH RAISING/SHIFTING OF LINE FOR CONSTRUCTION OF NH-353 FROM RAJURA- KORPANA- ADILABAD UP TO MS BORDER FROM EXT.	PO	220 KV
WARORA - HINGANGHAT	31-05-2024	07:18	31-05-2024	10:17	1) FOR DIAGNOSTIC TESTING (I.E. CRM,CB TIMING AND TAN DELTA OF CT OF 220 KV HINGANGHAT- WARORA LINE(BAY))	PO	220 KV
200 MVA 220/132 KV ICT 1 @ GIRWALI	31-05-2024	15:05	31-05-2024	15:48	220 KV BUS SECTIONALISER R PH CT BURST 220KV BUS BAR PROT OPTD.	T	220 KV

Transmission Line Outages/Trippings from 27.05.2024 to 02.06.2024							
Name of Line	Date Trip	Time Trip	Date Sync	Time Sync	Reason	Outage Type	Voltage
200 MVA 220/132 KV ICT 2 @ GIRWALI	31-05-2024	15:05	31-05-2024	16:10	220 KV BUS SECTIONALISER R PH CT BURST 220KV BUS BAR PROT OPTD.	T	220 KV
200 MVA 220/132 KV ICT 3 @ GIRWALI	31-05-2024	15:05	31-05-2024	15:58	220 KV BUS SECTIONALISER R PH CT BURST 220KV BUS BAR PROT OPTD.	T	220 KV
220 KV GIRWALI (400 KV) -PARLI U-8 CKT	31-05-2024	15:05	31-05-2024	15:59	220 KV BUS SECTIONALISER R PH CT BURST 220KV BUS BAR PROT OPTD.	T	220 KV
220 KV GIRWALI - MURUD CKT	31-05-2024	15:05	31-05-2024	15:50	220 KV BUS SECTIONALISER R PH CT BURST 220KV BUS BAR PROT OPTD.	T	220 KV
220/100 KV 200 MVA ICT 2 @ KOLSHET	31-05-2024	12:52	31-05-2024	22:08	1) Replacement of Differential, HV Backup LV Backup relays, 2) Pre-monsoon maintenance work, bay R&M work.	PO	220 KV
220/100 KV 200 MVA ICT 3 @ APTA	31-05-2024	11:42	31-05-2024	14:35	100 kV BUS 2 Outage :- ICT-3 & 4 Premonsoon maintenance work	PO	220 KV
220/100 KV 200 MVA ICT 4 @ APTA	31-05-2024	11:40	31-05-2024	14:36	100 kV BUS 2 Outage :- ICT-3 & 4 Premonsoon maintenance work	PO	220 KV
220/132 KV 100MVA ICT 2	31-05-2024	09:16	31-05-2024	16:27	DIAGNOSTIC TESTING (TAN DELTA, TIMING TEST ,CRM TEST)	PO	220 KV
220/132 KV 200 MVA ICT 1 @ MALEGAON	31-05-2024	10:04	31-05-2024	11:53	For Pre-monsoon maintenance work	PO	220 KV
220/132 KV 200 MVA ICT 2 @ MALEGAON	31-05-2024	12:03	31-05-2024	12:45	For Pre-monsoon maintenance work	PO	220 KV
220/132 KV 200 MVA ICT 1 @ BOISAR-II	31-05-2024	10:02	31-05-2024	11:59	Pre Monsoon maintenance work	PO	220 KV
220/132 KV 200 MVA ICT 2 @ BOISAR-II	31-05-2024	12:45	31-05-2024	16:01	Annual maintenance work of NIFPS (CTR make) system.	PO	220 KV
220/33 KV 50 MVA PTR 1 @ MALEGAON	31-05-2024	07:15	31-05-2024	08:12	For Pre-monsoon maintenance work	PO	220 KV
220/33 KV 50 MVA PTR 2 @ MALEGAON	31-05-2024	08:17	31-05-2024	08:53	For Pre-monsoon maintenance work	PO	220 KV
220/33 KV 50 MVA T/F 3 @ MALEGAON	31-05-2024	09:50	31-05-2024	09:50	For Pre-monsoon maintenance work	PO	220 KV

Transmission Line Outages/Trippings from 27.05.2024 to 02.06.2024							
Name of Line	Date Trip	Time Trip	Date Sync	Time Sync	Reason	Outage Type	Voltage
220/33 KV 50 MVA TF - 1@BELWANDI	31-05-2024	10:12	31-05-2024	12:21	Pre-monsoon maintenance work	PO	220 KV
220/33 KV 50 MVA TF - 2@BELWANDI	31-05-2024	12:24	31-05-2024	13:20	Pre-monsoon maintenance work	PO	220 KV
220KV GIS DCHI - COLOURCHEM	31-05-2024	04:30			For de-stringing & stringing of old circuit at new tower Loc. No. 6.	PO	220 KV
220KV KURUNDA -GIRWALI CKT	31-05-2024	15:05	31-05-2024	15:33	220 KV BUS SECTIONALISER R PH CT BURST 220KV BUS BAR PROT OPTD.	T	220 KV
MHAISAL - ALKUD	31-05-2024	16:56	31-05-2024	21:55	Wedge Connector Work	PO	220 KV
NERUL - SEAWOOD CABLE CKT - 1	31-05-2024	09:09	31-05-2024	13:21	Pre-Monsoon Maintenance and LA Meggering work	PO	220 KV
PALGHAR - NALASOPARA	31-05-2024	04:46	31-05-2024	08:20	Replacement of Insulator String Identified in PID.	PO	220 KV
BUTIBORI 3-PURTI	01-06-2024	19:28	02-06-2024	02:57	Distance protection	T	220 KV
BUTIBORI-INOX	01-06-2024	09:13	01-06-2024	00:04	SF6 BREAKER MAINTENANCE & N2 SYSTEM INSTALLATION AT M/S. INOX (220KV INOX S/S.)	PO	220 KV
GADCHANDUR - VIRUR-I	01-06-2024	05:12	01-06-2024	15:15	Diagnostic testing work	PO	220 KV
KALWA - SIEMENS	01-06-2024	22:26	02-06-2024	06:33	For the installation of saver assembly sets at TL no. 43, 45, 46, 47 & 48 (Total 18 sets out of 18 sets are to be installed)	PO	220 KV
220/100 KV 200 MVA ICT 3 @ TROMBAY	01-06-2024	06:34	01-06-2024	10:55	For 1) Premonsoon maintenance work & 2) RM work.	PO	220 KV
220/132 KV 200 MVA ICT 1 @ RAYMOND	01-06-2024	08:30	01-06-2024	11:31	1. Replacement of 132kV LA 2. Premonsoon maintenance 3. Complete bay maintenance work	PO	220 KV
220/132 KV 200 MVA ICT 2 @ RAYMOND	01-06-2024	07:15	01-06-2024	08:02	Premonsoon Maintenance	PO	220 KV
220/132 KV 200 MVA ICT 3 @ AHMEDNAGAR	01-06-2024	09:55			Premansoon maintenance work	PO	220 KV
220/33 KV 25 MVA PTR 1 @ AHMEDNAGAR	01-06-2024	09:55	01-06-2024	14:17	Premonsoon maintenance and attending oil leakage	PO	220 KV
220/33 KV 25 MVA PTR 2 @ AHMEDNAGAR	01-06-2024	15:30	01-06-2024	18:38	Premonsoon maintenance and attending oil leakage	PO	220 KV
EKLAHARA(GCR)(NASIK)-BABLESHWAR 2	01-06-2024	22:53	02-06-2024	03:44	Replacement of old disc insulator with porcelain long rod insulator strings,	PO	220 KV
ISMT TAP LINE TO JEJURI-BARAMATI	01-06-2024	11:01	01-06-2024	15:12	Replacement of B-ph LA of Jejuri-ISMT-Baramati line at 220 kV Baramati S/S.	PO	220 KV

Transmission Line Outages/Trippings from 27.05.2024 to 02.06.2024							
Name of Line	Date Trip	Time Trip	Date Sync	Time Sync	Reason	Outage Type	Voltage
KHARGHAR - BORIVALI CKT - 2	01-06-2024	22:27	02-06-2024	06:39	For the installation of saver assembly sets at TL no. 43, 45, 46, 47 & 48, 27/3 & 28 (Total 24 sets out of 66 sets are to be installed, total completed - 6 sets	PO	220 KV
MAIN BUS-1 @ HINJEWADI 3(GIS)	01-06-2024	11:43	01-06-2024	11:15	Bus Extension for Bay 208 of 220kV Nextra2 Ss for project work	PO	220 KV
MHAISAL - ALKUD	01-06-2024	17:48	02-06-2024	02:24	Wedge connector work	PO	220 KV
NERLE - PEDAMBE	01-06-2024	07:13	01-06-2024	11:15	220 KV Nerale Bay for Bay P/M work.	PO	220 KV
PALGHAR - NALASOPARA	01-06-2024	06:25	01-06-2024	09:09	Replacement of Insulator String Identified in PID.	PO	220 KV
VSNL- KHADKI	01-06-2024	07:13	01-06-2024	17:41	For Stringing of R,Y,B phase conductors between New Monopole Loc No. 29A to 30 (River Crossing)	PO	220 KV
WAGHIVALI - DHARAVI 7 - ANTOP HILL - 1	01-06-2024	07:40	01-06-2024	10:19	For dismantling of MSETCL Towers along with destringing of conductors at NMIA Airport project site.	PO	220 KV
WAGHIVALI - DHARAVI 8	01-06-2024	07:30	01-06-2024	10:15	Project work- For dismantling of MSETCL Towers along with destringing of conductors at NMIA Airport project site.	PO	220 KV
220/33 KV 50 MVA PTR NO 3 @ ALEPHATA	02-06-2024	12:14	02-06-2024	15:27	For wrapping of plastic cover (Pre monsoon maintenance) & general bay maintenance	PO	220 KV
BHUGAON - WARDHA (PG)	02-06-2024	23:10	03-06-2024	00:10	H/T due to State OD at Low frequency.	HT	220 KV
GADCHANDUR - VIRUR-I	02-06-2024	09:54	02-06-2024	11:13	Attending Hotspot work R-ph CT clamp		220 KV
220 / 110 / 33kv 250MVA AT 1 @ BACKBAY	02-06-2024	10:14	02-06-2024	17:45	33KV side cable termination replacement work	PO	220 KV
220/33 KV 50MVA PTR NO 1 @ ALEPHATA	02-06-2024	17:21	02-06-2024	19:49	For wrapping of plastic cover (Pre monsoon maintenance) & general bay maintenance	PO	220 KV
220/33 KV, 50MVA, PTR NO 2 @ ALEPHATA	02-06-2024	15:34	02-06-2024	17:17	For wrapping of plastic cover (Pre monsoon maintenance) & general bay maintenance	PO	220 KV
220/33KV 50MVA T/F-I @ BRIDGESTONE	02-06-2024	10:35	02-06-2024	14:10	Diagnostic testing work, half Yearly and pre monsoon maintenance .	PO	220 KV
KAMBA - VASAI	02-06-2024	04:39	03-06-2024	01:17	1) Cut point formation over newly erected monopole & work will be carried out at loc no 4 9 and also related de-stringing & stringing work will be carried out. 2) Dismantling of old existing tower no. 53 & 54. 3) After cut point formation & conductor stringing work kamba- Vasai line will be charged at 22:00 Hrs of 02.06.2024.		220 KV

Transmission Line Outages/Trippings from 27.05.2024 to 02.06.2024							
Name of Line	Date Trip	Time Trip	Date Sync	Time Sync	Reason	Outage Type	Voltage
KAMBA - VASAI	02-06-2024	04:39	03-06-2024	01:17	work 1) Cut point formation over newly erected Monopole work will be carry out at loc.no.48,49 and amp;49A on 220kV Kamba-Vasai line and also related tower 65533;s conductor destringing & stringing work will be carry out of above said ckt. 2) Dismantaling work of old existing tower at Loc.No.48 & 49	PO	220 KV
KAMBA - VASAI	02-06-2024	04:39	03-06-2024	01:17	Work of replacement of old C&R panel by new and diagnostic testing work		220 KV
WAGHIVALI - DHARAVI 7 - ANTOP HILL - 1	02-06-2024	06:03	02-06-2024	16:00	for dismantling of MSETCL Towers along with destringing of conductors at NMIA Airport project site	PO	220 KV
WAGHIVALI - DHARAVI 8	02-06-2024	05:59	02-06-2024	15:57	for dismantling of MSETCL Towers along with destringing of conductors at NMIA Airport project site	PO	220 KV
KANHAN-PENCH	29-05-2024	09:05	29-05-2024	16:28	for testing of switchyard elements	PO	132 KV
AMBERNATH - KALYAN CKT - 1	27-05-2024	15:22	27-05-2024	20:32	CT STABILITY	PO	110 KV
KHOPOLI - KARANJADE	27-05-2024	10:05	27-05-2024	11:17	BIRD NEST REMOVAL	PO	110 KV
KARANJADE - BHOKARPADA	31-05-2024	08:02	31-05-2024	12:32	For RM	PO	110 KV
WAGHIVALI - CHEMBUR	01-06-2024	08:13	01-06-2024	10:53	Project work - For dismantling of MSETCL Towers along with destringing of conductors at NMIA Airport project site.	PO	110 KV
WAGHIVALI - MANKHURD	01-06-2024	07:50	01-06-2024	10:29	Project Work - for dismantling of MSETCL Towers along with destringing of conductors at NMIA Airport project site.	PO	110 KV
WAGHIVALI - CHEMBUR	02-06-2024	05:44	02-06-2024	16:19	for dismantling of MSETCL Towers along with destringing of conductors at NMIA Airport project site	PO	110 KV
WAGHIVALI - MANKHURD	02-06-2024	05:50	02-06-2024	16:29	for dismantling of MSETCL Towers along with destringing of conductors at NMIA Airport project site	PO	110 KV