

State Load Despatch Center,Airoli (MSETCL)
Power System Position from 26/Oct/2015 to 01/Nov/2015

Supply Position During Morning Peak (MW)

Date	Time	MSGENCO				Central Sector Receipt	Wind	CPP	SOLAR	TPCL Exch.	MSEDCL Catered Demand	Load Shedding(LS)	MSEDCL Demand (Incl. LS)	TPCL Gen.	R-INFRA Gen.	State Demand Met	State Demand (Incl. LS)	Freq.
		THM	HYDRO	GAS	Total													
		MW	MW	MW	MW	MW	MW	MW	MW	MW	MW	MW	MW	MW	MW	MW	MW	Hzs
26/10/2015	11 Hrs	5023	995	430	6448	6680	128	5220	133	-1566	17043	450	17493	1105	515	20229	20679	49.94
27/10/2015	12 Hrs	5165	1399	436	7000	6902	58	4572	152	-1560	17124	621	17745	1136	513	20333	20954	49.99
28/10/2015	12 Hrs	5422	850	293	6565	6266	107	5488	168	-1512	17082	422	17504	1096	509	20199	20621	50.03
29/10/2015	12 Hrs	5668	465	288	6421	6252	56	5437	174	-1522	16818	500	17318	1119	509	19968	20468	49.99
30/10/2015	12 Hrs	6170	573	147	6890	5488	103	5658	173	-1659	16653	372	17025	1159	258	19729	20101	50.01
31/10/2015	12 Hrs	6227	765	134	7126	5285	198	5423	147	-1285	16894	420	17314	1137	511	19827	20247	50.03
01/11/2015	12 Hrs	5745	425	260	6430	5273	356	5237	205	-970	16531	487	17018	840	514	18855	19342	50.01
Maximum		6227	1399	436	7126	6902	356	5658	205	-970	17124	621	17745	1159	515	20333	20954	50.03
Minimum		5023	425	134	6421	5273	56	4572	133	-1659	16531	372	17018	840	258	18855	19342	49.94
Average		5631	782	284	6697	6021	144	5291	165	-1439	16878	467	17345	1085	476	19877	20345	50.00

Supply Position During Day Peak (MW)

Date	Time	MSGENCO				Central Sector Receipt	Wind	CPP	SOLAR	TPCL Exch.	MSEDCL Catered Demand	Load Shedding(LS)	MSEDCL Demand (Incl. LS)	TPCL Gen.	R-INFRA Gen.	State Demand Met	State Demand (Incl. LS)	Freq.
		THM	HYDRO	GAS	Total													
		MW	MW	MW	MW	MW	MW	MW	MW	MW	MW	MW	MW	MW	MW	MW	MW	Hzs
26/10/2015	13 Hrs	5017	1108	420	6545	6920	126	5239	121	-1560	17391	530	17921	1190	516	20657	21187	49.95
27/10/2015		5144	1257	432	6833	6682	66	4579	142	-1539	16763	709	17472	1159	515	19976	20685	49.96
28/10/2015	16 Hrs	5468	542	292	6302	6799	20	5484	72	-1583	17094	257	17351	1140	508	20325	20582	49.99
29/10/2015	13 Hrs	5774	372	288	6434	6350	24	5428	183	-1528	16891	547	17438	1105	514	20038	20585	49.98
30/10/2015	15 Hrs	5896	340	147	6383	5716	32	5611	140	-1645	16237	335	16572	1016	380	19278	19613	49.97
31/10/2015	14 Hrs	6441	697	120	7258	5287	61	5303	178	-1361	16726	445	17171	976	518	19581	20026	50.02
01/11/2015	13 Hrs	5668	772	259	6699	5194	135	5276	167	-1003	16468	535	17003	832	514	18817	19352	49.83
Maximum		6441	1257	432	7258	6920	135	5611	183	-1003	17391	709	17921	1190	518	20657	21187	50.02
Minimum		5017	340	120	6302	5194	20	4579	72	-1645	16237	257	16572	832	380	18817	19352	49.83
Average		5630	727	280	6636	6135	66	5274	143	-1460	16796	480	17275	1060	495	19810	20290	49.96

Supply Position During Evening Peak (MW)

Date	Time	MSGENCO				Central Sector Receipt	Wind	CPP	SOLAR	TPCL Exch.	MSEDCL Cateder Demand	Load Shedding(LS)	MSEDCL Demand (Incl. LS)	TPCL Gen.	R-INFRA Gen.	State Demand Met	State Demand (Incl. LS)	Freq.
		THM	HYDRO	GAS	Total													
		MW	MW	MW	MW	MW	MW	MW	MW	MW	MW	MW	MW	MW	MW	MW	MW	Hzs
26/10/2015	19 Hrs	5099	303	429	5831	6076	90	5249	0	-1535	15711	158	15869	1128	514	18888	19046	49.98
27/10/2015	19 Hrs	5046	1189	430	6665	5866	86	4585	0	-1481	15721	245	15966	1184	515	18901	19146	49.95
28/10/2015	19 Hrs	5567	343	296	6206	5645	105	5521	0	-1528	15949	249	16198	1189	512	19178	19427	49.98
29/10/2015	19 Hrs	6043	281	285	6609	4888	105	5498	0	-1520	15580	240	15820	1013	513	18626	18866	49.97
30/10/2015	20 Hrs	5851	755	150	6756	4719	258	5271	0	-1538	15466	253	15719	982	518	18504	18757	50.04
31/10/2015	19 Hrs	6008	538	62	6608	4582	130	5573	0	-1387	15506	291	15797	1014	514	18421	18712	49.97
01/11/2015	20 Hrs	4977	699	262	5938	4640	187	5156	0	-1202	14719	225	14944	858	396	17175	17400	49.99
Maximum		6043	1189	430	6756	6076	258	5573	0	-1202	15949	291	16198	1189	518	19178	19427	50.04
Minimum		4977	281	62	5831	4582	86	4585	0	-1538	14719	158	14944	858	396	17175	17400	49.95
Average		5513	587	273	6373	5202	137	5265	0	-1456	15522	237	15759	1053	497	18528	18765	49.98

Supply Position During Night Off Peak (MW)

Date	Time	MSGENCO				Central Sector Receipt	Wind	CPP	SOLAR	TPCL Exch.	MSEDCL Cateder Demand	Load Shedding(LS)	MSEDCL Demand (Incl. LS)	TPCL Gen.	R-INFRA Gen.	State Demand Met	State Demand (Incl. LS)	Freq.
		THM	HYDRO	GAS	Total													
		MW	MW	MW	MW	MW	MW	MW	MW	MW	MW	MW	MW	MW	MW	MW	MW	Hzs
26/10/2015	5 Hrs	4723	89	451	5263	5062	72	4819	0	-719	14497	285	14782	884	395	16495	16780	50.02
27/10/2015	5 Hrs	5025	128	441	5594	4682	98	5231	0	-652	14953	312	15265	882	516	17003	17315	49.96
28/10/2015	3 Hrs	5194	102	438	5734	5357	91	4738	0	-859	15061	90	15151	831	518	17269	17359	49.99
29/10/2015	24 Hrs	5441	554	292	6287	4314	190	5016	0	-1439	14368	127	14495	627	395	16829	16956	49.99
30/10/2015	23 Hrs	5872	435	153	6460	4105	338	4349	0	-1420	13832	122	13954	713	432	16397	16519	50.01
31/10/2015	4 Hrs	5791	126	155	6072	3861	612	4578	0	-863	14260	175	14435	626	395	16144	16319	50.00
01/11/2015	23 Hrs	4913	133	263	5309	4421	482	4926	0	-1327	13811	131	13942	703	396	16237	16368	49.95
Maximum		5872	554	451	6460	5357	612	5231	0	-652	15061	312	15265	884	518	17269	17359	50.02
Minimum		4723	89	153	5263	3861	72	4349	0	-1439	13811	90	13942	626	395	16144	16319	49.95
Average		5280	224	313	5817	4543	269	4808	0	-1040	14397	177	14575	752	435	16625	16802	49.99

Details of Supply Position (MUs)

Date	MSGENCO				Pench (MS)	Central Sector Receipt	Central Sector Share	WIND	CPP	SOLAR	TPCL Gen.	R-INFRA Gen.	TPCL Exch.	Energy Requirement		
	THM	HYDRO	GAS	Total										MSEDCL	MUMBAI	STATE
	Mus	Mus	Mus	Mus	Mus	Mus	Mus	Mus	Mus	Mus	Mus	Mus	Mus	Mus	Mus	Mus
26/10/2015	118.873	11.368	10.437	140.678	0.871	141.614	143.040	2.759	122.523	0.864	23.779	11.903	-30.838	377.600	66.520	444.120
27/10/2015	121.682	17.876	10.287	149.845	0.828	141.014	141.272	1.935	116.857	0.954	23.772	12.385	-30.152	380.453	66.309	446.762
28/10/2015	129.242	7.217	8.465	144.924	0.552	139.726	145.197	2.583	124.041	0.946	23.638	12.247	-30.598	381.622	66.484	448.106
29/10/2015	136.767	5.714	6.928	149.409	0.853	128.864	131.160	2.610	125.388	1.207	22.048	11.438	-30.600	376.879	64.086	440.965
30/10/2015	139.645	9.574	5.027	154.246	0.857	114.192	117.054	6.202	124.106	1.157	20.524	8.848	-33.378	366.523	62.747	429.270
31/10/2015	143.566	10.084	3.036	156.686	0.915	111.274	113.384	7.189	123.953	1.154	20.378	11.058	-28.957	371.299	60.393	431.692
01/11/2015	132.071	7.894	5.908	145.873	0.873	111.545	111.027	8.851	121.898	1.190	18.061	10.670	-24.167	365.189	52.898	418.087
Maximum	143.566	17.876	10.437	156.686	0.915	141.614	145.197	143.566	125.388	1.207	23.779	12.385	-24.167	381.622	66.520	448.106
Minimum	118.873	5.714	3.036	140.678	0.552	111.274	111.027	118.873	116.857	0.864	18.061	8.848	-33.378	365.189	52.898	418.087
Average	131.692	9.961	7.155	148.809	0.821	126.890	128.876	131.692	122.681	1.067	21.743	11.221	-29.813	374.224	62.777	437.000

Details of Koyna Water Consumption (in TMC)

Date	For the Day	For the Month	Balance
26/10/2015	0.226	5.916	45.097
27/10/2015	0.329	6.245	44.768
28/10/2015	0.118	6.363	44.650
29/10/2015	0.052	6.415	44.598
30/10/2015	0.146	6.561	44.452
31/10/2015	0.150	6.711	44.302
01/11/2015	0.088	0.088	44.214

State Load Despatch Center, Airoli (MSETCL)
Central Sector Share/Drawal from 26/Oct/2015 to 01/Nov/2015

Date	DAY	Central Sector Share		Total Interstate Bilateral Purchase		Total Share		Total Drawal		Overdrawal(+) / UnderDrawal(-)	
		MUs	Avg. MW	MUs	Avg. MW	MUs	Avg. MW	MUs	Avg. MW	MUs	Avg. MW
		1		2		1+2=3		4		3-4=5	
26/10/2015	MONDAY	97.457	5914	45.583	1899	143.040	5960	141.614	5901	-1.426	-59
27/10/2015	TUESDAY	102.282	5847	38.990	1625	141.272	5886	141.014	5876	-0.258	-11
28/10/2015	WEDNESDA	103.921	6009	41.276	1720	145.197	6050	139.726	5822	-5.471	-228
29/10/2015	THURSDAY	96.708	5431	34.452	1435	131.160	5465	128.864	5369	-2.296	-96
30/10/2015	FRIDAY	89.039	4849	28.015	1167	117.054	4877	114.192	4758	-2.862	-119
31/10/2015	SATURDAY	93.079	4704	20.305	846	113.384	4724	111.274	4636	-2.110	-88
01/11/2015	SUNDAY	92.730	4608	18.297	762	111.027	4626	111.545	4648	0.518	22
Total		675.215		226.919		902.134		888.229		-13.905	

GENERATING UNITS OUTAGES FOR THE WEEK FROM 26/10/2015 TO 01/11/2015							
Generator	Generating Unit	Capacity	Tripped Date	Tripped Time	Synch. Date	Synch Time	Reason
PLANNED OUTAGES							
Cent_Sect	Tarapur 2	160MW	10/Sep/2015	12.55		Continued.	Refuelling work
MSPGCL	Koyna Unit 4		28/Oct/2015	07.40	28/Oct/2015	17.45	Preventive Maintenance Work
MSPGCL	Koyna Unit 6		29/Oct/2015	08.00	29/Oct/2015	17.25	Preventive Maintenance Work
FORCED OUTAGES							
RGPP	Dabhol Dabhol 1B	230MW	28/May/2013	22:02		Continued.	Gas Shortage.
RGPP	Dabhol Dabhol 2A	230MW	06/Jun/2013	09.10		Continued.	Gas Shortage
RGPP	Dabhol Dabhol 3A	230MW	06/Jun/2013	08.28		Continued.	Gas Shortage
RGPP	Dabhol Dabhol 1A	230MW	27/Jun/2013	21.47		Continued.	Gas Shortage
RGPP	Dabhol Dabhol 1X	230MW	27/Jun/2013	21.46		Continued.	Gas Shortage
RGPP	Dabhol Dabhol 2X	230MW	15/Jul/2013	15.09		Continued.	Gas Shortage
RGPP	Dabhol Dabhol 2B	230MW	08/Aug/2013	15.03		Continued.	Gas Shortage
RGPP	Dabhol Dabhol 3X	230MW	29/Dec/2013	05.47		Continued.	Gas Shortage
RGPP	Dabhol Dabhol 3B	230MW	29/Dec/2013	06.14		Continued.	Gas Shortage
IPP	Dhariwal	300MW	28/May/2014	02.27		Continued.	No schedule
MSPGCL	Chandrapur Unit 1	210MW	28/Aug/2014	07:15		Continued.	Economic Shutdown.
MSPGCL	Bhusawal Unit 2	210MW	13/Sep/2014	12.43		Continued.	Economic shutdown
MSPGCL	Koradi Unit 6	210MW	20/Mar/2015	01.02		Continued.	Economic shutdown
MSPGCL	RPL(AMT) U-5	270MW	03/Apr/2015	14.22		Continued.	turbine Shaft Vibration high.
MSPGCL	Uran Unit 7	108MW	17/Apr/2015	00.07		Continued.	Gas turbine problem
MSPGCL	Parli Unit 3	210MW	14/Jun/2015	12.58		Continued.	Water Shortage
IPP	WPCL U-2	135MW	16/Jun/2015	00.00		Continued.	No Schdule
MSPGCL	Parli Unit 6	250MW	25/Jun/2015	15.03		Continued.	Water Shortage
MSPGCL	Parli Unit 4	210MW	05/Jul/2015	18.45		Continued.	Water Shortage
MSPGCL	Parli Unit 5	210MW	06/Jul/2015	14.55		Continued.	Water Shortage.
MSPGCL	Parli Unit 7	250MW	08/Jul/2015	12.08		Continued.	Water Shortage
IPP	Tata Trombay 6	500MW	15/Jul/2015	17.08		Continued.	Economic shutdown
IPP	Adani U-4	660MW	11/Sep/2015	20.49	28/Oct/2015	05.46	Abnormal sound in generater bearing
MSPGCL	Koradi Unit-8	660MW	21/Oct/2015	20.49	28/Oct/2015	02.10	ESP Problem.
MSPGCL	Khaparkheda Unit 4	210MW	22/Oct/2015	12.58	28/Oct/2015	17.05	Turbine Vibration High.
IPP	WPCL U-1	135MW	23/Oct/2015	17.31		Continued.	ESP filter problem
MSPGCL	Chandrapur Unit-8	500MW	24/Oct/2015	12.34	28/Oct/2015	23.31	clenkar formation in boiler
MSPGCL	Ghatghar Unit-1	125MW	25/Oct/2015	11.00	27/Oct/2015	19.20	Battery maintenance work
IPP	RPL(AMT) U-4	270MW	25/Oct/2015	15.23	27/Oct/2015	19.59	Water Tube Leakage.
MSPGCL	Ghatghar Unit-2	125MW	25/Oct/2015	11.00	27/Oct/2015	19.20	Battery maintenance work
MSPGCL	Bhusawal Unit 3	210MW	25/Oct/2015	07.29	27/Oct/2015	21.27	Drum level low
IPP	Trombay 7B	60MW	26/Oct/2015	13.35	26/Oct/2015	19.40	Mal operation of Fuel Gas control Valve
IPP	Trombay 7A	120MW	26/Oct/2015	13.35	26/Oct/2015	17.00	Mal operation of Fuel Gas control Valve
IPP	Adani U-3	660MW	27/Oct/2015	09.48		Continued.	Excitation Tranf. Abnormal Sound.

GENERATING UNITS OUTAGES FOR THE WEEK FROM 26/10/2015 TO 01/11/2015							
Generator	Generating Unit	Capacity	Tripped Date	Tripped Time	Synch. Date	Synch Time	Reason
IPP	Uran Unit 5	108MW	28/Oct/2015	10.56	31/Oct/2015	20.41	Gas shortage
MSPGCL	Chandrapur Unit-8	500MW	29/Oct/2015	22.39	30/Oct/2015	00.51	M.S.Temp.Low.
MSPGCL	Uran Unit 8	108MW	30/Oct/2015	09.35		Continued.	Gas Turbine Problem.
MSPGCL	Khaparkheda Unit 4	210MW	30/Oct/2015	12.12	30/Oct/2015	17.50	Flame Failure
IPP	REL Unit 2	250MW	30/Oct/2015	04.11	30/Oct/2015	13.45	Turbine Vibration Problem..
MSPGCL	Uran Unit B0	120MW	30/Oct/2015	09.35		Continued.	Gas Turbine Problem.
MSPGCL	Uran Unit A0	120MW	31/Oct/2015	13.55	31/Oct/2015	19.37	Bus Bar Protection Opted.
MSPGCL	Uran Unit 6	108MW	31/Oct/2015	13.55	31/Oct/2015	17.11	Bus Bar Protection Opted.
MSPGCL	Chandrapur Unit-8	500MW	31/Oct/2015	16.20		Continued.	Boiler Tube Leakage
MSPGCL	Uran Unit 5	108MW	01/Nov/2015	02.20	01/Nov/2015	05.27	Vibration Problem
MSPGCL	Bhusawal Unit 2	210MW	01/Nov/2015	02.34		Continued.	BTL
MSPGCL	Chandrapur Unit-7	500MW	01/Nov/2015	19.09	01/Nov/2015	22.31	Turbine Vibration

LINE OUTAGES FOR THE WEEK FROM 26/10/2015 TO 01/11/2015

Voltage	Name of Line	Tripping Date	Tripping Time	Synch Date	Synch Time	Reason
500 KV	HVDC Pole-I	31/Oct/2015	18.32	01/Nov/2015	21.50	Broken disc insulator replacement work.
400 KV	Akola II - Taptitanda ckt-II	06/Oct/2015	09.44		Continued.	For Controlling Line Loading.
400 KV	karad -kolhapur-I	25/Oct/2015	16.14	26/Oct/2015	06.52	Over Voltage
400 KV	Kolhapur Mapusa I	25/Oct/2015	16.42	26/Oct/2015	06.47	Over Voltage
400 KV	Karad - Jaigad - II	25/Oct/2015	16.44	26/Oct/2015	09.05	Over Voltage
400 KV	Bhusawal-Aurangabad	25/Oct/2015	17.42	26/Oct/2015	07.47	Over Voltage
400 KV	Dhule Sar'Sarovar I	25/Oct/2015	18.12	26/Oct/2015	06.38	Over Voltage
400 KV	Babhaleshwar-Taptitanda ckt-II	25/Oct/2015	19.26		Continued.	Controlling BBLR ICT Loading.
400 KV	Lonikand I - Koyna stage-IV	25/Oct/2015	22.03	26/Oct/2015	06.45	Over Voltage
400 KV	Dhule- Bableshwar - I	26/Oct/2015	10.29	28/Oct/2015	19.29	Relay repl.work (out for 3 days)
400 KV	Deepnagar Taptitanda	26/Oct/2015	12.36	26/Oct/2015	19.09	Rectification work
400 KV	karad -kolhapur-II	26/Oct/2015	16.34	27/Oct/2015	06.29	Over Voltage
400 KV	Karad-Jaigad - I	26/Oct/2015	17.08	27/Oct/2015	08.50	Over Voltage
400 KV	Bhusawal-Aurangabad	26/Oct/2015	18.10	27/Oct/2015	07.06	Over Voltage
400 KV	Dhule Sar'Sarovar I	26/Oct/2015	20.13	27/Oct/2015	05.48	Over Voltage
400 KV	Kolhapur Mapusa I	26/Oct/2015	21.04	27/Oct/2015	07.01	Over Voltage
400 KV	Khadka- Deepnagar Ckt 1	27/Oct/2015	09.18	27/Oct/2015	16.15	Nut Bolts Tightening work.
400 KV	Kolhapur Mapusa I	27/Oct/2015	10.05	27/Oct/2015	16.45	cvr replacement at mapusa end.
400 KV	Deepnagar Taptitanda	27/Oct/2015	10.07	27/Oct/2015	18.58	Jumper Tightening and Fixing of Nut Bolts
400 KV	Karad - Lonikand 1	27/Oct/2015	10.13		Continued.	Tower replacement work.
400 KV	Padghe - Kharghar	27/Oct/2015	10.42	27/Oct/2015	15.00	shifted on TBC.
400 KV	Dhule Sar'Sarovar I	27/Oct/2015	10.49	28/Oct/2015	06.57	Line Maintenance work.
400 KV	karad -kolhapur-II	27/Oct/2015	16.36	28/Oct/2015	08.44	Over Voltage
400 KV	Jaigad-Karad Ckt-II	27/Oct/2015	17.07	28/Oct/2015	08.56	Over Voltage
400 KV	Khadka-Aurangabad (Waluj)	27/Oct/2015	19.13	28/Oct/2015	06.37	Over Voltage
400 KV	Kolhapur Mapusa I	27/Oct/2015	21.13	28/Oct/2015	06.53	Over Voltage
400 KV	Khadka- Deepnagar Ckt 1	28/Oct/2015	09.26	28/Oct/2015	15.36	For Tightening Nut Bolts Arcing Horn Corona Ring.
400 KV	Chandrapur-Parali III	28/Oct/2015	10.03	28/Oct/2015	18.49	Fixing of Broken Spacer Cum Vibration Dampers.
400 KV	Dhule Sar'Sarovar I	28/Oct/2015	10.58	29/Oct/2015	06.50	Work @ SSNL End.
400 KV	Deepnagar Taptitanda	28/Oct/2015	11.23	28/Oct/2015	18.05	For Tightening of Nut Bolts Arcing Horn Corona Ring.
400 KV	Chandrapur - Chandrapur II	28/Oct/2015	14.19	28/Oct/2015	17.19	For Attending Sparking on R Phwave Trap.
400 KV	karad -kolhapur-I	28/Oct/2015	16.34	29/Oct/2015	06.40	Over Voltage
400 KV	Karad-Jaigad - I	28/Oct/2015	17.09	29/Oct/2015	06.30	Over Voltage
400 KV	Bhusawal-Aurangabad	28/Oct/2015	18.01	29/Oct/2015	06.27	Over Voltage
400 KV	Kolhapur Mapusa II	28/Oct/2015	20.16	29/Oct/2015	06.55	Over Voltage
400 KV	Chandrapur-Parali 2	29/Oct/2015	08.16	29/Oct/2015	18.58	For Fixing & Replacement of Broken Spacer Cum Vibration Dampers.
400 KV	Deepnagar Taptitanda	29/Oct/2015	10.20	29/Oct/2015	18.20	Balance Rectification Work Observed in Joint Prolonging.
400 KV	Karad-Jaigad - I	29/Oct/2015	16.33	30/Oct/2015	06.45	Over Voltage
400 KV	Kolhapur Mapusa I	29/Oct/2015	16.44	30/Oct/2015	06.37	Over Voltage
400 KV	Kolhapur Solapur (PG) II	29/Oct/2015	17.01	29/Oct/2015	18.46	To Attend Hot Spot on Isolator.
400 KV	Bhusawal-Aurangabad	29/Oct/2015	17.43	30/Oct/2015	09.42	Over Voltage
400 KV	Dhule Sar'Sarovar I	29/Oct/2015	20.07	30/Oct/2015	06.52	Over Voltage
400 KV	karad -kolhapur-II	29/Oct/2015	20.36	30/Oct/2015	06.40	Over Voltage
400 KV	Chandrapur-Parali III	30/Oct/2015	09.38	31/Oct/2015	00.24	For Fixing & Replacement of Broken Spacer Cum Vibration Dampers.
400 KV	Talegaon PG-Aurangabad-I	30/Oct/2015	12.32	30/Oct/2015	12.53	For Availing Bus-2 Outage @ Aurangabad.
400 KV	Waluj Aurangabad(PG) II	30/Oct/2015	12.42	30/Oct/2015	12.50	For Availing Bus-2 Outage @ Aurangabad.
400 KV	Main Bus-II @ Aurangabad	30/Oct/2015	12.58	30/Oct/2015	20.41	Replacement of 898 R Ph Scissor Assembly & PG Isolator Alignment.
400 KV	Padghe - Talegaon (PG)	30/Oct/2015	13.00	30/Oct/2015	19.57	R Ph WT Insulator String Burst.
400 KV	Padghe - Nagothane - II	30/Oct/2015	15.05	30/Oct/2015	17.58	Line Signature Analysis.
400 KV	karad -kolhapur-I	30/Oct/2015	16.35	31/Oct/2015	07.30	Over Voltage
400 KV	Karad - Jaigad - II	30/Oct/2015	16.39	31/Oct/2015	08.42	Over Voltage
400 KV	Parli(MS)-Parli (PG) II	30/Oct/2015	19.10	30/Oct/2015	20.44	Reactor of Lonikand-2 Line Burst @ Parli S/S.
400 KV	Parli(MS)-Parli (PG) I	30/Oct/2015	19.10	31/Oct/2015	00.36	Reactor of Lonikand-2 Line Burst @ Parli S/S.
400 KV	Chandrapur-Parali 2	30/Oct/2015	19.10	30/Oct/2015	19.29	Reactor of Lonikand-2 Line Burst @ Parli S/S.
400 KV	Girwali- Lonikand 2	30/Oct/2015	19.10	31/Oct/2015	10.17	Reactor of Lonikand-2 Line Burst @ Parli S/S.

Voltage	Name of Line	Tripping Date	Tripping Time	Synch Date	Synch Time	Reason
400 KV	Girwali - Lonikand 1	30/Oct/2015	19.34	31/Oct/2015	00.10	Reactor of Lonikand-2 Line Burst @ Parli S/S.
400 KV	Bhusawal-Aurangabad	30/Oct/2015	20.17	31/Oct/2015	07.10	Over Voltage
400 KV	Karad-Jaigad - I	31/Oct/2015	02.04	01/Nov/2015	07.24	Over Voltage
400 KV	Talegaon PG - Aurangabad - II	31/Oct/2015	03.03	31/Oct/2015	06.28	Due to Trip Coil Burn.
400 KV	Waluj Aurangabad(PG) II	31/Oct/2015	03.03	31/Oct/2015	06.28	Due to Trip Coil Burn.
400 KV	Kolhapur Mapusa I	31/Oct/2015	03.08	31/Oct/2015	06.51	Over Voltage
400 KV	New Koyna - Dabhol - Ii	31/Oct/2015	13.17	31/Oct/2015	17.58	Attending Hot Spot
400 KV	karad -kolhapur-II	31/Oct/2015	16.36	01/Nov/2015	06.54	Over Voltage
400 KV	Parli(MS)-Parli (PG) I	31/Oct/2015	17.50	31/Oct/2015	19.12	Insulator Fixing
400 KV	New Koyna - Dabhol - Ii	31/Oct/2015	18.01	01/Nov/2015	12.26	Distance Protection
400 KV	Bhusawal-Aurangabad	31/Oct/2015	19.56	01/Nov/2015	07.14	Over Voltage
400 KV	Dhule Sar'Sarovar I	31/Oct/2015	20.31	01/Nov/2015	07.24	Over Voltage
400 KV	Karad-Jaigad - I	01/Nov/2015	02.04	01/Nov/2015	07.24	Over Voltage
400 KV	Chandrapur-II - Warora - I	01/Nov/2015	09.24	01/Nov/2015	18.10	Line Maintenance work
400 KV	karad -kolhapur-I	01/Nov/2015	16.07	02/Nov/2015	08.23	Over Voltage
400 KV	Karad - Jaigad - II	01/Nov/2015	16.38	02/Nov/2015	08.58	Over Voltage
400 KV	Kolhapur Mapusa I	01/Nov/2015	16.42	02/Nov/2015	07.17	Over Voltage
400 KV	Bhusawal-Aurangabad	01/Nov/2015	17.12	02/Nov/2015	06.13	Over Voltage
400 KV	Dhule Sar'Sarovar I	01/Nov/2015	18.31	02/Nov/2015	06.04	Over Voltage
400 KV	karad -kolhapur-II	02/Nov/2015	16.14		Continued.	Over Voltage
400 KV	Karad-Jaigad - I	02/Nov/2015	16.35		Continued.	Over Voltage
220 KV	Chandrapur GCR - Warora - I	05/Apr/2015	09.13		Continued.	Bunching of conductor Loc no 86 Disconnecting of jumer at Loc no 86 & 107 and de-energising the line bet.86 to 107.
220 KV	Chandrapur GCR - Wani	05/Apr/2015	09.15		Continued.	Bunching of conductor Loc no 86 Disconnecting of jumer at Loc no 86 & 107 and de-energising the line bet.86 to 107.
220 KV	Nagothane - MSL	13/Oct/2015	16.44		Continued.	Distance Protection
220 KV	Kalwa-Salsette-IV	25/Oct/2015	05.54	26/Oct/2015	03.37	cvt replacement at salsete end
220 KV	Taloja II - OCIL-II	26/Oct/2015	02.47	26/Oct/2015	09.33	B Phase L A Burst.
220 KV	Taloja II - OCIL-I	26/Oct/2015	02.47	26/Oct/2015	03.20	B Phase LA Burst
220 KV	Nerul - Sonkhar	26/Oct/2015	04.44	26/Oct/2015	09.00	Attending Hot Spot
220 KV	Dhamangaon New - Badnera	26/Oct/2015	10.03	26/Oct/2015	15.27	Tan Delta Measurment of CTs
220 KV	Ongc Uran - Jnpt	26/Oct/2015	11.20	26/Oct/2015	17.30	Testing Work
220 KV	Eklahara(Gcr)(Nasik)- Bableshwar 2	26/Oct/2015	14.46	26/Oct/2015	19.28	CT Oil Leakage
220 KV	Parvati - Hybrid Pass	27/Oct/2015	07.46	27/Oct/2015	17.20	controlling line loading.
220 KV	Lonand-Baramati	27/Oct/2015	08.40	27/Oct/2015	20.05	Increase ground Clearance.
220 KV	Karad(400kv) - Ogalewadi Ckt 2	27/Oct/2015	08.55	27/Oct/2015	16.55	Testing Work
220 KV	Hinjawadi I- Chinchwad	27/Oct/2015	09.24	27/Oct/2015	17.17	controlling line loading.
220 KV	Kandalgaon - ONGC Panvel	27/Oct/2015	09.47	27/Oct/2015	18.30	r.m. work.
220 KV	Nasik Navsari I	27/Oct/2015	10.35	27/Oct/2015	19.00	insulator string replacement.
220 KV	Amalner - Bambhori	28/Oct/2015	09.22	28/Oct/2015	12.57	Replacement of Damaged Insulator String.
220 KV	Apta - Taloja	28/Oct/2015	13.42	28/Oct/2015	14.41	Attending Hot Spot
220 KV	Koradi-Khaperkheda	28/Oct/2015	20.21	28/Oct/2015	22.46	Distance Protection Operated Zone-I R Y Phase.
220 KV	Parli 3 (Oldgcr)-Harangul Ckt 2	28/Oct/2015	21.17	28/Oct/2015	21.55	Load Trimming Scheme Operated for ICT-I & III After Tripping of ICT-II.
220 KV	Parli 3 (Oldgcr)-Harangul Ckt I	28/Oct/2015	21.17	28/Oct/2015	21.28	Load Trimming Scheme Operated for ICT-I & III After Tripping of ICT-II.
220 KV	Chakan-Mahindra Vehicle	29/Oct/2015	09.22	29/Oct/2015	15.41	Half yearly maintenance work
220 KV	Chandrapur MIDC - GEPL Ckt I	29/Oct/2015	10.13	29/Oct/2015	16.13	Testing of CT PT Work @ GEPL.
220 KV	Dhule-Chalisagaon	29/Oct/2015	11.31	29/Oct/2015	13.01	For CB Timing & CT Tan Delta Measurment.
220 KV	Chitegaon-Shendra Ckt-I	29/Oct/2015	12.37	29/Oct/2015	14.05	Line Signature Test.
220 KV	Parli 2-(Girwali) -Murud	29/Oct/2015	12.54	29/Oct/2015	20.40	Tan Delta Measurment of CT & CC.
220 KV	Tata Borivli MSETCL Borivli 4	29/Oct/2015	14.44	29/Oct/2015	17.24	Attending Hot Spot
220 KV	Parli 3 (Old Gcr)-Osmanabad	30/Oct/2015	07.20	30/Oct/2015	13.30	Measurment of Tan Delta of CT's & CC's.
220 KV	Nashik-Padgha	30/Oct/2015	07.59	30/Oct/2015	18.34	Line Maintenance work
220 KV	Kandalgaon - ONGC Panvel	30/Oct/2015	09.35	30/Oct/2015	10.10	C B Maint.Work,Line Maint.Work.
220 KV	Karad -Mudshingi Ckt- IV	30/Oct/2015	10.03	30/Oct/2015	16.17	A.M.Work.
220 KV	Osmanabad - Barshi	30/Oct/2015	10.44	30/Oct/2015	13.36	Measurment of Tan Delta of CT's & CC's.
220 KV	Padghe - Wada	30/Oct/2015	10.58	30/Oct/2015	16.59	Attending Hot Spot
220 KV	Midc Chandrapur-Gachandur	30/Oct/2015	11.20	30/Oct/2015	11.50	Bus Bar Protection Operated
220 KV	Chalisgaon -Babhaleswar	30/Oct/2015	11.54	30/Oct/2015	16.05	Re-Orientation Work.

Voltage	Name of Line	Tripping Date	Tripping Time	Synch Date	Synch Time	Reason
220 KV	Vasai Boiser(PG)	30/Oct/2015	11.57	30/Oct/2015	17.26	For Outage on Padgha-Nalasopara Line.
220 KV	Padghe - Nalasopara	30/Oct/2015	12.00	30/Oct/2015	17.27	Attending Hot Spot
220 KV	Gadchandur - Grace	30/Oct/2015	12.10	30/Oct/2015	18.58	Replacement of Y Ph CT.