

State Load Despatch Center,Airoli (MSETCL)
Power System Position from 28/Dec/2015 to 03/Jan/2016

Supply Position During Morning Peak (MW)

Date	Time	MSGENCO				Central Sector Receipt	Wind	CPP	SOLAR	TPCL Exch.	MSEDCL Catered Demand	Load Shedding(LS)	MSEDCL Demand (Incl. LS)	TPCL Gen.	R-INFRA Gen.	State Demand Met	State Demand (Incl. LS)	Freq.
		THM	HYDRO	GAS	Total													
		MW	MW	MW	MW	MW	MW	MW	MW	MW	MW	MW	MW	MW	MW	MW	MW	Hzs
28/12/2015	10 Hrs	5216	824	299	6339	4276	1074	4890	116	-714	15981	13	15994	1108	439	18242	18255	49.88
29/12/2015	11 Hrs	5264	821	304	6389	4567	653	5225	167	-1134	15867	14	15881	989	406	18396	18410	49.91
30/12/2015	11 Hrs	5183	1327	422	6932	4389	310	5220	158	-1057	15952	13	15965	1117	405	18531	18544	49.85
31/12/2015	11 Hrs	5395	600	441	6436	4617	263	5445	153	-1093	15821	14	15835	1085	405	18404	18418	49.93
01/01/2016	11 Hrs	5222	574	283	6079	3853	453	5308	144	-1144	14693	15	14708	756	406	16999	17014	49.95
02/01/2016	12 Hrs	5081	599	286	5966	4821	24	5636	174	-938	15683	13	15696	1020	515	18156	18169	49.95
03/01/2016	10 Hrs	4668	1024	451	6143	4641	77	5375	107	-538	15805	14	15819	764	514	17621	17635	49.92
Maximum		5395	1327	451	6932	4821	1074	5636	174	-538	15981	15	15994	1117	515	18531	18544	49.95
Minimum		4668	574	283	5966	3853	24	4890	107	-1144	14693	13	14708	756	405	16999	17014	49.85
Average		5147	824	355	6326	4452	408	5300	146	-945	15686	14	15700	977	441	18050	18064	49.91

Supply Position During Day Peak (MW)

Date	Time	MSGENCO				Central Sector Receipt	Wind	CPP	SOLAR	TPCL Exch.	MSEDCL Catered Demand	Load Shedding(LS)	MSEDCL Demand (Incl. LS)	TPCL Gen.	R-INFRA Gen.	State Demand Met	State Demand (Incl. LS)	Freq.
		THM	HYDRO	GAS	Total													
		MW	MW	MW	MW	MW	MW	MW	MW	MW	MW	MW	MW	MW	MW	MW	MW	Hzs
28/12/2015	13 Hrs	5151	90	293	5534	4346	1114	4751	190	-1140	14795	13	14808	901	403	17239	17252	49.95
29/12/2015		4603	306	284	5193	4858	801	5302	181	-1046	15289	14	15303	1103	404	17842	17856	49.94
30/12/2015		5149	161	409	5719	4241	696	5406	163	-1129	15096	13	15109	1054	406	17685	17698	49.86
31/12/2015		5256	133	418	5807	4631	640	5067	180	-1234	15091	14	15105	968	407	17700	17714	49.96
01/01/2016		5038	185	284	5507	3883	491	5018	200	-1131	13968	15	13983	832	406	16337	16352	49.90
02/01/2016		5091	889	290	6270	3955	25	5565	183	-989	15009	13	15022	970	512	17480	17493	50.01
03/01/2016		4717	324	420	5461	4746	31	5426	167	-820	15011	14	15025	715	407	16953	16967	49.91
Maximum		5256	889	420	6270	4858	1114	5565	200	-820	15289	15	15303	1103	512	17842	17856	50.01
Minimum		4603	90	284	5193	3883	25	4751	163	-1234	13968	13	13983	715	403	16337	16352	49.86
Average		5001	298	343	5642	4380	543	5219	181	-1070	14894	14	14908	935	421	17319	17333	49.93

Supply Position During Evening Peak (MW)

Date	Time	MSGENCO				Central Sector Receipt	Wind	CPP	SOLAR	TPCL Exch.	MSEDCL Catered Demand	Load Shedding(LS)	MSEDCL Demand (Incl. LS)	TPCL Gen.	R-INFRA Gen.	State Demand Met	State Demand (Incl. LS)	Freq.
		THM	HYDRO	GAS	Total													
		MW	MW	MW	MW	MW	MW	MW	MW	MW	MW	MW	MW	MW	MW	MW	MW	Hzs
28/12/2015	19 Hrs	5113	625	282	6020	3185	606	4785	0	-1061	13535	13	13548	920	403	15919	15932	49.97
29/12/2015	19 Hrs	4902	931	427	6260	3323	508	4772	0	-1175	13688	16	13704	939	405	16207	16223	49.88
30/12/2015	19 Hrs	4946	549	433	5928	3612	396	4745	0	-1010	13671	12	13683	1063	512	16256	16268	49.93
31/12/2015	20 Hrs	5134	276	430	5840	3775	324	4691	0	-1232	13398	13	13411	870	404	15904	15917	49.97
01/01/2016	19 Hrs	4989	685	290	5964	3118	209	4682	0	-1111	12862	15	12877	798	404	15175	15190	49.98
02/01/2016	19 Hrs	4856	675	341	5872	3788	148	5452	0	-1072	14188	11	14199	900	404	16564	16575	49.93
03/01/2016	19 Hrs	4592	479	444	5515	4184	81	4511	0	-901	13390	12	13402	631	404	15326	15338	49.95
Maximum		5134	931	444	6260	4184	606	5452	0	-901	14188	16	14199	1063	512	16564	16575	49.98
Minimum		4592	276	282	5515	3118	81	4511	0	-1232	12862	11	12877	631	403	15175	15190	49.88
Average		4933	603	378	5914	3569	325	4805	0	-1080	13533	13	13546	874	419	15907	15920	49.94

Supply Position During Night Off Peak (MW)

Date	Time	MSGENCO				Central Sector Receipt	Wind	CPP	SOLAR	TPCL Exch.	MSEDCL Catered Demand	Load Shedding(LS)	MSEDCL Demand (Incl. LS)	TPCL Gen.	R-INFRA Gen.	State Demand Met	State Demand (Incl. LS)	Freq.
		THM	HYDRO	GAS	Total													
		MW	MW	MW	MW	MW	MW	MW	MW	MW	MW	MW	MW	MW	MW	MW	MW	Hzs
28/12/2015	3 Hrs	5114	118	307	5539	-157	1260	4202	0	-195	10649	10	10659	652	404	11900	11910	50.03
29/12/2015	4 Hrs	5109	90	296	5495	350	837	4710	0	-255	11137	11	11148	635	404	12431	12442	49.97
30/12/2015	3 Hrs	4829	87	429	5345	1129	488	4737	0	-378	11321	10	11331	630	404	12733	12743	49.96
31/12/2015	4 Hrs	5199	59	464	5722	1190	331	4709	0	-390	11562	11	11573	629	405	12986	12997	49.94
01/01/2016	4 Hrs	5047	68	453	5568	777	498	4655	0	-358	11140	12	11152	699	407	12604	12616	49.93
02/01/2016	3 Hrs	4480	777	303	5560	1203	131	4651	0	-563	10982	10	10992	517	405	12467	12477	49.95
03/01/2016	4 Hrs	4514	525	466	5505	1652	202	4749	0	-506	11602	10	11612	514	404	13026	13036	49.95
Maximum		5199	777	466	5722	1652	1260	4749	0	-195	11602	12	11612	699	407	13026	13036	50.03
Minimum		4480	59	296	5345	-157	131	4202	0	-563	10649	10	10659	514	404	11900	11910	49.93
Average		4899	246	388	5533	878	535	4630	0	-378	11199	11	11210	611	405	12592	12603	49.96

Details of Supply Position (MUs)

Date	MSGENCO				Pench (MS)	Central Sector Receipt	Central Sector Share	WIND	CPP	SOLAR	TPCL Gen.	R-INFRA Gen.	TPCL Exch.	Energy Requirement		
	THM	HYDRO	GAS	Total										MSEDCL	MUMBAI	STATE
	Mus	Mus	Mus	Mus	Mus	Mus	Mus	Mus	Mus	Mus	Mus	Mus	Mus	Mus	Mus	Mus
28/12/2015	122.914	7.550	7.018	137.482	0.376	58.549	59.476	23.954	110.313	1.257	18.920	9.873	-18.002	313.553	46.795	360.348
29/12/2015	118.798	11.989	8.573	139.360	0.581	65.438	65.850	16.170	116.319	1.285	19.787	9.720	-19.308	319.265	48.815	368.080
30/12/2015	116.443	11.270	10.487	138.200	0.407	71.928	72.314	10.888	116.236	1.205	20.730	9.938	-19.459	318.998	50.127	369.125
31/12/2015	124.505	7.271	10.695	142.471	0.485	71.664	71.378	8.949	115.722	1.182	19.779	9.714	-20.804	319.185	50.300	369.485
01/01/2016	120.374	10.659	8.213	139.246	0.499	61.929	62.692	8.275	115.023	1.174	17.081	9.711	-20.845	304.800	47.637	352.437
02/01/2016	113.357	18.001	8.018	139.376	0.415	73.701	72.178	2.693	123.228	1.233	17.214	10.608	-20.909	319.322	48.731	368.053
03/01/2016	110.426	11.129	10.917	132.472	0.580	82.484	83.602	2.058	117.168	1.159	15.291	10.206	-16.335	319.006	41.832	360.838
Maximum	124.505	18.001	10.917	142.471	0.581	82.484	83.602	124.505	123.228	1.285	20.730	10.608	-16.335	319.322	50.300	369.485
Minimum	110.426	7.271	7.018	132.472	0.376	58.549	59.476	110.426	110.313	1.159	15.291	9.711	-20.909	304.800	41.832	352.437
Average	118.117	11.124	9.132	138.372	0.478	69.385	69.641	118.117	116.287	1.214	18.400	9.967	-19.380	316.304	47.748	364.052

Details of Koyna Water Consumption (in TMC)

Date	For the Day	For the Month	Balance
28/12/2015	0.099	2.451	38.635
29/12/2015	0.201	2.652	38.434
30/12/2015	0.202	2.854	38.232
31/12/2015	0.117	2.971	38.115
01/01/2016	0.161	0.161	37.954
02/01/2016	0.366	0.527	37.588
03/01/2016	0.197	0.724	37.391

State Load Despatch Center,Airoli (MSETCL)
Central Sector Share/Drawal from 28/Dec/2015 to 03/Jan/2016

Date	DAY	Central Sector Share		Total Interstate Bilateral Purchase		Total Share		Total Drawal		Overdrawal(+) / UnderDrawal(-)	
		MUs	Avg. MW	MUs	Avg. MW	MUs	Avg. MW	MUs	Avg. MW	MUs	Avg. MW
		1		2		1+2=3		4		3-4=5	
28/12/2015	MONDAY	63.431	2482	-3.955	-165	59.476	2478	58.549	2440	-0.927	-39
29/12/2015	TUESDAY	68.117	2746	-2.267	-94	65.850	2744	65.438	2727	-0.412	-17
30/12/2015	WEDNESDA	68.440	3009	3.874	161	72.314	3013	71.928	2997	-0.386	-16
31/12/2015	THURSDAY	74.316	2977	-2.938	-122	71.378	2974	71.664	2986	0.286	12
01/01/2016	FRIDAY	72.135	2622	-9.443	-393	62.692	2612	61.929	2580	-0.763	-32
02/01/2016	SATURDAY	75.118	3010	-2.940	-122	72.178	3007	73.701	3071	1.523	63
03/01/2016	SUNDAY	75.038	3475	8.564	357	83.602	3483	82.484	3437	-1.118	-47
Total		496.594		-9.104		487.490		485.693		-1.797	

GENERATING UNITS OUTAGES FOR THE WEEK FROM 28/12/2015 TO 03/01/2016							
Generator	Generating Unit	Capacity	Tripped Date	Tripped Time	Synch. Date	Synch Time	Reason
PLANNED OUTAGES							
Cent_Sect	Tarapur 2	160MW	10/Sep/2015	12.55		Continued.	Refuelling work
MSPGCL	Koyna Unit 10	80MW	29/Dec/2015	08:00		Continued.	Annual Overhaul
IPP	REL Unit 1	250MW	03/Jan/2016	23.46		Continued.	Annual Overhaul
FORCED OUTAGES							
RGPPL	Dabhol Dabhol 1B	230MW	28/May/2013	22:02		Continued.	Gas Shortage.
RGPPL	Dabhol Dabhol 2A	230MW	06/Jun/2013	09.10		Continued.	Gas Shortage
RGPPL	Dabhol Dabhol 3A	230MW	06/Jun/2013	08.28		Continued.	Gas Shortage
RGPPL	Dabhol Dabhol 1A	230MW	27/Jun/2013	21.47		Continued.	Gas Shortage
RGPPL	Dabhol Dabhol 1X	230MW	27/Jun/2013	21.46		Continued.	Gas Shortage
RGPPL	Dabhol Dabhol 2X	230MW	15/Jul/2013	15.09		Continued.	Gas Shortage
RGPPL	Dabhol Dabhol 2B	230MW	08/Aug/2013	15.03		Continued.	Gas Shortage
IPP	Dhariwal	300MW	28/May/2014	02.27		Continued.	No schedule
MSPGCL	Chandrapur Unit 1	210MW	28/Aug/2014	07:15		Continued.	Economic Shutdown.
MSPGCL	Koradi Unit 6	210MW	20/Mar/2015	01.02		Continued.	Economic shutdown
MSPGCL	Uran Unit 7	108MW	17/Apr/2015	00.07		Continued.	Gas turbine problem
MSPGCL	Parli Unit 3	210MW	14/Jun/2015	12.58		Continued.	Water Shortage
IPP	WPCL U-2	135MW	16/Jun/2015	00.00		Continued.	No Schdule
MSPGCL	Parli Unit 6	250MW	25/Jun/2015	15.03		Continued.	Water Shortage
MSPGCL	Parli Unit 4	210MW	05/Jul/2015	18.45		Continued.	Water Shortage
MSPGCL	Parli Unit 5	210MW	06/Jul/2015	14.55		Continued.	Water Shortage.
MSPGCL	Parli Unit 7	250MW	08/Jul/2015	12.08		Continued.	Water Shortage
IPP	Tata Trombay 6	500MW	15/Jul/2015	17.08		Continued.	Economic shutdown
IPP	WPCL U-1	135MW	23/Oct/2015	17.31	28/Dec/2015	02.16	ESP filter problem
MSPGCL	Chandrapur Unit-8	500MW	10/Nov/2015	12.10		Continued.	Drum level low
IPP	Adani U-4	660MW	14/Dec/2015	06.55		Continued.	Hot air line leakage
IPP	JSW (J) U3	300MW	23/Dec/2015	13.18		Continued.	Economic shutdown
IPP	Adani U-5	660MW	24/Dec/2015	17.40	28/Dec/2015	06.34	Leakage in HRH Line
MSPGCL	Uran Unit 6	108MW	26/Dec/2015	22.16	29/Dec/2015	10.43	Gas shortage
MSPGCL	Chandrapur Unit 5	500MW	27/Dec/2015	18.50		Continued.	Capital Overhaul.
MSPGCL	Koradi Unit-8	660MW	29/Dec/2015	11.42	29/Dec/2015	14.58	metal temperature high
IPP	WPCL U-3	135MW	29/Dec/2015	05.56		Continued.	PA Fan problem
MSPGCL	Khaparkhedha Unit 2	210MW	30/Dec/2015	02.56	30/Dec/2015	05.00	Bus Bar Protection Optd (220kv Bus Coupler Y-ph CT Burst)
MSPGCL	Khaparkhedha Unit 1	210MW	30/Dec/2015	02.56	30/Dec/2015	04.34	Bus Bar Protection Optd (220kv Bus Coupler Y-ph CT Burst)
IPP	RPL(AMT) U-2	270MW	31/Dec/2015	15.10	31/Dec/2015	16.21	Tripped on SPS operation
IPP	Trombay 7A	120MW	01/Jan/2016	21.37	03/Jan/2016	13.54	Replacing fine Filters of GT(48Hrs)
MSPGCL	Koradi Unit 5	200MW	01/Jan/2016	00.12		Continued.	ID Fan Problem
MSPGCL	Uran Unit 5	108MW	01/Jan/2016	09.20	02/Jan/2016	17.13	Gas shortage
IPP	Trombay 7B	60MW	01/Jan/2016	21.07	03/Jan/2016	19.25	Replacing fine Filters of GT(48Hrs)
MSPGCL	Koradi Unit-8	660MW	02/Jan/2016	01.12		Continued.	LILo arrangement for 400KV koradi I to India Bulls Line and charging of 400 KV koradi II to Wardha(PG) line.
IPP	RPL(AMT) U-5	270MW	03/Jan/2016	07.54		Continued.	Cooling Water Line Leakage.

LINE OUTAGES FOR THE WEEK FROM 28/12/2015 TO 03/01/2016

Voltage	Name of Line	Tripping Date	Tripping Time	Synch Date	Synch Time	Reason
400 KV	Babhaleshwar-Taptitanda ckt-I	19/Dec/2015	07.28		Continued.	Over Voltage (RFC 17.58 Hrs)
400 KV	Akola II - Taptitanda ckt-I	22/Dec/2015	12.15	31/Dec/2015	15.11	change over & availed outage(RFC 17.20Hrs)
400 KV	karad -kolhapur-II	24/Dec/2015	15.57	30/Dec/2015	09.56	Over Voltage
400 KV	Karad - Jaigad - II	24/Dec/2015	16.04	29/Dec/2015	11.07	Over Voltage
400 KV	Dabhol Nagothane II	25/Dec/2015	02.30	29/Dec/2015	10.11	Over Voltage
400 KV	Padghe - Nagothane - I	27/Dec/2015	01.58	28/Dec/2015	09.01	Over Voltage
400 KV	Lonikand I - Koyna stage-IV	27/Dec/2015	09.06	28/Dec/2015	10.06	Distance Protection
400 KV	Kolhapur Solapur (PG) II	27/Dec/2015	16.10	28/Dec/2015	09.21	Over Voltage
400 KV	Dhule Sar'Sarovar I	27/Dec/2015	17.02	28/Dec/2015	08.09	Over Voltage
400 KV	Bhusawal-Aurangabad	27/Dec/2015	17.10	28/Dec/2015	07.10	Over Voltage
400 KV	Chandrapur2-Parali 2 ckt1	28/Dec/2015	09.43	28/Dec/2015	18.30	Fixing & Replacement of broken specers & Vibration dampers
400 KV	Akola Aurangabad(PG) II	28/Dec/2015	10.54	28/Dec/2015	11.56	DT Recived, Main & Tie Breaker Trip.
400 KV	Dabhol Newkoyna II	28/Dec/2015	10.58	29/Dec/2015	10.11	Over Voltage
400 KV	Kolhapur Solapur (PG) II	28/Dec/2015	17.11	29/Dec/2015	08.41	Over Voltage
400 KV	Dhule Sar'Sarovar I	28/Dec/2015	17.18	29/Dec/2015	07.45	Over Voltage
400 KV	Dhule Sar'Sarovar II	28/Dec/2015	17.18	28/Dec/2015	17.42	Over Voltage
400 KV	Bhusawal-Aurangabad	28/Dec/2015	17.32	29/Dec/2015	07.02	Over Voltage
400 KV	Parli(MS)-Parli (PG) I	28/Dec/2015	19.00	28/Dec/2015	23.03	Attending Hot Spot
400 KV	Lonikand I - Koyna stage-IV	28/Dec/2015	19.48	29/Dec/2015	10.16	Over Voltage
400 KV	Padghe - Nagothane - I	29/Dec/2015	00.52	29/Dec/2015	08.02	Over Voltage
400 KV	Chakan Talegaon(Pg)	29/Dec/2015	08.24	29/Dec/2015	19.20	Stringing work
400 KV	Chandrapur2-Parali 2 ckt 2	29/Dec/2015	08.39	29/Dec/2015	19.18	Replacement work
400 KV	Akola Aurangabad(PG) I	29/Dec/2015	11.20	30/Dec/2015	06.26	commissioning of line /reator at aurangabad and bays amp works
400 KV	Karad-Jaigad - I	29/Dec/2015	16.07	03/Jan/2016	09.17	Over Voltage
400 KV	Kolhapur Solapur (PG) II	29/Dec/2015	17.11	30/Dec/2015	06.37	Over Voltage
400 KV	Dhule Sar'Sarovar II	29/Dec/2015	17.11	29/Dec/2015	17.28	Over Voltage
400 KV	Dhule Sar'Sarovar I	29/Dec/2015	17.11	30/Dec/2015	08.06	Over Voltage
400 KV	Bhusawal-Aurangabad	29/Dec/2015	17.35	30/Dec/2015	06.23	Over Voltage
400 KV	Lonikand I - Koyna stage-IV	29/Dec/2015	20.35	30/Dec/2015	10.20	Over Voltage
400 KV	Koradi-Khaperkheda II	30/Dec/2015	13.03	31/Dec/2015	14.56	Shifted on TBC
400 KV	karad -kolhapur-I	30/Dec/2015	15.53	02/Jan/2016	11.16	Over Voltage
400 KV	Kolhapur Solapur(PG) I	30/Dec/2015	16.52	31/Dec/2015	07.34	Over Voltage
400 KV	Dhule Sar'Sarovar I	30/Dec/2015	17.35	31/Dec/2015	06.57	Over Voltage
400 KV	Koradi-Bhusawal	30/Dec/2015	18.29	30/Dec/2015	19.13	Bus bar operated
400 KV	Khadka- Deepnagar Ckt 1	30/Dec/2015	18.29	30/Dec/2015	19.22	Bus bar operated
400 KV	Bhusawal-Aurangabad	30/Dec/2015	18.29		Continued.	Over Voltage
400 KV	Lonikand I - Koyna stage-IV	30/Dec/2015	21.26	31/Dec/2015	10.06	Over Voltage
400 KV	Kolhapur Solapur (PG) II	30/Dec/2015	21.54	31/Dec/2015	08.21	Over Voltage
400 KV	Main Bus- II @ Jejuri	31/Dec/2015	10.12	31/Dec/2015	13.09	Erection of Beam for new end Bay
400 KV	Lonikand I - Koyna stage-IV	31/Dec/2015	11.09	01/Jan/2016	10.28	Insulator repl.work(RFC 19.10Hrs)
400 KV	Main Bus-I @ Jejuri	31/Dec/2015	13.14	31/Dec/2015	15.58	Erection of Beam for new end Bay
400 KV	Akola Aurangabad(PG) I	31/Dec/2015	15.31	31/Dec/2015	18.15	To take Line Reactor in service at A'Bad end
400 KV	Dhule Sar'Sarovar I	31/Dec/2015	17.20	01/Jan/2016	07.23	Over Voltage
400 KV	Padghe - Kalwa- I	31/Dec/2015	18.09	31/Dec/2015	23.14	Distance Protection
400 KV	Kolhapur Solapur(PG) I	31/Dec/2015	18.10	01/Jan/2016	08.40	Over Voltage
400 KV	Akola II - Taptitanda ckt-II	31/Dec/2015	18.16		Continued.	Chanage over
400 KV	Kolhapur Solapur(PG) I	01/Jan/2016	16.37	02/Jan/2016	07.00	Over Voltage
400 KV	Lonikand I - Koyna stage-IV	01/Jan/2016	16.40	02/Jan/2016	09.25	Over Voltage
400 KV	Dhule Sar'Sarovar I	01/Jan/2016	17.05	03/Jan/2016	07.04	Over Voltage
400 KV	Kolhapur Solapur (PG) II	01/Jan/2016	18.02	02/Jan/2016	07.16	Over Voltage
400 KV	Padghe - Kalwa- I	02/Jan/2016	06.17	02/Jan/2016	09.30	To remove Earth Wire
400 KV	Lonikand I - Koyna stage-IV	02/Jan/2016	10.33		Continued.	Distance Protection B Ph to Earth.
400 KV	Koradi Satpur	02/Jan/2016	11.41	02/Jan/2016	18.02	Attending Hot Spot
400 KV	karad -kolhapur-II	02/Jan/2016	16.10		Continued.	Over Voltage
400 KV	Kolhapur Solapur (PG) II	02/Jan/2016	17.20	03/Jan/2016	07.31	Over Voltage

Voltage	Name of Line	Tripping Date	Tripping Time	Synch Date	Synch Time	Reason
400 KV	Padghe - Talegaon (PG)	03/Jan/2016	09.50	03/Jan/2016	18.12	Replacement of Tower Peak Demand During OPGW Work.
400 KV	Kalwa - Talegaon(PG)	03/Jan/2016	10.34	03/Jan/2016	18.26	Replacement of Tower Peak Demand During OPGW Work.
400 KV	Karad - Jaigad - II	03/Jan/2016	16.12		Continued.	Over Voltage
400 KV	Kolhapur Solapur (PG) II	03/Jan/2016	16.42	04/Jan/2016	06.58	Over Voltage
400 KV	Dhule Sar'Sarovar I	03/Jan/2016	17.11	04/Jan/2016	06.39	Over Voltage
400 KV	Dabhol Nagothane II	04/Jan/2016	04.00		Continued.	Over Voltage
220 KV	Chandrapur GCR - Warora - I	05/Apr/2015	09.13		Continued.	Bunching of conductor Loc no 86 Disconnecting of jumer at Loc no 86 & 107 and de-energising the line bet.86 to 107.
220 KV	Chandrapur GCR - Wani	05/Apr/2015	09.15		Continued.	Bunching of conductor Loc no 86 Disconnecting of jumer at Loc no 86 & 107 and de-energising the line bet.86 to 107.
220 KV	Wadkhai - Ndi3	14/Nov/2015	10.58		Continued.	Strengthening work
220 KV	Ghodbunder - Versova	07/Dec/2015	08:45	28/Dec/2015	16.11	Modification of existing towers from broad based to narrow based towers in MBMC area
220 KV	Ghodbunder - Gorai	09/Dec/2015	08:18	28/Dec/2015	16.45	Modification of existing towers from broad based to narrow based towers in MBMC area
220 KV	Boisar(M) - Ghodbunder	16/Dec/2015	08.29	31/Dec/2015	17.07	Tower Erection and Stringing work
220 KV	Borivali - Tarapur	16/Dec/2015	09.34	31/Dec/2015	20.06	Tower Erection and Stringing work
220 KV	Wadkhai - Ipc2	19/Dec/2015	11.00		Continued.	Conductor Replacement Work With High Amacity Conductor.
220 KV	Halkarni-Mahalaxmiline	28/Dec/2015	09.08	28/Dec/2015	18.31	cleaning of polluted insulator string
220 KV	Nasik Navsari II	28/Dec/2015	09.30	28/Dec/2015	18.30	Insulator Replacement Work
220 KV	Karad(400kv) - Wathar	28/Dec/2015	10.39	28/Dec/2015	17.37	Quarterly Maintainance Work
220 KV	Loteaparshuram- Dasturi Line	28/Dec/2015	12.30	28/Dec/2015	17.40	Attending Oil Leakage
220 KV	Eklahara(OCR)-Raymond (Padagha-I)	28/Dec/2015	14.56	28/Dec/2015	16.11	Due to Bus Bar Optd at OCR.
220 KV	Nasik Navsari I	28/Dec/2015	14.56	28/Dec/2015	15.36	Bus Bar Optd at Nashik OCR.
220 KV	Halkarni-Mahalaxmiline	29/Dec/2015	08.34	29/Dec/2015	17.45	Cleaning of polluted insulator
220 KV	Nasik Navsari II	29/Dec/2015	08.35	29/Dec/2015	18.18	Insulator Replacement Work
220 KV	220KV Theur- NandedCity	29/Dec/2015	10.07	29/Dec/2015	13.26	Dismantling of jumper on loc no 2
220 KV	Uran - Apta IV	29/Dec/2015	10.25	29/Dec/2015	11.32	Mockdrill at uran
220 KV	Mahad - Posco	29/Dec/2015	11.35	29/Dec/2015	19.30	Earth wire replacement work
220 KV	Vankuswade - Kdph	29/Dec/2015	11.50	29/Dec/2015	14.55	Replacement of R-phase
220 KV	Bus 1 @ Khaparkheda	30/Dec/2015	02.56	30/Dec/2015	04.27	Bus Bar Protection Optd (220kv Bus Coupler Y ph CT Burst)
220 KV	Bus 2 @ Khaparkheda	30/Dec/2015	02.56	30/Dec/2015	04.57	Bus Bar Protection Optd (220kv Bus Coupler Y ph CT Burst)
220 KV	Dahanu Ghodbunder Line 2	30/Dec/2015	07.35	30/Dec/2015	10.11	Attending Hot Spot
220 KV	Halkarni-Mahalaxmiline	30/Dec/2015	08.44	30/Dec/2015	19.09	Insulator cleaning
220 KV	Nasik Navsari II	30/Dec/2015	08.45	30/Dec/2015	18.45	Insulator Replacement Work
220 KV	Urse-Chinchwad	30/Dec/2015	14.30	31/Dec/2015	16.20	Shifted on TBC TO Attending Hot Spot
220 KV	Main Bus I @ Kalwa	30/Dec/2015	17.03	30/Dec/2015	17.39	220kv bus bar operated at kalwa
220 KV	Kalwa-Salsette-VI	30/Dec/2015	17.03	30/Dec/2015	17.48	220kv bus bar operated at kalwa
220 KV	Bus Coupler @ Kalwa	30/Dec/2015	17.03	30/Dec/2015	17.53	220kv bus bar operated at kalwa
220 KV	Kalwa-Salsette-IV	30/Dec/2015	17.03	30/Dec/2015	17.51	220kv bus bar operated at kalwa
220 KV	Kalwa - Siemens	30/Dec/2015	17.03	30/Dec/2015	17.53	220kv bus bar operated at kalwa
220 KV	Kalwa - Mulund 1	30/Dec/2015	17.03	30/Dec/2015	17.45	220kv bus bar operated at kalwa
220 KV	Kalwa - Borivali	30/Dec/2015	17.03	30/Dec/2015	19.05	220kv bus bar operated at kalwa
220 KV	Kalwa - Colourchem	30/Dec/2015	17.03	30/Dec/2015	17.39	220kv bus bar operated at kalwa